

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

January 31, 1979

Mr. Harold R. Denton, Director	Serial No. 603B/101978
Office of Nuclear Reactor Regulation	PO/DLB:scj
Attn: Mr. D. G. Eisenhut, Acting Assistant	Docket Nos.: 50-280
Director for Systems and Projects	50-281
Division of Operating Reactors	License Nos.: DPR-32
U. S. Nuclear Regulatory Commission	DPR-37
Washington, D. C. 20555	

Dear Mr. Denton:

In our letter of December 15, 1978 we stated our intention to perform certain tests, inspections, and analyses of the low head safety injection (LHSI) pumps, the outside recirculation spray (ORS) pumps, and the inside recirculation spray (IRS) pumps. The status of our activities for each of these pumps is discussed below.

A. LHSI

A temporary test rig will be installed to permit testing of a Unit 2 LHSI pump at a moderate flow rate, i.e. 1500 to 3000 gpm. The test has been tentatively scheduled for March 1979. An exact date is not available due to uncertainties in the availability of materials and in the test rig completion date.

The test will run for a total of 100 hours. During the test, periodic measurements of pump suction and discharge pressure, water temperature, discharge flow rate, upper and lower motor bearing vibration, and pump shaft and suction bell vibration will be recorded. Following the test the pump will be disassembled for measurement of bearing wear and inspection for evidence of abnormal shaft wear. A report of test results will be forwarded within 30 days of test completion.

B. ORS Pump

In our letter of December 15, 1978 we agreed to provide a modal analysis in order to demonstrate that the Surry ORS pumps are sufficiently similar to the tested North Anna ORS pumps to justify applying the results of the North Anna tests to the Surry pumps. The results of this analysis are attached. The modal analysis results confirm our initial contention that the North Anna test results are applicable to Surry and that no additional testing is necessary.


7902060289

A001
S
40/40

C. IRS Pump

During the Unit 1 steam generator inspection outage, IRS pump 1-RS-P-1B was inspected and optically aligned. All casing and impeller wear ring clearances were measured and were within the manufacturers accepted tolerances. There was no evidence of abnormal bearing or shaft wear. Both Unit 1 IRS pumps have now been inspected with satisfactory results. Both Unit 2 IRS pumps will be inspected during the steam generator replacement outage. Results of these inspections will be forwarded as they are available.

Very truly yours,



C. M. Stallings
Vice President-Power Supply
and Production Operations

Attachment

OUTSIDE RECIRCULATION SPRAY PUMPS
COMPARISON OF NATURAL FREQUENCY CHARACTERISTICS
NORTH ANNA AND SURRY
VIRGINIA ELECTRIC AND POWER COMPANY

Modal analyses of the Outside Recirculation Spray Pumps installed at Surry and North Anna show similar natural frequency characteristics. Mathematical models of each pump were developed to describe the geometry of the motor, motor stand, discharge head, pump column and bowl sections, shafting, fluid, casing, and support systems (see Figure 1). A computer model of each pump was analyzed by the STRUDL computer program to determine the free vibrational characteristics of the pump as represented by the mass and stiffness of the pump elements. Natural frequencies (eigen values) and mode shapes (eigen vectors or relative amplitudes) of the pump system were evaluated.

Table 1 provides a comparison of the natural frequencies of the North Anna and Surry recirculation spray pumps. The results indicate the similarity of the vibration characteristics of both units. Figures 1-4 describe the geometry and computer models of the pump installations. Natural frequencies and mode shapes for the North Anna recirculation spray pumps are shown in Figures 5-14, while Figures 15-23 provide comparable data for the Surry pumps. From a vibration standpoint, the Surry and North Anna recirculation spray pumps have similar natural frequency characteristics. As can be seen by comparison of the mode shapes and corresponding natural frequencies, the relative amplitudes of vibration are primarily bending of the pump column, pump casing, motor support, and pump shafting. Based on the satisfactory vibration amplitudes recorded during extensive operational testing of the North Anna recirculation spray pumps and the similarity of vibration

frequency traits, the Surry recirculation spray pumps have satisfactory natural frequency characteristics for long-term continuous operation.

TABLE 1

OUTSIDE RECIRCULATION SPRAY PUMPS
COMPARISON OF NATURAL FREQUENCY CHARACTERISTICS
NORTH ANNA AND SURRY
VIRGINIA ELECTRIC AND POWER COMPANY

<u>MODE</u>	<u>NORTH ANNA</u>	<u>SURRY</u>
1	3.37	2.88
2	6.80	6.28
3	8.24	9.04
4	15.28	15.03
5	19.02	18.26
6	24.45 (V)	21.16
7	28.24	26.53 (V)
8	39.56	28.42
9	40.79	35.19
10	41.67 (V)	37.22
11	43.79	38.86
12	44.33	39.97

NOTE: (V) is for vertical natural frequency. All other natural frequencies shown are in the horizontal direction. Vertical mode shapes are not shown.

CALCULATION SHEET

STORE'S WEDGETE ENGINEERING CORPORATION

J.O./W.O./CALCULATION NO.

REVISION

PAGE

A501061

PREPARED/DATE

JAF 12/14/78

REVIEWER/CHECKER/DATE

INDEPENDENT REVIEWER/DATE

SUBJECT/TITLE


OUTSIDE RECIRC. SPRAY PUMP

QA CATEGORY/CODE CLASS

GEOMETRY SKETCH

FIGURE 1

	<u>Surry</u>	<u>NA</u>
①	8' 6 3/8"	9' 2 7/8"
②	51' 10 7/8"	49' 9 1/8"
③	52' 8 3/8"	50' 1 1/8"



CALCULATION SHEET

1	Client	VSPCW	Location	NA 182	Est. No.	J.O. No.	11715
2	Subject	OUTSIDE RECIRC SPRAY PUMP	Date	5/15/78	By	SAL	
3			Checked	5/31/78	By	SNC	
4	Based on		Revised		By		

Computer Model (Joint Numbers)




FIGURE 2

PREPARER/DATE
S.A.L 5/19/78

REVIEWER/CHECKER/DATE
S.W.C 5/31/79

INDEPENDENT REVIEWER/DATE

SUBJECT/TITLE
OUTSIDE RECIRC SPRAY PUMP

QA CATEGORY/CODE CLASS
I

Computer Model (Member Numbers)




FIGURE 3

PREPARER/DATE
SAL 5/19/78


REVIEWER/CHECKER/DATE
S.W.C 5/21/78

INDEPENDENT REVIEWER/DATE

SUBJECT/TITLE
OUTSIDE RECIRC SPRAY PUMP

QA CATEGORY/CODE CLASS
I

COMPUTER MODEL (CONTINUED)



○ member numbers

FIGURE 4

FIGURES 5 to 14
NORTH ANNA UNITS 1 & 2
OUTSIDE RECIRCULATION SPRAY PUMPS
NATURAL FREQUENCIES AND MODE SHAPES


1 Client **VEPCO** Location **NORTHANNA** Est. No. **J.O. No. 11715**
 2 Subject **RECIRCULATION SPRAY PUMP (OUTSIDE)** Date **5/19/78** By **SAL**
 3 **VIBRATION MODE SHAPES** Checked **5/31/78** By **LJC**
 4 Based on Revised By

RELATIVE AMPLITUDES

Δ ACCELEROMETER LOCATIONS

Y AXIS, I SUCTON #1, 3, 5, 7, 9

X AXIS, II SUCTON #2, 4, 6, 8, 10




Mode 1
 $f = 3.37 \text{ cps}$
 (202 cpm)

FIGURE 5

1 Client VEPCO Location NA 1&Z Est. No. J.O. No. 11715
 2 Subject RECIRCULATION SPRAY PUMP (OUTSIDE) Date 5/19/78 By SAL
 3 Checked 5/31/78 By JWC
 4 Based on Revised By


5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50



Mode 2
 $f = 6.80 \text{ cps}$
 (408 cpm)
 FIGURE 6

1 Client VESCO Location NA 1 & 2 Est. No. J.O. No. 11715
 2 Subject RECIRCULATION SPRAY PUMP (OUTSIDE) Date 5/19/58 By SAL
 3 Checked 5/31/70 By JAE
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50



Mode 3
 $f = 8.24 \text{ cps}$
 (494 cpm)


FIGURE 7

CALCULATION SHEET

Item 348-CBE

1 Client **VEDCO** Location **NA 1 E 2** Est. No. J.O. No. **11715**
 2 Subject **RECIRCULATION SPRAY PUMP (OUTSIDE)** Date **5/19/78** By **SAL**
 3 Checked **5/31/78** By **JME**
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50




Mode 4
 $F = 15.28 \text{ cps}$
 (917 cps)
 FIGURE 8

CALCULATION SHEET

Item 343-CBE


1	Client	V&P CO	Location	NA 1 & 2	Est. No.	J.O. No.	11715	
2	Subject	RECIRCULATION SPRAY PUMP (OUTSIDE)			Date	5/19/78	By	SAL
3					Checked	5/31/78	By	JNE
4	Based on				Revised		By	



Mode 5
 $f = 19.02 \text{ cps}$
 (1140 cpm)
 FIGURE 9

1 Client VEPCO Location NA 1&2 Est. No. J.O. No. 11715
 2 Subject RECIRCULATION SPRAY PUMP (OUTSIDE) Date 5/19/78 By SAL
 3 Checked 5/31/78 By SME
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50




Mode 7
 $f = 28.24$
 (1690 cpm)
 FIGURE 10

CALCULATION SHEET

Preliminary Item 348-CRE

1 Client Veeco Location NAI 2 Est. No. J.O. No. 11715
 2 Subject RECIRCULATION SPRAY PUMP (OUTSIDE) Date 5/19/78 By SAL
 3 Checked 5/31/78 By AME
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50




Mode 8
 $f = 39.56$ cps
 (2380 cps)

FIGURE 11

1 Client VOPCO Location NA 187 Est. No. I.O. No. 11715
 2 Subject RECIRCULATION SPRAY PUMP (OUTSIDE) Date 5/19/78 By SAL
 3 Checked 5/31/78 By AME
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50




Mode 9
 $f = 40.79 c$
 (2450 cpm)

FIGURE 12

CALCULATION SHEET

1 Client Varco Location NA1#2 Est. No. J.O. No. 11715
 2 Subject RECIRCULATION SPRAY PUMP (OUTSIDE) Date 5/19/78 By SAL
 3 Checked 5/31/78 By JME
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50




Mode 11
 $f = 43.79$
 (2630 cpm)
 FIGURE 13

CALCULATION SHEET

1 Client NEPCO Location NAIEZ Est. No. J.O. No. 11715
 2 Subject RECIRCULATION SPRAY PUMP (OUTSIDE) Date 5/19/78 By SAL
 3 Checked 5/31/78 By JMC
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50



Mode 12
 $f = 44.33$
 (2660 cpm)
 FIGURE 14

FIGURES 15 to 23
SURRY UNITS 1 & 2
OUTSIDE RECIRCULATION SPRAY PUMPS
NATURAL FREQUENCIES AND MODE SHAPES

Client **VERCO**

Location **SUPEY**

Est. No.

J.O. No **12246.0**

Subject **OUTSIDE RECIEC SPRAY PUMPS**

Date **5/4/73**

By **BAB**

Checked **5/19/78**


By **JMC**

Based on

Revised

By

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50




MODE No. 1

FREQUENCY 2.88 Hz

FIGURE 15

1 Client **VERCO** Location **SUPRY** Est. No. J.O. No. 12846
 2 Subject **OUTSIDE RECIP SPRAY PUMPS** Date **5/4/78** By **RAB**
 3 Checked **5/19/78** By **JMC**
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50




MODE NO. 2

FREQUENCY 6.28 Hz

FIGURE 16

1 Client **VEPCO** Location **SUPPLY** Est. No. **J.O. No. 12846.0**
 2 Subject **OUTSIDE REPAIR SPRAY PUMPS** Date **5/4/78** By **BAB**
 3 Checked **5/19/78** By **JNE**
 4 Based on Revised By

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50



MODE NO. 3
 FREQUENCY 9.04 Hz
 FIGURE 17

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50

Client **VEPCO**

Location **SUPPLY**

Est. No.

I.O. No. **12846.0**

Subject **OUTSIDE RECIRC SPRAY PUMPS**

Date **5/4/78**

By **BAB**


Checked **5/19/78**

By **ane**

Based on

Revised

By




MODE NO. 4

FREQUENCY 15.03 Hz

FIGURE 1B

1 Client **VEPCO** Location **SUREY** Est. No. **12246**
 2 Subject **OUTSIDE RECIPRO SPRAY PUMPS** Date **5/4/78** By **RJB**
 3 Checked **5/19/78** By **AME**
 4 Based on _____ Revised _____ By _____



MODE NO. 5

FREQUENCY 18.26 Hz

FIGURE 19

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50

Client **VERCO** Location **SURREY**


Est. No. I.O. No. 12246.3

Subject **OUTSIDE RECIPRO SPRAY PUMPS**

Date **5/4/78** By **BAB**

Checked **5/19/78** By **JNE**

Based on Revised By



MODE NO. 6

FREQUENCY 21.16 Hz


FIGURE 20:

Client **VERCO** Location **SUPPLY** Est. No. **J.O. No. 12846.3**

Subject **OUTSIDE REPAIR SPRAY PUMPS** Date **5/4/78** By **BAB**

Checked **5/19/78** By **JNE**

Based on _____ Revised _____ By _____



MODE NO. 8

FREQUENCY 28.42 Hz

FIGURE 21

Client: **VEPCO**

Location: **SURRY**

Est. No.

J.O. No. **12246.0**

Subject: **OUTSIDE RECIRC SPRAY PUMPS**

Date: **5/4/78**

By: **BLB**

Checked: **5/19/78**


By: **JME**

Based on

Revised

By

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50



MODE NO. 9

FREQUENCY 35.19 Hz

FIGURE 27

Client **VERCO**

Location **SUPPLY**

Est. No.

J.O. No. **12245.0**

Subject **OUTSIDE RECIRC SPRAY PUMPS**

Date **5/4/78**

By **BAB**

Checked **5/19/78**


By **19/C**

Based on

Revised

By

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50



MODE NO. 10

FREQUENCY 37.22 Hz

FIGURE 23