

**50-335**

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

**2**

TO: Mr. V. Stello

FROM: FPL  
Miami, Fla. 33101  
R. E. Uhrig

DATE OF DOCUMENT

**2/2/78**

DATE RECEIVED

**2/8/78**

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP

**XXX**

INPUT FORM

NUMBER OF COPIES RECEIVED

**1 CC**

DESCRIPTION Ltr requesting withholding pursuant to Sec. 2.790 from the public the following PROP info.....2P

ENCLOSURE GEN-79-P entitled "Reactor Operation with Guide Tube Wear".....1½....

*(see prop reports)*

PLANT NAME : 88. Lucie Plant

**Dist per PM 2-14-78**

**10 cys ENCL Rec'd**

SAFETY	FOR ACTION/INFORMATION	ENVIRONMENTAL
ASSIGNED AD:		ASSIGNED AD: V. MOORE (LTR)
<input checked="" type="checkbox"/> BRANCH CHIEF: <b>LTR DAVIS</b>		BRANCH CHIEF:
<input checked="" type="checkbox"/> PROJECT MANAGER: <b>LTR Reeves</b>		PROJECT MANAGER:
<input checked="" type="checkbox"/> LIC. ASST: <b>LTR Diggs</b>		LIC. ASST:
		B. HARLESS

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILES - <b>CY #1</b>	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
<input checked="" type="checkbox"/> NRC PDR - <b>LTR</b>	R. MATTSON	TEDESCO	ENVIRON ANALYSIS
<input checked="" type="checkbox"/> I & E - <b>CY #2</b>	SCHROEDER	BENAROYA	DENTON & MULLER
<input checked="" type="checkbox"/> OELD - <b>LTR</b>		LATNAS	CRUTCHFIELD
GOSSICK & STAFF	ENGINEERING	IPPOLITO	
HANAUER	KNIGHT	E. ROSA	ENVIRON TECH
MIPC	BOSNAK		ERNST
CASE	SIHWEIL	OPERATING REACTORS	BALLARD
BOYD	PAWLICKI	STELLO	YOUNGBLOOD
		<input checked="" type="checkbox"/> EISENHUT - <b>LTR</b>	<b>CY #9 + 10</b>
PROJECT MANAGEMENT	REACTOR SAFETY	<input checked="" type="checkbox"/> SHAO - <b>2 cys Adv.</b>	SITE TECH
SKOVHOLT	ROSS	<input checked="" type="checkbox"/> BAER - <b>CY #4</b>	GAMMILL (2)
P. COLLINS	NOVAK	<input checked="" type="checkbox"/> BUTLER - <b>LTR</b>	
HOUSTON	ROSZTOCZY	<input checked="" type="checkbox"/> GRIMES - <b>LTR</b>	SITE ANALYSIS
MELTZ	CHECK		VOLLMER
HELTEMES		<input checked="" type="checkbox"/> <b>DAVIS - 2</b>	BUNCH
SK	AT & I	<b>CY #5 + 6</b>	<input checked="" type="checkbox"/> J. COLLINS - <b>LTR</b>
<input checked="" type="checkbox"/> H. Smith - <b>CY #3</b>	SALTZMAN		KREGER
	RUTBERG		

EXTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> LPDR: FT. Pierce - <b>LTR</b>	NAT LAB:	
<input checked="" type="checkbox"/> TIC - <b>LTR</b>		
<input checked="" type="checkbox"/> NSIC - <b>LTR</b>		
REG V (J. HANCHETT)		
<input checked="" type="checkbox"/> <b>2</b> CYS SENT CATEGORY	<b>B</b>	<b>TO ACRS - CY #7 + 8</b>

CONTROL NUMBER  
**MR 2**  
780460007  
**GD**

1977-1982

1981-1982

1983-1984

DOCKET NO. 50-335  
DATE: 2-14-78

NOTE TO NRC AND/OR LOCAL PUBLIC DOCUMENT ROOMS


The following item submitted with letter dated 2-7-78  
from FP+L is being withheld from  
public disclosure, pending review, in accordance with Section 2.790.

PROPRIETARY INFORMATION

CEN-79-P-REACTOR opr w/ Guide  
Tube MEAB

Dow Sauls  
016

Regulatory File Room



February 7, 1978  
L-78-43

Office of Nuclear Reactor Regulation  
Attention: Mr. Victor Stello, Director  
Division of Operating Licenses  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Stello:

Re: St. Lucie Unit 1  
Docket No. 50-335  
CEA Guide Tube Wear

Your letter of January 18, 1978 requested justification that excessive guide tube wear does not exist at St. Lucie Unit 1 or information justifying continued operation of St. Lucie Unit 1 considering the potential for guide tube wear.

St. Lucie Unit 1 is presently scheduled to be shutdown for refueling about April 1, 1978, and we will be unable to determine the amount of guide tube wear for the unit until that time. Our NSSS Vendor has prepared a report which is responsive to your request for justification of continued operation. The report specifically addresses reactor operation with guide tube wear and supports continued operation of St. Lucie Unit 1. This report (CEN-79-P) discusses inspection results from other facilities and evaluates the impact of guide tube wear on SAR analyses. The report concludes that reactor operation with worn guide tubes does not create undue risk to the health and safety of the public.

↓  
Changed per  
telecon with  
FPL 2/14/78  
RZC

78046007

Mr. Victor Stello  
February 7, 1978  
Page Two

We had planned to forward a copy of the report with this letter. However, due to inclement weather in the Northeast (where our NSSS vendor is located) our receipt of the report has been delayed. We expect to receive the report within the next few days at which time we will promptly forward a copy to your office.

Very truly yours,

  
Robert. E. Uhrig  
Vice President

REU:MAS:sl

cc: Mr. James P. O'Reilly, Region II  
Harold F. Reis, Esquire  
Mr. Edward Reeves ✓

