

C 53-78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)  
DISTRIBUTION FOR INCOMING MATERIAL 50-335

REC: REID R W  
NRC

ORG: UHRIG R E  
FL PWR & LIGHT

DOCDATE: 05/01/78  
DATE RCVD: 05/04/78  
03

DOCTYPE: LETTER NOTARIZED: NO  
SUBJECT:  
REQUEST THAT CONDITIONS OF LICENSE N, O & P BE DELETED.

COPIES RECEIVED  
LTR 3 ENCL 0

PLANT NAME: ST LUCIE #1

REVIEWER INITIAL: XEF  
DISTRIBUTOR INITIAL: ME

\*\*\*\*\* DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS \*\*\*\*\*

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.  
(DISTRIBUTION CODE A001)

FOR ACTION: BR CHIEF REID\*\*LTR ONLY(7)

INTERNAL:

REG FILE\*\*LTR ONLY(1)  
I & E\*\*LTR ONLY(2)  
HANAUER\*\*LTR ONLY(1)  
EISENHUT\*\*LTR ONLY(1)  
BAER\*\*LTR ONLY(1)  
EEB\*\*LTR ONLY(1)  
J. MCGOUGH\*\*LTR ONLY(1)

NRC PDR\*\*LTR ONLY(1)  
OELD\*\*LTR ONLY(1)  
CHECK\*\*LTR ONLY(1)  
SHAO\*\*LTR ONLY(1)  
BUTLER\*\*LTR ONLY(1)  
J COLLINS\*\*LTR ONLY(1)

EXTERNAL:

LPDR'S  
FT PIERCE, FL\*\*LTR ONLY(1)  
TIC\*\*LTR ONLY(1)  
NSIC\*\*LTR ONLY(1)  
ACRS CAT B\*\*LTR ONLY(16)

DISTRIBUTION: LTR 40 ENCL 0  
SIZE: 1P


CONTROL NBR: 781220140

\*\*\*\*\* THE END \*\*\*\*\*

ED  
MA 4



REGULATORY DOCKET FILE COPY



May 1, 1978  
L-78-158

Office of Nuclear Reactor Regulation  
Attention: Mr. Robert W. Reid, Chief  
Operating Reactor Branch #4  
Division of Operating Reactors  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Reid:

Re: Conditions of License N, O, and P  
St. Lucie Unit No. 1, Docket No. 50-335

By Amendment No. 19 to the Operating License for St. Lucie Unit No. 1, the Nuclear Regulatory Commission granted a one-time extension to the surveillance frequency for resistance temperature detector tests, snubber functional tests, and Class 1E underground cable tests in response to FPL's request dated August 22, 1977 (L-77-256), as supplemented by our letters dated September 2, 1977 (L-77-276), and November 1, 1977 (L-77-338). The amendment extended the surveillance intervals for these tests to allow the testing to be performed during the first scheduled refueling outage. The completion of these tests was required as Conditions of License N, O, and P, respectively.

The surveillances required by Technical Specifications 4.3.1.1.3 (Reactor Protective Instrumentation Response Time Tests), 4.7.10.1.3 (snubber functional tests), and 4.8.1.1.3 (Class 1E underground cable tests) have been completed. Documentation relating to these surveillances is available onsite for review by NRC personnel. It is accordingly requested that Conditions N, O, and P be deleted from Enclosure 1 as having been satisfied.

Very truly yours,

Robert E. Uhrig  
Vice President

REU:MAS:s1

cc: Mr. Peter B. Erickson  
Mr. J. P. O'Reilly, Region II  
Harold F. Reis, Esquire

781220140

Approved  
5/10

