

F 04/27/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-335

REC: REID R W
NRC

ORG: UHRIG R E
FL PWR & LIGHT

DOCDATE: 04/18/78
DATE RCVD: 04/26/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED

SUBJECT:

LTR 3 ENCL 0

FURNISHING CORRECTION TO TYPOGRAPHICAL ERROR CONTAINED IN APPLICANT'S LTR DTD
03/23/78 TO ITEM 3 FOUND ON PAGE 3 IN RESPONSE TO NRC JAN 1978 GENERIC LTR ON
ASSYMETRIC LOADS.

PLANT NAME: ST LUCIE #1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *W*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE:
(DISTRIBUTION CODE A001)

FOR ACTION: BR CHIEF REID**LTR ONLY(7)

INTERNAL:

REG FILE**LTR ONLY(1)

I & E**LTR ONLY(2)

HANAUER**LTR ONLY(1)

EISENHUT**LTR ONLY(1)

BAER**LTR ONLY(1)

EEB**LTR ONLY(1)

J. MCGOUGH**LTR ONLY(1)

NRC PDR**LTR ONLY(1)

OELD**LTR ONLY(1)

CHECK**LTR ONLY(1)

SHAO**LTR ONLY(1)

BUTLER**LTR ONLY(1)

J COLLINS**LTR ONLY(1)

EXTERNAL:

LPDR'S

FT PIERCE, FL**LTR ONLY(1)

TIC**LTR ONLY(1)

NSIC**LTR ONLY(1)

ACRS CAT B**LTR ONLY(16)

DISTRIBUTION: LTR 40 ENCL 0
SIZE: 1P

CONTROL NBR: 781160188

***** THE END *****

MA 4
60

THE UNITED STATES OF AMERICA
DEPARTMENT OF THE ARMY
OFFICE OF THE CHIEF OF STAFF
WASHINGTON, D. C. 20315

MEMORANDUM FOR THE CHIEF OF STAFF
SUBJECT: [Illegible]

1. [Illegible]

2. [Illegible]


3. [Illegible]

4. [Illegible]

5. [Illegible]

6. [Illegible]

7. [Illegible]



April 18, 1978

L-78-138

US NRC
DISTRIBUTION SERVICES
BRANCH

1978 APR 26 AM 10 33

RECEIVED DISTRIBUTION
SERVICES UNIT

Director of Nuclear Reactor Regulation
 Attention: Mr. Robert W. Reid, Chief
 Operating Reactors Branch #4
 Division of Operating Reactors
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

Dear Mr. Reid:

Re: St. Lucie Unit 1
 Docket No. 50-335
Assymetric LOCA Loads

REGULATORY DOCKET FILE COPY

My letter to Mr. Don K. Davis dated March 23, 1978, provided our response to his request that we review the NRC staff's January 1978 generic letter on assymetric loads and indicate how we would modify the August 1977 report for St. Lucie Unit 1 in light of the staff's letter. In reviewing our response, we have discovered a typographical error which should be corrected. Item 3 found on page 3 of our submittal should read as follows (the underlined portion was omitted):

3. The size of the flaw required to initiate a cold-leg guillotine is about 0.862" deep X 8" long. An initial flaw about 0.2" deep X 2" long could conceivably grow to the critical flaw size over a 10 year period. This flaw size is above code allowable and is well above the lower level of detectability of available NDT equipment. Its undetected presence in RCS piping is considered negligible.

Very truly yours,

Robert E. Uhrig
 Vice President

REU:LLL:sl

cc: Mr. James P. O'Reilly, Region II
 Harold F. Reis, Esquire

781160188

A001
5/10

