

DISTRIBUTION

Docket Files 50-280 and 50-281

TERA
J. Buchanan
ACRS (16)
V. Noonan
J. P. Knight
L. Heller
J. Schauer
B. D. Law

MAY 25 1979

NRC PDR (2)
Local PDR
NRR Rdg
ORB1 Rdg
V. Stello
D. Eisenhut
R. Vollmer
B. Grimes
W. Russell
J. Carter
A. Schwencer
D. Neighbors
D. Wigginton
C. Parrish
P. Kreuzer
OELD
I&E (3)

Docket Nos. 50-280
and 50-281

Mr. W. L. Proffitt
Senior Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Proffitt:

The purpose of this letter is to state our position regarding the use of soil structure interaction for the seismic pipestress analyses being performed for Surry Power Station, Units 1 and 2.

Based on the results of the information you provided by your letter dated May 24, 1979 in response to our May 18, 1979 letter and in other meetings, we confirm that soil structure interaction methodology may be used for Surry provided that seismic stresses calculated are increased by a factor of 1.5. This factor applies to the seismic stresses derived from amplified response spectra using 1% damping. It is further acknowledged that certain individual analyses may require consideration on a case by case basis.

The earthquake of primary safety concern is the SSE. However, due to the nonlinearities of the soil which are considered in the soil structure interaction analyses, the stiffness of the subgrade is a function of the earthquake level. Since the floor response spectra are sensitive to the stiffness of the subgrade, they too are dependent on the earthquake level. Therefore, it is requested that the following two points be addressed:

1. Discuss in detail why it can be concluded that the piping analyzed for the SSE condition will safely withstand all earthquakes up to and including the SSE.
2. For any piping systems which meet SSE requirements but do not meet the FSAR OBE design requirements, provide the level of earthquake for which the FSAR OBE design requirements are met.

JPKnight
05/25/79

WTRussell
05/25/79

VNoonan
05/25/79

Sincerely,
15/

7906250039

OFFICE	DOR:ORB1	DOR:ORB1	DOR:AD,S&P	DOR:AD,S&P
SURNAME	JDKneighors	JBASchwencer	RVoNmer	D. C. Eisenhut, Deputy Director
DATE	05/25/79	05/179	05/179	05/25/79



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 25, 1979

Docket Nos. 50-280
and 50-281

Mr. W. L. Proffitt
Senior Vice President - Power
Virginia Electric and Power Company
Post Office Box 26666
Richmond, Virginia 23261

Dear Mr. Proffitt:

The purpose of this letter is to state our position regarding the use of soil structure interaction for the seismic pipestress analyses being performed for Surry Power Station, Units 1 and 2.

Based on the results of the information you provided by your letter dated May 24, 1979 in response to our May 18, 1979 letter and in other meetings, we confirm that soil structure interaction methodology may be used for Surry provided that seismic stresses calculated are increased by a factor of 1.5. This factor applies to the seismic stresses derived from amplified response spectra using 1% damping. It is further acknowledged that certain individual analyses may require consideration on a case by case basis.

The earthquake of primary safety concern is the SSE. However, due to the nonlinearities of the soil which are considered in the soil structure interaction analyses, the stiffness of the subgrade is a function of the earthquake level. Since the floor response spectra are sensitive to the stiffness of the subgrade, they too are dependent on the earthquake level. Therefore, it is requested that the following two points be addressed:

1. Discuss in detail why it can be concluded that the piping analyzed for the SSE condition will safely withstand all earthquakes up to and including the SSE.
2. For any piping systems which meet SSE requirements but do not meet the FSAR OBE design requirements, provide the level of earthquake for which the FSAR OBE design requirements are met.

Sincerely,

A handwritten signature in dark ink, appearing to read "D. G. Eisenhut", is written over a horizontal line.

D. G. Eisenhut, Deputy Director
Division of Operating Reactors

cc: See next page

Mr. W. L. Proffitt
Virginia Electric and Power Company

cc: Mr. Michael W. Maupin
Hunton and Williams
Post Office Box 1535
Richmond, Virginia 23213

Swem Library
College of William and Mary
Williamsburg, Virginia 23185

Donald J. Burke
U. S. Nuclear Regulatory Commission
Region II
Office of Inspection and Enforcement
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303