

**NUCLEAR REGULATORY COMMISSION**

**[Docket Nos. 52-025 and 52-026; NRC-2008-0252]**

**Southern Nuclear Operating Company, Inc.**

**Vogtle Electric Generating Plant, Units 3 and 4**

**Main Control Room Emergency Habitability System Changes**

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Exemption and combined license amendment; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) has issued an exemption to allow a departure from the certification information of Tier 1 of the generic design control document and issued License Amendment Nos. 108 and 107 to Combined License (COL) Nos. NPF-91 and NPF-92, respectively. The COLs were issued to Southern Nuclear Operating Company, Inc., and Georgia Power Company; Oglethorpe Power Corporation; MEAG Power SPVM, LLC; MEAG Power SPVJ, LLC; MEAG Power SPVP, LLC; and the City of Dalton, Georgia (the licensee), for construction and operation of the Vogtle Electric Generating Plant (VEGP), Units 3 and 4, located in Burke County, Georgia.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

**DATES:** The exemption and amendment were issued on February 1, 2018.

**ADDRESSES:** Please refer to Docket ID **NRC-2008-0252** when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- **Federal Rulemaking Web Site:** Go to <http://www.regulations.gov> and search for Docket ID **NRC-2008-0252**. Address questions about NRC dockets to Jennifer Borges telephone: 301-287-9127; e-mail: [Jennifer.Borges@nrc.gov](mailto:Jennifer.Borges@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- **NRC's Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "[ADAMS Public Documents](#)" and then select "[Begin Web-based ADAMS Search](#)." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to [pdresource@nrc.gov](mailto:pdresource@nrc.gov). The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated May 9, 2017 (ADAMS Accession No. ML17129A608), as supplemented by letter dated September 15, 2017 (ADAMS Accession No. ML17258B211).

- **NRC's PDR:** You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** Chandu Patel, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-3025; e-mail: [Chandu.Patel@nrc.gov](mailto:Chandu.Patel@nrc.gov).

**SUPPLEMENTARY INFORMATION:**

**I. Background**

The NRC is granting an exemption from paragraph B of section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment Nos. 108 and 107 to COL Nos. NPF-91 and NPF-92, respectively, to the licensee. The exemption is required by paragraph A.4 of section VIII, "Processes for Changes and Departures," appendix D, to 10 CFR part 52, to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee sought proposed changes to Updated Final Safety Analysis Report Tier 2 information and plant-specific Tier 1 information, with corresponding changes to COL Appendix C. Specifically, the changes revise the licensing basis information to reflect design changes to the main control room emergency habitability system to address the main control room envelope temperature response.

Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption was necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the

license amendment. The exemption met all applicable regulatory criteria set forth in sections 50.12 and 52.7 of 10 CFR, and section VIII.A.4 of appendix D to 10 CFR part 52. The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML18011A894.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to the licensee for VEGP, Units 3 and 4 (COL Nos. NPF-91 and NPF-92). The exemption documents for VEGP, Units 3 and 4, can be found in ADAMS under Accession Nos. ML18011A888 and ML18011A889, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COL Nos. NPF-91 and NPF-92 are available in ADAMS under Accession Nos. ML18011A890 and ML18011A891, respectively. A summary of the amendment documents is provided in Section III of this document.

## **II. Exemption**

Reproduced below is the exemption document issued to VEGP, Units 3 and Unit 4. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In a letter dated May 9, 2017, as supplemented by letter dated September 15, 2017, Southern Nuclear Operating Company requested from the Commission an exemption to allow departures from Tier 1 information in the certified design control document incorporated by reference in 10 CFR part 52, appendix D, as

part of license amendment request 17-001, "Main Control Room Emergency Habitability System Changes to Satisfy Post-Actuation Performance Requirements."

For the reasons set forth in Section 3.1 of the NRC staff's safety evaluation, the Commission finds that:

- A. The exemption is authorized by law;
- B. The exemption presents no undue risk to public health and safety;
- C. The exemption is consistent with the common defense and security;
- D. Special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;
- E. The special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and
- F. The exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, the licensee is granted an exemption from the certified design control document Tier 1 information, with corresponding changes to Appendix C of the Facility Combined License, as described in the request dated May 9, 2017, as supplemented by letter dated September 15, 2017. This exemption is related to, and necessary for the granting of License Amendment No. 108 [for Unit 3 and No. 107 for Unit 4], which is being issued concurrently with this exemption.

3. As explained in Section 5.0 of the NRC staff's safety evaluation, this exemption meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

### III. License Amendment Request

By letter dated May 9, 2017, as supplemented by letter dated September 15, 2017, the licensee requested that the NRC amend the COLs for VEGP, Units 3 and 4, COL Nos. NPF-91 and NPF-92. The proposed amendment is described in Section I of this *Federal Register* notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or COL, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the *Federal Register* on July 18, 2017 (82 FR 32884). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

#### **IV. Conclusion**

Using the reasons set forth in the combined safety evaluation, the staff granted the exemptions and issued the amendments that the licensee requested on May 9, 2017, as supplemented by letter dated September 15, 2017.

The exemptions and amendments were issued on February 1, 2018, as part of a combined package to the licensee (ADAMS Accession No. ML18011A885).

Dated at Rockville, Maryland, this 23<sup>rd</sup> day of May, 2018.

For the Nuclear Regulatory Commission.

*/RA/*

Paul B. Kallan, Acting Branch Chief,  
Licensing Branch 4,  
Division of New Reactor Licensing,  
Office of New Reactors.