

CENTRAL FILES

VIRGINIA ELECTRIC AND POWER COMPANY

Surry Power Station  
P. O. Box 315  
Surry, Virginia 23883

July 12, 1979

Docket No: 50-280

- J. P. D'REILLY
- ~~W. B. KENNA~~
- C. M. UPRIGHT
- P. D. CHENDEN
- W. B. KENNA
- F. J. LONG
- C. E. MURPHY
- J. T. SUTHERLAND
- K. M. CLARK

*Kenns  
Jeffers*

USNRC REG  
NTA

19 JUL 13 A 7: 36

Mr. James P. O'Reilly  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Sir:

In accordance with the provisions of Item 4, I.E. Bulletin No. 79-13, VEPSCO submits the following report for Surry Power Station:

With radiography of all feedwater welds inside containment in progress and 50% complete, two rejectable indications have been found to date. Specifically, 'B' S.G. Feedwater Line (14-WFPD-13-601) Weld #1 has a small area of rejectable porosity. 'A' S.G. Feedwater Line (14-WFPD-17-601) Weld #13 has small areas of rejectable incomplete fusion.

Very truly yours,

*W. L. Stewart*

W. L. Stewart  
Station Manager

*204  
CP*

790817060  
09/02/8062