



May 2, 2018

NRC 2018-0025
TS 5.5.13
10 CFR 50.71(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Point Beach Nuclear Plant, Units 1 and 2
Dockets 50-266 and 50-301
Renewed License Nos. DPR-24 and DPR-27

Technical Specification Bases Change Summary

In accordance with the requirements of Technical Specification (TS) 5.5.13 and 10 CFR 50.71(e), NextEra Energy Point Beach, LLC (NextEra) is submitting a summary of changes made to the Point Beach Nuclear Plant TS Bases without prior NRC approval.

The enclosure contains the TS Bases change summary for the period January 1, 2016, through March, 31 2018. NextEra previously submitted the TS Bases change summary for January 1, 2015, through December 31, 2015, on August 23, 2016 (ML16236A267).

This letter contains no new commitments and no revisions to existing commitments.

If you have any questions or require additional information, please contact me at (920) 755-7854.

Sincerely,

NextEra Energy Point Beach, LLC

John P. Scheid for
THOMAS P. SCHNEIDER

Eric Schultz
Licensing Manager

Enclosure

cc: Administrator, Region III, USNRC
Project Manager, Point Beach Nuclear Plant, USNRC
Resident Inspector, Point Beach Nuclear Plant, USNRC

NextEra Energy Point Beach, LLC

6610 Nuclear Road, Two Rivers, WI 54241

ENCLOSURE

NEXTERA ENERGY POINT BEACH, LLC POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

TECHNICAL SPECIFICATION (TS) BASES CHANGE SUMMARY FOR JANUARY 1, 2016 – MARCH 31, 2018

Affected Section	Date of Change	Affected Page(s)	Summary
3.0	July 2017	B 3.0-11 thru 14	Clarified applicability to Technical Specification Chapter 5 programs.
3.4.6	September 2016	B 3.4.6-5	Clarified that design basis acceptance criteria are used to assess operability. Clarified when surveillance is met. Clarified past operability requirement.
3.4.7	September 2016	B 3.4.7-5, 6	Clarified that design basis acceptance criteria are used to assess operability. Clarified when surveillance is met. Clarified past operability requirement.
3.4.8	September 2016	B 3.4.8-3, 4	Clarified that design basis acceptance criteria are used to assess operability. Clarified when surveillance is met. Clarified past operability requirement.
3.5.2	September 2016	B 3.5.2-4, 7	Added clarifying information in regards to containment spray and operability.
3.5.3	October 2017	B 3.5.3-2, 3	Removed extraneous verbiage and provided clarifying information pertaining to the resolution of concerns raised by NRC IN 2010-011.
3.6.6	September 2016	B 3.6.6-7, 13	Added clarifying information in regards to containment spray and operability.
3.8.1	April 2016	3.8.1-3, 4	Changed the verbiage to discuss Unit 1 and Unit 2 separately.
3.8.1	June 2016	3.8.1-5, 6	Aligned room temperatures for all emergency diesel generators.
3.8.9	April 2016	3.8.9-1, 5	Changed the verbiage to discuss Unit 1 and Unit 2 separately.
3.8.10	April 2016	3.8.10-3	Changed the verbiage to discuss Unit 1 and Unit 2 separately.
3.9.4	September 2016	3.9.4-4	Clarified that design basis acceptance criteria are used to assess operability. Clarified when surveillance is met. Clarified past operability requirement.
3.9.5	September 2016	3.9.5-4	Clarified that design basis acceptance criteria are used to assess operability. Clarified when surveillance is met. Clarified past operability requirement.