



May 2, 2018

NRC 2018-0026
10 CFR 50.71(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Point Beach Nuclear Plant, Units 1 and 2
Dockets 50-266 and 50-301
Renewed License Nos. DPR-24 and DPR-27

Technical Requirements Manual Change Summary

In accordance with 10 CFR 50.71(e), NextEra Energy Point Beach, LLC (NextEra), is submitting changes made to the Point Beach Nuclear Plant Technical Requirements Manual (TRM).


The enclosure contains the TRM change summary for the period January 1, 2016, through March 31, 2018. NextEra previously submitted the TRM change summary for January 1, 2015, through December 31, 2015, on August 17, 2016 (ML16230A369).

This letter contains no new commitments and no revisions to existing commitments.

If you have any questions or require additional information, please contact me at (920) 755-7854.

Sincerely,

NextEra Energy Point Beach, LLC


THOMAS P. SCHNEIDER

Eric Schultz
Licensing Manager

Enclosure

cc: Administrator, Region III, USNRC
Project Manager, Point Beach Nuclear Plant, USNRC
Resident Inspector, Point Beach Nuclear Plant, USNRC

ENCLOSURE

NEXTERA ENERGY POINT BEACH, LLC POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

TECHNICAL REQUIREMENTS MANUAL CHANGE SUMMARY FOR JANUARY 1, 2016 – MARCH 31, 2018

Affected Section	Date of Change	Affected Page(s)	Summary
1.0	August 2017	1.0-2	Updated references.
3.4.4	July 2017	3.4.4-5	Added that this program is part of the Inservice Testing Program.
3.7.2	October 2016	All	Rewrote to clarify alignment with TS 3.0.2 and TS 3.0.6.
3.7.6	February 2018	3.7.6-3, 7	Changed Functionality test of crossover steam dump valves from 31 days to 6 months.
4.1	March 2017	All	Updated to reflect changes made to ODCM.
4.4	March 2017	All	Updated to reflect changes made to ODCM.
4.8	January 2016	All	Updated references and definition of Plugging Criteria.
4.12	September 2017	4.12-1, 2, 3, 7	Updated references.
4.13	August 2017	4.13-2	Updated references.
4.15	July 2017	4.15-2	Added that this program is part of the Inservice Testing Program.
4.16	July 2017	4.16-1	Added that this program is part of the Inservice Testing Program.
4.17	January 2017	4.17-1	Updated the applicable code.
4.18	June 2016	4.18-1	Updated references.