

C06/09/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-335

REC: OREILLY J P
NRC

ORG: SCHMIDT A D
FL PWR & LIGHT

DOCDATE: 05/23/78
DATE RCVD: 06/06/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 1

FORWARDING LICENSEE EVENT REPT (RO 50-335/78-015) ON 04/23/78 CONCERNING
OPERATOR BLEW DOWN THE 1B BMT LEVEL INSTRUMENT TO PREVENT SENSING LINE
BLOCKAGE, CAUSING INSTRUMENT TO FAIL HIGH.

PLANT NAME: ST LUCIE #1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *M*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF ORB#4 BC**W/4 ENCL

INTERNAL:

REG FILE**W/ENCL
I & E**W/2 ENCL
I & C SYSTEMS BR**W/ENCL
NOVAK/CHECK**W/ENCL
AD FOR ENG**W/ENCL
HANAUER**W/ENCL
AD FOR OPER TECH**W/ENCL
ENGINEERING BR**W/ENCL
KREGER/J. COLLINS**W/ENCL
K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
EMERGENCY PLAN BR**W/ENCL
EEB**W/ENCL
PLANT SYSTEMS BR**W/ENCL
AD FOR PLANT SYSTEMS**W/ENCL
REACTOR SAFETY BR**W/ENCL
VOLLMER/BUNCH**W/ENCL
POWER SYS BR**W/ENCL

EXTERNAL:

LPDR'S
FT PIERCE, FL**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P

CONTROL NBR: 781600308

A04 50

***** THE END *****



Handwritten marks and scribbles in the top right corner.



FLORIDA POWER & LIGHT COMPANY

May 23, 1978
PRN-LI-78-144

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
230 Peachtree Street, N.W., Suite 1217
Atlanta, Georgia 30303

US NRC
DISTRIBUTION SERVICES
BRANCH

1978 JUN 6 PM 12 20

RECEIVED DISTRIBUTION
SERVICES UNIT

Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 335-78-15
ST. LUCIE UNIT 1
DATE OF OCCURRENCE: APRIL 23, 1978
TECHNICAL SPECIFICATION 3.1.2.7
BORIC ACID MAKEUP TANK 1B

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9 to provide 30-day notification of the subject occurrence.

Very truly yours,

J. R. Beusen
for A. D. Schmidt
Vice President
Power Resources

MAS/mb

Attachment

cc: Robert Lowenstein, Esquire
Director, Office of Inspection and Enforcement (30)
Director, Office of Management Information and
Program Control (3)

781600308

*A002
5/11*

