

NRC DISTRIBUTION OR PART 50 DOCKET MATERIAL

FILE NUMBER

TO: D.L. ZIEMANN

FROM: FLORIDA PWR & LIGHT CO.
R.E. UHRIG
MIAMI, FLORIDA

DATE OF DOCUMENT
10-30-76

DATE RECEIVED
10-29-76

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1

DESCRIPTION
LTR. RE. THEIR 6-30-76 LTR....TRANS THE FOLLOWING

ENCLOSURE

SEISMIC ANALYSIS OF CONTAINMENT FAN COOLER,
UNITS.....

(1 SIGNED CY. RECEIVED)
(21 PAGES)

ACKNOWLEDGED

DO NOT REMOVE

PLANT NAME: ST. LUCIE # 1

SAFETY

FOR ACTION/INFORMATION

ENVIRO

SAB 11-3-76

ASSIGNED AD:		ASSIGNED AD:
BRANCH CHIEF:	ZIEMANN <i>W/6</i>	BRANCH CHIEF:
PROJECT MANAGER:	+	PROJECT MANAGER:
LIC. ASST.:	DIGGS	LIC. ASST.:

INTERNAL DISTRIBUTION

<input checked="" type="checkbox"/> REG FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
<input checked="" type="checkbox"/> NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
<input checked="" type="checkbox"/> I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
<input checked="" type="checkbox"/> OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACCARRY	KIRKWOOD	ERNST
CASE	KNIGHT		BALLARD
HANAUER	SIHWEIL	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
			SITE TECH.
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	GAMMILL
BOYD	ROSS	EISENHUT	STAPP
P. COLLINS	NOVAK	SHAO	HULMAN
HOUSTON	ROSZTOCZY	BAER	
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		GRIMES	VOLLMER
HELTEMES	AT & I		BUNCH
SKOVHOLT	SALTZMAN		J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

<input checked="" type="checkbox"/> LPDR: FT. PIERCE, FLA.	NAT LAB:	BROOKHAVEN NAT LAB
<input checked="" type="checkbox"/> TIC:	REG. VIE	ULRIKSON(ORNL)
<input checked="" type="checkbox"/> NSIC:	LA PDR	
<input checked="" type="checkbox"/> ASLB:	CONSULTANTS	
<input checked="" type="checkbox"/> ACRS 16CYS HOLDING/SENT TO ACRS CAT "B"		

10903

44-1110

NO. 10-11
NO. 10-11

UNITED STATES DEPARTMENT OF JUSTICE
FEDERAL BUREAU OF INVESTIGATION
WASHINGTON, D. C. 20535

CONFIDENTIAL

Re: [Illegible] (S)
[Illegible] (S)

(S)

[Illegible]

[Illegible]

[Illegible]



(S)

[Illegible]

[Illegible]

Regulatory

File by



August 30, 1976
L-76-314



Office of Nuclear Reactor Regulation
Attn: Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Ziemann:

Re: St. Lucie Unit No. 1 (Docket No. 50-335)
Seismic Analysis of Containment Fan Cooler Units

Enclosed herewith is the document entitled "Seismic Analysis Report of the St. Lucie Unit 1 Fan Coolers." This document supplies information regarding the analytical techniques which were employed in the seismic analysis of the containment fan cooler units at St. Lucie Unit No. 1.

We are submitting this information in accordance with our commitment made in my letter of June 30, 1976 (L-76-243) and referred to in the Staff's Safety Analysis supporting Amendment No. 6 to the St. Lucie Unit 1 Operating License.

Very truly yours,

Robert E. Uhrig
Robert E. Uhrig
Vice President

REU/NR/hlc
Attachment

cc: Norman C. Moseley, Region II
Jack R. Newman, Esq.

10903



Small, faint, illegible text or markings at the bottom center of the page.

SEISMIC ANALYSIS REPORT
OF THE
ST. LUCIE UNIT 1 FAN COOLERS

by
C. W. Lin
H. S. LaPay
J. Parelio
G. A. Balotinas

REC'D BY TELECOPIER FPL - PWR PLT ENG
FROM: _____
DATE: AUG 27 1976
TIME: 4:00
REC'D BY: <i>[Signature]</i>

APPROVED BY: *[Signature]*
G. J. Bohm, Acting Manager
Structural Technology

Westinghouse Electric Corporation

August 1976

TABLE OF CONTENTS

SECTION		PAGE
1	Introduction	1
2	Description of Fan General Assembly	2
3	Analytical Methods and Criteria	4
4	Input Description	5
5	Results	12
6	Conclusions	17

TABLE OF ILLUSTRATIONS

FIGURE		PAGE
1	Schematic Representation of the Fan General Assembly	3
2	Floor Response Spectra for Vertical Direction, OBE and 0.5% Damping	6
3	Floor Response Spectra for Vertical Direction, OBE and 1% Damping	7
4	Floor Response Spectra for Horizontal Direction, OBE and 1% Damping - Elev. 60	8
5	Floor Response Spectra for Horizontal Direction, OBE and 0.5% Damping - Elev. 60	9
6	Floor Response Spectra for Horizontal Direction, OBE and 0.5% Damping - Elev. 44	10
7	Floor Response Spectra for Horizontal Direction, OBE and 1% Damping - Elev. 44	11

SECTION 1

INTRODUCTION

This analysis was performed to verify the structural integrity and operability of the St. Lucie - Unit 1 reactor containment fan coolers when subjected to seismic loads. It was found from the seismic analysis that the reactor containment fan coolers conform to the St. Lucie - Unit 1 seismic criteria.

Presented in this document are the results from the seismic analysis demonstrating the seismic structural adequacy and operability of the St. Lucie - Unit 1 fan coolers. Also, given is a discussion of the analytical methods employed, a description of the input used, and a description of the fan cooler structural system.

DESCRIPTION OF FAN GENERAL ASSEMBLY

The general assembly (Fig. 1 Schematic Dwg.) consists of fan assembly, motor base, and heat exchanger assembly. The motor is mounted on top of motor heat exchanger assembly which is bolted to fan assembly. The complete assembly is welded to the floor foundation. The specific details are discussed below.

The fan assembly consists of rotor assembly, housing assembly, bearing base, inlet, spherical roller bearings, and inlet flange ring. Housing assembly is made of welded steel plates and consists of side sheets and scroll. The rotor consists of centrifugal airfoil bladed wheel assembly and the shaft. The wheel assembly is pressed on the shaft and is also retained on the shaft by two 3/4-10 set screws. The spherical roller bearings are mounted on the rotor assembly and bolted to the bearing base assembly. The rotor assembly is connected to the motor with a flexible coupling. The bearing base is fabricated using welded steel construction. The inlet is of all welded steel construction and is used to guide air into the wheel assembly.

The motor base is of all welded construction and compartmented so that hot air is blown over the heat exchanger and returned to cool the motor which is bolted on top of the base. The motor heat exchanger is bolted to the welded steel mounting frame inside the motor base.




FIGURE 1: Schematic Representation of the Fan General Assembly

SECTION 3

ANALYTICAL METHODS AND CRITERIA

As described in the previous section, there is no interaction between the fan and motor rotors of the fan cooler structure because each rotor has its own fixed bearing and the shafts are connected through a flexible coupling. Based on this fact, the fan and motor were independently analyzed.

Drawings for the reactor containment fan cooler were used to determine the general assembly, dimensions, and properties of components.

The structure was modeled as spring mass systems and the natural frequencies were computed to determine the behavior of the components during seismic excitation. As explained in Section 4, the amplification levels are determined based on the floor response spectra. It was determined that the frequencies associated with the fan motor system including coils and coil banks have frequencies in the region of zero amplifications. Therefore, the seismic analysis was performed using equivalent static loads.

Stresses and deflections were calculated using elastic relations for the worst combination of operating loads, horizontal seismic (DBE), vertical seismic (DBE), and accident pressure (coils and coil banks).

Limit values used were in accordance with the elastic provisions in Part I (fan cooler structural components) AISC-69 and ASME Sec. VIII, Pressure Vessels Specifications (coil tube and fin material). No analysis was made for the OBE since it was shown that the DBE stress levels are within OBE elastic limits as defined in the criteria documents above.

Operability of the fan cooler during seismic event is ensured after establishing that the stresses are within elastic limits and that the deflections are limited and will remain within allowable values of the operating clearances.

SECTION 4

INPUT DESCRIPTION

The seismic design values used in the calculations were obtained from the floor response spectra included in the EBASCO specification containment fan coolers No. FLO-8770.775, dated May 26, 1971, Section 18.

Shown in Figures 2 to 7 are the floor response spectra for OBE. Figures 2 and 3 are vertical floor response spectra for 0.5% and 1% equipment damping values, respectively. Figures 4 and 5 are horizontal floor response spectra for 0.5% and 1% equipment damping values, respectively, at reactor building elevation 60. Figures 6 and 7 are horizontal floor response spectra for 0.5% and 1% equipment damping values, respectively, at reactor building elevation 44.

As shown in Figures 2 to 7, the response spectral peaks are at and above 0.30 second period. Less than or equal to 0.05 second period which includes all natural frequencies calculated for the assembly, the response spectral values have converged to the floor acceleration values. Consequently, the assembly can be considered as rigid for the floor response spectra shown in Figures 2 to 7. However, for the purpose of conservatism, static accelerations of 0.6g and 0.4g for horizontal and vertical directions, respectively, have been chosen as the OBE input to the assembly.

To obtain the maximum hypothetical earthquake (DBE) values, the above values were multiplied by 2. The following DBE acceleration values were used:

VERTICAL SEISMIC

0.6g

HORIZONTAL SEISMIC

Elev. 44'

Elev. 60'

1.2g

1.2g

The vertical and horizontal seismic loads were applied simultaneously to allow for the worst possible conditions. In addition, the coils were subjected to a differential pressure of 2 psf to represent the blowdown transient pressure difference.

FL. SPECTRA VERT.

REACT. BLDG.

FLORIDA POWER & LIGHT COMPANY
NUCLEONIC ISLAND PLANT
1973-020,559 KW ESTABLISHED UNIT NO. 1

GROUND ACCELERATION 0.085g




FIGURE 2: Floor Response Spectra for Vertical Direction, 0.08g and 0.5% Damping

FL-SPECTRA VERT.

REACT. BLDG.

FLORIDA POWER & LIGHT COMPANY

HUTCHINSON ISLAND PLANT

1973 320,000 KW INSTALLATION UNIT NO. 1

GROUND ACCELERATION 0.035G




FIGURE 3: Floor Response Spectra For Vertical Direction, OBE and 1% Damping

FL: SPECTRA (HOR.)

REACT. BLDG EL. 60-0

AT&T POWER & LIGHT COMPANY
ROCKWELL ISLAND PLANT
1973-990,000 IN INSTALLATION-TEST NO. 1

GROUND ACCELERATION 0.053





FIGURE 4: Floor Response Spectra for Horizontal Direction, OBE and 1% Damping
Elev. 60



FLOOR SPECTRA (HOR.)

REACT. SLS EL. 60.0

FLOOR POWER & LIGHT SUPPLY
REFLECTION GLASS FLAT
1970-554,000 KW ESTIMATED COST EX T
GROUND ACCELERATION 0.05g




FIGURE 5: Floor Response Spectra for Horizontal Direction, OBE and 0.5% Damping Elev. 60

FL. SPECTRA (HOR.)

REACT. BLDG EL. 44.0

FLORIDA POWER & LIGHT COMPANY
NORTHSHORE ENERGY PLANT
1073-001-000 NY ESTABLISHMENT NO. 1
GROUND ACCELERATION 0.05




FIGURE 6: Floor Response Spectra for Horizontal Direction, OBE and 0.5% Damping

Elev. 44

FL. SPECTRA (HOR.)

REACT. LOG. EL. 44.0

ELCORA POWER & LIGHT COMPANY

ANTHONY BLAKE BROTHERS

1075 622,000 KVA CAPACITANCE NO. 1

GROUND ACCELERATION 0.02




FIGURE 7: Floor Response Spectra for Horizontal Direction, BSE and 1/2 Damping
Elev. 44

SECTION 5

RESULTS

The fan motor system spring constants and natural frequencies were calculated. As shown in Table 1, all natural frequencies are above 20 Hz including the rotor assembly which is 24.6 Hz. These frequencies are at and above the rigid range of the floor response spectra, (Figures 2 to 7), i.e., the floor response spectra converge to the constant response values with zero amplification at and above 20 Hz (or 0.05 sec.). Because all natural frequencies are in the region of zero amplification, the fan motor system was analyzed using seismic equivalent static loads.

Shown in Table 2 are the calculated and limit behavior along with the margin of strength for different modes. OBE seismic loads were used to calculate the values in Table 2. Since the elastic limits associated with an OBE event were not exceeded when OBE seismic levels were used, it is not necessary to perform an OBE seismic analysis.

TABLE I

NATURAL FREQUENCIES

ITEM	DESCRIPTION	FREQUENCY (CPS)	BEHAVIOR
1.	Bearing Base Horizontal	106	Rigid
2.	Bearing Base Vertical	425	Rigid
3.	Motor Base and Motor Coil Horizontal	35.09	Rigid
4.	Motor Base with Motor & Coil Horizontal	67.89	Rigid
5.	Rotor Assy on Brg Base & Bearings 1st	24.6	Near Rigid Region
6.	Rotor Assy on Brg Base & Bearings 2nd	153.50	Rigid
7.	Motor Shaft on Motor Brg. Bracket	56.65	Rigid

*Approximate - Cantilever Beam Ref.

Den Hartog, Mechanical Vibrations 4th Ed.

P. 432, McGraw-Hill Book Co.

TABLE 2 - SEISMIC ANALYSIS OF REACTOR CONTAINMENT FAN COOLER

IT #	POSTULATED FAILURE MODE DESCRIPTION	UNITS	CALCULATED BEHAVIOR	LIMIT BEHAVIOUR	MARGIN OF STRENGTH*
1	Deflection of fan wheel & housing to cause rubbing	in.	.0239	.125	5.23
2	Wheel - Shaft Attachment	lb.	1753.	2600	1.48
3	Max fan shaft stress - combined	psi	5046	24,300	4.28
4	Motor coil hold down bolts (shear)	psi	5865	10000	1.70
5	Motor coil support stress	psi	1534	22000	14.30
6	Motor - Motor Base Bolts (tension-2 bolts)	psi	2785	20000	7.18
7	Motor - Motor base bolts (shear-4 bolts)	psi	2228	10000	4.49
8	Motor base - Sub base bolts (tension-10 bolts)	psi	2148	20000	9.31
9	Motor base - Sub base bolts (shear-20 bolts)	psi	1300	10000	7.69
10	Bearing bolts End brg (shear)	psi	868	10000	11.51
11	Bearing bolts End brg (tension)	psi	736	20000	27.16
12	Bearing bolts fltg brg. (shear)	psi	1152	10000	8.67
13	Motor coil tuba stress	psi	3001	6000	2.00
14	Motor coil end frame stress	psi	230	22000	96.0
15	Motor coil nozzle stress	psi	1029	6000	5.83
16	Motor rotor deflection (air gap)	in.	.00745	.0395	5.20
17	Motor shaft stress combined	psi	4441	22000	4.95

GENERAL CORPORATION

TABLE 2 - SEISMIC ANALYSIS OF DUCTED CONTAINMENT FAN COOLER

PAGE TWO

ITEM	POSTULATED FAILURE MODE DESCRIPTION	UNITS	CALCULATED BEHAVIOUR	LIMIT BEHAVIOUR	FACTOR OF SAFETY
16.	Motor shaft stress shear	psi	4236	14500	3.42
19.	Motor Bearings fnd brg B ₁₀	Hr	180000 ^{ad}	-	-
20.	Motor Bearings fltg brg B ₁₀	Hr	293000 ^{ad}	-	-
21.	Fan Bearings fnd & fltg B ₁₀ (See FBC registered brg anal. 73618)	Hr	200,000 ^{ad}	-	-
22.	Coupling	HRF	154	405	2.63
23.	Coil Bank coil tube end (shear)	psi	51.6	3406	65.97
24.	Coil Bank coil tube stress	psi	3899	3900	1.51
25.	Coil Bank coil fin stress (vert.-load)	psi	97.4	1345	13.8
26.	Coil Bank coil top & bottom plt stress	psi	1183	13200	9.75
27.	Coil Bank coil fin stress @ fin suppt	psi	598	1952	3.26
28.	Fin Support Bolts @ center (Shear)	psi	6906	10000	1.45
29.	Fin Support Bolts @ center (Shear)	psi	4577	10000	2.18
30.	Coil Top & Bottom end bolts (Shear)	psi	1433	10000	6.98
31.	Coil Header Nozzle Stress	psi	419	5500	14.05
32.	Coil - Coil Bank Frame Bolts (Shear)	psi	1298	10000	7.7

WINDHOUSE ELECTRIC CORPORATION

TABLE 2 - SEISMIC ANALYSIS OF REACTOR CONTAINMENT FAN COOLER-Page Three

ITEM	POSTULATED FAILURE MODE DESCRIPTION	UNITS	CALCULATED BEHAVIOUR	LIMIT BEHAVIOUR	RATIO OF LIMIT TO CALCULATED BEHAVIOR
33.	Coil Trough - Coil Bank Frame Bolts (Shear)	psi	6637	10000	1.50
34.	Coil Bank Frame - Top Bolts (Shear)	psi	5842	10000	1.71
35.	Coil Bank Frame - Bottom Bolts (Tension)	psi	10334	20000	1.93
36.	Coil Bank - Enclosure Attachment (Tension)	psi	6443	20000	3.10
37.	Coil Bank - Enclosure Attachment (shear)	psi	1326	10000	7.53
38.	Coil Bank Base - Enclosure Attachment (shear)	psi	776	10000	12.87
39.	Coil Bank Base - Enclosure Attachment (tension)	psi	1054	20000	18.97
40.	Motor Base Piping Brace	psi	4838	22000	4.55
41.	Fan Housing Ass'y Piping Brace	psi	726	22000	30.29
42.	Bearing Base Piping Brace	psi	611	22000	36.01
43.	RCFC Roof Ass'y Piping Brace	psi	3900	22000	5.64
44.	RCFC Manifold Pipe Support	psi	4892	22000	4.50
45.	RCFC Manifold "U" Clamp Stress (Shear)	psi	1770	10000	5.65
46.	RCFC Manifold Lower Pipe Support	psi	16764	22000	1.31

** Seismic Effect has No Effect on BRG Life.

SECTION 6

CONCLUSIONS

Based upon the seismic analysis conducted, the fan system, cooling coils, and coil banks can more than support the maximum earthquake (DBE) loads in combination with operating and accident loads called for in the specifications. The above will remain elastic under specified maximum loads. The design, therefore, is adequate. Therefore, the St. Lucie Unit 1 reactor containment fan cooler seismic structural integrity and operability has been demonstrated to meet the St. Lucie Unit No. 1 seismic requirements.

