

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:
Mr. Don K. Davis

FROM:
Florida Power & Light Company
Miami, Florida
Robert E. Uhrig

DATE OF DOCUMENT
5/26/77

DATE RECEIVED
6/1/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP
INPUT FORM

NUMBER OF COPIES RECEIVED
1 SIGNED

DESCRIPTION

DO NOT REMOVE

DISTRIBUTION OF MATERIAL CONCERNING DIESEL ALARM CIRCUITRY FOR DEESEL GENERATORS.

PLANT NAME: (1-P)
St. Lucie Unit No. 1

RJL

ACKNOWLEDGED

ENCLOSURE

Consists of requested additional information regarding the alarm and control circuitry for the diesel generators.....

(3-P)

SAFETY		FOR ACTION/INFORMATION		ENVIRO	
ASSIGNED AD:		ASSIGNED AD:		ASSIGNED AD:	
BRANCH CHIEF:	(5) Davis	BRANCH CHIEF:		BRANCH CHIEF:	
PROJECT MANAGER:	Reeves	PROJECT MANAGER:		PROJECT MANAGER:	
LIC. ASST.:	Diggs	LIC. ASST.:		LIC. ASST.:	

INTERNAL DISTRIBUTION			
REG-FILE	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY &
NRC PDR	HEINEMAN	TEDESCO	ENVIRO ANALYSIS
I & E (2)	SCHROEDER	BENAROYA	DENTON & MULLER
OELD		LAINAS	
GOSSICK & STAFF	ENGINEERING	IPPOLITO	ENVIRO TECH.
MIPC	MACCARRY	KIRKWOOD	ERNST
CASE	KNIGHT		BALLARD
HANAUER	SINWEY	OPERATING REACTORS	SPANGLER
HARLESS	PAWLICKI	STELLO	
PROJECT MANAGEMENT	REACTOR SAFETY	OPERATING TECH.	SITE TECH.
BOYD	ROSS	EISENHUT	GAMMILL
P. COLLINS	NOVAK	SHAO	STEPP
HOUSTON	ROSZTOCZY	BAER	HULMAN
PETERSON	CHECK	BUTLER	SITE ANALYSIS
MELTZ		CRIMES	VOLLNER
HELTENES	AT & I	E. ROSA	BUNCH
SKOVHOLT	SALTZMAN	T. WAMBACH	J. COLLINS
	RUTBERG		KREGER

EXTERNAL DISTRIBUTION			CONTROL NUMBER
LA PDR: Ft Pierce, Fla	NAT LAB:	BROOKHAVEN, NAT LAB	<div style="border: 1px solid black; padding: 5px; display: inline-block;">771530106</div>
TIC:	REG. VIE	ULRIKSON (ORNL)	
NSIC:	LA PDR		
ASLB:	CONSULTANTS		
ACRS 16 CYS / AKOAYWQ / EN	AS CAT. "B"		

MA 4

60



May 26, 1977
L-77-161

REGULATORY DOCKET FILE COPY

Office of Nuclear Reactor Regulation
Attention: Mr. Don K. Davis, Acting Chief
Operating Reactors Branch #2
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555




Dear Mr. Davis:

Re: St. Lucie Unit 1
Docket No. 50-335
Diesel Generator Information

We have reviewed your April 7, 1977 information request regarding the alarm and control circuitry for the diesel generators at our St. Lucie facility. The information you requested is attached.

Very truly yours,


Robert E. Uhrig
Vice President

REU/MAS/cpc

Attachment

cc: Mr. Norman C. Moseley, Region II
Robert Lowenstein, Esquire

771530106



ATTACHMENT

St. Lucie Unit 1
Docket No. 50-335
Diesel Generator Information

CONDITIONS THAT PREVENT DIESEL GENERATOR FROM RESPONDING TO EMERGENCY START SIGNAL:	WORDING ON ANNUNCIATOR WINDOW(S) IN CONTROL ROOM CORRESPONDING TO ALARMED CONDITIONS:	WORDING ON ANNUNCIATOR WINDOW AT LOCAL PANEL CORRESPONDING TO ALARMED CONDITIONS:	ANY OTHER ALARM SIGNALS THAT ALSO CAUSE THE SAME CONTROL ROOM ANNUNCIATOR TO ALARM:	REMARKS:
OVERSPEED TRIP	EMERGENCY DIESEL GEN 1A LOCKOUT EMERGENCY DIESEL GEN 1A LOCAL ALARM	- OVERSPEED TRIP	HIGH ENGINE WATER OUTLET TEMPERATURE; LOW ENGINE OIL SYSTEM PRESSURE ANY OTHER ALARM ON LOCAL PANEL	LOCKOUT SIGNALS DUE TO HIGH ENGINE WATER OUTLET TEMPERATURE OR LOW ENGINE OIL SYSTEM PRESSURE OVERRIDDEN AS A RESULT OF AN SIAS, CIS, CSAS, OR LOSS OF OFF-SITE POWER -
LOW START SYSTEM AIR PRESSURE	EMERGENCY DIESEL GEN 1A LOCAL ALARM	STARTING AIR LOW PRESSURE	ANY OTHER ALARM ON LOCAL PANEL	-
AIR START RECEIVER ISOLATED	EMERGENCY DIESEL GEN 1A LOCAL ALARM	AIR RECEIVER DISCONNECTED	ANY OTHER ALARM ON LOCAL PANEL	-
FUEL OIL DAY TANK EMPTY	EMERGENCY DIESEL GEN 1A LOCAL ALARM	FUEL DAY TANK HIGH-LOW LEVEL	ANY OTHER ALARM ON LOCAL PANEL	-

<p>LOCAL START NORMAL - ISOLATE SWITCH SELECTED TO ISOLATE POSITION</p>	<p>EMERGENCY DIESEL GEN 1A BKR CLOSE FAILURE/CS ISOLATED</p> <p>EMERGENCY DIESEL GEN 1A LOCAL ALARM</p>	<p>-</p> <p>START DC FAILURE CS ISOLATED</p>	<p>DIESEL GENERATOR DC POWER FAILURE</p> <p>ANY OTHER ALARM ON LOCAL PANEL</p>	<p>DIESEL WILL START UPON UV, WILL NOT START ON SIAS, CIS, OR CSAS UNLESS IN CONJUNCTION WITH OR FOLLOWED BY AN UV</p> <p>-</p>
<p>GENERATOR DIFFERENTIAL CURRENT TRIP</p>	<p>EMERGENCY DIESEL GEN 1A LOCAL ALARM</p>	<p>GENERATOR DIFFERENTIAL CURRENT TRIP</p>	<p>ANY OTHER ALARM ON LOCAL PANEL</p>	<p>-</p>
<p>DIESEL GENERATOR DC POWER FAILURE</p>	<p>EMERGENCY DIESEL GEN 1A BKR CLOSE FAILURE/CS ISOLATED</p> <p>EMERGENCY DIESEL GEN 1A LOCAL ALARM</p>	<p>-</p> <p>START DC FAILURE CS ISOLATED</p>	<p>LOCAL START NORMAL- ISOLATE SWITCH TO ISOLATE POSITION</p> <p>ANY OTHER ALARM ON LOCAL PANEL</p>	<p>-</p>
<p>DIESEL GENERATOR BREAKER FAILS TO CLOSE</p>	<p>EMERGENCY DIESEL GEN 1A BREAKER FAIL TO CLOSE</p>	<p>-</p>	<p>-</p>	<p>-</p>
<p>GENERATOR POTENTIAL TRANSFORMER FUSE FAILURE</p>	<p>EMERGENCY DIESEL GEN 1A LOCAL ALARM</p>	<p>GENERATOR POT TRANSFER FUSE FAILURE</p>	<p>ANY OTHER ALARM ON LOCAL PANEL</p>	<p>-</p>
<p>DIESEL FAILS TO START</p>	<p>EMERGENCY DIESEL GEN 1A ONE ENGINE NOT RUNNING</p>	<p>-</p>	<p>-</p>	<p>-</p>
<p></p>	<p></p>	<p></p>	<p></p>	<p></p>

- NOTES: (1) THE ANNUNCIATOR WORDINGS LISTED IN THE SECOND COLUMN ARE FOR THE 1A DIESEL GENERATOR; THERE ARE SIMILAR ANNUNCIATOR WINDOWS FOR THE 1B DIESEL GENERATOR.
- (2) ALL CONDITIONS THAT COULD PREVENT A DIESEL GENERATOR FROM RESPONDING TO AN AUTOMATIC START SIGNAL ARE ALARMED IN THE CONTROL ROOM.
- (3) NO PROPOSED MODIFICATIONS HAVE RESULTED FROM THIS EVALUATION.
- (4) THE FSAR CHAPTER 8 SUBSECTION ON DIESEL GENERATORS LISTS SEVEN CONDITIONS WHICH CAN CAUSE A DIESEL GENERATOR LOCKOUT. HOWEVER, ALL BUT TWO CONDITIONS ARE OVERRIDDEN IF THE DIESEL IS STARTED AS A RESULT OF AN SIAS, CIS, CSAS, OR LOSS OF OFFSITE POWER. THOSE WHICH REMAIN FUNCTIONAL ARE "ENGINE OVERSPEED" AND "GENERATOR DIFFERENTIAL," AND THESE TWO CONDITIONS ARE CONSIDERED IN THE PRECEDING TABLE.
- (5) A MEANS OF PERIODICALLY TESTING THE PROTECTIVE RELAYING COMPONENTS AND THE DIESEL GENERATOR SYSTEM AS A WHOLE ARE PROVIDED BY DESIGN. IF A DIESEL IS BEING TESTED WHEN A LOSS OF OFF-SITE POWER OCCURS OR AN ENGINEERED SAFETY FEATURES SIGNAL IS RECEIVED, THE DIESEL GENERATOR BREAKER OPENS AND AUTOMATIC BREAKER CLOSING AND LOAD SEQUENCING OCCURS.