

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

8005090268

April 29, 1980

Darrell G. Eisenhut, Acting Director  
Division of Operating Reactors  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 378  
NO/CEN:baw  
Docket Nos: 50-280  
50-281

Dear Mr. Eisenhut:

SURRY 1 AND 2 TURBINE DISC INTEGRITY

Your letter of February 25, 1980, requested information about disc integrity in operating Westinghouse nuclear turbines. In particular, your letter included a list of "Site Specific General Questions" and another of "Generic Questions."

This letter will respond to the Site Specific General Questions for Vepco's Surry Power Station, Units 1 and 2. Responses to the Generic Questions, on the other hand, have been coordinated through a task force whose representation includes all owners of Westinghouse nuclear low-pressure turbines and which is chaired by Mr. Wayne Stiede of Commonwealth Edison. The consensus responses to the Generic Questions are contained in a letter of March 14, 1980, to you from Westinghouse's J. M. Schmerling, which is provided as Attachment 5.

Accompanying this letter are the following documents:

- Attachment 1 - Westinghouse's "Application for Withholding Proprietary Information for Public Disclosure"
- Attachment 2 - Affidavit of Robert Williamson in support of Westinghouse's Application for Withholding
- Attachment 3 - Vepco's Responses to Site Specific General Questions for Surry No. 1
- Appendix A - Westinghouse Proprietary Information referenced in Attachment 3.

Twenty four (24) pages of Westinghouse supplied computer printouts.

Two (2) tables of calculated crack sizes

- Appendix B - Surry #1 nondestructive test reports

OTHERS  
RECEIVE  
LTR  
NP

A001  
5/10  
PROP ENCL TO:  
FILES  
W ROSS  
ENG BR  
BC (3)  
AT ACROSS  
LEADS

Appendix C - Nonproprietary version of Appendix A with proprietary information deleted

Attachment 4 - Vepco's Responses to Site Specific Questions for Surry No. 2

Appendix A - Westinghouse proprietary information referenced in Attachment 4

Twenty four (24) pages of Westinghouse supplied computer printouts

Two (2) tables of calculated crack sizes


Appendix B - Nonproprietary version of Appendix A with proprietary information deleted

Attachment 5 - Westinghouse Consensus Responses to Generic Questions

The site specific responses contain proprietary information of the Westinghouse Electric Corporation. In conformance with the requirements of 10 CFR 2.790 of the Commission's regulations, we are enclosing Attachment 1, an application for withholding for public disclosure, and Attachment 2, an affidavit. The affidavit sets forth the basis on which the information may be withheld from public disclosure by the Commission. Correspondence concerning the affidavit or application for withholding should reference AW-80-11 and be addressed to Mr. R. Williamson, Manager, Customer Order Engineering, Westinghouse Electric Corporation, Steam Turbine Divisions, Lester Branch, Box 9175, Philadelphia, PA 19113, with a copy to Vepco.

Please let us know if you require additional information. We shall do our best to cooperate.

Very truly yours,



J. H. Ferguson  
Executive Vice President  
Power



50-280

NRC 2/25/80 site specific general questions re  
disc integrity of Westinghouse nuclear turbines.  
(nonproprietary version)

Received wth ltr dtd 4/29/80

— NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE  
DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN  
CHARGED TO YOU FOR A LIMITED TIME PERIOD AND  
MUST BE RETURNED TO THE RECORDS FACILITY  
BRANCH 016. PLEASE DO NOT SEND DOCUMENTS  
CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY  
PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST  
BE REFERRED TO FILE PERSONNEL.

DEADLINE RETURN DATE

Docket # 50-260  
Control # 8005090268  
Date 4/29/80 of Documents  
REGULATORY DOCKET FILE

REGULATORY DOCKET FILE COPY

RECORDS FACILITY BRANCH



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

MEMORANDUM FOR: TERA Corp.  
FROM: US NRC/TIDC/Distribution Services Branch  
SUBJECT: Special Document Handling Requirements

1. Please use the following special distribution list for the attached document.

2. The attached document requires the following special considerations:

- Do not send oversize enclosure to the NRC PDR.
- Only one oversize enclosure was received - please return for Regulatory File storage.
- Proprietary information - send affidavit only to the NRC PDR *LR, NP*
- Other: (specify)

Docket # 50-280  
Control # 8005090268  
Date 4/29/80 of Document  
REGULATORY DOCKET FILE

REGULATORY DOCKET FILE COPY

cc: DSB Files

TIDC/DSB Authorized Signature

DOCKET NO. 50-280/281  
DATE: 5-13-80

NOTE TO NRC AND/OR LOCAL PUBLIC DOCUMENT ROOMS

The following item submitted with letter dated 4-29-80  
from WEPCO is being withheld from public  
disclosure in accordance with Section 2.790.

PROPRIETARY INFORMATION

INFO ON disc. Integrity of  
Westinghouse NUCLEAR TURBINES

---

---

---

Dow Lanham  
016

Distribution Service's Branch

March 14, 1980

Darrell G. Eisenhut  
Division of Operating Reactors  
Office of Nuclear Reactor Regulation  
US Nuclear Regulatory Commission  
Washington DC 20555

APPLICATION FOR WITHHOLDING PROPRIETARY  
INFORMATION FROM PUBLIC DISCLOSURE

Subject: North Anna #1 Docket #50-338  
Information in Response to NRC Request for Information of  
February 25, 1980, Relative to Low Pressure Turbine Disc  
Integrity.

Reference: Appendix A letter from C. M. Stallings to Eisenhut, dated  
3/19/80

Dear Mr. Eisenhut:

This application for withholding is submitted by Westinghouse Electric Corporation ("Westinghouse") pursuant to the provisions of paragraph (b)(1) of Section 2.790 of the Commission's regulations. Withholding from public disclosure is requested with respect to the subject information which is further identified in the affidavit accompanying this application.


The undersigned has reviewed the information sought to be withheld and is authorized to apply for its withholding on behalf of Westinghouse, STG-TCD.

The affidavit accompanying this application sets forth the basis on which the information may be withheld from public disclosure by the Commission and addresses with specificity the considerations listed in paragraph (b)(4) of Section 2.790 of the Commission's regulations.

Accordingly, it is respectfully requested that the subject information which is proprietary to Westinghouse and which is further identified in the affidavit be withheld from public disclosure in accordance with 10CFR Section 2.790 of the Commission's regulations.

Correspondence with respect to this application for withholding or the accompanying affidavit should be addressed to the undersigned.

Very truly yours,


  
R. Williamson, Manager  
Customer Order Engineering  
Westinghouse Electric Corporation

REGULATORY DOCKET FILE COPY

AFFIDAVIT

COMMONWEALTH OF PENNSYLVANIA  
COUNTY OF DELAWARE:

Before me, the undersigned authority, personally appeared Robert Williamson, who, being by me duly sworn according to law, deposes and says that he is authorized to execute this Affidavit on behalf of Westinghouse Electric Corporation ("Westinghouse") and that the averments of fact set forth in this Affidavit are true and correct to the best of his knowledge, information, and belief:

  
\_\_\_\_\_  
Robert Williamson, Manager  
Customer Order Engineering

Given to and subscribed before me  
this.....day of..... 19.....

HENRY E. SQUILLACE  
Notary Public, Marple Twp., Delaware Co.  
My Commission Expires Oct. 15, 1990



- (1) I am Manager, Customer Order Engineering in the Steam Turbine Generator Technical Operations Division of Westinghouse Electric Corporation and as such, I have been specifically delegated the function of reviewing the proprietary information sought to be withheld from public disclosure in connection with nuclear power plant licensing, and am authorized to apply for its withholding on behalf of the Westinghouse Power Generation Divisions.
  
- (2) I am making this Affidavit in conformance with the provisions of 10 CFR Section 2.790 of the Commission's regulations and in conjunction with the Westinghouse application for withholding accompanying this Affidavit.
  
- (3) I have personal knowledge of the criteria and procedures utilized by Westinghouse Power Generation Divisions in designating information as a trade secret, privileged or as confidential commercial or financial information.
  
- (4) Pursuant to the provisions of paragraph (b)(4) of Section 2.790 of the Commission's regulations, the following is furnished for consideration by the Commission in determining whether the information sought to be withheld from public disclosure should be withheld.
  - (i) The information sought to be withheld from public disclosure is owned and has been held in confidence by Westinghouse.
  
  - (ii) The information is of a type customarily held in confidence by Westinghouse and not customarily disclosed to the public. Westinghouse has a rational basis for determining the types of information customarily held in confidence by it and, in that connection, utilizes a system to determine when and whether to hold certain types of information in confidence. The application of that system and the substance of that system constitutes Westinghouse policy and provides the rational basis required.

Under that system, information is held in confidence if it falls in one or more of several types, the release of which might result in the loss of an existing or potential competitive advantage, as follows:

- (a) The information reveals the distinguishing aspects of a process (or component, structure, tool, method, etc.) where prevention of its use by any of Westinghouse's competitors without license from Westinghouse constitutes a competitive economic advantage over other companies.
- (b) It consists of supporting data, including test data, relative to a process (or component, structure, tool, method, etc.), the application of which data secures a competitive economic advantage, e.g., by optimization or improved marketability.
- (c) Its use by a competitor would reduce his expenditure of resources or improve his competitive position in the design, manufacture, shipment, installation, assurance of quality, or licensing a similar product.
- (d) It reveals cost or price information, production capacities, budget levels, or commercial strategies of Westinghouse, its customers or suppliers.
- (e) It reveals aspects of past, present, or future Westinghouse or customer funded development plans and programs of potential commercial value to Westinghouse.
- (f) It contains patentable ideas, for which patent protection may be desirable.
- (g) It is not the property of Westinghouse, but must be treated as proprietary by Westinghouse according to agreements with the owner.

- (h) Public disclosure of this information would allow unfair and untruthful judgments on the performance and reliability of Westinghouse equipment components and improper comparison with similar components made by competitors.

There are sound policy reasons behind the Westinghouse system which include the following:

- (a) The use of such information by Westinghouse gives Westinghouse a competitive advantage over its competitors. It is, therefore, withheld from disclosure to protect the Westinghouse competitive position.
- (b) It is information which is marketable in many ways. The extent to which such information is available to competitors diminishes the Westinghouse ability to sell products and services involving the use of the information.
- (c) Use by our competitor would put Westinghouse at a competitive disadvantage by reducing his expenditure of resources at our expense.
- (d) Each component of proprietary information pertinent to a particular competitive advantage is potentially as valuable as the total competitive advantage. If competitors acquire components of proprietary information, any one component may be the key to the entire puzzle, thereby depriving Westinghouse of a competitive advantage.
- (e) Unrestricted disclosure would jeopardize the position of prominence of Westinghouse in the world market, and thereby give a market advantage to the competition in those countries.

- (f) The Westinghouse capacity to invest corporate assets in research and development depends upon the success in obtaining and maintaining a competitive advantage.
- (iii) The information is being transmitted to the Commission in confidence and, under the provisions of 10 CFR Section 2.790, it is to be received in confidence by the Commission.
- (iv) The information is not available in public sources to the best of our knowledge and belief.
- (v) The proprietary information sought to be withheld in this submittal is that which is appropriately marked in Appendix A to letter from C. M. Stallings to Eisenhut, dated March 19, 1980 concerning information in response to NRC request for information of February 25, 1980, relative to low pressure turbine disc integrity.

The information enables Westinghouse to:

- (a) Develop test inputs and procedures to satisfactorily verify the design of Westinghouse supplied equipment.
- (b) Assist its customers to obtain licenses.

Further, the information has substantial commercial value as follows.

- (a) Westinghouse can sell the use of this information to customers.
- (b) Westinghouse uses the information to verify the design of equipment which is sold to customers.

(c) Westinghouse can sell services based upon the experience gained and the test equipment and methods developed.

Public disclosure of this information is likely to cause substantial harm to the competitive position of Westinghouse because it would enhance the ability of competitors to design, manufacture, verify, and sell electrical equipment for commercial turbine-generators without commensurate expenses. Also, public disclosure of the information would enable others having the same or similar equipment to use the information to meet NRC requirements for licensing documentation without purchasing the right to use the information.

The development of the equipment described in part by the information is the result of many years of development by Westinghouse and the expenditure of a considerable sum of money.

This could only be duplicated by a competitor if he were to invest similar sums of money and provided he had the appropriate talent available and could somehow obtain the requisite experience.

Further the deponent sayeth not.

Attachment 3

SURRY 1

Vepco's Responses to  
SITE SPECIFIC GENERAL QUESTIONS  
on Turbine Disc Integrity  
Surry Power Station, Unit 1

I. Provide the following information for each LP turbine:

I.A. Turbine type

The Virginia Electric and Power Company Surry No. 1 unit has one tandem compound four flow, three casing, condensing, 1800 rpm turbine using 44-inch last-row blades in each low-pressure element. The low-pressure element is designated a Building Block 81.

I.B. Number of hours of operation for each LP turbine at time of last turbine inspection or if not inspected, postulated to inspection

The number of hours of operation from beginning of operation until February 19, 1980, when the current outage began, is 38,915.

I.C. Number of turbine trips and overspeeds

There have been eighty (80) turbine trips. There

have been seven (7) overspeeds, all of them intentional for the purpose of verifying the overspeed setpoint.

I.D. For each disc:

I.D.1. Type of material including material specifications

The material is Ni-Cr-Mo-V steel similar to ASTM-A-471. The minimum yield strength specified for each disc is given in Section B<sup>1</sup> of Appendix A to this Attachment 3.

I.D.2. Tensile properties data

Tensile properties data of tests taken from the disc hub and rim material are given in Sections B and C, respectively, of Appendix A to this Attachment 3.

I.D.3. Toughness properties data including Fracture Appearance Transition Temperature and upper energy and temperature

Toughness properties for the disc hub and rim are given in Sections B and C, respectively, of Appendix A to this Attachment 3. The upper shelf energy is not presented in this Attachment 3 when it is the same as the room temperature energy.

---

<sup>1</sup>Note that the first 24 pages of Appendix A consist of Westinghouse computer print-outs, each with separate sections A through G. (For example, Section A is "Unit Identification.") It is to those sections we refer when we cite, for example, Section B of Appendix A to Attachment 3.

I.D.4. Keyway temperatures

The keyway temperatures are presented in Section G of Appendix A to this Attachment 3. The temperatures given are the calculated temperatures two inches from the exhaust face of the disc at the bore during full-load operation with all moisture separator reheaters in service.

I.D.5. Calculated keyway crack size for turbine time specified in "B" above

The calculated maximum keyway crack size is designated item G-3, in keeping with the notation suggested by Westinghouse, and is found in Appendix A to this Attachment 3. G-3 is calculated by multiplying the number of hours of operation (see I.B above) by the crack growth rate  $da/dt$ . The crack growth rate is calculated as described in the response to I.D.8 below.

I.D.6 Critical crack size

The critical crack size at 1800 rpm and at design (120%) overspeed is given in Section F of Appendix A to this Attachment 3.

I.D.7. Ratio of calculated crack to critical crack sizes

The ratio of calculated crack size to critical crack size,  $a/a_{cr}(eff)$ , is designated G-4 and given in Appendix A to this Attachment 3. This number is calculated simply by dividing item G-3 by item F-2.



I.D.8. Crack growth rate

The crack growth rate is given as G-2' in Appendix A to this Attachment 3. These crack growth rates are the maximum expected rates based on known cracks to date.

Westinghouse has changed the basis for determining these rates to use the NRC "gray book" operating hours. The NRC value for the crack growth rate is given as item G-2 on the computer print-outs (first 24 pages of Appendix A to this Attachment 3). Because Westinghouse's crack growth rates over the relevant range are consistently larger than the NRC values, however, the G-2 numbers from the print-outs have been multiplied by a factor, provided in Appendix A, to yield the more conservative G-2' figures, which are also given in Appendix A.

Westinghouse's opinion is that the crack growth rate of disc numbers 1 and 6 for Surry 1 should be assumed to be zero because these discs operate dry under normal conditions. However, to be conservative (and consistent with the calculations for the other discs), Vepco has calculated a crack size for disc numbers 1 and 6, using the same methods as for the other discs.

I.D.9. Calculated bore and keyway stress at operating speed and design overspeed

The bore tangential stresses at 1800 rpm and at design overspeed are given in Section E of Appendix A to this

Attachment 3. The values presented include the stresses due to shrink fit and centrifugal force loads only. Additional analysis to include thermal stresses and pressure stresses are being made but are not yet available.

Westinghouse has not provided the keyway stresses, because Westinghouse's analysis assumes that the keyway is part of the crack, and so the only significant stress is the bore stress.

I.D.10. Calculated  $K_{IC}$  data

The fracture toughness,  $K_{IC}$ , of each disc is calculated from the Charpy v-notch and tensile data. The values, presented in Sections B and C of Appendix A to this Attachment 3, are calculated at the upper shelf temperature or room temperature, whichever gives the lower result.

I.D.11. Minimum yield strength specified for each disc

The values for minimum yield strength are presented in Section B of Appendix A to this Attachment 3.

II. Provide details of the results of any completed inservice inspection of LP turbine rotors, including areas examined since issuance of an operating license. For each indication detected, provided details of the location of the crack, its orientation, and size.

Surry Unit 1 was put into service<sup>2</sup> in 1972, and the LP

---

<sup>2</sup>/Initial criticality July 1, 1972; first commercial operation July 7, 1972; full thermal output December 22, 1972.

turbines were recently inspected (February 27 - March 10, 1980). A Westinghouse field inspection team ultrasonically inspected the LP rotors (#1 LP 13A3291, #2 LP 13A3292) for disc cracks. The inspection method used was ultrasonic inspection of discs 1 through 6, both ends on each rotor, and an ultrasonic 360° scan on the outlet and inlet side of each disc. The inspection results for both rotors showed no indications of disc cracks. In addition, pertinent non-destructive test reports that were done in May 1978 and March 1980 are provided as Appendix B to Attachment 3.

III. Provide the nominal water chemistry conditions for each LP turbine and describe any condenser inleakages or other significant changes in secondary water chemistry to this point in its operating life. Discuss the occurrence of cracks in any given turbine as related to history of secondary water chemistry in the unit.

See the enclosed report on "Surry #1 Secondary System Chemistry."

IV. If your plant has not been inspected, describe your proposed schedule and approach to ensure that turbine cracking does not exist in your turbine.

Both LP rotors were recently inspected by a Westinghouse field inspection team, and the ultrasonic inspection report stated that there was no indication of disc cracking. Vepco's approach to ensure that unacceptable cracking does not occur in the future is based on calculations of the ratio  $a/a_{cr}(eff)$  for the worst-case disc in order to be sure that this ratio remains

less than unity. A calculation to determine the number of hours that the worst-case disc (disc no. 1, generator end, LP 2) could operate before  $a/a_{cr}(\text{eff})$  became unity, using the values of  $a_{cr}(\text{eff})$  and  $da/dt$  from Appendix A to this Attachment 3, yields a result of 19,836 hours.

- V. If your plant has been inspected and plans to return or has returned to power with cracks, provide your proposed schedule for the next turbine inspection and the basis for this inspection schedule.
- 

The plant was recently inspected and all turbine discs were found to be free of cracks.

- VI. Indicate whether an analysis and evaluation regarding turbine missiles have been performed for your plant and provided to the staff. If such an analysis and evaluation has been performed and reported, please provide appropriate references to the available documentation. In the event that such studies have not been made, consideration should be given to scheduling such an action.
- 

An analysis of the turbine missile risk for Surry 1 has been done and provided to the Staff. The analysis can be found in the Final Safety Analysis Report, Supplemental Volume 2, S14.9 dated 10-15-70.

Surry 1 Secondary System Chemistry

Secondary system chemistry data for Surry Power Station from 1973 through 1979 was reviewed.

Operating specifications, as supplied by Westinghouse Electric Corporation, are shown in Tables I through IV. Prior to January 1975, this unit was operated with a coordinated phosphate treatment for corrosion inhibition control of the secondary side. The sodium/phosphate molar ratio, as per Westinghouse's criteria, varied from 2.0 to 2.6, 2.2 to 2.6 and 2.4 to 2.6. All Volatile Treatment was thereafter initiated using ammonium hydroxide, cyclohexylamine or morpholine for pH control. This unit has experienced condenser inleakage. Condenser cooling water is brackish.

A synopsis of the chemistry review follows.

Surry Unit No. 1

1973

- Utilized coordinated phosphate treatment control.
- Table I denotes specifications.
- Main steam average pH was  $9.00 \pm 0.2$  with the maximum being 10.02. Total average conductivity was  $3.8 \pm 0.5$  mmhos.

- Condenser sodium was not routinely analyzed.
- Condenser inleakage was experienced approximately 50% of the operating time.

1974

- Utilized coordinated phosphate treatment control.
- Table I denotes specifications.
- Main Steam average pH was  $9.00 \pm 0.2$  with the maximum being 10.20. Total average conductivity was  $4.0 \pm 1.0$  mmhos.
- Condenser sodium was 0-10 ppb, 50%; 10-100 ppb, 45%; and greater than 100 ppb, 5% of the time.
- Condenser inleakage occurred approximately 75% of the operating time.

1975

- Utilized all volatile treatment control using ammonia and hydrazine.
- Tables II and III denote specifications.
- Main steam average pH was  $8.80 \pm 0.2$  with the maximum being 9.60. Total average conductivity was 5.0 mmhos.
- Condenser sodium was 0-10 ppb, 50%; 10-100 ppb, 45%; and greater than 100ppb, 5% of the time.
- Blowdown chemistry specifications were maintained approximately 25% of the time.
- Condenser inleakage occurred approximately 80% of the operating time.

1976

- Utilized all volatile treatment control using cyclohexylamine and hydrazine.
- Tables II and III denote specifications.

- Main steam average pH was  $9.5 \pm 0.2$  with the maximum being 10.20. Total average conductivity was 10.0 mmhos.
- Condenser sodium was 0-10 ppb, 50%; 10-100 ppb, 49%; and greater than 100 ppb, 1% of the time.
- Blowdown chemistry specifications were maintained approximately 25% of the time.
- Condenser inleakage occurred approximately 80% of the operating time.

1977

- Utilized all volatile treatment control using morpholine and hydrazine.
- Tables II and III denote specifications.
- Main steam average pH was  $9.1 \pm 0.2$  with the maximum being 10.10. Total average conductivity was 5.0 mmhos.
- Condenser sodium was 0-10 ppb, 65%, 10-100 ppm; 34%; and greater than 100 ppb, 1% of the time.
- Blowdown chemistry specifications were maintained approximately 30% of the time.
- Condenser inleakage occurred approximately 75% of the operating time.

1978

- Utilized all volatile treatment control using morpholine and hydrazine.
- Tables II, III and IV denote specifications.
- Main steam average pH was  $8.9 \pm 0.2$  with the maximum being 9.60. Total average conductivity was 4.0 mmhos.
- Condenser sodium was 0-10 ppb, 75%; 10-100 ppb, 24%; and greater than 100 ppb, 1% of the time.

- Blowdown chemistry specifications were maintained approximately 40% of the time.
- Condenser inleakage occurred approximately 60% of the operating time.

1979

- Utilized all volatile treatment control using morpholine and hydrazine.
- Tables II, III and IV denote specifications.

January 2, 1979 - March 15, 1979

- Main steam average pH was 9.0. Total average conductivity was 3.0 mmhos.
- Condensate sodium was 0-10 ppb, 98%; and 10-100 ppb, 2% of the time.
- Blowdown chemistry specifications were maintained 80-85% of the time.
- Condenser inleakage occurred approximately 10% of the operating time.

October 24, 1979 - December 19, 1979

- Main steam average pH was 9.0. Total average conductivity was 3.0 mmhos.
- Condensate sodium was 0-10 ppb, 85%; 10-100 ppb, 14%; and greater than 100 ppb, 1% of the time.
- Blowdown chemistry specifications were maintained approximately 75% of the time.
- Condenser inleakage occurred approximately 15% of the operating time.



1979 continued from previous page

- Unit off-line other than times listed above.

NOTE: The following condensate sodium values  
approximately equate to the indicated  
condenser inleakage rate on the average:

10ppb - 0.1 gpm  
100ppb - 1.0 gpm

COORDINATED PHOSPHATE CONTROL

TABLE I

	<u>POWER OPERATION</u>	
	<u>FEEDWATER</u>	<u>BLOWDOWN</u>
pH at 25°C	8.9 - 9.2	8.5 - 10.6
Phosphate, ppm	NA	25-80
Blowdown Rate, gpm	NA	greater than 5 (continuous)
Free Hydroxide	NA	Zero
Dissolved Oxygen, ppm	less than 0.005	less than 0.005
Hydrazine, ppm	greater than 0.01 residual	NA
Chloride, ppm	NA	less than 75
TDS, ppm	NA	less than 125
Susp. Solids, ppm	NA	less than 5.0
Iron & Copper, ppm	less than 0.01	less than 5.0
Silica, ppm	NA	less than 5.0

ALL VOLATILE TREATMENT

TABLE II

	<u>POWER OPERATION</u>
	<u>BLOWDOWN</u>
pH at 25°C	8.5 - 9.0
Free Hydroxide as ppm CaCO <sub>3</sub>	less than 0.15
Cation Cond., mmhos at 25°C	less than 2.0
Sodium, ppm	less than 0.10
Chloride, ppm	less than 0.15
Ammonia, ppm	less than 0.25
Diss. Oxygen, ppm	less than 0.005
Silica, ppm	less than 1.0
Suspended Solids, ppm	less than 1.0

TABLE III

LIMITING AVT SPECIFICATIONS FOR  
POWER OPERATIONS - BRACKISH WATER SITES

	<u>BLOWDOWN</u>		
	<u>Two Weeks</u>	<u>24 Hours</u>	<u>Immediate</u>
pH at 25°C	*8.0 - 9.2 <sup>1</sup>	NA	< 8.0 or > 9.4 <sup>1</sup>
Cation Cond., mmhos at 25°C	>*2.0 but ≤120	NA	≥ 120
Free Hydroxide, ppm as CaCO <sub>3</sub>	NA <sup>2</sup>	> 0.15 but < 1.0	≥ 1.0

---

\*Instrumented Measurement Recommended.

N/A Not Applicable.

Comment: Operation beyond the normal AVT specifications is limited as indicated above. Corrective action including shutdown, if necessary, is recommended within the time periods as applicable.

---

1/An increase of 0.4 pH units to the normal control pH limit of 9.0 will result from a Free Hydroxide concentration of 1.0 ppm as CaCO<sub>3</sub>. However, pH is not intended to be the Free Hydroxide determinant.

2/No relief for Free Hydroxide over and above the Normal Operating Control Limit is provided for periods in excess of 24 hours.

TABLE IV

Steam Generator Blowdown AVT Specification

<u>Chemistry Parameter</u>	<u>Control</u>	<u>Expected</u>
pH at 25°C	8.5 - 9.0 <sup>1</sup>	8.5 - 9.0 <sup>1</sup>
Free Hydroxide as ppm CaCO <sub>3</sub>	0.15	< 0.15
Cation Cond., mmhos/cm at 25°C	2.0	< 2.0
Chloride, ppm	NA	< 0.15 <sup>2</sup>
Sodium, ppm	NA	< 0.1
NH <sub>3</sub> , ppm	NA	< 0.25
Dissolved Oxygen, ppb	NA	< 5
SiO <sub>2</sub> , ppm	NA	< 1.0
Suspended Solids, ppm	NA	< 1.0
Blowdown Rate, gpm/Steam Generator	As required to maintain control parameters.	

Continued operation with known chloride ingress even through blowdown permits observance of the normal specification is not recommended. The cause of the contamination should be corrected. Continuous monitoring of the blowdown is essential if chloride exposure is to be minimized.

---

1/To be maintained with morpholine at sea and brackish water sites.

2/Chloride ion concentration is limited by cation conductivity. Confirmatory analysis for chloride is required.

Response to OFF Normal Conditions (Continued from Table IV)

- Sea or brackish Water Plants

As stated above, field and laboratory data reveal that even low bulk water chloride concentrations can produce denting.

Further, plant operating histories suggest the chloride effect may be cumulative.

# 895.80						LIQUID PENETRANT INSPECTION REPORT					
NDT - PT - FORM 1						VIRGINIA ELECTRIC AND POWER COMPANY					
STATION: <i>Unit #1</i>		SYSTEM: <i>L.P. Turbine</i>		PROCEDURE: <i>NDT-PT-13.1</i>		DATE: <i>May 5, 1978</i>					
ITEM, COMPONENT INSPECTED: <i>Steeple where blades were removed "A" rotor</i>						MAINTENANCE REPORT NO: <i>NA</i>					
MATERIAL: <i>alloy steel</i>			SURFACE CONDITION: <i>has beaded, emery clothed &amp; clean</i>								
MANUFACTURER: <i>NA</i>			TYPE: <i>NA</i>			BATCH NO.: <i>NA</i>			TYPE OF PENETRANT: <input checked="" type="checkbox"/> WATER SOLUBLE		
CLEANER: <i>NA</i>			TYPE: <i>NA</i>			BATCH NO.: <i>NA</i>			<input checked="" type="checkbox"/> FLUORESCENT		
PENETRANT: <i>Sherrin</i>			TYPE: <i>HM-3</i>			BATCH NO.: <i>16E316H</i>			<input type="checkbox"/> VISIBLE RED DYE		
EMULSIFIER: <i>NA</i>			TYPE: <i>NA</i>			BATCH NO.: <i>NA</i>			<input type="checkbox"/> SOLVENT REMOVABLE		
REMOVER: <i>NA</i>			TYPE: <i>water</i>			BATCH NO.: <i>NA</i>			<input type="checkbox"/> POST EMULSIFIABLE		
DEVELOPER: <i>Sherrin</i>			TYPE: <i>D-100</i>			BATCH NO.: <i>PL659</i>					
PENETRANT APPLICATION: <input type="checkbox"/> DIPPING <input checked="" type="checkbox"/> SPRAYING <input type="checkbox"/> BRUSHING				PENETRANT DWELL TIME: <i>15</i> MIN.		TEMP: <i>75</i> OF		EMULSIFIER DWELL TIME: <i>NA</i> MIN.			
REMOVAL TECHNIQUE FOR EXCESS PENETRANT: <input checked="" type="checkbox"/> FLOWING WATER <input type="checkbox"/> WIPED SOLVENT <input type="checkbox"/> WIPED WATER <input type="checkbox"/> DIP CLEANING						DRYING TIME: <i>5</i> MIN.		TEMP: <i>75</i> OF			
DEVELOPER APPLICATION: <input type="checkbox"/> DIPPING <input checked="" type="checkbox"/> SPRAYING <input type="checkbox"/> BRUSHING				DEVELOPING TIME: <i>7</i> MIN.		TEMP: <i>75</i> OF					
TEST PERFORMED BY: <i>D. Spooner</i>						LEVEL OF CERTIFICATION: <i>II</i>					
AREA INSPECTED			SIZE AND LOCATION OF INDICATIONS			27	28				
<i>Two steeples in L-3 where MT indications previously reported</i>			<i>PT confirms MT indication</i>			ACCEPT	REJECT				
DISPOSITION OF REJECTED INDICATIONS:											29
AUTHORIZED INSPECTOR: <i>David A. Spooner</i>						30	DATE: <i>May 5, 1978</i>	31			

= 885.92

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Survey #1* 1 SYSTEM: *L.P. Turbine* 2 PROCEDURE: *NDT-MT-12.1* 3 DATE: *May 4, 1978* 4

ITEM, COMPONENT INSPECTED: *"A" Rotor (2nd Time)* 5 MAINTENANCE REPORT NO: *NA* 6

MATERIAL: *Alloy Steel* 7 SURFACE CONDITION: *Sand blasted* 8

TYPE OF PARTICLES: 9 BATCH NO: 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: *Magnaflux* 11 TYPE: *20A* 12

MAGNETIZATION: 13 CURRENT: 14  
 COIL *2000* AMPERE TURNS  
 PROD. \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_  
 AC  
 DC  
 HWDC

TEST PERFORMED BY: *O. Spooner, D. Fowler, T. Boyers, A. Hamel, D. Dickens* 15 LEVEL OF CERTIFICATION: *II, I, A, I, I* 16

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	18	19	20
			ACCEPT	REJECT
<i>Row L-3 Gov. End</i>	<i>Blades 47, 168, 173 Crack in root entry side</i>			<input checked="" type="checkbox"/>
<i>Row L-4 Gov. End</i>	<i>Blade 155 Crack in root entry side</i>			<input checked="" type="checkbox"/>
<i>[Large scribble]</i>	<i>[Large scribble]</i>			

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: *David L. Spooner* 22 DATE: *May 4, 1978* 23







3

# 885.82

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Survey #1* SYSTEM: *L.P. Turbine* PROCEDURE: *NDT - MT - 12.1* DATE: *May 2, 1978*

ITEM, COMPONENT INSPECTED: *"A" L.P. Rotor* MAINTENANCE REPORT NO: *NA*

MATERIAL: *Alloy Steel* SURFACE CONDITION: *Sandblasted & clean*

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT BATCH NO:

MANUFACTURER: *Magnaflux* TYPE: *20A*

MAGNETIZATION:  COIL *2000* AMPERE TURNS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  CIRCULAR \_\_\_\_\_ AMPERES  YOKE \_\_\_\_\_  
 CONTINUOUS  RESIDUAL  AC  DC  RWDC

TEST PERFORMED BY: *Hamel, Dickens, Gibson, Fowler, Hall, Spooner* LEVEL OF CERTIFICATION: *I, I, A, I, A, II*

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Blading Round GEN. End L-0</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>L-1</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>L-2</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>Turbome End L-0</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>L-1</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>L-2</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: *S S*

NOTED MAY 02 1978 D.S.T.

AUTHORIZED INSPECTOR: *David L. Spooner* DATE: *May 2, 1978*

(2)

# 885.82

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>Swing #1</i>	SYSTEM: <i>L.P. Turbine</i>	PROCEDURE: <i>NDT - MT - 12.1</i>	DATE: <i>May 2, 1978</i>
ITEM, COMPONENT INSPECTED: <i>"A" L.P. Rotor</i>			MAINTENANCE REPORT NO: <i>NA</i>
MATERIAL: <i>Alloy Steel</i>	SURFACE CONDITION: <i>Sandblasted &amp; clean</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: <i></i>
MANUFACTURER: <i>Magnaflux</i>		TYPE: <i>20A</i>	
MAGNETIZATION: <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <i>1600</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> YOKE _____			

TEST PERFORMED BY: <i>Hamel, Dickens, Gibson, Fowler, Hall, Spooner</i>	LEVEL OF CERTIFICATION: <i>I, I, A, I, A, II</i>
---	--

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Blading Rows</i>	<i>Gen. End</i>		
	<i>L-3</i>		<input checked="" type="checkbox"/>
	<i>L-4</i>		<input checked="" type="checkbox"/>
	<i>L-5</i>	<input checked="" type="checkbox"/>	
	<i>L-6</i>	<input checked="" type="checkbox"/>	
	<i>Turbine End</i>		
	<i>L-3</i>	<input checked="" type="checkbox"/>	
	<i>L-4</i>	<input checked="" type="checkbox"/>	
	<i>L-5</i>	<input checked="" type="checkbox"/>	
	<i>L-6</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 21

*Row L-3 To be investigated further and possibly replaced*

*Row L-4 To be replaced*

NOTED MAY 02 1978 D.S.T.

AUTHORIZED INSPECTOR: <i>David Spooner</i>	DATE: <i>May 2, 1978</i>
--	--------------------------

VISUAL INSPECTION REPORT  
 NDT - VT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>Surry #</i>	SYSTEM: <i>L.P. Turbine</i>	PROCEDURE: <i>NDT-VT-15.1</i>	DATE: <i>May 2, 1978</i>
ITEM, COMPONENT INSPECTED: <i>"A" Rotor</i>			MAINTENANCE REPORT NO: <i>NA</i>
VISUAL AIDS: <i>Flash light &amp; mirror</i>			
PERFORMED BY: <i>D.L. Spooner</i>			LEVEL OF CERTIFICATION: <i>II</i>
INDICATIONS NOTED: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			

INDICATIONS

AREA INSPECTED	DESCRIPTION OF INDICATIONS (SIZE, TYPE, AND LOCATION)	ACCEPT	REJECT
Where blade # 193 <i>Gen. End</i> Broke off Row L-3	No indication of damage to Steeples	*	*
Where blade # 1 & 42 <i>Gen. End</i> Broke off Row L-4	No indications of damage to Steeples	*	*
Where blade # 107, <i>Gen. End</i> 144 & 145 broke off Row L-4	Pieces missing from Steeples between blade # 107 & 108 and between # 144 & 145		
	Crack in top of steeples between blades # 145 & 146	*	*

DISPOSITION OF REJECTED INDICATIONS.

\* Accept - Reject deferred until blade roots are removed and (W) evaluation & recommendation are available.

AUTHORIZED INSPECTOR: <i>David L. Spooner</i>	DATE: <i>May 2, 1978</i>
---	--------------------------

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Sunny #1* 1 SYSTEM: *L.P. Turbine* 2 PROCEDURE: *NDT-MT-12.1* 3 DATE: *May 5, 1978* 4

ITEM, COMPONENT INSPECTED: *Steeple where blades were removed "A" Rotor* 5 MAINTENANCE REPORT NO: *NA* 6

MATERIAL: *Alloy steel* 7 SURFACE CONDITION: *glass beaded & clean* 8

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT 9 BATCH NO: 10

MANUFACTURER: *Magnaflux* 11 TYPE: *20A* 12

MAGNETIZATION:  COIL *800* AMPERE TURNS 13 CURRENT:  AC  DC  RWOC  
 CONTINUOUS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  
 YOKE \_\_\_\_\_

TEST PERFORMED BY: *D. Fowler & T. Boyers* 15 LEVEL OF CERTIFICATION: *I, A* 16

AREA INSPECTED 17	SIZE AND LOCATION OF INDICATIONS 18	ACCEPT 19	REJECT 20
<i>Steeple L-3</i>	<i>Two steeples cracked bottom platform. One entirely interior the other coming out on the exit side approx. 1/16" The steeples are not numbered but are well marked. These two indications are the same as previously reported.</i>		<input checked="" type="checkbox"/>
<i>Steeple L-4</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: *David L. Groover* 22 DATE: *May 5, 1978* 23

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <i>Survey #1</i>	SYSTEM: 2 <i>L.P. Turbine</i>	PROCEDURE: 3 <i>NDT - MT - AS per (W)</i>	DATE: 4 <i>May 5, 1978</i>
ITEM, COMPONENT INSPECTED: 5 <i>Steeple where blades were removed "A" Rotor</i>		MAINTENANCE REPORT NO: 6 <i>NA</i>	
MATERIAL: 7 <i>alloy steel</i>	SURFACE CONDITION: 8 <i>glass Bead Blasted &amp; Clean</i>		
TYPE OF PARTICLES 9 <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT		BATCH NO: 10	
MANUFACTURER: 11 <i>Magnaflex</i>		TYPE: 12 <i>20 A</i>	
MAGNETIZATION: 13 <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: 14 <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	
<input type="checkbox"/> COIL _____ AMPERE TURNS <input type="checkbox"/> PROD. _____ SPACING _____ AMPS <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> YOKE _____		<input checked="" type="checkbox"/> SPECIAL See Dwg on Back	

TEST PERFORMED BY: 15 <i>D. Spooner, T. Boyers, D. Fowler, S. Zimmerman</i>	LEVEL OF CERTIFICATION: 16 <i>II, A, I, A</i>
--	--

17	18	19	20
AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Steeple L-3</i>	<i>Two steeples cracked bottom section. One entirely interior the other coming out on the exit side approx. 1/16" The blades are not #12 The steeples are not numbered but are well marked</i>		<input checked="" type="checkbox"/>
<i>steeples L-4</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22 <i>David L. Spooner</i>	DATE: 23 <i>May 5, 1978</i>
---	--------------------------------

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Survey #1* 1 SYSTEM: *L.P. Turbine* 2 PROCEDURE: *NDT-MT-12.1* 3 DATE: *May 5, 1978*

ITEM, COMPONENT INSPECTED: *"A" Rotor blade roots removed from rotor* 5 MAINTENANCE REPORT NO: *NA*

MATERIAL: *Alloy Steel* 7 SURFACE CONDITION: *Sand blasted & clean*

TYPE OF PARTICLES: 9 BATCH NO: 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: *Magnaflux* 11 TYPE: *20A* 12

MAGNETIZATION: 13 CURRENT: 14  
 COIL *800* AMPERE TURNS  
 PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_  
 AC  
 DC  
 HWOC

TEST PERFORMED BY: *D. Dickens & A. Hamel* 15 LEVEL OF CERTIFICATION: *I, I* 16

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Row 1-3</i>	<i>NR I</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>Row 1-4</i>	<i>Blades 40 and 147 Crack in root</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: *David L. [Signature]* 22 DATE: *May 5, 1978* 23



885.80

LIQUID PENETRANT INSPECTION REPORT  
NDT - PT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 *Sherwin* SYSTEM: 2 *Turbine* PROCEDURE: 3 *NOT-PT-13.1* DATE: 4 *May 6 1978*

ITEM, COMPONENT INSPECTED: 5 *# A ROTOR* MAINTENANCE REPORT NO: 6 *SI-804200909*

MATERIAL: 7 *ALLOY STEEL* SURFACE CONDITION: 8 *SAND BLASTED AS WELDED*

MANUFACTURER 9		TYPE 10	BATCH NO. 11	TYPE OF PENETRANT: 12
CLEANER	<i>WATER</i>	-	-	<input checked="" type="checkbox"/> WATER SOLUBLE
PENETRANT	<i>SHERWIN</i>	<i>HM-3</i>	<i>16E3164</i>	<input checked="" type="checkbox"/> FLUORESCENT
EMULSIFIER	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<input type="checkbox"/> VISIBLE RED DYE
REMOVER	<i>WATER</i>	-	-	<input type="checkbox"/> SOLVENT REMOVABLE
DEVELOPER	<i>SHERWIN</i>	<i>D 100</i>	<i>P.659</i>	<input type="checkbox"/> POST EMULSIFIABLE

PENETRANT APPLICATION: 13  DIPPING  SPRAYING  BRUSHING PENETRANT DWELL TIME: 14 *20* MIN. TEMP: 15 *70* OF EMULSIFIER DWELL TIME: 16 *N/A* MIN.

REMOVAL TECHNIQUE FOR EXCESS PENETRANT: 17  FLOWING WATER  WIPED SOLVENT  WIPED WATER  DIP CLEANING DRYING TIME: 18 *7* MIN. TEMP: 19 *70* OF

DEVELOPER APPLICATION: 20  DIPPING  SPRAYING  BRUSHING DEVELOPING TIME: 21 *10* MIN. TEMP: 22 *70* OF

TEST PERFORMED BY: 23 *FOWLER ZIMMERMAN, BOVERS FRIEL* LEVEL OF CERTIFICATION: 24 *I-A-A-II*

AREA INSPECTED 25	SIZE AND LOCATION OF INDICATIONS 26	ACCEPT 27	REJECT 28
<i>L-1 Row UNDER</i>	<i>LINEARS IN WELDS 76, 77</i>		<i>X</i>
<i>SHROUD WELDS</i>	<i>83, 153, 157, 160, 155, 167</i>		<i>X</i>
<i>L-4 Row UNDER</i>	<i>WELD ON #4 1/2" LINEARS</i>		<i>X</i>
<i>SHROUD WELD</i>			
<i>L-3</i>	<i>NO REPORTABLE INDICATIONS</i>	<i>✓</i>	
<i>L-1 GEN END</i>	<i>NO REPORTABLE INDICATIONS</i>	<i>✓</i>	

DISPOSITION OF REJECTED INDICATIONS: 29

AUTHORIZED INSPECTOR: 30 *RR Friel* DATE: 31 *MAY 7 1978*

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>Sunny #1</i>	SYSTEM: <i>L.P. Turbine</i>	PROCEDURE: <i>NDT-MT-12.1</i>	DATE: <i>May 8, 1978</i>
ITEM, COMPONENT INSPECTED: <i>Steeple L-4 Row Gen. End "A" Rotor</i>		MAINTENANCE REPORT NO: <i>NA</i>	
MATERIAL: <i>alloy steel</i>	SURFACE CONDITION: <i>gloss bead blasted &amp; clean</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT		BATCH NO:	
MANUFACTURER: <i>Magnaflux</i>		TYPE: <i>20A</i>	
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <i>1500</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> RESIDUAL <input type="checkbox"/> YOKE _____		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> RWDC	

TEST PERFORMED BY: <i>D. Spooner, S. Zimmerman</i>	LEVEL OF CERTIFICATION: <i>II, A</i>
--	--------------------------------------

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Steeple 107-108</i>	<i>Cracked Top Land convex side approx. 1 1/4" long</i>		<input checked="" type="checkbox"/>
<i>Steeple 144-145</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	
<i>Steeple 145-146</i>	<i>Cracked across face exit side and down concave and convex sides approx. 5/8" at top land</i>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21  
*Note these Steeples were previously reported as damaged on Visual report. Steeple 144-145 is damaged as reported in that report, no MT indications*

AUTHORIZED INSPECTOR: <i>David L. Spooner</i>	DATE: <i>May 8, 1978</i>
---	--------------------------

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Sung #1* 1 SYSTEM: *L.P. Turbine* 2 PROCEDURE: *NDT - MT - 12.1* 3 DATE: *May 10, 1978* 4

ITEM, COMPONENT INSPECTED: *Steeple where blades were removed "A" Rotor* 5 MAINTENANCE REPORT NO: *NA* 6

MATERIAL: *Alloy Steel* 7 SURFACE CONDITION: *glass bead Blasted & clean* 8

TYPE OF PARTICLES: 9 BATCH NO: 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: *magnaflex* 11 TYPE: *20A* 12

MAGNETIZATION:  COIL *1200* AMPERE TURNS 13 CURRENT: 14  
 CONTINUOUS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  AC  
 RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  DC  
 YOKE \_\_\_\_\_  HWOC

TEST PERFORMED BY: *D. Spooner* 15 LEVEL OF CERTIFICATION: *II* 16

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Row L-3 Gen. End</i>	<i>In investigating the two cracked Steeples previously reported two more were seen adjacent to Blade 13 and 15 in - 2 Row. The entire area where blades had not been put back in was checked and no additional cracks were found. Advising removal of Blades to re-check rest of steeples</i>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: *David L. Spooner* 22 DATE: *May 10, 1978* 23



MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <u>Surry #1</u>	SYSTEM: <u>L.P. Turbine</u>	PROCEDURE: <u>NDT - MT - 12.1</u>	DATE: <u>May 11, 1978</u>
ITEM, COMPONENT INSPECTED: <u>Steeles where blades were removed "A" rotor</u>		MAINTENANCE REPORT NO: <u>NA</u>	
MATERIAL: <u>alloy steel</u>	SURFACE CONDITION: <u>Glass bead blasted &amp; clean</u>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: _____
MANUFACTURER: <u>magna flux</u>		TYPE: <u>20A</u>	
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <u>2000</u> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> RWDC	

TEST PERFORMED BY: <u>D. Spooner, D. Fowler, D. Dickens, A. Hamel, T. Gibson</u>	LEVEL OF CERTIFICATION: <u>II, I, I, I, A</u>
--	---

17	18	19	20
AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
Row L-4 Gov. End	NRI	✓	
Row L-4 Gen. End	This is the 2nd MT of this row no further indication than those previously reported		✓
Row L-3 Gen. End	The following <sup>PLATFORMS</sup> steeps are cracked, The blade No's are the corresponding blade in Row L-2 4, 10, 12, 14, 19 154, 155 - This is the second M.T. of this row.		✓

DISPOSITION OF REJECTED INDICATIONS: \_\_\_\_\_

AUTHORIZED INSPECTOR: <u>David L. Spooner</u>	DATE: <u>May 11, 1978</u>
---	---------------------------



STEEPLE DISTRESS SUMMARY

ROW  
S.O.


SHO END  
UNIT

STEEPLE

DATE


Draw in indication (and/or) what we have explored, metal removed. We need the length, width, depth.

across from blade #11 L-2 row



Outlet


OUTLET SIDE




Inlet

~~CONVEX SIDE~~

Ground area on top of bottom serration approx. 1/8" deep



CONVEX SIDE



INLET SIDE

# 885.82

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: Unit #1 SYSTEM: L.P. Turbine PROCEDURE: NOT-MT-12.4 DATE: May 16, 1978

ITEM, COMPONENT INSPECTED: Steeple where blades were removed "A" Rotor MAINTENANCE REPORT NO: NA

MATERIAL: alloy steel SURFACE CONDITION: glass bead blasted & clean

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT BATCH NO:

MANUFACTURER: magnaflex TYPE: 20A

MAGNETIZATION:  CONTINUOUS  RESIDUAL  COIL \_\_\_\_\_ AMPERE TURNS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  CIRCULAR \_\_\_\_\_ AMPERES  YOKE Roller Poles CURRENT:  AC  DC  RWOC

TEST PERFORMED BY: D. Fowler's D. Spooner LEVEL OF CERTIFICATION: I & II

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	18	19 ACCEPT	20 REJECT
<u>L-3 Gov. End</u>	<u>Steeple 48-49, 49-50, 170-171</u>			<input checked="" type="checkbox"/>
	<u>have crack indications</u>			
	<u>on the concave side Steeple</u>			
	<u>169-170, 171-172, 172-173, 173-174</u>			
	<u>have pitting lined up that</u>			
	<u>could be masking a crack</u>			
	<u>Steeple 48-49 also has some</u>			
	<u>smearred metal from blade</u>			
	<u>removal</u>			

DISPOSITION OF REJECTED INDICATIONS: \_\_\_\_\_

AUTHORIZED INSPECTOR: David L. Spooner DATE: May 16, 1978



# 885.82

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <b>SURRY</b>	SYSTEM: 2 <b>TURBINE</b>	PROCEDURE: 3 <b>NDT - MT - 12.1</b>	DATE: 4 <b>19 MAY 1978</b>
ITEM, COMPONENT INSPECTED: 5 <b>UNIT #1 "A" ROTOR Governor End L-3 stage steeple</b>		MAINTENANCE REPORT NO: 6 <b>51804200909</b>	
MATERIAL: 7 <b>Metal Alloy</b>	SURFACE CONDITION: 8 <b>Clean / Glass bead blasted</b>		
TYPE OF PARTICLES: 9 <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT		BATCH NO: 10 <b>N/A</b>	
MANUFACTURER: 11 <b>MAGNAFLUX</b>		TYPE: 12 <b>20-A</b>	
MAGNETIZATION: 13 <input checked="" type="checkbox"/> COIL <b>2000</b> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: 14 <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	

TEST PERFORMED BY: 15 <b>Armand P. Hamel / Lloyd T. Gibson / Thomas Powers</b>	LEVEL OF CERTIFICATION: 16 <b>I / A / A</b>
---	--

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<b>Steeple # 165</b>	<b>INDICATION IN CONVEX AREA BACK LEND <math>5/16</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 173</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>1/2</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 181</b>	<b><math>1/8</math>" INDICATION ON FACE OF STEEPLE INLET SIDE FAINT (2)</b>		<input checked="" type="checkbox"/>
<b>Steeple # 140</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>1</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 209</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>5/16</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 116</b>	<b>FAINT INDICATION IN CONCAVE AREA NEAR RADIUS</b>		<input checked="" type="checkbox"/>
<b>Steeple # 105</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>3/4</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 102</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>1 1/2</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 101</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>1/2</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 100</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>2</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 99</b>	<b>INDICATION IN CONCAVE AREA <del>AREA</del> NEAR RADIUS <math>3/4</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 91</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>1/2</math>"</b>		<input checked="" type="checkbox"/>
<b>Steeple # 90</b>	<b>INDICATION IN CONCAVE AREA NEAR RADIUS <math>1 1/2</math>"</b>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

*(Large handwritten X mark)*

AUTHORIZED INSPECTOR: 22 <b>David L. Zwooner MT level II</b>	DATE: 23 <b>May 19, 1978</b>
---	---------------------------------

PAGE 1 OF 2

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1 (SUPPLEMENT)  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: **Surry** SYSTEM: **Turbine** PROCEDURE: **NDT - MT - 12.1** DATE: **19 MAY 1978**

ITEM, COMPONENT INSPECTED: **UNIT #1A Rotor Clearance End L-3 stage steeples** MAINTENANCE REPORT NO: **51804 200 909**

7 AREA INSPECTED	8 SIZE AND LOCATION OF INDICATIONS	9 ACCEPT	10 REJECT
Steeple # 87	INDICATION IN CONCAVE AREA NEAR RADIUS 2"		X
Steeple # 79	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 2"		X
Steeple # 77	INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 69	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 68	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 67	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/4"		X
Steeple # 64	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1"		X
Steeple # 61	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 49	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1"		X
Steeple # 48	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 47	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 44	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 43	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1"		X
Steeple # 42	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 35	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X
Steeple # 18	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/4"		X
Steeple # 230	FAINT INDICATION IN CONCAVE AREA NEAR RADIUS 1 1/2"		X

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: **David L. Spooner, MT Level II** DATE: **May 19, 1978**



VISUAL INSPECTION REPORT  
 NDT - VT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

1 SYSTEM: *L.P. Turbine* 2 PROCEDURE: *NDT - VT - 15.1* 3 DATE: *May 3, 1978* 4  
 ITEM, COMPONENT INSPECTED: *B Rotor* 5 MAINTENANCE REPORT NO: *NA* 6  
 VISUAL AIDS: *Flashlight & mirror* 7  
 PERFORMED BY: *D. Spooner, D. Fowler, A. Hamel, D. Ocken* 8 LEVEL OF CERTIFICATION: *II, II, II, II* 9  
 INDICATIONS NOTED:  YES  NO 10

INDICATIONS

11 AREA INSPECTED	12 DESCRIPTION OF INDICATIONS (SIZE, TYPE, AND LOCATION)	13 ACCEPT	14 REJECT
<i>Row L-3 Gov. End</i>	<i>Blades #145, 62, 63, 39 &amp; 74 &amp; 143 have</i>		
	<i>cracks in undershroud weld</i>		<input checked="" type="checkbox"/>
	<i>Staples between Blades 168-169, 15-16,</i>	<input checked="" type="checkbox"/>	
	<i>57-58, &amp; 58-59 have visual indication</i>		
	<i>of cracks. Unable to get any indication</i>		
	<i>with mag particle indications</i>		
	<i>judged to be erosion &amp; pitting</i>		

DISPOSITION OF REJECTED INDICATIONS.

15

AUTHORIZED INSPECTOR: *David L. Spooner* 16 DATE: *May 3, 1978* 17

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

1 LOCATION: *Survey #1* 2 SYSTEM: *L.P. Fueline* 3 PROCEDURE: *NDT-MT-12.1* 4 DATE: *May 3, 1978*

5 ITEM, COMPONENT INSPECTED: *B" Rotor* 6 MAINTENANCE REPORT NO: *NA*

7 MATERIAL: *alloy steel* 8 SURFACE CONDITION: *sandblasted & clean*

9 TYPE OF PARTICLES: *WET*  DRY  VISIBLE  FLUORESCENT 10 BATCH NO:

11 MANUFACTURER: *Magnaflex* 12 TYPE: *20A*

13 MAGNETIZATION:  COIL *2000* AMPERE TURNS 14 CURRENT:  AC  DC  RWDC  
 CONTINUOUS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  YOKE \_\_\_\_\_

15 TEST PERFORMED BY: *D. Spooner, D. Fowler, D. Dickens, A. Hamel* 16 LEVEL OF CERTIFICATION: *II, I, I, I*

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Blading Row L-3 Gov. End</i>	<i>Blade 180 crack in root exit side. Blade 35, 71 &amp; 142 cracks in root entry side</i>		<input checked="" type="checkbox"/>
	<i>Rotor Disc. below blades 67-68 had an indication appearing to be magnetic writing. However De-mag and emery cloth would not remove indication. Should be investigated further when blades are removed.</i>		

21 DISPOSITION OF REJECTED INDICATIONS:  
*INDICATION ID ROTOR DISC WAS GROUND OUT LIGHTLY - RE-INSPECTED M.T. AND V.T. INDICATION WAS REMOVED.*  
*J.P. Mangan*  
*5-4-78*

22 AUTHORIZED INSPECTOR: *David L. Groome* 23 DATE: *May 3, 1978*







SURRY POWER STATION

ROTOR NO. 2

ROW NO. 1-4

DATE: 3-18-5

GEN. ENG








UNIT NO. 1  
SURRY POWER STATION

ROTOR NO. 2  
ROW NO. L-4  
STEEPLE NO. 104  
DRAWING NO. 1  
DATE 3-16-80



L-4 GENERATOR END

# 885.82

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 *SURRY 1* SYSTEM: 2 *LP TURBINE* PROCEDURE: 3 *NDT-MT-12.1* DATE: 4 *3-15-80*

ITEM, COMPONENT INSPECTED: 5 *LP #2 ROTOR L-4 GOVERNOR END* MAINTENANCE REPORT NO: 6 *51002210414*

MATERIAL: 7 *ALLOY CARBON STEEL* SURFACE CONDITION: 8 *GLASS BEAD BLAST CLEAN*

TYPE OF PARTICLES: 9  WET  DRY  VISIBLE  FLUORESCENT BATCH NO: 10 *56002*

MANUFACTURER: 11 *MAGNAFLUX* TYPE: 12 *20A*

MAGNETIZATION: 13  COIL *2400-3600* AMPERE TURNS CURRENT: 14  AC  DC  RWDC  
 CONTINUOUS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  YOKE \_\_\_\_\_

TEST PERFORMED BY: 15 *T. GIBSON / J. DALTON / W. FONG* LEVEL OF CERTIFICATION: 16 *A/A/II*

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>STEEPLE # 194</i>	<i>INLET ROTOR STEEPLE FACE HAS 3/8"</i>		
	<i>LINEAR INDICATION SEE DRAWING # 1</i>		<input checked="" type="checkbox"/>
<i>DISC AREA</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 21  
*\* DEFERRED TO @ Jg*

AUTHORIZED INSPECTOR: 22 *William Fong II* DATE: 23 *3-15-80*

UNIT No. 1

SURRY POWER STATION


ROTOR NO. 2

ROW No. L-4

STEEPLE No. 194

DRAWING No. 1

DATE 3-15-80



ID # : D081102501

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81

2. UNIT SURRY #1

3. CUSTOMER: VEPCO

4. LPH

5. LOCATION Gov

6. DISC# 1

7. TEST NO. TD29568

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. (KSI)) b, c, e TD

2. SUPPLIER: MIDVALE HEPPENSTALL b, c, e

3. Y.S. (KSI)

4. U.T.S. (KSI)

5. ELONGATION

6. R.A.

7. FATT (DEG.F)

8. R.T. IMPACT (FT.LB.)

9. U.S. IMPACT TEMP. (DEG.F)

10. U.S. IMPACT ENG. (FT.LB.)

11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)

2. U.T.S. (KSI)

3. ELONGATION

4. R.A.

5. FATT (DEG.F)

6. R.T. IMPACT (FT.LB.)

7. U.S. IMPACT TEMP. (DEG.F)

8. U.S. IMPACT ENG. (FT.LB.)

9. U.S. KIC (KSI\*SQRT(IN.))

b, c, e

D. CHEMISTRY

[C] b, c, e [MN] b, c, e [SI] b, c, e [P] b, c, e [CR] b, c, e [MO] b, c, e [V] b, c, e

[NI] b, c, e [AS] b, c, e [SB] b, c, e [SN] b, c, e [AL] b, c, e [CU] b, c, e S<sub>010</sub> b, c, e

E. BORE STRESS

SPEED (RPM) STRESS

1. 1800 [ ] b, c, e

2. 2160 (120%) [ ] b, c, e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b, c, e

2. A-CR-OS (OVERSPEED) (IN.) [ ] b, c, e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b, c, e

2. ESTIMATED MAX DA/DT (IN/HR)  $G-2' = [ ] b, c, e$

3. Max. expected Keyway Crack size (in) [ ] b, c, e

4. Ratio A/A - CR - OS [ ]

Appendix C  
to Attachment 3

ID # : D081102501

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP# 1  
5. LOCATION GOV  
6. DISC# 2  
7. TEST NO. TD35160

B. MATERIAL PROPERTIES (HUB)

1. TYPE b, c, e, TD  
(MIN. Y.S. (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b, c, e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[C] b, c, e [MN] b, c, e [SI] b, c, e [P] b, c, e [CR] b, c, e [MO] b, c, e [V] b, c, e  
[Ni] b, c, e [AS] b, c, e [Sb] b, c, e [SN] b, c, e [AL] b, c, e [CU] b, c, e [S] b, c, e

E. CORE STRESS

SPEED (RPM) STRESS  
1. 1800 [KSI] b, c, e  
2. 2160 (120%) [KSI]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) b, c, e  
2. A-CR-OS (OVERSPEED) (IN.)

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) b, c, e  
2. ESTIMATED MAX DA/DT (IN/HR) G-2'11= [ ] b, c, e  
3. Max. expected Keyway Crack size (in) - [ ] b, c, e  
4. Ratio A/A - CR - OS [ ]

ID # : D081102501

LP TURBINE DISC INFORMATION

<b>A. UNIT IDENTIFICATION</b>		<b>B. MATERIAL PROPERTIES (HUB)</b>		<b>C. MATERIAL PROPERTIES (RIM)</b>	
1. BUILDING BLOCK	81	1. TYPE	[ ] b,c,e VT		
		(MIN. Y.S. (KSI))	[ ] b,c,e		
2. UNIT	SURRY #1	2. SUPPLIER:	MIDVALE HEPPESTALI		
3. CUSTOMER:	VEPCO	3. Y.S. (KSI)	[ ] b,c,e	1. Y.S. (KSI)	[ ] b,c,e
4. LPH		4. U.T.S. (KSI)	[ ]	2. U.T.S. (KSI)	[ ]
5. LOCATION	1 GOV	5. ELONGATION	[ ]	3. ELONGATION	[ ]
6. DISC#	3	6. R.A.	[ ]	4. R.A.	[ ]
7. TEST NO.	TD35164	7. FATT (DEG.F)	[ ]	5. FATT (DEG.F)	[ ]
		8. R.T. IMPACT (FT.LB.)	[ ]	6. R.T. IMPACT (FT.LB.)	[ ]
		9. U.S. IMPACT TEMP. (DEG.F)	[ ]	7. U.S. IMPACT TEMP. (DEG.F)	[ ]
		10. U.S. IMPACT ENG. (FT.LB.)	[ ]	8. U.S. IMPACT ENG. (FT.LB.)	[ ]
		11. U.S. KIC (KSI*SQRT(IN.))	[ ]	9. U.S. KIC (KSI*SQRT(IN.))	[ ]

**D. CHEMISTRY**

[ C ]	b,c,e	[ MN ]	b,c,e	[ SI ]	b,c,e	[ P ]	b,c,e	[ CR ]	b,c,e	[ MO ]	b,c,e	[ V ]	b,c,e
[ NI ]	b,c,e	[ AS ]	b,c,e	[ SB ]	b,c,e	[ SN ]	b,c,e	[ AL ]	b,c,e	[ CU ]	b,c,e	[ S ]	b,c,e

<b>E. BORE STRESS</b>		<b>F. CRACK DATA</b>	
SPEED (RPM)	STRESS		
1. 1800	{ KSI }	[ ]	b,c,e
2. 2160 (120%)	{ KSI }	[ ]	b,c,e
		1. A-CR-OP (1800 RPM) (IN.)	[ ]
		2. A-CR-OS (OVERSPEED) (IN.)	[ ]

**G. SERVICE DATA**

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ]	b,c,e		
2. ESTIMATED MAX DA/DT (IN/HR)	[ ]		G-2' =	[ ] b,c,e
3. Max. expected Keyway Crack size (in) -	[ ]		b,c,e	
4. Ratio A/A - CR - OS	[ ]			

ID # : 0081102501

LP TURBINE DISC INFORMATION

<b>A. UNIT IDENTIFICATION</b>		<b>B. MATERIAL PROPERTIES (HUB)</b>		<b>C. MATERIAL PROPERTIES (RIH)</b>	
1. BUILDING BLOCK	81	1. TYPE	[ ] b,c,e TD	1. Y.S. (KSI)	[ ] b,c,e
2. UNIT	SURRY #1	2. SUPPLIER	[ ] (MIN. Y.S. [ ] (KSI))	2. U.T.S. (KSI)	[ ]
3. CUSTOMER:	VEPCO	3. Y.S. (KSI)	MIDVALE HEPPENSTALL	3. ELONGATION	[ ]
4. LPH		4. U.T.S. (KSI)		4. R.A.	[ ]
5. LOCATION	1 GOV	5. ELONGATION		5. FATT (DEG.F)	[ ]
6. DISC#	4	6. R.A.		6. R.T. IMPACT (FT.LB.)	[ ]
7. TEST NO.	TD23458	7. FATT (DEG.F)		7. U.S. IMPACT TEMP. (DEG.F)	[ ]
		8. R.T. IMPACT (FT.LB.)		8. U.S. IMPACT ENG. (FT.LB.)	[ ]
		9. U.S. IMPACT TEMP. (DEG.F)		9. U.S. KIC (KSI*SQRT(IN.))	[ ]
		10. U.S. IMPACT ENG. (FT.LB.)			
		11. U.S. KIC (KSI*SQRT(IN.))			

**D. CHEMISTRY**

[ ] C	[ ] b,c,e	[ ] MN	[ ] b,c,e	[ ] SI	[ ] b,c,e	[ ] P	[ ] b,c,e	[ ] CR	[ ] b,c,e	[ ] MO	[ ] b,c,e	[ ] V	[ ] b,c,e
[ ] NI	[ ] b,c,e	[ ] AS	[ ] b,c,e	[ ] SA	[ ] b,c,e	[ ] SN	[ ] b,c,e	[ ] AL	[ ] b,c,e	[ ] CU	[ ] b,c,e	[ ] S	[ ] b,c,e

<b>E. BORE STRESS</b>		<b>F. CRACK DATA</b>	
SPEED (RPM)	STRESS		
1. 1800	[ ] (KSI)	1. A-CR-OP (1800 RPM) (IN.)	[ ] b,c,e
2. 2160 (120%)	[ ] (KSI)	2. A-CR-OS (OVERSPEED) (IN.)	[ ]

**G. SERVICE DATA**

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ] b,c,e
2. ESTIMATED MAX DA/DT (IN/HR)	[ ] G-2' = [ ] b,c,e
3. Max. expected Keyway Crack size (in) -	[ ] b,c,e
4. Ratio A/A - CR - OS	[ ]



ID # : D081102501

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP# 1  
5. LOCATION GOV  
6. DISC# 5  
7. TEST NO. TD23437

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e VS  
2. MIN. Y.S. (KSI) [ ]  
3. SUPPLIER: MIDVALE HEPPENSTALL  
4. Y.S. (KSI) [ ]  
5. U.T.S. (KSI) [ ]  
6. ELONGATION [ ]  
7. H.A. [ ]  
8. FATT (DEG.F) [ ]  
9. R.T. IMPACT (FT.LB.) [ ]  
10. U.S. IMPACT TEMP. (DEG.F) [ ]  
11. U.S. IMPACT ENG. (FT.LB.) [ ]  
12. U.S. KIC (KSI\*SQRT(IN.)) [ ]

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI) [ ]  
3. ELONGATION [ ]  
4. R.A. [ ]  
5. FATT (DEG.F) [ ]  
6. R.T. IMPACT (FT.LB.) [ ]  
7. U.S. IMPACT TEMP. (DEG.F) [ ]  
8. U.S. IMPACT ENG. (FT.LB.) [ ]  
9. U.S. KIC (KSI\*SQRT(IN.)) [ ]

D. CHEMISTRY

[C] b,c,e [Mn] b,c,e [Si] b,c,e [P] b,c,e [Cr] b,c,e [Mo] b,c,e [V] b,c,e  
[Ni] b,c,e [As] b,c,e [Sb] b,c,e [Sn] b,c,e [Al] b,c,e [Cu] b,c,e [S] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ]  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

ID # : 0081102501

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION		B. MATERIAL PROPERTIES (HUB)		C. MATERIAL PROPERTIES (RIM)	
1. BUILDING BLOCK	81	1. TYPE	[ ] b,c,e TD	1. Y.S. (KSI)	[ ] b,c,e
2. UNIT	SURRY #1	2. IMIN. Y.S. (KSI)	[ ]	2. U.T.S. (KSI)	[ ]
3. CUSTOMER:	VEPCO	3. SUPPLIER:	MIDVALE HEPPENSTALL	3. ELONGATION	[ ]
4. LP#		4. Y.S. (KSI)	[ ]	4. R.A.	[ ]
5. LOCATION	1 GOV	5. U.T.S. (KSI)	[ ]	5. FATT (DEG.F)	[ ]
6. DISC#	6	6. ELONGATION	[ ]	6. R.T. IMPACT (FT.LB.)	[ ]
7. TEST NG.	TD5869	7. R.A.	[ ]	7. U.S. IMPACT TEMP. (DEG.F)	[ ]
		8. FATT (DEG.F)	[ ]	8. U.S. IMPACT ENG. (FT.LB.)	[ ]
		9. R.T. IMPACT (FT.LB.)	[ ]	9. U.S. KIC (KSI*SQRT(IN.))	[ ]
		10. U.S. IMPACT TEMP. (DEG.F)	[ ]		
		11. U.S. IMPACT ENG. (FT.LB.)	[ ]		

D. CHEMISTRY

[ ] c	[ ] b,c,e	[ ] MN	[ ] b,c,e	[ ] SI	[ ] b,c,e	[ ] P	[ ] b,c,e	[ ] CR	[ ] b,c,e	[ ] MO	[ ] b,c,e	[ ] V	[ ] b,c,e
[ ] NI	[ ] b,c,e	[ ] AS	[ ] b,c,e	[ ] SB	[ ] b,c,e	[ ] SN	[ ] b,c,e	[ ] AL	[ ] b,c,e	[ ] CU	[ ] b,c,e	[ ] S	[ ] b,c,e

E. BORE STRESS		F. CRACK DATA	
SPEED (RPM)	STRESS		
1. 1800	[ ] (KSI)	1. A-CR-OP (1800 RPM) (IN.)	[ ] b,c,e
2. 2160 (120%)	[ ] (KSI)	2. A-CR-OS (OVERSPEED) (IN.)	[ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ] b,c,e	G-2' =	[ ] b,c,e
2. ESTIMATED MAX DA/DT (IN/HR)	[ ]		
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)	[ ] b,c,e		
4. RATIO A/A - CR - OS	[ ]		

ID # : D081102502

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP#  
5. LOCATION GEN  
6. DISC#  
7. TEST NO. TD26058

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. (KSI)) b,c,e TD  
2. SUPPLIER: MIDVALE HEPPELSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 [ KSI ]  
2. 2160 (120%) [ KSI ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.)  
2. A-CR-OS (OVERSPEED) (IN.)

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

ID # : D081102502

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP# 1  
5. LOCATION GEN  
6. DISC# 2  
7. TEST NO. TD29573

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TO  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPESTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1600 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

ID # : D081102502

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP#  
5. LOCATION 1 GEN  
6. DISC# 3  
7. TEST NO. TD35363

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e VT  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION [ ]  
6. R.A. [ ]  
7. FATT (DEG.F) [ ]  
8. R.T. IMPACT (FT.LB.) [ ]  
9. U.S. IMPACT TEMP. (DEG.F) [ ]  
10. U.S. IMPACT ENG. (FT.LB.) [ ]  
11. U.S. KIC (KSI\*SQRT(IN.)) [ ]

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI) [ ]  
3. ELONGATION [ ]  
4. R.A. [ ]  
5. FATT (DEG.F) [ ]  
6. R.T. IMPACT (FT.LB.) [ ]  
7. U.S. IMPACT TEMP. (DEG.F) [ ]  
8. U.S. IMPACT ENG. (FT.LB.) [ ]  
9. U.S. KIC (KSI\*SQRT(IN.)) [ ]

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

ID # : D081102502

LP TURBINE DISC INFORMATION

<b>A. UNIT IDENTIFICATION</b>		<b>B. MATERIAL PROPERTIES (HUB)</b>		<b>C. MATERIAL PROPERTIES (RIM)</b>	
1. BUILDING BLOCK	81	1. TYPE	[ ] b,c,e TD	1. Y.S. (KSI)	[ ] b,c,e
2. UNIT	SURRY #1	2. SUPPLIER	MIDVALE HEPPESTALL	2. U.T.S. (KSI)	[ ] b,c,e
3. CUSTOMER:	VEPCO	3. Y.S. (KSI)	[ ]	3. ELONGATION	[ ]
4. LP#	1	4. U.T.S. (KSI)	[ ]	4. R.A.	[ ]
5. LOCATION	GEN	5. ELONGATION	[ ]	5. FATT (DEG.F)	[ ]
6. DISCH	4	6. R.A.	[ ]	6. R.T. IMPACT (FT.LB.)	[ ]
7. TEST NO.	Y023454	7. FATT (DEG.F)	[ ]	7. U.S. IMPACT TEMP. (DEG.F)	[ ]
		8. R.T. IMPACT (FT.LB.)	[ ]	8. U.S. IMPACT ENG. (FT.LB.)	[ ]
		9. U.S. IMPACT TEMP. (DEG.F)	[ ]	9. U.S. KIC (KSI*SQRT(IN.))	[ ]
		10. U.S. IMPACT ENG. (FT.LB.)	[ ]		
		11. U.S. KIC (KSI*SQRT(IN.))	[ ]		

**D. CHEMISTRY**

[ C ]	b,c,e	[ MN ]	b,c,e	[ SI ]	b,c,e	[ P ]	b,c,e	[ CR ]	b,c,e	[ MO ]	b,c,e	[ V ]	b,c,e
[ NI ]	b,c,e	[ AS ]	b,c,e	[ SB ]	b,c,e	[ SN ]	b,c,e	[ AL ]	b,c,e	[ CU ]	b,c,e	[ S ]	b,c,e

<b>E. BORE STRESS</b>		<b>F. CRACK DATA</b>	
SPEED (RPM)	STRESS	1. A-CR-OP (1800 RPM) (IN.)	[ ] b,c,e
1. 1800	[ KSI ]	2. A-CR-OS (OVERSPEED) (IN.)	[ ]
2. 2160 (120%)	[ ]		

**G. SERVICE DATA**

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ] b,c,e	G-2' =	[ ] b,c,e
2. ESTIMATED MAX DA/DT (IN/HR)	[ ]		
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)	[ ] b,c,e		
4. RATIO A/A - DR - OS	[ ]		

ID # : D081102502

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LPH  
5. LOCATION 1 GEN  
6. DISC# 5  
7. TEST NO. TD23432

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ]<sup>c</sup> [ ]<sup>b,c,e</sup> [ ]<sup>MN</sup> [ ]<sup>b,c,e</sup> [ ]<sup>SI</sup> [ ]<sup>b,c,e</sup> [ ]<sup>P</sup> [ ]<sup>b,c,e</sup> [ ]<sup>CR</sup> [ ]<sup>b,c,e</sup> [ ]<sup>MO</sup> [ ]<sup>b,c,e</sup> [ ]<sup>V</sup> [ ]<sup>b,c,e</sup>  
[ ]<sup>NI</sup> [ ]<sup>b,c,e</sup> [ ]<sup>AS</sup> [ ]<sup>b,c,e</sup> [ ]<sup>SB</sup> [ ]<sup>b,c,e</sup> [ ]<sup>SN</sup> [ ]<sup>b,c,e</sup> [ ]<sup>AL</sup> [ ]<sup>b,c,e</sup> [ ]<sup>CU</sup> [ ]<sup>b,c,e</sup> [ ]<sup>S</sup> [ ]<sup>b,c,e</sup>

E. BORE STRESS

SPEED (RPM) STRESS [ ]<sup>b,c,e</sup>  
1. 1800 (KSI)  
2. 2160 (120%) (KSI)

F. CRACK DATA

1. A-CR-CP (1800 RPM) (IN.) [ ]<sup>b,c,e</sup>  
2. A-CR-OS (OVERSPEED) (IN.)

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ]<sup>b,c,e</sup>  
2. ESTIMATED MAX DA/DT (IN/HR) G-2' = [ ]<sup>b,c,e</sup>  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ]<sup>b,c,e</sup>  
4. RATIO A/A - CR - OS [ ]

ID # : D081102502

LP TURBINE DISC INFORMATION

<b>A. UNIT IDENTIFICATION</b>		<b>B. MATERIAL PROPERTIES (HUB)</b>		<b>C. MATERIAL PROPERTIES (RIH)</b>	
1. BUILDING BLOCK	81	1. TYPE	[ ] b,c,e TC	1. Y.S. (KSI)	[ ] b,c,e
2. UNIT	SURRY #1	2. (MIN. Y.S. (KSI))	[ ]	2. U.T.S. (KSI)	[ ]
3. CUSTOMER:	VEPCO	3. SUPPLIER:	MIDVALE HEPPENSTALL	3. ELONGATION	[ ]
4. LPH		4. Y.S. (KSI)	[ ]	4. R.A.	[ ]
5. LOCATION	1 GEN	5. U.T.S. (KSI)	[ ]	5. FATT (DEG.F)	[ ]
6. DISCH	6	6. ELONGATION	[ ]	6. R.T. IMPACT (FT.LB.)	[ ]
7. TEST NO.	TD5870	7. R.A.	[ ]	7. U.S. IMPACT TEMP. (DEG.F)	[ ]
		8. FATT (DEG.F)	[ ]	8. U.S. IMPACT ENG. (FT.LB.)	[ ]
		9. R.T. IMPACT (FT.LB.)	[ ]	9. U.S. KIC (KSI*SQRT(IN.))	[ ]
		10. U.S. IMPACT TEMP. (DEG.F)	[ ]		
		11. U.S. IMPACT ENG. (FT.LB.)	[ ]		

**D. CHEMISTRY**

[ C ]	[ b,c,e ]	[ MN ]	[ b,c,e ]	[ SI ]	[ b,c,e ]	[ P ]	[ b,c,e ]	[ CR ]	[ b,c,e ]	[ MO ]	[ b,c,e ]	[ V ]	[ b,c,e ]
[ NI ]	[ b,c,e ]	[ AS ]	[ b,c,e ]	[ SB ]	[ b,c,e ]	[ SN ]	[ b,c,e ]	[ AL ]	[ b,c,e ]	[ CU ]	[ b,c,e ]	[ S ]	[ b,c,e ]

<b>E. BORE STRESS</b>	<b>F. CRACK DATA</b>
SPEED (RPM)	
1. 1600	1. A-CR-OP (1800 RPM) (IN.)
2. 2160 (120%)	2. A-CR-OS (OVERSPEED) (IN.)
STRESS (KSI)	[ ] b,c,e
[ ]	[ ]

**G. SERVICE DATA**

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ] b,c,e
2. ESTIMATED MAX DA/DT (IN/HR)	G-2' = [ ] b,c,e
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)	[ ] b,c,e
4. RATIO A/A - CR - OS	[ ]



ID # : 0081102503

LP TURBINE DISC INFORMATION

<b>A. UNIT IDENTIFICATION</b>		<b>B. MATERIAL PROPERTIES (HUB)</b>		<b>C. MATERIAL PROPERTIES (RIM)</b>	
1. BUILDING BLOCK	81	1. TYPE	[ ] b,c,e TD	1. Y.S. (KSI)	[ ] b,c,e
2. UNIT	SURRY #1	2. SUPPLIER	MIDVALE HEPPENSTALL	2. U.T.S. (KSI)	[ ] b,c,e
3. CUSTOMER:	VEPCO	3. Y.S. (KSI)	[ ]	3. ELONGATION	[ ]
4. LPH	2	4. U.T.S. (KSI)	[ ]	4. R.A.	[ ]
5. LOCATION	Gov	5. ELONGATION	[ ]	5. FATT (DEG.F)	[ ]
6. DISC#	1	6. R.A.	[ ]	6. R.T. IMPACT (FT.LB.)	[ ]
7. TEST NO.	TD29566	7. FATT (DEG.F)	[ ]	7. U.S. IMPACT TEMP. (DEG.F)	[ ]
		8. R.T. IMPACT (FT.LB.)	[ ]	8. U.S. IMPACT ENG. (FT.LB.)	[ ]
		9. U.S. IMPACT TEMP. (DEG.F)	[ ]	9. U.S. KIC (KSI*SQRT(IN.))	[ ]
		10. U.S. IMPACT ENG. (FT.LB.)	[ ]		
		11. U.S. KIC (KSI*SQRT(IN.))	[ ]		

**D. CHEMISTRY**

[ ] c	[ ] b,c,e	[ ] MN	[ ] b,c,e	[ ] SI	[ ] b,c,e	[ ] P	[ ] b,c,e	[ ] CR	[ ] b,c,e	[ ] MO	[ ] b,c,e	[ ] V	[ ] b,c,e
[ ] NI	[ ] b,c,e	[ ] AS	[ ] b,c,e	[ ] SB	[ ] b,c,e	[ ] SN	[ ] b,c,e	[ ] AL	[ ] b,c,e	[ ] CU	[ ] b,c,e	[ ] S	[ ] b,c,e

<b>E. BORE STRESS</b>	<b>F. CRACK DATA</b>
SPEED (RPM)	
1. 1800 (KSI)	1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e
2. 2160 (120%) (KSI) [ ] b,c,e	2. A-CR-OS (OVERSPEED) (IN.) [ ]

**G. SERVICE DATA**

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ] b,c,e
2. ESTIMATED MAX DA/DT (IN/HR)	G-2' = [ ] b,c,e
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)	[ ] b,c,e
4. RATIO A/A - CR - OS	[ ]

ID # : D081102503

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP# 2  
5. LOCATION GOV  
6. DISC# 2  
7. TEST NO. TD35158

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPELSTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ] b,c,e [MN] b,c,e [SI] b,c,e [P] b,c,e [CR] b,c,e [MO] b,c,e [Y] b,c,e  
[NI] b,c,e [AS] b,c,e [SB] b,c,e [SN] b,c,e [AL] b,c,e [CU] b,c,e [S] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 [ ] b,c,e  
2. 2160 (120%) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ]  $G-2^{1/2} =$  [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

ID # : D081102503

LP TURBINE DISC INFORMATION

<b>A. UNIT IDENTIFICATION</b>		<b>B. MATERIAL PROPERTIES (HUB)</b>		<b>C. MATERIAL PROPERTIES (RIM)</b>	
1. BUILDING BLOCK	81	1. TYPE	b, c, e VT		
2. UNIT	SURRY #1	2. SUPPLIER:	(MIN. Y.S. (KSI))		
3. CUSTOMER:	VEPCO	3. Y.S. (KSI)	MIDVALE HEPPELSTAL	b, c, e	b, c, e
4. LP#	2	4. U.T.S. (KSI)		1. Y.S. (KSI)	
5. LOCATION	GOV	5. ELONGATION		2. U.T.S. (KSI)	
6. DISC#	3	6. R.A.		3. ELONGATION	
7. TEST NO.	TD35162	7. FATT (DEG.F)		4. R.A.	
		8. R.T. IMPACT (FT.LB.)		5. FATT (DEG.F)	
		9. U.S. IMPACT TEMP. (DEG.F)		6. R.T. IMPACT (FT.LB.)	
		10. U.S. IMPACT ENG. (FT.LB.)		7. U.S. IMPACT TEMP. (DEG.F)	
		11. U.S. KIC (KSI*SQRT(IN.))		8. U.S. IMPACT ENG. (FT.LB.)	
				9. U.S. KIC (KSI*SQRT(IN.))	

**D. CHEMISTRY**

[ C ]	b, c, e	[ MN ]	b, c, e	[ SI ]	b, c, e	[ P ]	b, c, e	[ CR ]	b, c, e	[ MO ]	b, c, e	[ V ]	b, c, e
[ NI ]	b, c, e	[ AS ]	b, c, e	[ SB ]	b, c, e	[ SN ]	b, c, e	[ AL ]	b, c, e	[ CU ]	b, c, e	[ S ]	b, c, e

<b>E. BORE STRESS</b>		<b>F. CRACK DATA</b>	
SPEED (RPM)	STRESS		
1. 1800	(KSI)		1. A-CR-OP (1800 RPM) (IN.)
2. 2160 (120%)	(KSI)	b, c, e	2. A-CR-OS (OVERSPEED) (IN.)

**G. SERVICE DATA**

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ]	b, c, e	G-2' = [ ]	b, c, e
2. ESTIMATED MAX DA/DT (IN/HR)	[ ]			
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)	[ ]	b, c, e		
4. RATIO A/A - CR - OS	[ ]			

ID # : 0081102503

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION  
1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LPH 2  
5. LOCATION GOV  
6. DISCH 4  
7. TEST NO. TD23451

B. MATERIAL PROPERTIES (HUB)  
1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION [ ]  
6. R.A. [ ]  
7. FATT (DEG.F) [ ]  
8. R.T. IMPACT (FT.LB.) [ ]  
9. U.S. IMPACT TEMP. (DEG.F) [ ]  
10. U.S. IMPACT ENG. (FT.LB.) [ ]  
11. U.S. KIC (KSI\*SQRT(IN.)) [ ]

C. MATERIAL PROPERTIES (RIM)  
1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI) [ ]  
3. ELONGATION [ ]  
4. R.A. [ ]  
5. FATT (DEG.F) [ ]  
6. R.T. IMPACT (FT.LB.) [ ]  
7. U.S. IMPACT TEMP. (DEG.F) [ ]  
8. U.S. IMPACT ENG. (FT.LB.) [ ]  
9. U.S. KIC (KSI\*SQRT(IN.)) [ ]

D. CHEMISTRY  
[ ]<sup>c</sup> [ ]<sup>b,c,e</sup> [ ]<sup>MN</sup> [ ]<sup>b,c,e</sup> [ ]<sup>SI</sup> [ ]<sup>b,c,e</sup> [ ]<sup>P</sup> [ ]<sup>b,c,e</sup> [ ]<sup>CR</sup> [ ]<sup>b,c,e</sup> [ ]<sup>MO</sup> [ ]<sup>b,c,e</sup> [ ]<sup>V</sup> [ ]<sup>b,c,e</sup>  
[ ]<sup>NI</sup> [ ]<sup>b,c,e</sup> [ ]<sup>AS</sup> [ ]<sup>b,c,e</sup> [ ]<sup>SB</sup> [ ]<sup>b,c,e</sup> [ ]<sup>SN</sup> [ ]<sup>b,c,e</sup> [ ]<sup>AL</sup> [ ]<sup>b,c,e</sup> [ ]<sup>CU</sup> [ ]<sup>b,c,e</sup> [ ]<sup>S</sup> [ ]<sup>b,c,e</sup>

E. BORE STRESS  
SPEED (RPM) STRESS  
1. 1800 (KSI) [ ]  
2. 2160 (120%) (KSI) [ ]  
[ ]<sup>b,c,e</sup>

F. CRACK DATA  
1. A-CR-OP (1800 RPM) (IN.) [ ]  
2. A-CR-OS (OVERSPEED) (IN.) [ ]  
[ ]<sup>b,c,e</sup>

G. SERVICE DATA  
1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ]  
2. ESTIMATED MAX DA/DT (IN/HR) [ ]<sup>b,c,e</sup> G-2' = [ ]<sup>b,c,e</sup>  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ]<sup>b,c,e</sup>  
4. RATIO A/A - CR - OS [ ]

ID # : 0081102503

LP TURBINE DISC INFORMATION

<b>A. UNIT IDENTIFICATION</b>		<b>B. MATERIAL PROPERTIES (HUB)</b>		<b>C. MATERIAL PROPERTIES (RIM)</b>	
1. BUILDING BLOCK	81	1. TYPE	[ ] b,c,e TD	1. Y.S. (KSI)	[ ] b,c,e
2. UNIT	SURRY #1	2. SUPPLIER	[ ] (KSI) MIDVALE HEPPENSTALL	2. U.T.S. (KSI)	[ ]
3. CUSTOMER:	VEPCO	3. Y.S. (KSI)	[ ]	3. ELONGATION	[ ]
4. LPH	2	4. U.T.S. (KSI)	[ ]	4. R.A.	[ ]
5. LOCATION	GOV	5. ELONGATION	[ ]	5. FATT (DEG.F)	[ ]
6. DISC#	5	6. R.A.	[ ]	6. R.T. IMPACT (FT.LB.)	[ ]
7. TEST NO.	TD23441	7. FATT (DEG.F)	[ ]	7. U.S. IMPACT TEMP. (DEG.F)	[ ]
		8. R.T. IMPACT (FT.LB.)	[ ]	8. U.S. IMPACT ENG. (FT.LB.)	[ ]
		9. U.S. IMPACT TEMP. (DEG.F)	[ ]	9. U.S. KIC (KSI*SQRT(IN.))	[ ]
		10. U.S. IMPACT ENG. (FT.LB.)	[ ]		
		11. U.S. KIC (KSI*SQRT(IN.))	[ ]		

**D. CHEMISTRY**

[ C ]	[ ] b,c,e	[ MN ]	[ ] b,c,e	[ SI ]	[ ] b,c,e	[ P ]	[ ] b,c,e	[ CR ]	[ ] b,c,e	[ MO ]	[ ] b,c,e	[ V ]	[ ] b,c,e
[ NI ]	[ ] b,c,e	[ AS ]	[ ] b,c,e	[ SB ]	[ ] b,c,e	[ SN ]	[ ] b,c,e	[ AL ]	[ ] b,c,e	[ CU ]	[ ] b,c,e	[ S ]	[ ] b,c,e

<b>E. BORE STRESS</b>		<b>F. CRACK DATA</b>	
SPEED (RPH)	STRESS	1. A-CR-OP (1800 RPM) (IN.)	[ ] b,c,e
1. 1800 (KSI)	[ ] b,c,e	2. A-CR-OS (OVERSPEED) (IN.)	[ ]
2. 2160 (120%) (KSI)	[ ]		

**G. SERVICE DATA**

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)	[ ] b,c,e	μ =	[ ] b,c,e
2. ESTIMATED MAX DA/DT (IN/HR)	[ ]	G-2' =	[ ] b,c,e
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)	[ ] b,c,e		
4. RATIO A/A - CR - OS	[ ]		

ID # : D081102503

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP# 2  
5. LOCATION GOV  
6. DISC# 6  
7. TEST NO. TD18613

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. (KSI)) b,c,e TD  
2. SUPPLIER: MIDVALE HEPPENSTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS  
SPEED (RPM) STRESS

1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e

3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e

4. RATIO A/A - CR - OS [ ]

ID # : D081102504

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LPH  
5. LOCATION 2 GEN  
6. DISC# 1  
7. TEST NO. TD35153

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPESTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION [ ]  
6. R.A. [ ]  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI) [ ]  
3. ELONGATION [ ]  
4. R.A. [ ]  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ c ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
 2. UNIT SURRY #1  
 3. CUSTOMER: VEPCO  
 4. LP# 2  
 5. LOCATION GEN  
 6. DISC# 2  
 7. TEST NO. TD35159

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
 (MIN. Y.S. [ ] (KSI))  
 2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
 3. Y.S. (KSI)  
 4. U.T.S. (KSI)  
 5. ELONGATION  
 6. R.A.  
 7. FATT (DEG.F)  
 8. R.T. IMPACT (FT.LB.)  
 9. U.S. IMPACT TEMP. (DEG.F)  
 10. U.S. IMPACT ENG. (FT.LB.)  
 11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
 2. U.T.S. (KSI)  
 3. ELONGATION  
 4. R.A.  
 5. FATT (DEG.F)  
 6. R.T. IMPACT (FT.LB.)  
 7. U.S. IMPACT TEMP. (DEG.F)  
 8. U.S. IMPACT ENG. (FT.LB.)  
 9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
 [ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
 1. 1800 (KSI) [ ]  
 2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-0P (1800 RPM) (IN.) [ ] b,c,e  
 2. A-CR-0S (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
 2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
 3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
 4. RATIO A/A - CR - OS [ ]



ID # : D081102504

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LP#  
5. LOCATION 2 GEN  
6. DISC# 3  
7. TEST NO. TD35163

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e VT  
(MIN. Y.S. (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ] c b,c,e [ ] MN b,c,e [ ] SI b,c,e [ ] P .00% b,c,e [ ] CR b,c,e [ ] MO b,c,e [ ] V b,c,e  
[ ] NI b,c,e [ ] AS b,c,e [ ] SB b,c,e [ ] SN b,c,e [ ] AL b,c,e [ ] CU b,c,e [ ] S b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

ID # : 0081102504

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LPH 2  
5. LOCATION GEN  
6. DISC# 4  
7. TEST NO. TD35371

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ] c [ ] b,c,e [ ] MN [ ] b,c,e [ ] SI [ ] b,c,e [ ] P [ ] b,c,e [ ] CR [ ] b,c,e [ ] MO [ ] b,c,e [ ] V [ ] b,c,e  
[ ] NI [ ] b,c,e [ ] AS [ ] b,c,e [ ] SB [ ] b,c,e [ ] SN [ ] b,c,e [ ] AL [ ] b,c,e [ ] CU [ ] b,c,e [ ] S [ ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 [ ] b,c,e  
2. 2160 (120%) [ ] (KSI)

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.)

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e

3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e

4. RATIO A/A - CR - OS [ ]

ID # : 0081102504

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81

2. UNIT SURRY #1

3. CUSTOMER: VEPCO

4. LPH 2

5. LOCATION GEN

6. DISC# 5

7. TEST NO. TD23433

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD

2. SUPPLIER: MIDVALE HEPPENSTALL (KSI) b,c,e

3. Y.S. (KSI)

4. U.T.S. (KSI)

5. ELONGATION

6. R.A.

7. FATT (DEG.F)

8. R.T. IMPACT (FT.LB.) (DEG.F)

9. U.S. IMPACT TEMP. (DEG.F)

10. U.S. IMPACT ENG. (FT.LB.)

11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)

2. U.T.S. (KSI)

3. ELONGATION

4. R.A.

5. FATT (DEG.F)

6. R.T. IMPACT (FT.LB.) (DEG.F)

7. U.S. IMPACT TEMP. (DEG.F)

8. U.S. IMPACT ENG. (FT.LB.)

9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ] c [ ] b,c,e [ ] MN [ ] b,c,e [ ] SI [ ] b,c,e [ ] P [ ] b,c,e [ ] CR [ ] b,c,e [ ] MO [ ] b,c,e [ ] V [ ] b,c,e

[ ] NI [ ] b,c,e [ ] AS [ ] b,c,e [ ] SA [ ] b,c,e [ ] SN [ ] b,c,e [ ] AL [ ] b,c,e [ ] CU [ ] b,c,e [ ] S [ ] b,c,e

E. BORE STRESS

SPEED (RPH) STRESS

1: 1800 (KSI) [ ] b,c,e

2: 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1: A-CR-OP (1800 RPM) (IN.) [ ] b,c,e

2: A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e

2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e

3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e

4. RATIO A/A - CR - OS [ ]

ID # : D081102504

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION  
1. BUILDING BLOCK 81  
2. UNIT SURRY #1  
3. CUSTOMER: VEPCO  
4. LPH 2  
5. LOCATION GEN  
6. DISCH 6  
7. TEST NO. TD24062

B. MATERIAL PROPERTIES (HUB)  
1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION [ ]  
6. R.A. [ ]  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)  
1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION [ ]  
4. R.A. [ ]  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY  
[C] b,c,e [MN] b,c,e [SI] b,c,e [P] b,c,e [CR] b,c,e [MO] b,c,e [V] b,c,e  
[NI] b,c,e [AS] b,c,e [SB] b,c,e [SN] b,c,e [AL] b,c,e [CU] b,c,e [S] b,c,e

E. BORE STRESS SPEED (RPM) STRESS [ ] b,c,e  
1. 1800 (KSI)  
2. 2160 (120%) (KSI)

F. CRACK DATA [ ] b,c,e  
1. A-CR-OP (1800 RPH) (IN.)  
2. A-CR-OS (OVERSPEED) (IN.)

G. SERVICE DATA  
1. OPER. TEMP, METAL TEMP, HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A - CR - OS [ ]

Attachment 4

SURRY 2

Vepco's Responses to  
SITE SPECIFIC GENERAL QUESTIONS  
on Turbine Disc Integrity  
Surry Power Station, Unit 2

I. Provide the following information for each LP turbine:

I.A. Turbine type

The Virginia Electric and Power Company Surry No. 2 unit has one tandem compound four flow, three casing, condensing, 1800 rpm turbine using 44-inch last-row blades in each low-pressure element. The low-pressure element is designated a Building Block 81.

I.B. Number of hours of operation for each LP turbine at time of last turbine inspection or if not inspected, postulated to inspection

The number of hours of operation from beginning of operation until February 24, 1979, when the current outage began, is 33,996.

I.C. Number of turbine trips and overspeeds

There have been fifty (50) turbine trips. There has been one (1) overspeed, which was intentional for the purpose of verifying the overspeed setpoint.

I.D. For each disc:

I.D.1. Type of material including material specifications

The material is Ni-Cr-Mo-V steel similar to ASTM-A-471. The minimum yield strength specified for each disc is given in Section B<sup>1</sup> of Appendix A to this Attachment 4.

I.D.2. Tensile properties data

Tensile properties data of tests taken from the disc hub and rim material are given in Sections B and C, respectively, of Appendix A to this Attachment 4.

I.D.3. Toughness properties data including Fracture Appearance Transition Temperature and upper energy and temperature

Toughness properties for the disc hub and rim are given in Sections B and C, respectively, of Appendix A to this Attachment 4. The upper shelf energy is not presented in this Attachment 4 when it is the same as the room temperature energy.

I.D.4. Keyway temperatures

The keyway temperatures are presented in Section G of Appendix A to this Attachment 4. The temperatures given are the calculated temperatures two inches from the exhaust

---

1/Note that the first 24 pages of Appendix A consist of Westinghouse computer print-outs, each with separate sections A through G. (For example, Section A is "Unit Identification.") It is to those sections we refer when we cite, for example, Section B of Appendix A to Attachment 3.

face of the disc at the bore during full-load operation with all moisture separator reheaters in service.

I.D.5. Calculated keyway crack size for turbine specified in "B" above

The calculated maximum keyway crack size is designated item G-3, in keeping with the notation suggested by Westinghouse, and is found in Appendix A to this Attachment 4. G-3 is calculated by multiplying the number of hours of operation (see I.B above) by the crack growth rate  $da/dt$ . The crack growth rate is calculated as described in the response to I.D.8 below.

I.D.6 Critical crack size

The critical crack size at 1800 rpm and at design (120%) overspeed is given in Section F of Appendix A to this Attachment 4.

I.D.7. Ratio of calculated crack to critical crack sizes

The ratio of calculated crack size to critical crack size,  $a/a_{cr}(\text{eff})$ , is designated G-4 and given in Appendix A to this Attachment 4. This number is calculated simply by dividing item G-3 by item F-2.

I.D.8. Crack growth rate

The crack growth rate is given as G-2' in Appendix A to this Attachment 4. These crack growth rates are the maximum expected rates based on known cracks to date.

Westinghouse has changed the basis for determining these rates to use the NRC "gray book" operating hours. The NRC value for the crack growth rate is given as item G-2 on the computer print-outs (first 24 pages of Appendix A to this Attachment 4). Because Westinghouse's crack growth rates over the relevant range are consistently larger than the NRC values, however, the G-2 numbers from the print-outs have been multiplied by a factor, provided in Appendix A, to yield the more conservative G-2' figures, which are also given in Appendix A.

Westinghouse's opinion is that the crack growth rate of disc numbers 1 and 6 for Surry 2 should be assumed to be zero because these discs operate dry under normal conditions. However, to be conservative (and consistent with the calculations for the other discs), Vepco has calculated a crack size for disc numbers 1 and 6, using the same methods as for the other discs.

I.D.9. Calculated bore and keyway stress at operating speed and design overspeed

The bore tangential stresses at 1800 rpm and at design overspeed are given in Section E of Appendix A to this Attachment 4. The values presented include the stresses due to shrink fit and centrifugal force loads only. Additional analysis to include thermal stresses and pressure stresses are being made but are not yet available.



Westinghouse has not provided the keyway stresses, because Westinghouse's analysis assumes that the keyway is part of the crack, and so the only significant stress is the bore stress.

I.D.10. Calculated  $K_{IC}$  data

The fracture toughness,  $K_{IC}$ , of each disc is calculated from the Charpy v-notch and tensile data. The values, presented in Section B and C of Appendix A to this Attachment 4, are calculated at the upper shelf temperature or room temperature, whichever gives the lower result.

I.D.11. Minimum yield strength specified for each disc

The values for minimum yield strength are presented in Section B of Appendix A to this Attachment 4.

II. Provide details of the results of any completed inservice inspection of LP turbine rotors, including areas examined since issuance of an operating license. For each indication detected, provided details of the location of the crack, its orientation, and size.

Surry Unit 2 was put into service<sup>2</sup> in 1973, and a Westinghouse inspection team ultrasonically inspected the Surry 2 LP rotors 13A3295 (LP1) and 13A3296 (LP2) at the Westinghouse Charlotte plant in September 1979. The inspection method used at that time was to inspect ultrasonically all keyways on discs

---

2/Initial criticality March 7, 1973; first commercial operation March 11, 1973; full thermal output May 1, 1973.

1 and 2, both ends of each rotor, and to perform an ultrasonic 360° scan on the outlet side of each disc. The inlet scan was completed at the Surry Station in January 1980.

The inspection results for discs 1 and 2 are as follows:

# 1 LP - Disc #1	Gov. End	No Indications
Disc #1	Gen. End	No Indications
Disc #2	Gov. End	No Indications
Disc #2	Gen. End	.360" Deep Indication (Keyway #2) <sup>3</sup>

# 2 LP - No Indications

Both rotors were unstacked (discs 3, 4, 5, and 6) at Charlotte in the summer and fall of 1979. During this time, new no. 3 discs were installed and nos. 4, 5 and 6 were restacked. Magnetic particle inspection of the unstacked discs, including the original no. 3 disc, which was scrapped, are as follows:

#1 LP - Disc #3, 4, 5 & 6	Gov. End	No Indications
Disc #3, 4, 5 & 6	Gen. End	No Indications
#2 LP - Disc #4, 5 & 6	Gov. End	No Indications
Disc #3, 4, 5 & 6	Gen. End	No Indications

---

3/The #1 LP, Disc #2, Generator End with .360" deep indication (Keyway #2) was repaired.

Disc #3 (scrapped)      Gen. End      .300" Deep  
Indication  
(Keyway 2)<sup>4</sup>

III. Provide the nominal water chemistry conditions for each LP turbine and describe any condenser inleakages or other significant changes in secondary water chemistry to this point in its operating life. Discuss the occurrence of cracks in any given turbine as related to history of secondary water chemistry in the unit.

---

See the enclosed report on "Surry #2 Secondary System Chemistry."

IV. If your plant has not been inspected, describe your proposed schedule and approach to ensure that turbine cracking does not exist in your turbine.

---

Both LP rotors were recently inspected as explained in response to question II above. Vepco's approach to ensure that unacceptable cracking does not occur in the future is based on calculations of the ratio  $a/a_{cr}(eff)$  for the worst-case disc in order to be sure that this ratio remains less than unity. A calculation to determine the number of hours that the worst-case disc (disc no. 1, governor end, LP 1) could operate before  $a/a_{cr}(eff)$  became unity, using the values of  $a_{cr}(eff)$  and  $da/dt$  from Appendix A to this Attachment 4, yields a result of 29,098 hours.

---

4/The #2 LP, Disc #3, Generator End with .300" deep indication (Keyway #3) was replaced.

- V. If your plant has been inspected and plans to return or has returned to power with cracks, provide your proposed schedule for the next turbine inspection and the basis for this inspection schedule.
- 

The plant was recently inspected and all defects were corrected.

- VI. Indicate whether an analysis and evaluation regarding turbine missiles have been performed for your plant and provided to the staff. If such an analysis and evaluation has been performed and reported, please provide appropriate references to the available documentation. In the event that such studies have not been made, consideration should be given to scheduling such an action.
- 

An analysis of the turbine missile risk for Surry 2 has been done and provided to the Staff. The analysis can be found in the Final Safety Analysis Report, Supplemental Volume 2, S14.9 dated 10-15-70.

Westinghouse  
Proprietary

Surry 2 Secondary System Chemistry

Secondary system chemistry data for Surry Power Station from 1974 through 1979 was reviewed.

Operating specifications, as supplied by Westinghouse Electric Corporation, are shown in Tables I through IV. Prior to January 1975, these units were operated with a coordinated phosphate treatment for corrosion inhibition control of the secondary side. The sodium/phosphate molar ratio, as per Westinghouse's criteria, varied from 2.0 to 2.6, 2.2 to 2.6 and 2.4 to 2.6. All Volatile Treatment was thereafter initiated using ammonium hydroxide, cyclohexylamine or morpholine for pH control. This unit has experienced condenser inleakage. Condenser cooling water is brackish.

A synopsis of the chemistry review follows.

Surry Unit No. 2

1974

- Utilized coordinated phosphate treatment control.
- Table I denotes specifications.
- Main steam average pH was  $9.00 \pm 0.2$  with the maximum being 9.65. Total average conductivity was 4.5 mmhos.

- Condensate sodium was 0-10 ppb, 47%; 10-100 ppb, 49%; and greater than 10 ppb, 3% of the time.
- Blowdown chemistry specifications were maintained approximately 80% of the time.
- Condenser inleakage occurred approximately 75% of the operating time.

1975

- Utilized all volatile treatment control using ammonium hydroxide and hydrazine.
- Tables II and III denote specifications.
- Main steam average pH was  $8.90 \pm 0.2$  with the maximum being 9.80. Total average conductivity was 9.80 mmhos.
- Condensate sodium was 0-10 ppb, 60%; 10-100 ppb, 38%; and greater than 100 ppb, 2% of the time.
- Blowdown chemistry specifications were maintained approximately 25% of the time.
- Condenser inleakage occurred approximately 75% of the operating time.

1976

- Utilized all volatile treatment control using cyclohexylamine and hydrazine.
- Tables II and III denote specifications.
- Main steam average pH was  $9.40 \pm 0.2$  with the maximum being 10.30. Total average conductivity was 12.0 mmhos.
- Condensate sodium was 0-10 ppb, 60%, 10-100 ppb, 35%; and greater than 100 ppb, 5% of the operating time.
- Steam generator chemistry specifications were maintained approximately 25% of the operating time.

- Condenser inleakage occurred approximately 75% of the operating time.

1977

- Utilized all volatile treatment control using morpholine and hydrazine.
- Tables II and III denote specifications.
- Main steam average pH was  $9.0 \pm 0.2$  with the maximum being 10.3. Total average conductivity was 5.0 mmhos.
- Condensate sodium was 0-10 ppb, 62%; 10-100 ppb, 35%; and greater than 100 ppb 3% of the operating time.
- Steam generator chemistry specifications were maintained approximately 25% of the operating time.
- Condenser inleakage occurred approximately 75% of the operating time.

1978

- Utilized all volatile treatment control using morpholine and hydrazine.
- Tables II, III and IV denote specifications.
- Main steam average pH was  $8.9 \pm 0.2$ . Total average conductivity was 3.5 mmhos.
- Condensate sodium was 0-10 ppb, 80%; 10-100 ppb, 33%; and greater than 100 ppb, 2% of the operating time.
- Steam generator chemistry specifications were maintained approximately 40% of the operating time.
- Condenser inleakage occurred approximately 60% of the operating time.

1979

- Unit shutdown February 4, 1979, for the remainder the year for replacement of the steam generators.

NOTE: The following condensate sodium values approximately equate to the indicated condenser inleakage rate on an average:

10 ppb - 0.1 gpm

100 ppb - 1.0 gpm



COORDINATED PHOSPHATE CONTROL

TABLE I

	<u>POWER OPERATION</u>	
	<u>FEEDWATER</u>	<u>BLOWDOWN</u>
pH at 25°C	8.9 - 9.2	8.5 - 10.6
Phosphate, ppm	NA	25-80
Blowdown Rate, gpm	NA	greater than 5 (continuous)
Free Hydroxide	NA	Zero
Dissolved Oxygen, ppm	less than 0.005	less than 0.005
Hydrazine, ppm	greater than 0.01 residual	NA
Chloride, ppm	NA	less than 75
TDS, ppm	NA	less than 125
Susp. Solids, ppm	NA	less than 5.0
Iron & Copper, ppm	less than 0.01	less than 5.0
Silica, ppm	NA	less than 5.0

ALL VOLATILE TREATMENT

TABLE II

	<u>POWER OPERATION</u>
	<u>BLOWDOWN</u>
pH at 25°C	8.5 - 9.0
Free Hydroxide as ppm CaCO <sub>3</sub>	less than 0.15
Cation Cond., mmhos at 25°C	less than 2.0
Sodium, ppm	less than 0.10
Chloride, ppm	less than 0.15
Ammonia, ppm	less than 0.25
Diss. Oxygen, ppm	less than 0.005
Silica, ppm	less than 1.0
Suspended Solids, ppm	less than 1.0

TABLE III

LIMITING AVT SPECIFICATIONS FOR  
POWER OPERATIONS - BRACKISH WATER SITES

	<u>BLOWDOWN</u>		
	<u>Two Weeks</u>	<u>24 Hours</u>	<u>Immediate</u>
pH at 25°C	*8.0 - 9.2 <sup>1</sup>	NA	< 8.0 or >9.4 <sup>1</sup>
Cation Cond., mmhos at 25°C	>*2.0 but ≤120	NA	>120
Free Hydroxide, ppm as CaCO <sub>3</sub>	NA <sup>2</sup>	>0.15 but <1.0	≥1.0

---

\*Instrumented Measurement Recommended.

N/A Not Applicable.

Comment: Operation beyond the normal AVT specifications is limited as indicated above. Corrective action including shutdown, if necessary, is recommended within the time periods as applicable.

---

1/An increase of 0.4 pH units to the normal control pH limit of 9.0 will result from a Free Hydroxide concentration of 1.0 ppm as CaCO<sub>3</sub>. However, pH is not intended to be the Free Hydroxide determinant.

2/No relief for Free Hydroxide over and above the Normal Operating Control Limit is provided for periods in excess of 24 hours.

TABLE IV

Steam Generator Blowdown AVT Specification

<u>Chemistry Parameter</u>	<u>Control</u>	<u>Expected</u>
pH at 25°C	8.5 - 9.0 <sup>1</sup>	8.5 - 9.0 <sup>1</sup>
Free Hydroxide as ppm CaCO <sub>3</sub>	0.15	<0.15
Cation Cond., mmhos/cm at 25°C	2.0	<2.0
Chloride, ppm	NA	<0.15 <sup>2</sup>
Sodium, ppm	NA	<0.1
NH <sub>3</sub> , ppm	NA	<0.25
Dissolved Oxygen, ppb	NA	<5
SiO <sub>2</sub> , ppm	NA	<1.0
Suspended Solids, ppm	NA	<1.0
Blowdown Rate, gpm/Steam Generator	As required to maintain control parameters.	

Continued operation with known chloride ingress even through blowdown permits observance of the normal specification is not recommended. The cause of the contamination should be corrected. Continuous monitoring of the blowdown is essential if chloride exposure is to be minimized.

---

1/To be maintained with morpholine at sea and brackish water sites.

2/Chloride ion concentration is limited by cation conductivity. Confirmatory analysis for chloride is required.

Response to OFF Normal Conditions (Continued from Table IV)

- Sea or brackish Water Plants

As stated above, field and laboratory data reveal that even low bulk water chloride concentrations can produce denting.

Further, plant operating histories suggest the chloride effect may be cumulative.

ID # : D061102601

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
 2. UNIT SURRY #2  
 3. CUSTOMER: VEPCO  
 4. LP#  
 5. LOCATION GOV  
 6. DISC# 1  
 7. TEST NO. TD55535

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e TO  
 2. SUPPLIER: BETHLEHEM STEEL (KSI)  
 3. Y.S. (KSI)  
 4. U.T.S. (KSI)  
 5. ELONGATION  
 6. R.A.  
 7. FATT (DEG.F)  
 8. R.T. IMPACT (FT.LB.)  
 9. U.S. IMPACT TEMP. (DEG.F)  
 10. U.S. IMPACT ENG. (FT.LB.)  
 11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
 2. U.T.S. (KSI)  
 3. ELONGATION  
 4. R.A.  
 5. FATT (DEG.F)  
 6. R.T. IMPACT (FT.LB.)  
 7. U.S. IMPACT TEMP. (DEG.F)  
 8. U.S. IMPACT ENG. (FT.LB.)  
 9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

C [.23] b,c,e    MN [ ] b,c,e    SI [ ] b,c,e    P [ ] b,c,e    CR [ ] b,c,e    HO [ ] b,c,e    V [ ] b,c,e  
 NI [3.52] b,c,e    AS [ ] b,c,e    SB [ ] b,c,e    SN [ ] b,c,e    AL [ ] b,c,e    CU [ ] b,c,e    S [ ] b,c,e

E. BORE STRESS

SPEED (RPM)    STRESS  
 1. 1800 (KSI) [ ] b,c,e  
 2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
 2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
 2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
 3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
 4. RATIO A/A-CR-OS [ ] b,c,e

Appendix B  
to Attachment 4

ID # : D081102601

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPH 1  
5. LOCATION GOV  
6. DISCH 2  
7. TEST NO. TD60028

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e TD (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.) -  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT E.G. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

C [ ] b,c,e MN [ ] b,c,e SI [ ] b,c,e P [ ] b,c,e CR [ ] b,c,e MO [ ] b,c,e V [ ] b,c,e  
NI [ ] b,c,e AS [ ] b,c,e SR [ ] b,c,e SN [ ] b,c,e AL [ ] b,c,e CU [ ] b,c,e S [ ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR)  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS

G-2' = [ ] b,c,e

ID # : D081102601

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPH 1  
5. LOCATION GOV  
6. DISC# 3  
7. TEST NO. TD36431

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TE  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPESTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.) (DEG.F)  
9. U.S. IMPACT TEMP. (FT.LB.)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.) (DEG.F)  
7. U.S. IMPACT TEMP. (FT.LB.)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

C [ ] b,c,e MN [ ] b,c,e SI [ ] b,c,e P [ ] b,c,e CR [ ] b,c,e MO [ ] b,c,e V [ ] b,c,e  
NI [ ] b,c,e AS [ ] b,c,e SR [ ] b,c,e SN [ ] b,c,e AL [ ] b,c,e CU [ ] b,c,e S [ ] b,c,e

E. BORE STRESS  
SPEED (RPM) STRESS

1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A-CR-OS [ ] b,c,e



ID # : DC81102601

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LP# 1  
5. LOCATION GOV  
6. DISC# 4  
7. TEST NO. TD44534

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TE  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPESTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT. (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ] b,c,e [ ] MN [ ] b,c,e [ ] SI [ ] b,c,e [ ] P [ ] b,c,e [ ] CR [ ] b,c,e [ ] MO [ ] b,c,e [ ] V [ ] b,c,e  
[ ] NI [ ] b,c,e [ ] AS [ ] b,c,e [ ] SB [ ] b,c,e [ ] SN [ ] b,c,e [ ] AL [ ] b,c,e [ ] CU [ ] b,c,e [ ] S [ ] b,c,e

E. CORE STRESS

SPEED (RPM) STRESS

1: 1800 [ ] b,c,e  
2: 2160 (120%) [ ] b,c,e

F. CRACK DATA

1: A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2: A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR)  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS

G-2' = [ ] b,c,e

ID # : D081102601

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LB#  
5. LOCATION 1 Gov  
6. DISC# S  
7. TEST NO. TD35353

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TO  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI) [ ] b,c,e  
3. ELONGATION [ ] b,c,e  
4. R.A. [ ] b,c,e  
5. FATT (DEG.F) [ ] b,c,e  
6. R.T. IMPACT (FT.LB.) [ ] b,c,e  
7. U.S. IMPACT TEMP. (DEG.F) [ ] b,c,e  
8. U.S. IMPACT ENG. (FT.LB.) [ ] b,c,e  
9. U.S. KIC (KSI\*SQRT(IN.)) [ ] b,c,e

D. CHEMISTRY

[ ] b,c,e [ ] MN [ ] b,c,e [ ] SI [ ] b,c,e [ ] P [ ] b,c,e [ ] CR [ ] b,c,e [ ] MO [ ] b,c,e [ ] V [ ] b,c,e  
[ ] NI [ ] b,c,e [ ] AS [ ] b,c,e [ ] SB [ ] b,c,e [ ] SN [ ] b,c,e [ ] AL [ ] b,c,e [ ] CU [ ] b,c,e [ ] S [ ] b,c,e

E. CORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
 2. UNIT SURRY #2  
 3. CUSTOMER: VEPCO  
 4. L.P.  
 5. LOCATION 1 GOV  
 6. DISC 6  
 7. TEST NO. T055531

B. MATERIAL PROPERTIES (HUB)

1. TYPE b,c,e TD  
 2. IMIN. Y.S. [ ] (KSI)  
 3. SUPPLIER: BETHLEHEM STEEL  
 4. Y.S. (KSI)  
 5. U.T.S. (KSI)  
 6. ELONGATION  
 7. R.A.  
 8. FATT (DEG.F)  
 9. R.T. IMPACT (FT.LB.)  
 10. U.S. IMPACT TEMP. (DEG.F)  
 11. U.S. IMPACT ENG. (FT.LB.)  
 12. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
 2. U.T.S. (KSI)  
 3. ELONGATION  
 4. R.A.  
 5. FATT (DEG.F)  
 6. R.T. IMPACT (FT.LB.)  
 7. U.S. IMPACT TEMP. (DEG.F)  
 8. U.S. IMPACT ENG. (FT.LB.)  
 9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

C ] b,c,e    MN ] b,c,e    SI ] b,c,e    P ] b,c,e    CR ] b,c,e    MO ] b,c,e    V ] b,c,e  
 NI ] b,c,e    AS ] b,c,e    SB ] b,c,e    SN ] b,c,e    AL ] b,c,e    CU ] b,c,e    S ] b,c,e

E. CORE STRESS

SPEED (RPM)    STRESS  
 1. 1800 (KSI) [ ] b,c,e  
 2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
 2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
 2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
 3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
 4. RATIO A/A-CR-OS [ ] b,c,e

ID # : D081102602

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LP#  
5. LOCATION 1 GEN  
6. DISC# 1  
7. TEST NO. T055536

B. MATERIAL PROPERTIES (HUB)

1. TYPE b,c,e TD  
(MIN. Y.S. L ] (KSI))  
2. SUPPLIER: BETHLEHEM STEEL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI)  
2. 2160 (120%) (KSI)

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.)  
2. A-CR-OS (OVERSPEED) (IN.)

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F)  
2. ESTIMATED MAX DA/DT (IN/HR)  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS

A-G-2' = [ ] b,c,e

ID # : P081102602

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPM 1  
5. LOCATION GEN  
6. DISC# 2  
7. TEST NO. TDS7959

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] b,c,e (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. CORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI)

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.)

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR)  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS G-2' = [ ] b,c,e

ID # : 0081102602

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPP  
5. LOCATION 1 GEN  
6. DISC# 3  
7. TEST NO. T060931

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ]<sup>C</sup> ] b,c,e [ ]<sup>MN</sup> ] b,c,e [ ]<sup>SI</sup> ] b,c,e [ ]<sup>P</sup> ] b,c,e [ ]<sup>CR</sup> ] b,c,e [ ]<sup>MO</sup> ] b,c,e [ ]<sup>V</sup> ] b,c,e  
[ ]<sup>NI</sup> ] b,c,e [ ]<sup>AS</sup> ] b,c,e [ ]<sup>SB</sup> ] b,c,e [ ]<sup>SN</sup> ] b,c,e [ ]<sup>AL</sup> ] b,c,e [ ]<sup>CU</sup> ] b,c,e [ ]<sup>S</sup> ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ]  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] G-2' = [ ] b,c,e  
4. RATIO A/A-CR-OS [ ]

ID # : D081102602

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK B1  
2. UNIT SUPRY #2  
3. CUSTOMER: VEPCO  
4. LPH  
5. LOCATION 1 GEN  
6. DISC# 4  
7. TEST NO. TD55595

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e TO  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[C] b,c,e [MN] b,c,e [SI] b,c,e [P] b,c,e [CR] b,c,e [MO] b,c,e [V] b,c,e  
[NI] b,c,e [AS] b,c,e [SB] b,c,e [SN] b,c,e [AL] b,c,e [CU] b,c,e [S] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR)  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A-CR-OS [ ] b,c,e

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
 2. UNIT SURRY #2  
 3. CUSTOMER: VEPCO  
 4. LPH  
 5. LOCATION GEN  
 6. DISC# 5  
 7. TEST NO. TD55520

B. MATERIAL PROPERTIES (HUB)

1. TYPE Y.S. [ ] b,c,e TD  
 (MIN. Y.S. [ ] (KSI))  
 2. SUPPLIER: BETHLEHEM STEEL  
 3. Y.S. (KSI)  
 4. U.T.S. (KSI)  
 5. ELONGATION  
 6. R.A.  
 7. FATT (DEG.F)  
 8. R.T. IMPACT (FT.LB.)  
 9. U.S. IMPACT TEMP. (DEG.F)  
 10. U.S. IMPACT ENG. (FT.LB.)  
 11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
 2. U.T.S. (KSI)  
 3. ELONGATION  
 4. R.A.  
 5. FATT (DEG.F)  
 6. R.T. IMPACT (FT.LB.)  
 7. U.S. IMPACT TEMP. (DEG.F)  
 8. U.S. IMPACT ENG. (FT.LB.)  
 9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ]<sup>C</sup> b,c,e [ ]<sup>MN</sup> b,c,e [ ]<sup>SI</sup> b,c,e [ ]<sup>P</sup> b,c,e [ ]<sup>CR</sup> b,c,e [ ]<sup>MO</sup> b,c,e [ ]<sup>V</sup> b,c,e  
 [ ]<sup>NI</sup> b,c,e [ ]<sup>AS</sup> b,c,e [ ]<sup>SA</sup> b,c,e [ ]<sup>SN</sup> b,c,e [ ]<sup>AL</sup> b,c,e [ ]<sup>CU</sup> b,c,e [ ]<sup>S</sup> b,c,e

E. BORE STRESS SPEED (RPM) STRESS

1. 1800 (KSI) [ ] b,c,e  
 2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
 2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
 2. ESTIMATED MAX DA/DT (IN/HR) [ ]  
 3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ]  
 4. RATIO A/A-CR-OS [ ] G-2' = [ ] b,c,e



ID # : D081102602

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK BI  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LP# 1  
5. LOCATION GEN  
6. DISC# 6  
7. TEST NO. TD63045

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: BETHLEHEM STEEL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ] C [ ] b,c,e [ ] MN [ ] b,c,e [ ] SI [ ] b,c,e [ ] P [ ] b,c,e [ ] CR [ ] b,c,e [ ] MO [ ] b,c,e [ ] V [ ] b,c,e  
[ ] NI [ ] b,c,e [ ] AS [ ] b,c,e [ ] SB [ ] b,c,e [ ] SN [ ] b,c,e [ ] AL [ ] b,c,e [ ] CU [ ] b,c,e [ ] S [ ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1900 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS

G-2' = [ ] b,c,e

ID # : D081102603

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPH 2  
5. LOCATION GOV  
6. DISCH 1  
7. TEST NO. TD55534

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e TD  
2. SUPPLIER: BETHLEHEM STEEL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ ] b,c,e [HN] b,c,e [SI] b,c,e [P] b,c,e [CR] b,c,e [MO] b,c,e [V] b,c,e  
[NI] b,c,e [AS] b,c,e [SB] b,c,e [SN] b,c,e [AL] b,c,e [CU] b,c,e [S] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS

1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A-CR-OS [ ] b,c,e

ID # : 0081102603

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LP# 2  
5. LOCATION GOV  
6. DISC# 2  
7. TEST NO. TD44514

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPESTALL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[C] b,c,e [MN] b,c,e [SI] b,c,e [P] b,c,e [CR] b,c,e [MO] b,c,e [V] b,c,e  
[NI] b,c,e [AS] b,c,e [SB] b,c,e [SN] b,c,e [AL] b,c,e [CU] b,c,e [S] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 {KSI} [ ] b,c,e  
2. 2160 (120%) {KSI} [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A-CR-OS [ ] b,c,e

ID # : D081102603

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPH 2  
5. LOCATION GOV  
6. DISC# 3  
7. TEST NO. TD11795

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e) TC  
2. SUPPLIER: UNITED STATES STEEL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) b,c,e  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. MEAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) G-2' = [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS

ID # : P081102603

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LP# 2  
5. LOCATION GOV  
6. DISC# 4  
7. TEST NO. TD35376

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e ) TD  
2. SUPPLIER: MIDVALE HEPPELSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ HO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-0P (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-0S (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP, METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ]  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ]  
4. RATIO A/A-CR-0S [ ] G-2' = [ ] b,c,e

ID # : 0081102603

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPH  
5. LOCATION 2 GOV  
6. DISC# S  
7. TEST NO. TD55517

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: BETHLEHEM STEEL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) [ ] b,c,e  
2. U.T.S. (KSI) [ ]  
3. ELONGATION [ ]  
4. R.A. [ ]  
5. FATT (DEG.F) [ ]  
6. R.T. IMPACT (FT.LB.) [ ]  
7. U.S. IMPACT TEMP. (DEG.F) [ ]  
8. U.S. IMPACT ENG. (FT.LB.) [ ]  
9. U.S. KIC (KSI\*SQRT(IN.)) [ ]

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS  
SPEED (RPM) STRESS

1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ]  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ]  
4. RATIO A/A-CR-OS [ ]  
G-2 = [ ] b,c,e

ID # : 0081102603

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK BI

2. UNIT SURRY #2

3. CUSTOMER: VEPCO

4. LP# 2

5. LOCATION GOV

6. DISCH 6

7. TEST NO. TD44500

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD

2. SUPPLIER: [ ] b,c,e MIDVALE HEPPESTALL

3. Y.S. (KSI) [ ] b,c,e

4. U.T.S. (KSI) [ ] b,c,e

5. ELONGATION [ ] b,c,e

6. R.A. [ ] b,c,e

7. FATT (DEG.F) [ ] b,c,e

8. R.T. IMPACT (FT.LB.) [ ] b,c,e

9. U.S. IMPACT TEMP. (DEG.F) [ ] b,c,e

10. U.S. IMPACT ENG. (FT.LB.) [ ] b,c,e

11. U.S. KIC (KSI\*SQRT(IN.)) [ ] b,c,e

C. MATERIAL PROPERTIES (RIK)

1. Y.S. (KSI) [ ] b,c,e

2. U.T.S. (KSI) [ ] b,c,e

3. ELONGATION [ ] b,c,e

4. R.A. [ ] b,c,e

5. FATT (DEG.F) [ ] b,c,e

6. R.T. IMPACT (FT.LB.) [ ] b,c,e

7. U.S. IMPACT TEMP. (DEG.F) [ ] b,c,e

8. U.S. IMPACT ENG. (FT.LB.) [ ] b,c,e

9. U.S. KIC (KSI\*SQRT(IN.)) [ ] b,c,e

D. CHEMISTRY

C [ ] b,c,e

MM [ ] b,c,e

SI [ ] b,c,e

P [ ] b,c,e

CR [ ] b,c,e

HO [ ] b,c,e

V [ ] b,c,e

NI [ ] b,c,e

AS [ ] b,c,e

SB [ ] b,c,e

SN [ ] b,c,e

AL [ ] b,c,e

CU [ ] b,c,e

S [ ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS

1. 1800 [ ] b,c,e

2. 2160 (120%) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e

2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e

2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e

3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e

4. RATIO A/A-CR-OS [ ] b,c,e

ID # : 0081102604

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPH 2  
5. LOCATION GEN  
6. DISCH 1  
7. TEST NO. TD55533

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e) TD  
2. SUPPLIER: BETHLEHEM STEEL  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[C] b,c,e [MN] b,c,e [SI] b,c,e [P] b,c,e [CR] b,c,e [NO] b,c,e [V] b,c,e  
[NI] b,c,e [AS] b,c,e [SB] b,c,e [SN] b,c,e [AL] b,c,e [CU] b,c,e [S] b,c,e

E. BORE STRESS

SPEED (RPH) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-0P (1800 RPH) (IN.) [ ] b,c,e  
2. A-CR-0S (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b,c,e  
4. RATIO A/A-CR-0S [ ] b,c,e



ID # : D081102604

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK BI  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPH 2  
5. LOCATION GEN  
6. DISCH 2  
7. TEST NO. TD35386

B. MATERIAL PROPERTIES (HUB)

1. TYPE (MIN. Y.S. [ ] b,c,e TD  
2. SUPPLIER: MIDVALE HEPPESTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[ C ] b,c,e [ MN ] b,c,e [ SI ] b,c,e [ P ] b,c,e [ CR ] b,c,e [ MO ] b,c,e [ V ] b,c,e  
[ NI ] b,c,e [ AS ] b,c,e [ SB ] b,c,e [ SN ] b,c,e [ AL ] b,c,e [ CU ] b,c,e [ S ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-0P (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-0S (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-0S [ ] b,c,e

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

- 1. BUILDING BLOCK 81
- 2. UNIT SURRY #2
- 3. CUSTOMER: VEPCO
- 4. LP# 2
- 5. LOCATION GEN
- 6. DISC# 3
- 7. TEST NO. TD44492 NEW REPLACEMENT DISC

B. MATERIAL PROPERTIES (HUB)

- 1. TYPE [ ] TC
- (MIN. Y.S. [ ] (KSI))
- 2. SUPPLIER: UNITED STATES STEEL
- 3. Y.S. (KSI)
- 4. U.T.S. (KSI)
- 5. ELONGATION
- 6. R.A.
- 7. FATT (DEG.F)
- 8. R.T. (IMPACT (FT.LB.))
- 9. U.S. IMPACT TEMP. (DEG.F)
- 10. U.S. IMPACT ENG (FT.LB.)
- 11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

- 1. Y.S. (KSI)
- 2. U.T.S. (KSI)
- 3. ELONGATION
- 4. R.A.
- 5. FATT (DEG.F)
- 6. R.T. IMPACT (FT.LB.)
- 7. U.S. IMPACT TEMP. (DEG.F)
- 8. U.S. IMPACT ENG. (FT.LB.)
- 9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

- [ ]<sup>C</sup> ] b,c,e [ ]<sup>MN</sup> ] b,c,e
- [ ]<sup>NI</sup> ] b,c,e [ ]<sup>AS</sup> ] b,c,e
- [ ]<sup>SI</sup> ] b,c,e [ ]<sup>P</sup> ] b,c,e [ ]<sup>CR</sup> ] b,c,e [ ]<sup>MO</sup> ] b,c,e [ ]<sup>V</sup> ] b,c,e
- [ ]<sup>SB</sup> ] b,c,e [ ]<sup>SN</sup> ] b,c,e [ ]<sup>AL</sup> ] b,c,e [ ]<sup>CU</sup> ] b,c,e [ ]<sup>S</sup> ] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS

- 1. 1800 (KSI) [ ] b,c,e
- 2. 2160 (120%) (KSI) [ ]

F. CRACK DATA

- 1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e
- 2. A-CR-OS (OVERSPEED) (IN.) [ ]

G. SERVICE DATA

- 1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e
- 2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e
- 3. MAX EXPECTED KEYWAY CRACK SIZE [ ] b,c,e
- 4. RATIO A/A-CR-OS [ ]

G-2' = [ ] b,c,e

ID # : D081102604

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81  
2. UNIT SURRY #2  
3. CUSTOMER: VEPCO  
4. LPU 2  
5. LOCATION GEN  
6. DISC# 4  
7. TEST NO. TD35377

B. MATERIAL PROPERTIES (HUB)

1. TYPE [ ] b,c,e TD  
(MIN. Y.S. [ ] (KSI))  
2. SUPPLIER: MIDVALE HEPPENSTALL b,c,e  
3. Y.S. (KSI)  
4. U.T.S. (KSI)  
5. ELONGATION  
6. R.A.  
7. FATT (DEG.F)  
8. R.T. IMPACT (FT.LB.)  
9. U.S. IMPACT TEMP. (DEG.F)  
10. U.S. IMPACT ENG. (FT.LB.)  
11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI) b,c,e  
2. U.T.S. (KSI)  
3. ELONGATION  
4. R.A.  
5. FATT (DEG.F)  
6. R.T. IMPACT (FT.LB.)  
7. U.S. IMPACT TEMP. (DEG.F)  
8. U.S. IMPACT ENG. (FT.LB.)  
9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

[C] b,c,e [MN] b,c,e [SI] b,c,e [P] b,c,e [CR] b,c,e [MO] b,c,e [V] b,c,e  
[NI] b,c,e [AS] b,c,e [SR] b,c,e [SN] b,c,e [Al] b,c,e [CU] b,c,e [S] b,c,e

E. BORE STRESS

SPEED (RPM) STRESS  
1. 1800 (KSI) [ ] b,c,e  
2. 2160 (120%) (KSI) [ ] b,c,e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b,c,e  
2. A-CR-OS (OVERSPEED) (IN.) [ ] b,c,e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b,c,e  
2. ESTIMATED MAX DA/DT (IN/HR) [ ] b,c,e  
3. MAX EXPECTED KEYWAY CRACK SIZE (IN)  
4. RATIO A/A-CR-OS [ ] b,c,e

ID # : D081102604

LP TURBINE DISC INFORMATION

A. UNIT IDENTIFICATION

1. BUILDING BLOCK 81

2. UNIT SURRY #2

3. CUSTOMER: VEPCO

4. LPH 2

5. LOCATION GEN

6. DISC# 5

7. TEST NO. T035359

B. MATERIAL PROPERTIES (HUB)

1. TYPE D, c, e TD

2. SUPPLIER: MIDVALE HEPPENSTALL

3. Y.S. (KSI)

4. U.T.S. (KSI)

5. ELONGATION

6. R.A.

7. FATT (DEG.F)

8. R.T. IMPACT (FT.LB.)

9. U.S. IMPACT TEMP. (DEG.F)

10. U.S. IMPACT ENG. (FT.LB.)

11. U.S. KIC (KSI\*SQRT(IN.))

C. MATERIAL PROPERTIES (RIM)

1. Y.S. (KSI)

2. U.T.S. (KSI)

3. ELONGATION

4. R.A.

5. FATT (DEG.F)

6. R.T. IMPACT (FT.LB.)

7. U.S. IMPACT TEMP. (DEG.F)

8. U.S. IMPACT ENG. (FT.LB.)

9. U.S. KIC (KSI\*SQRT(IN.))

D. CHEMISTRY

C ] b, c, e    MN ] b, c, e    SI ] b, c, e    P ] b, c, e    CR ] b, c, e    MO ] b, c, e    V ] b, c, e

NI ] b, c, e    AS ] b, c, e    SB ] b, c, e    SN ] b, c, e    AL ] b, c, e    CU ] b, c, e    S ] b, c, e

E. BORE STRESS

SPEED (RPH) STRESS

1. 1800 (KSI) [ ] b, c, e

2. 2160 (120%) (KSI) [ ] b, c, e

F. CRACK DATA

1. A-CR-OP (1800 RPM) (IN.) [ ] b, c, e

2. A-CR-OS (OVERSPEED) (IN.) [ ] b, c, e

G. SERVICE DATA

1. OPER. TEMP. METAL TEMP. HUB (DEG.F) [ ] b, c, e

2. ESTIMATED MAX DA/DT (IN/HR) [ ] b, c, e

3. MAX EXPECTED KEYWAY CRACK SIZE (IN) [ ] b, c, e

4. RATIO A/A-CR-OS [ ] b, c, e



Westinghouse  
Electric Corporation

Power Generation  
Group

Steam Turbine Division

Letter Station Box 2175  
Philadelphia, Pennsylvania 19103

March 14, 1980

Darrell G. Eisenhut, Acting Director  
Division of Operating Reactors  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Eisenhut,

Your letters of February 25, 1980, to licensees with operating Westinghouse steam turbines requested certain site specific and generic information relative to turbine disc integrity. You urged in your letter that the licensees address the generic questions and coordinate the responses through an owners' group.

Licensees with nuclear power plants and Westinghouse steam turbines have formed a Turbine Disc Integrity Task Force, with Mr. Wayne Stiede of Commonwealth Edison Company selected as Chairman. Westinghouse has been working with this Task Force to generate responses to your generic questions.

At a Task Force meeting on March 12 and 13, 1980, the utilities present prepared and approved consensus responses to each of your generic questions. The Task Force further directed Westinghouse Electric Corporation to transmit these responses directly to you. The purpose of this letter is to transmit that information to you.

It is our understanding that Mr. Wayne Stiede, Chairman of the Task Force, will also confirm to you by separate letter, the Task Force's decision to have Westinghouse transmit these responses direct to you. We also understand that each utility, in their specific response to your letter to that utility, will discuss the extent to which they agree with these consensus responses.

If you have any questions on these, please contact me.

Sincerely,

*J. M. Schmerling per PSZ*  
J. M. Schmerling,  
Disc Integrity Program Manager

cc: W. J. Ross, Operating Reactors Branch  
USNRC, Washington DC 20555

Duped of 8003210426 6 pp.

GENERIC QUESTIONS - TO BE COMPLETED IN 20 DAYS

- I. Describe what quality control and inspection procedures are used for the disc bore and keyways.

ANSWER:

Chemical analyses are made from each heat of steel. During manufacture mechanical tests are made from the disc bore region. These include tensile and Charpy v-notch impact tests. Each disc bore region is subject to ultrasonic and magnetic particle inspections. On later units, the disc keyways are inspected after machining, using liquid penetrant techniques.

For in-service inspection two ultrasonic techniques, namely the tangential aim and radial aim scans, have been developed to detect and determine the depth of disc keyway and bore cracks. The in-service ultrasonic inspection does not require unshrinking discs from the rotor.

The tangential aim scan is used to locate cracks. The technique requires sound energy to be coupled and directed tangentially towards the keyway from a precalculated position on the hub. This is accomplished by means of a compound angled plexiglass wedge. The wedge is machined to provide a contoured face which makes complete contact with the disc hub, while aiming the sound energy at the disc bore/keyway. Crack indications occurring in the vicinity of the keyway apex and at the bore will reflect the sound energy. The tangential aim scan is performed both in the clockwise and counterclockwise directions to permit locating crack indications with respect to the keyway apex.

A radial aim technique is used to confirm cracks located by the tangential aim scan. The technique is also used to determine the crack depth by comparing the time lapsed in obtaining a ultrasonic reflection from the crack with the time to obtain a reflection from the keyway or bore.

- II. Provide details of the Westinghouse repair/replacement procedures for faulty discs.

ANSWER:

When cracks are found by an inservice inspection their severity is evaluated by means of an allowable life calculation. The allowable life is relatable to the time required for the crack to grow to critical size for fracture. Based upon the results of this calculation, the following actions may be taken:

- A. If the affected disc has a calculated allowable life greater than zero a reinspection of the disc is recommended at approximately one-half of the allowable life.

B. If the affected disc has an allowable life less than or close to zero, one or more of the following may be employed:

1. The affected disc is removed by "machining", and is replaced with a collar and pressure drop baffle.
2. Upstream keyways may be drilled oversize to remove cracks after the downstream disc is removed.
3. The affected disc may be replaced. This requires unstacking and restacking several discs on the rotor.

III.A. What immediate and long term actions are being taken by Westinghouse to minimize future stress corrosion problems with turbine discs?

ANSWER:

The following short range actions are being taken:

1. Those discs which have been observed to be most susceptible to stress corrosion cracking are being redesigned. The new designs will achieve lower bore stresses and utilize lower yield strength material. These changes will increase the margin against stress corrosion cracking.
2. Designs that will eliminate spacers and bore keyways are being explored.

The following long range solutions are being examined:

1. Bore Heating - Ways and means to keep the disc keyways dry are being explored.
2. Sealing - Ways of sealing the hub and bore from the steam environment are being studied.
3. Coatings - Another method of sealing is to apply a protective coating. We are continuing to experiment with different coatings, but extensive work is still required to develop processes for their application and to demonstrate their benefits.
4. Partial Integral Rotors - Since one piece forgings cannot be procured at this time, we are exploring the possibilities of partial integral rotors where the first two or three discs are made a part of the shaft. Only the last few discs will have to be shrunk on.
5. Integral Rotors - A welded rotor design is being evaluated as a means to produce an integral rotor.

III.B. What actions are being recommended to utilities to minimize stress corrosion cracking?

ANSWER:

Westinghouse has developed recommended limits for steam purity. When these limits are exceeded corrective actions should be taken.

IV.A. Identify the impurities known to cause cracking in the low pressure turbine, and their sources.

ANSWER:

The main chemical species known to cause or contribute to stress corrosion of steam turbine materials in steam environments are:

Sodium hydroxide  
Sodium chloride  
Sodium sulfate  
Oxygen

The sources of these impurities are under study.

IV.B. Discuss the relationship between steam generator chemistry and steam chemistry relative to the introduction of corrosive impurities into the turbine, including phosphate, AVT, and BWR chemistry.

ANSWER:

Analyses of material within LP disc cracks from PWR units shows the presence of Na, K, Ca, Si, Cl, OH, and C together with Fe, Co, V, Al and Ni ions.

In PWR units with recirculating steam generators, the total carry-over of non-volatile dissolved solids, such as NaOH and NaCl depends mainly on the mechanical carry-over. However, where ammonia is used for pH control such as with the all volatile water treatment, carry-over of anions may increase due to a formation of volatile ammonium salts.

In the PWR units with once-through steam generators, the high pressure turbine steam purity is similar to the feedwater purity. Most impurities entering the steam generator are carried directly into the turbine.

The published information on BWR systems indicates the concentration of oxygen in the steam is in the range of 10 to 30 ppm. With respect to other elements, however, it is likely that high steam purity standards will be maintained for control of radioactivity. To achieve this, BWR reactor water is generally double demineralized.

IV.C. Discuss the mechanism of deposition of these impurities that can lead to their concentration in certain areas of keyways and bores.



ANSWER:

The impurities from steam can get into shrunk-on disc bores and keyways in several possible ways:

1. After deposition in the steam path during operation, corrodents can wash into disc keyways during layup due to moisture condensation.
  2. In the wet steam regions, the moisture can dry on hot metal surfaces.
  3. As long as the disc retains its shrink fit we are not aware of any mechanism which can concentrate impurities on the bore.
- V. What role does the refluxing action in the steam separation portion of the steam generator have on scrubbing corrosive impurities from the steam?

ANSWER:

Two modes of transport of corrosive impurities from the steam generator to the turbine are mechanical entrainment and volatility.

The non-volatile chemical species are transported by mechanical entrainment which is normally expected to be small.

The steam generator scrubbing equipment has minimum effectiveness in preventing the transport of volatile impurities, such as ammonium chloride, to the turbine. The concentration of volatile impurities in turbine steam is determined by their concentration in the steam generator bulk water and their specific volatility coefficient which differs with each species.

- VL To what extent can the buildup of corrosive impurities in the LP turbine be alleviated? What would be the effects of the following action:
- A. Pumping moisture separator condensate to condenser?

ANSWER:

Pumping moisture separator condensate to the condenser would be beneficial in units with condensate polishing. In units without condensate polishing, there will be no effect.

- B. Periodically moving (the) point of condensation to prevent localized buildup of corrosive impurities.

ANSWER:

Conceptually, dilution of contaminants by increased levels of moisture and their subsequent transport to the condensate system could substantially reduce the buildup of impurities. However, the effectiveness of this technique and the means for successful control of the local environment of particular turbine parts must be developed and experimentally verified.

Several of the less volatile active corrodants, such as sodium chloride and sodium sulphate precipitate as concentrated liquid solutions in a region slightly above the equilibrium saturated vapor line of pure water. This region occurs within a given stage during normal operation and migrates toward the exhaust as load reduces. Control of the zone can be affected by changes in steam and moisture separator reheater (MSR) outlet temperature.

- VII Describe fabrication and heat treatment sequence for discs, including thermal exposure during shrinking operation.

ANSWER:

The typical sequence for producing a disc forging includes the following operations, not all of which are necessarily applicable to any given disc.

A. Melting and casting of Ingot. Most discs manufactured since the early 1960's are made using basic electric furnace steel which is vacuum stream degassed or vacuum-carbon-deoxidized.

B. Forging The ingot is heated to forging temperature, block forged and cut into 2 to 4 pieces from which the individual disc forgings are made.

C. Preliminary Heat Treatment This step consists of austenitizing and tempering the forging to promote structure uniformity, grain refinement, and good machineability.

D. Preliminary Machining The forging is machined to the disc contour.

E. Preliminary Ultrasonic Inspection Typically the supplier makes a partial ultrasonic inspection of the forging to assure that the quality warrants continued manufacturing effort.

F. Heat Treatment for Properties The forging is austenitized and tempered at appropriate temperatures to achieve the desired mechanical properties. Cooling from the austenitizing treatment is achieved by water quenching. After tempering the forging is cooled in the furnace at a controlled rate.

G. Mechanical Properties Tensile properties are tested to determine if the required strength level has been achieved. Since about 1960, Charpy v-notch impact tests are made on each forging.

H. NDE Inspection The forgings are rough machined to the Westinghouse drawing requirements and an ultrasonic inspection of the flat surfaces of the hub, web, and rim of the disc is performed.

I. Stress Relief This treatment is required when a significant amount of metal is machined off of the forging after it has been heat treated for properties. The stress relief treatment is 50-100° F below the tempering temperature. Cooling is accomplished by a controlled furnace cool.

J. Mechanical Properties When a stress relief is used, the mechanical properties are tested after the stress relief treatment. (Reference Step G)

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM I  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Survey #1* SYSTEM: *L.P. Turbine* PROCEDURE: *NDT - MT - 724* DATE: *May 3, 1978*

ITEM, COMPONENT INSPECTED: *"B" Rotor* MAINTENANCE REPORT NO:

MATERIAL: *Alloy Steel* SURFACE CONDITION: *Sandblasted & clean*

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT BATCH NO:

MANUFACTURER: *Magnaflex* TYPE: *20A*

MAGNETIZATION:  COIL *2000* AMPERE TURNS  PROD. SPACING AMPS  CIRCULAR AMPERES  YOKE CURRENT:  AC  DC  RND

CONTINUOUS  RESIDUAL

TEST PERFORMED BY: *D. Spooner, A. Homel, D. Dickens* LEVEL OF CERTIFICATION: *II, I, I*

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Blading Row L-4 Gov. End</i>	<i>Blade 104-105 has crack in shroud, one crack in shroud between</i>		<input checked="" type="checkbox"/>
	<i>Blades 134, 166, 2, &amp; 32 have cracks in the root on the</i>		<input checked="" type="checkbox"/>
	<i>exit side.</i>		
	<i>Blades 165 has crack in root</i>		<input checked="" type="checkbox"/>
	<i>entry side</i>		
	<i>Blade 121 is cracked thru</i>		<input checked="" type="checkbox"/>
	<i>from entry side to exit side in</i>		
	<i>the root</i>		
	<i>Stegle between blades 165-166</i>		<input checked="" type="checkbox"/>
	<i>cracked on entry side</i>		

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: *David L. Spooner* DATE: *May 3, 1978* 23

VISUAL INSPECTION REPORT  
NDT - VT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

1 *Survey # 1* SYSTEM: 2 *L.P. Turbine* PROCEDURE: 3 *NDT - VT - 15.1* DATE: 4 *May 4, 1978*

ITEM, COMPONENT INSPECTED: 5 *"B" Rotor* MAINTENANCE REPORT NO: 6

VISUAL AIDS: 7 *Flashlight & mirror*

PERFORMED BY: 8 *A. Hamel & D. Dickens* LEVEL OF CERTIFICATION: 9 *II, II*

INDICATIONS NOTED:  YES  NO 10

INDICATIONS

11 AREA INSPECTED	12 DESCRIPTION OF INDICATIONS (SIZE, TYPE, AND LOCATION)	13 ACCEPT	14 REJECT
<i>Row L-3 Gen. End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>Row L-4 Gen. End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS. 15

AUTHORIZED INSPECTOR: 16 *David L. Groome level II* DATE: 17 *May 4, 1978*

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>Unit #1</i>	SYSTEM: <i>L.P. Turbine</i>	PROCEDURE: <i>NDT-MT-12.1</i>	DATE: <i>May 4, 1978</i>
ITEM, COMPONENT INSPECTED: <i>"B" Rotor</i>			MAINTENANCE REPORT NO: <i>NA</i>
MATERIAL: <i>alloy steel</i>	SURFACE CONDITION: <i>Sandblasted &amp; clean</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO:
MANUFACTURER: <i>Magnaflex</i>	TYPE: <i>20A</i>		
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> RWDC	
<input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		<input type="checkbox"/> PROD _____ SPACING _____ AMPS <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> YOKE _____	

TEST PERFORMED BY: *A. Hamel & D. Dickens* LEVEL OF CERTIFICATION: *I, I*

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>L-3 Gen End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>L-4 Gen End</i>	<i>Blade 66 cracked in root entry side</i>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: *David L. Groome level II* DATE: *May*

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 *Survey #1* SYSTEM: 2 *L.P. Turbine* PROCEDURE: 3 *NDT-MT-12.1* DATE: 4 *May 4, 1978*

ITEM, COMPONENT INSPECTED: 5 *'B' Rotor* MAINTENANCE REPORT NO.: 6 *NA*

MATERIAL: 7 *Alloy Steel* SURFACE CONDITION: 8 *Sandblasted & clean*

TYPE OF PARTICLES: 9  WET  DRY  VISIBLE  FLUORESCENT BATCH NO.: 10

MANUFACTURER: 11 *Magnaflux* TYPE: 12 *20A*

MAGNETIZATION: 13  COIL *2400* AMPERE TURNS CURRENT: 14  AC  DC  HWDC  
 CONTINUOUS  PROD. \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  
 YOKE \_\_\_\_\_

TEST PERFORMED BY: 15 *D. Spooner, D. Fowler, A. Hamel, D. Dickens* LEVEL OF CERTIFICATION: 16 *II, I, I, I*

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Row L-0 Gen. End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	
<i>Row L-1 Gov. End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	
<i>Row L-0 Gov. End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22 *David L. Boone* DATE: 23 *May 4, 1978*

### MAGNETIC PARTICLE INSPECTION REPORT NDT-MT-FORM 1 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1	SYSTEM: 2	PROCEDURE: 3	DATE: 4
<i>Sunny #1</i>	<i>L. P. Turbine</i>	<i>NDT-MT-12.1</i>	<i>May 5, 1978</i>
ITEM, COMPONENT INSPECTED: 5		MAINTENANCE REPORT NO: 6	
<i>"B" Rotor</i>		<i>NA</i>	
MATERIAL: 7	SURFACE CONDITION: 8		
<i>alloy steel</i>	<i>Sandblasted &amp; clean</i>		
TYPE OF PARTICLES: 9		BATCH NO: 10	
<input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			
MANUFACTURER: 11	TYPE: 12		
<i>Magneflux</i>	<i>20A</i>		
MAGNETIZATION: 13	CURRENT: 14		
<input checked="" type="checkbox"/> COIL <i>2200</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL	<input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> WDC		

TEST PERFORMED BY: 15	LEVEL OF CERTIFICATION: 16
<i>A. Hamel, D. Dickens</i>	<i>I, I</i>

AREA INSPECTED 17	SIZE AND LOCATION OF INDICATIONS 18	ACCEPT 19	REJECT 20
<i>Row L-2 <del>End</del> Gen Smooth</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22	DATE: 23
<i>David L. Groover</i>	<i>May 5, 1978</i>

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Unit #1* 1 SYSTEM: *L.P. Turbine* 2 PROCEDURE: *NDT-MT-12.1* 3 DATE: *May 5, 1978* 4

ITEM, COMPONENT INSPECTED: *"B" Rotor* 5 MAINTENANCE REPORT NO: *NA* 6

MATERIAL: *alloy steel* 7 SURFACE CONDITION: *sandblasted & clean* 8

TYPE OF PARTICLES: 9 BATCH NO: 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: *magna flux* 11 TYPE: *20A* 12

MAGNETIZATION: 13 CURRENT: 14  
 COIL *1600* AMPERE TURNS  
 PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_  
 AC  
 DC  
 HWDC

TEST PERFORMED BY: *A. Hamel, D. Deckers* 15 LEVEL OF CERTIFICATION: *I, I* 16

AREA INSPECTED 17	SIZE AND LOCATION OF INDICATIONS 18	ACCEPT 19	REJECT 20
<i>Row L-5 Gurr and</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>Row L-6 Gurr and</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: *David L. Brown* 22 DATE: *May 5, 1978* 23



MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Survey #1* 1 SYSTEM: *L.P. Turbine* 2 PROCEDURE: *NDT - MT - 12.1* 3 DATE: *May 5, 1978* 4

ITEM, COMPONENT INSPECTED: *"R" Rotor* 5 MAINTENANCE REPORT NO: *NA* 6

MATERIAL: *alloy steel* 7 SURFACE CONDITION: *sandblasted & clean* 8

TYPE OF PARTICLES: 9 BATCH NO: 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: *magnaflex* 11 TYPE: *20A* 12

MAGNETIZATION: 13 CURRENT: 14  
 COIL *2700* AMPERE TURNS \*  
 PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_  
 AC  
 DC  
 WDC

TEST PERFORMED BY: *A. Hamel, D. Duchs* 15 LEVEL OF CERTIFICATION: *I, F* 16

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	18	19 ACCEPT	20 REJECT
<i>Row L-7 Gen End</i>	<i>NRI</i>		<input checked="" type="checkbox"/>	
<i>Row L-8 Gen End</i>	<i>NRI</i>		<input checked="" type="checkbox"/>	
<i>Row L-7 Cow End</i>	<i>NRI</i>		<input checked="" type="checkbox"/>	
<i>Row L-8 Cow End</i>	<i>NRI</i>		<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 21  
*\* Rows L-7 & L-8 shot together due to limited space*

AUTHORIZED INSPECTOR: *David L. Joone* 22 DATE: *May 5, 1978* 23

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 *Geny #1* SYSTEM: 2 *L.P. Turbine* PROCEDURE: 3 *NDT-MT-2.1* DATE: 4 *May 6, 1978*

ITEM, COMPONENT INSPECTED: 5 *B\* Rotor* MAINTENANCE REPORT NO: 6 *N/A*

MATERIAL: 7 *alloy steel* SURFACE CONDITION: 8 *sandblasted & clean*

TYPE OF PARTICLES: 9 BATCH NO: 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: 11 *magnaflex* TYPE: 12 *20 A*

MAGNETIZATION: 13 CURRENT: 14  
 COIL *2400* AMPERE TURNS  
 PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_  
 AC  
 DC  
 WDC

TEST PERFORMED BY: 15 *D. Fowler, S. Zimmerman, T. Boggs* LEVEL OF CERTIFICATION: 16 *F, A, A*

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Row L-1 Geny End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22 *David L. Moore* DATE: 23 *May 6, 1978*

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Summary #1* SYSTEM: *h. P. Turbine* PROCEDURE: *NDT - MT - 12.1* DATE: *May 6, 1978*

ITEM, COMPONENT INSPECTED: *"B" Rotor* MAINTENANCE REPORT NO: *NA*

MATERIAL: *alloy steel* SURFACE CONDITION: *sand blasted & clean*

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT BATCH NO:

MANUFACTURER: *magnum flux* TYPE: *20A*

MAGNETIZATION:  COIL *200* AMPERE TURNS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  CIRCULAR \_\_\_\_\_ AMPERES  YOKE \_\_\_\_\_  
 CONTINUOUS  RESIDUAL  AC  DC  WDC

TEST PERFORMED BY: *D. Fowler, S. Zimmerman, T. Rogers* LEVEL OF CERTIFICATION: *I, A, A*

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Row L-2 Gen End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: \_\_\_\_\_

AUTHORIZED INSPECTOR: *David L. Moore* DATE: *May 6, 1978*  
PAGE 1 OF 1

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>Survey # 1</i>	SYSTEM: <i>L.P. Turbine</i>	PROCEDURE: <i>NDT - MT - 12.1</i>	DATE: <i>May 6, 1978</i>
ITEM, COMPONENT INSPECTED: <i>B" Rotor</i>	MAINTENANCE REPORT NO: <i>NA</i>		
MATERIAL: <i>alloy steel</i>	SURFACE CONDITION: <i>sandblasted &amp; clean</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT	BATCH NO: _____		
MANUFACTURER: <i>magnaflex</i>	TYPE: <i>20A</i>		
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <i>1600</i> AMPERE TURNS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL	CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> RWD		

TEST PERFORMED BY: <i>D. Fowler, S. Zimmerman, T. Boyers</i>	LEVEL OF CERTIFICATION: <i>F, A, A.</i>
--	---

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Row L- 6 Gen End</i>	<i>NRF</i>	<input checked="" type="checkbox"/>	
<i>Row L- 5 Gen End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: <i>David L. Brown</i>	DATE: <i>May 6, 1978</i>
---	--------------------------

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Unit #1* SYSTEM: *L.P. Turbine* PROCEDURE: *NOT-MT-12.1* DATE: *May 9, 1978*

ITEM COMPONENT INSPECTED: *Steeple where blades were removed B-Rotor* MAINTENANCE REPORT NO: *WA*

MATERIAL: *alloy steel* SURFACE CONDITION: *glass bead blasted & clean*

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT BATCH NO:

MANUFACTURER: *magnaflex* TYPE: *20A*

MAGNETIZATION:  COIL *2000* AMPERE TURNS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  CIRCULAR \_\_\_\_\_ AMPERES  YOKE \_\_\_\_\_ CURRENT:  AC  DC  WDC

TEST PERFORMED BY: *A. Friel, D. Fowler, S. Zimmerman, T. Bayers* LEVEL OF CERTIFICATION: *I, I, A, A*

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Row L-4 Gov. End</i>	<i>3 small cracks in the platform where blades 144 (3/16" long), 77 (1/8" long) and 195 (7/16" long) were removed</i>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: *David L. Swanson* DATE: *May 9, 1978*

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>Sunny #1</i>	SYSTEM: <i>L.P. Turbine</i>	PROCEDURE: <i>NDT-MT-12.1</i>	DATE: <i>May 9, 1978</i>
ITEM, COMPONENT INSPECTED: <i>Steeple where blades were removed "B" Rotor</i>			MAINTENANCE REPORT NO: <i>NA</i>
MATERIAL: <i>Alloy Steel</i>	SURFACE CONDITION: <i>glass bead Blasted &amp; Clean</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO:
MANUFACTURER: <i>Magnaflux</i>	TYPE: <i>20A</i>		
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS	CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> RWDC		
<input checked="" type="checkbox"/> CONTINUOUS	<input type="checkbox"/> PROD _____ SPACING _____ AMPS		
<input type="checkbox"/> RESIDUAL	<input type="checkbox"/> CIRCULAR _____ AMPERES		
<input type="checkbox"/> YOKE _____			

TEST PERFORMED BY: <i>A. Hamel, D. Dickens, A. Friel, S. Zimmerman, Boyers</i>	LEVEL OF CERTIFICATION: <i>I, I, I, A, A</i>
--	--

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>L-4 Row Gen. End.</i>	<i>Crack indication in platform where the following blades were</i>		<input checked="" type="checkbox"/>
	<i>2, 4, 5, 6, 8, 10, 12, 26, 27, 33, 35, 42, 43, 44,</i>		
	<i>45, 49, 50, 51, 52, 53, 54, 55, 58, 59, 61, 63, 65</i>		
	<i>66, 67, 68, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 83</i>		
	<i>84, 86, 90, 91, 93, 94, 95, 99, 100, 105, 108, 109</i>		
	<i>110, 111, 112, 113, 114, 115, 118, 119, 120, 122, 123</i>		
	<i>126, 127, 133, 134, 138, 142, 143, 144, 145</i>		
	<i>146, 147, 148, 149, 150, 151, 152, 153, 154, 155</i>		
	<i>156, 157, 158, 159, 160, 161, 162, 163, 164, 165</i>		
	<i>166, 169, 171, 173, 175, 176, 177, 178, 179, 180, 181</i>		
	<i>182, 183, 184, 185, 186, 188, 190, 191, 193, 193, 194, 195</i>		
	<i>196, 197, 198, 199, 200, 201, 202, 203, 204, 205, 206, 207</i>		

DISPOSITION OF REJECTED INDICATIONS: *210, 214, 217, 220, 221, 224, 225*

*Note: 28 of these indications were very light and could possibly be buffed out.*

AUTHORIZED INSPECTOR: <i>David L. Jooner MT Level II</i>	DATE: <i>May 9, 1978</i>
PAGE 1 OF 1	

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: **SURRY** 1 SYSTEM: **L.P. TURBINE** 2 PROCEDURE: **NDT - MT - 12.1** 3 DATE: **May 11, 1978** 4

ITEM, COMPONENT INSPECTED: **"B" ROTOR** 5 MAINTENANCE REPORT NO: 6

MATERIAL: **Alloy STEEL** 7 SURFACE CONDITION: **SAND BLASTED & CLEAN** 8

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT 9 BATCH NO: 10

MANUFACTURER: **MAGNA FLUX** 11 TYPE: **20 A** 12

MAGNETIZATION:  COIL **1000** AMPERE TURNS 13 CURRENT: 14

CONTINUOUS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  AC

RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  DC

YOKE \_\_\_\_\_  RWDC

TEST PERFORMED BY: **Dickens** 15 LEVEL OF CERTIFICATION: **I** 16

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
ROW L-4 GOV END "B" ROTOR	BLADE #2 ch. 1/2" long in top of root extending to end of root 1/8" ck in center of root on end of root		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: **David L. Johnson** 22 DATE: **May 11, 1978** 23  
**MT Level II**

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: Surry 1 SYSTEM: TURBINE 2 PROCEDURE: NDT-MT-12.1 3 DATE: May 10, 1978 4

ITEM, COMPONENT INSPECTED: Unit 1 #2 LP L-4 GEN END BLADES 5 MAINTENANCE REPORT NO: SI 804200 909 6

MATERIAL: Alloy steel 7 SURFACE CONDITION: sand blasted + clean 8

TYPE OF PARTICLES: 9 BATCH NO: 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: Magnaflux 11 TYPE: Z012 12

MAGNETIZATION: 13 CURRENT: 14  
 COIL 1600 AMPERE TURNS  
 PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_  
 AC  DC  HWDC

TEST PERFORMED BY: Jelover/Boyer 15 LEVEL OF CERTIFICATION: I & A 16

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
Blade Roots of removed blades	#66 & #94 Cracked		✓

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: David L. Joone 22 DATE: May 10, 1978 23  
MT Level 4



885.80

NDT

LIQUID PENETRANT INSPECTION REPORT  
NDT - PT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Surray #1* SYSTEM: *L.P. Turbine* PROCEDURE: *NDT-PT-13.1* DATE: *May 10, 1978*

ITEM, COMPONENT INSPECTED: *Undershroud welds "B" Rotor* MAINTENANCE REPORT NO.: *NA*

MATERIAL: *3/8 welds on Alloy Steel* SURFACE CONDITION: *Sand blasted & clean*

MANUFACTURER	TYPE	BATCH NO.	TYPE OF PENETRANT:
CLEANER: <i>NA</i>	<i>NA</i>	<i>NA</i>	<input checked="" type="checkbox"/> WATER SOLUBLE
PENETRANT: <i>Slimwin</i>	<i>HM-3</i>	<i>16E316H</i>	<input checked="" type="checkbox"/> FLUORESCENT
EMULSIFIER: <i>NA</i>	<i>NA</i>	<i>NA</i>	<input type="checkbox"/> VISIBLE RED DYE
REMOVER: <i>NA</i>	<i>Water</i>	<i>NA</i>	<input type="checkbox"/> SOLVENT REMOVABLE
DEVELOPER: <i>Slimwin</i>	<i>D-100</i>	<i>P659</i>	<input type="checkbox"/> POST EMULSIFIABLE

PENETRANT APPLICATION:  DIPPING  SPRAYING  BRUSHING PENETRANT DWELL TIME: *15* MIN. TEMP: *75* OF EMULSIFIER DWELL TIME: *NA* MIN.

REMOVAL TECHNIQUE FOR EXCESS PENETRANT:  FLOWING WATER  WIPED SOLVENT  WIPED WATER  DIP CLEANING DRYING TIME: *30* MIN. TEMP: *75* OF

DEVELOPER APPLICATION:  DIPPING  SPRAYING  BRUSHING DEVELOPING TIME: *7-30* MIN. TEMP: *75* OF

TEST PERFORMED BY: *D. Dickens, T. Gibson, D. Fowler, A. Friel, S. Zimmerman, T. Boyers, A. Hamel* LEVEL OF CERTIFICATION: *I, II, A, II, I, A*

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Row L-1 Gov. End</i>	<i>weld on exit side of blades 3, 4, 6, 7, 11, 13, 15, 16, 17, 46, 47, 49, 51, 152, 156, 157, 158, 159, 160, 161, 163, 164, 165, 166, 169, 170, 171, 172, 173, 175, 176, 177, 178, 179 broke loose from the shroud.</i>		<input checked="" type="checkbox"/>
<i>Row L-3 Gov. End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	
<i>Row L-3 Gov. End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: \_\_\_\_\_

AUTHORIZED INSPECTOR: *Continued on page 2* DATE: \_\_\_\_\_

**LIQUID PENETRANT INSPECTION REPORT  
 NDT - PT - FORM 1 (SUPPLEMENT)  
 VIRGINIA ELECTRIC AND POWER COMPANY**

STATION: Unit #1 SYSTEM: L.P. Turbine PROCEDURE: NDT - PT - 13.1 DATE: May 10, 1978

ITEM, COMPONENT INSPECTED: Undershroud welds "B" Rotor MAINTENANCE REPORT NO: NA

7 AREA INSPECTED	8 SIZE AND LOCATION OF INDICATIONS	9 ACCEPT	10 REJECT
<u>Row L-1 Gen. End</u>	<u>welds on exit side of blades</u>		<input checked="" type="checkbox"/>
	<u>1, 2, 3, 4, 6, 7, 8, 13, 14, 18, 20</u>		
	<u>26, 27, 28, 35, 36, 48, 51, 52,</u>		
	<u>53, 54, 55, 56, 61, 63, 64, 67, 68</u>		
	<u>72, 76, 88, 91, 101, 102, 112, 116</u>		
	<u>117, 118, 119, 142, 144, 146, 148</u>		
	<u>152, 161, 164, 168, 173, 176, 178</u>		
	<u>179 broke loose from shroud</u>		
	<u>Blades 141 &amp; 156 weld</u>		
	<u>Broke loose from blade</u>		

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: Daniel L. Swore PT level II DATE: May 10, 1978

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: *Unit # 1* SYSTEM: *L.P. Turbine* PROCEDURE: *NDT-MT-12.1* DATE: *May 6, 1978*

ITEM, COMPONENT INSPECTED: *B" Rotor* MAINTENANCE REPORT NO: *NA*

MATERIAL: *alloy steel* SURFACE CONDITION: *sandblasted & clean*

TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT BATCH NO:

MANUFACTURER: *magnaflex* TYPE: *20A*

MAGNETIZATION:  COIL *1600* AMPERE TURNS CURRENT:  AC  DC  RWDC  
 CONTINUOUS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  
 YOKE \_\_\_\_\_

TEST PERFORMED BY: *D. Fowler, S. Zimmerman, T. Royer* LEVEL OF CERTIFICATION: *F, A, A.*

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Row L-6 Gen End</i>	<i>NRF</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<i>Row L-5 Gen End</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: *David L. Brown* DATE: *May 6, 1978*

NDT

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 **SURRY** SYSTEM: 2 **TURBINE** PROCEDURE: 3 **NDT-MT-12.1** DATE: 4 **15 May 1978**

ITEM, COMPONENT INSPECTED: 5 **UNIT #1 B ROTOR GOVERNOR END STAPLES** MAINTENANCE REPORT NO: 6 **N/A**

MATERIAL: 7 **MetAl Alloy** SURFACE CONDITION: 8 **Clean / Glass bead blasted**

TYPE OF PARTICLES: 9  WET  DRY  VISIBLE  FLUORESCENT BATCH NO: 10 **N/A**

MANUFACTURER: 11 **MAGNAFLEX** TYPE: 12 **20-11**

MAGNETIZATION: 13  COIL **2000** AMPERE TURNS CURRENT: 14  AC  DC  HWDC  
 PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_

TEST PERFORMED BY: 15 **Armand P. Hame** LEVEL OF CERTIFICATION: 16 **I**

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<b>Steeple # 165</b>	<b>CRACK ON FACE AT EXIT Side which extends back into the back LAND APPROX. 5/16"</b>		<input checked="" type="checkbox"/>
<b>X</b>			

DISPOSITION OF REJECTED INDICATIONS: 21 **Referred to MARK ROWE @ engineer for Resolution Armand Hame**

AUTHORIZED INSPECTOR: 22 **David L. Swann** DATE: 23 **May 15, 1978**

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: SURRY 1 SYSTEM: TURBINE 2 PROCEDURE: NDT-MT-12.1 3 DATE: 17 MAY 1978 4

ITEM, COMPONENT INSPECTED: UNIT #1 B ROTOR GEN END L-4 STAGE STEEPLES 5 MAINTENANCE REPORT NO: N/A 6

MATERIAL: METAL ALLOY 7 SURFACE CONDITION: CLEAN / GLASS BEAD BLASTED 8

TYPE OF PARTICLES: 9 BATCH NO: N/A 10  
 WET  DRY  VISIBLE  FLUORESCENT

MANUFACTURER: MAGNIFLUX 11 TYPE: 20-A 12

MAGNETIZATION: 13 CURRENT: 14  
 COIL 2000 AMPERE TURNS  
 PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 CONTINUOUS  CIRCULAR \_\_\_\_\_ AMPERES  
 RESIDUAL  YOKE \_\_\_\_\_  
 AC  
 DC  
 HWDC

TEST PERFORMED BY: DAVID L. SPOONEN / DAVID FOWLER 15 LEVEL OF CERTIFICATION: II / I 16

17	18	19	20
AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
STEEPLE # 85	PITTING IN LINE		X
STEEPLE # 82	SMEARED METAL		X
STEEPLE # 65	PITTING IN LINE		X
STEEPLE # 185	CRACK IN STEEPLE NEAR RADIUS		X
STEEPLE # 188	CRACK IN STEEPLE NEAR RADIUS		X
STEEPLE # 191	CRACK IN STEEPLE NEAR RADIUS		X
STEEPLE # 176	CRACK IN STEEPLE NEAR RADIUS		X
STEEPLE # 179	CRACK IN DISC INLET SIDE		X
STEEPLE # 102	SMEARED METAL		X
<del>_____</del>			
<del>_____</del>			
<del>_____</del>			

DISPOSITION OF REJECTED INDICATIONS: \_\_\_\_\_ 21

AUTHORIZED INSPECTOR: David L. Spoonen 22 DATE: May 17, 1978 23

### MAGNETIC PARTICLE INSPECTION REPORT

NDT - MT - FORM 1

VIRGINIA ELECTRIC AND POWER COMPANY

STATION: SURY	SYSTEM: Turbine	PROCEDURE: NDT-MT-12-4	DATE: 17 May 1978
ITEM, COMPONENT INSPECTED: UNIT #1 "B" ROTOR GAV END L-3 STAGE STROOPES		MAINTENANCE REPORT NO: N/A	
MATERIAL: Metal Alloy	SURFACE CONDITION: Clean / Glass bead blasted		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: N/A
MANUFACTURER: Magna Flux	TYPE: 20-A		
MAGNETIZATION: <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		<input type="checkbox"/> COIL _____ AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input type="checkbox"/> CIRCULAR _____ AMPERES <input checked="" type="checkbox"/> YOKE <u>Pickel Probe</u>	CURRENT: <input type="checkbox"/> AC <input checked="" type="checkbox"/> DC <input type="checkbox"/> HWDC

TEST PERFORMED BY: David L. Spooner / David Fowler      LEVEL OF CERTIFICATION: II / I

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
Stroop # 72	CRACK ON INLET SIDE CORNER SIDE		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: David L. Spooner      DATE: May 17, 1978

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <b>SURRY</b>	SYSTEM: 2 <b>Turbine</b>	PROCEDURE: 3 <b>NDT-MT-12.4</b>	DATE: 4 <b>17 MAY 1978</b>
ITEM, COMPONENT INSPECTED: 5 <b>UNIT #1 "B" ROTOR General L-3 Sprock stepples</b>			MAINTENANCE REPORT NO: 6 <b>N/A</b>
MATERIAL: 7 <b>Metal Alloy</b>	SURFACE CONDITION: 8 <b>Clean / glass bead blasted</b>		
TYPE OF PARTICLES: 9 <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: 10 <b>N/A</b>
MANUFACTURER: 11 <b>MAGNUL / IN</b>		TYPE: 12 <b>20-A</b>	
MAGNETIZATION: 13 <input type="checkbox"/> COIL _____ AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: 14 <input type="checkbox"/> AC <input checked="" type="checkbox"/> DC <input type="checkbox"/> HWDC	
TEST PERFORMED BY: 15 <b>David L. Spooner / David Fowler</b>		LEVEL OF CERTIFICATION: 16 <b>II / I</b>	

AREA INSPECTED 17	SIZE AND LOCATION OF INDICATIONS 18	ACCEPT 19	REJECT 20
Steeple # 182	CRACK IN STEEPLE NEAR RADIUS		<input checked="" type="checkbox"/>
Steeple # 183	CRACK IN STEEPLE NEAR RADIUS		<input checked="" type="checkbox"/>
Steeple # 185	CRACK IN STEEPLE NEAR RADIUS		<input checked="" type="checkbox"/>
Steeple # 138	CRACK IN STEEPLE NEAR RADIUS		<input checked="" type="checkbox"/>
Steeple # 140	CRACK IN STEEPLE NEAR RADIUS		<input checked="" type="checkbox"/>
Steeple # 143	CRACK IN STEEPLE NEAR RADIUS		<input checked="" type="checkbox"/>
Steeple # 73	CRACK IN STEEPLE NEAR RADIUS		<input checked="" type="checkbox"/>
<del>_____</del>			
<del>_____</del>			
<del>_____</del>			
<del>_____</del>			
<del>_____</del>			

DISPOSITION OF REJECTED INDICATIONS: 21

~~\_\_\_\_\_~~

~~\_\_\_\_\_~~

~~\_\_\_\_\_~~

AUTHORIZED INSPECTOR: 22 <b>David L. Spooner</b>	DATE: 23 <b>May 17, 1978</b>
---	---------------------------------

MAGNETIC PARTICLE INSPECTION REPORT

NDT - MT - FORM 1

VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <i>SURRY</i>	SYSTEM: 2 <i>Turbine</i>	PROCEDURE: 3 <i>NDT-MT-12.1</i>	DATE: 4 <i>17 May 1978</i>
----------------------------	-----------------------------	------------------------------------	-------------------------------

ITEM, COMPONENT INSPECTED: 5 <i>Unit #1 "B" Rotor Gen end L-4 Stage Steeples</i>	MAINTENANCE REPORT NO: 6 <i>N/A</i>
---	--

MATERIAL: 7 <i>Metal Alloy</i>	SURFACE CONDITION: 8 <i>Clean / Glass bead blasted</i>
-----------------------------------	---

TYPE OF PARTICLES: 9 <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT	BATCH NO: 10 <i>N/A</i>
---	----------------------------

MANUFACTURER: 11 <i>MAGNIFLUX</i>	TYPE: 12 <i>20-A</i>
--------------------------------------	-------------------------

MAGNETIZATION: 13	CURRENT: 14
<input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS	<input type="checkbox"/> AC
<input type="checkbox"/> PROD _____ SPACING _____ AMPS	<input type="checkbox"/> DC
<input checked="" type="checkbox"/> CONTINUOUS	<input checked="" type="checkbox"/> HWDC
<input type="checkbox"/> RESIDUAL	
<input type="checkbox"/> CIRCULAR _____ AMPERES	
<input type="checkbox"/> YOKE _____	

TEST PERFORMED BY: 15 <i>David L. Spooner / David Fowler</i>	LEVEL OF CERTIFICATION: 16 <i>II / I</i>
---	---

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<i>Steeple #66</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #65</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #62</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #57</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #54</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #53</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #51</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #48</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #47</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #46 (new)</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #45</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #44</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>
<i>Steeple #42 (new)</i>	<i>CRACK IN STEEPLE NEAR RADIUS</i>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21  
*N/A*

AUTHORIZED INSPECTOR: 22 <i>Continued on page 2</i>	DATE: 23 <i>17 May 1978</i>
--	--------------------------------




MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1 (SUPPLEMENT)  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <b>SURRY</b>	SYSTEM: <b>Turbine</b>	PROCEDURE: <b>NDT - MT - 12.1</b>	DATE: <b>17 May 1978</b>
ITEM, COMPONENT INSPECTED: <b>UNIT #1 8" Rotor Gen end L-4 Stage Steeples</b>		MAINTENANCE REPORT NO: <b>N/A</b>	

7 AREA INSPECTED	8 SIZE AND LOCATION OF INDICATIONS	9 ACCEPT	10 REJECT
Steeple # 35	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 33	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 31 (New)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 21 (New)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 13 (New)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 10	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 8	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 6	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 5	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 15	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 2	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 227	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 230	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 225 (New)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 224	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 221	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 220	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 219	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 214	CRACK IN STEEPLE NEAR RADIUS		X
Steeple # 213	CRACK IN STEEPLE NEAR RADIUS		X

DISPOSITION OF REJECTED INDICATIONS:



AUTHORIZED INSPECTOR: <b>Continued on page 3</b>	DATE: <b>17 May 1978</b>
--	--------------------------

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1 (SUPPLEMENT)  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <b>SURRY</b>	SYSTEM: 2 <b>TURBINE</b>	PROCEDURE: 3 <b>NDT - MT - 12.1</b>	DATE: 4 <b>17 MAY 1978</b>
ITEM, COMPONENT INSPECTED: 5 <b>Unit #1 "B" Rotor Gen end L-4 Stage Steeples</b>			MAINTENANCE REPORT NO: 6 <b>N/A</b>

7 AREA INSPECTED	8 SIZE AND LOCATION OF INDICATIONS	9 ACCEPT	10 REJECT
Steeple #210 (new)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #164 (new)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #162	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #163	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #171	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #197	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #201	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #111	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #112	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #123 (old+new)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #154	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #70	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #72	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #73	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #76 (new)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #83 (new)	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #89	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #99	CRACK IN STEEPLE NEAR RADIUS		X
Steeple #105	CRACK IN STEEPLE NEAR RADIUS		X

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: <i>David L. Groome</i>	DATE: 12 <b>May 17, 1978</b>
---	---------------------------------

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <i>Sunny</i>	SYSTEM: 2 <i>Turbine</i>	PROCEDURE: 3 <i>NDT-MT-12.1</i>	DATE: 4 <i>May 20, 78</i>
ITEM, COMPONENT INSPECTED: 5 <i>Unit 1 "B" Rotor Gen End L-3 Stage</i>		MAINTENANCE REPORT NO: 6 <i>N/A</i>	
MATERIAL: 7 <i>Metal alloy</i>	SURFACE CONDITION: 8 <i>Clean / Glass bead blasted</i>		
TYPE OF PARTICLES: 9 <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT		BATCH NO: 10 <i>N/A</i>	
MANUFACTURER: 11 <i>Magnaflux</i>		TYPE: 12 <i>20-A</i>	
MAGNETIZATION: 13 <input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> YOKE _____		CURRENT: 14 <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	

TEST PERFORMED BY: 15 <i>David E. Dickson / Armand P. Harrel</i>	LEVEL OF CERTIFICATION: 16 <i>I &amp; I</i>
---	--

AREA INSPECTED 17	SIZE AND LOCATION OF INDICATIONS 18	ACCEPT 19	REJECT 20
<i>Steeple # 3</i>	<i>2 ind. on concave side (outlet)</i>		
<i>Steeple # 6</i>	<i>1 ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>Steeple # 10</i>	<i>1 ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>Steeple # 11</i>	<i>1 ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>Steeple # 12</i>	<i>1 ind. on convex side 1/8" long</i>		<input checked="" type="checkbox"/>
<i>Steeple # 23</i>	<i>1 ind. on concave side 1/8" long</i>		<input checked="" type="checkbox"/>
<i>Steeple # 27</i>	<i>1 ind. on convex side 1/2" long (center)</i>		<input checked="" type="checkbox"/>
<i>Steeple # 35</i>	<i>1 ind. on concave inlet 3/4" long</i>		<input checked="" type="checkbox"/>
<i>Steeple # 48</i>	<i>1 ind. on concave inlet 1/2" long</i>		<input checked="" type="checkbox"/>
<i>Steeple # 57</i>	<i>1 ind. on concave (full length)</i>		<input checked="" type="checkbox"/>
<i>Steeple # 57</i>	<i>1 ind. on convex side 1/8" center</i>		<input checked="" type="checkbox"/>
<i>Steeple # 59</i>	<i>(2) ind. 1/8" each on concave (center)</i>		<input checked="" type="checkbox"/>
<i>* Note: all these indications are in first land groove</i>			<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22 <i>Continued on page 2</i>	DATE: 23
--	----------

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <i>Suzer</i>	SYSTEM: 2 <i>Turbines</i>	PROCEDURE: 3 NDT - MT - 12.1	DATE: 4 <i>May 20, 78</i>
ITEM, COMPONENT INSPECTED: 5 <i>Unit 1 "B" Rotor Gen. End L-3 Stage</i>			MAINTENANCE REPORT NO: 6 <i>N/A</i>
MATERIAL: 7 <i>Metal alloy</i>	SURFACE CONDITION: 8 <i>Clean / Glass bead blasted</i>		
TYPE OF PARTICLES: 9 <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: 10 <i>N/A</i>
MANUFACTURER: 11 <i>Magnafly</i>		TYPE: 12 <i>20-A</i>	
MAGNETIZATION: 13 <input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: 14 <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	

TEST PERFORMED BY: 15 <i>David L. Dickson / Armand P. Hamel</i>	LEVEL OF CERTIFICATION: 16 <i>I &amp; I</i>
--	--

AREA INSPECTED 17	SIZE AND LOCATION OF INDICATIONS 18	ACCEPT 19	REJECT 20
<i>Steeple # 63</i>	<i>(1) 3/4" ind. on concave side (center)</i>		<input checked="" type="checkbox"/>
<i>" # 63</i>	<i>(3) 1/8" ind on convex side</i>		<input checked="" type="checkbox"/>
<i>" # 65</i>	<i>(1) 1/4" ind. on convex outlet</i>		<input checked="" type="checkbox"/>
<i>" # 69</i>	<i>(1) 3/16" ind. on convex side</i>		<input checked="" type="checkbox"/>
<i>" # 69</i>	<i>(1) 1/4" ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>" # 70</i>	<i>(1) 3/16" ind. on convex side</i>		<input checked="" type="checkbox"/>
<i>" # 72</i>	<i>(1) 1/8" ind. on convex center</i>		<input checked="" type="checkbox"/>
<i>" # 75</i>	<i>(1) 1/8" ind on convex center</i>		<input checked="" type="checkbox"/>
<i>" # 76</i>	<i>(1) ind. on convex outlet</i>		<input checked="" type="checkbox"/>
<i>" # 78</i>	<i>(1) 1/4" ind on concave inlet</i>		<input checked="" type="checkbox"/>
<i>" # 79</i>	<i>(1) 3/4" ind on concave outlet</i>		<input checked="" type="checkbox"/>
<i>" # 84</i>	<i>(1) 1/8" ind. on convex side</i>		<input checked="" type="checkbox"/>

\* Note: All indications in hand grease next to shaft.

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22 <i>Continued on page 3</i>	DATE: 23
--	----------

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <u>Unit 1</u>	SYSTEM: <u>Turbine</u>	PROCEDURE: <u>NDT-MT-12.1</u>	DATE: <u>May 20, 78</u>
ITEM, COMPONENT INSPECTED: <u>Unit 1 "B" Rotor Gen. End L-3 Stage</u>			MAINTENANCE REPORT NO: <u>N/A</u>
MATERIAL: <u>Metal alloy</u>	SURFACE CONDITION: <u>Clean / Glass bead blasted</u>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: <u>N/A</u>
MANUFACTURER: <u>Magnaflex</u>	TYPE: <u>20-A</u>		
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <u>2000</u> AMPERE TURNS		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	
<input checked="" type="checkbox"/> CONTINUOUS		<input type="checkbox"/> PROD _____ SPACING _____ AMPS	
<input type="checkbox"/> RESIDUAL		<input type="checkbox"/> CIRCULAR _____ AMPERES	
<input type="checkbox"/> YOKE _____			

TEST PERFORMED BY: <u>David S. Dickson / Armand P. Hamel</u>	LEVEL OF CERTIFICATION: <u>I &amp; I</u>
--	--

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
Steepl. # 79	(1) ind. on concave outlet		X
" 86	(1) ind. on concave outlet		X
" 88	(1) 1/8" ind. on concave outlet		X
" 89	(1) 1/4" ind. on concave outlet		X
" 90	(1) ind. on concave side		X
" 95	(1) ind. on concave side		X
" 96	(1) ind. on concave side		X
" 95	(1) ind. on concave side		X
" 102	(1) 3/4" ind. on concave side		X
" 104	(2) 3/8" & (1) 1/2" ind. on concave side		X
" 105	(1) ind. on concave side		X
" 106	(1) ind. on concave & concave side		X
" 99	(1) ind. on concave side		X

DISPOSITION OF REJECTED INDICATIONS: 21

\* Note: All indications are in land groove near shaft.

AUTHORIZED INSPECTOR: <u>Continued on page 4</u>	DATE: _____
--	-------------

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 <i>Larry</i>	SYSTEM: 2 <i>Turbine</i>	PROCEDURE: 3 NDT - MT - <i>12.1</i>	DATE: 4 <i>May 20, 78</i>
ITEM, COMPONENT INSPECTED: 5 <i>Unit 1 "B" Rotor Gen. End L-3 Stage</i>			MAINTENANCE REPORT NO: 6 <i>N/A</i>
MATERIAL: 7 <i>Metal alloy</i>		SURFACE CONDITION: 8 <i>Clean / Glass bead blasted</i>	
TYPE OF PARTICLES: 9 <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: 10 <i>N/A</i>
MANUFACTURER: 11 <i>Magnalloy</i>		TYPE: 12 <i>20-A</i>	
MAGNETIZATION: 13 <input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS <input type="checkbox"/> PROD. _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: 14 <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	

TEST PERFORMED BY: 15 <i>David L. DeBono / Donald P. Hamel</i>	LEVEL OF CERTIFICATION: 16 <i>I &amp; I</i>
---	--

AREA INSPECTED: 17	SIZE AND LOCATION OF INDICATIONS: 18	ACCEPT: 19	REJECT: 20
<i>Steeple # 110</i>	<i>(1) ind. on concave side</i>		X
<i>" 114</i>	<i>(1) ind. on convex center</i>		X
<i>" 115</i>	<i>(1) ind. on convex side</i>		X
<i>" 121</i>	<i>(1) ind. on concave side.</i>		X
<i>" 125</i>	<i>(1) ind. on concave side.</i>		X
<i>" 126</i>	<i>(1) ind. on concave &amp; convex</i>		X
<i>" 127</i>	<i>(1) 1/8" ind. on convex side</i>		X
<i>" 129</i>	<i>(1) ind. on concave side.</i>		X
<i>" 133</i>	<i>(1) ind. on convex side</i>		X
<i>" 135</i>	<i>(1) ind. on convex side.</i>		X
<i>" 139</i>	<i>(1) ind. on convex side</i>		X
<i>" 139</i>	<i>(1) ind. on concave side</i>		X

*\* Note - all indications are in land groove near shaft*

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22 <i>Continued on page 5</i>	DATE: 23
--	----------

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>2024</i>	SYSTEM: <i>Turbine</i>	PROCEDURE: <i>NDT - MT - 12.1</i>	DATE: <i>May 20, 78</i>
ITEM, COMPONENT INSPECTED: <i>Unit 1 "B" Rotor Gen. End L-3 Stage</i>			MAINTENANCE REPORT NO: <i>N/A</i>
MATERIAL: <i>Metal Alloy</i>	SURFACE CONDITION: <i>clean / slow hand blasted</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: <i>N/A</i>
MANUFACTURER: <i>Magnaflex</i>		TYPE: <i>20-A</i>	
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	
TEST PERFORMED BY:		LEVEL OF CERTIFICATION:	

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Steeple # 145</i>	<i>(1) ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>" # 150</i>	<i>(1) ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>" 154</i>	<i>(1) ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>" 155</i>	<i>(1) ind on concave &amp; convex side</i>		<input checked="" type="checkbox"/>
<i>" 157</i>	<i>(1) ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>" 159</i>	<i>(1) ind on concave side</i>		<input checked="" type="checkbox"/>
<i>" 161</i>	<i>(1) ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>" 163</i>	<i>(1) ind. on convex &amp; concave side</i>		<input checked="" type="checkbox"/>
<i>" 167</i>	<i>(1) 1/2" ind. on convex (center)</i>		<input checked="" type="checkbox"/>
<i>" 167</i>	<i>(1) ind. on concave (center)</i>		<input checked="" type="checkbox"/>
<i>" 173</i>	<i>(1) ind. 1" long on convex inlet</i>		<input checked="" type="checkbox"/>
<i>" 174</i>	<i>(1) ind. 1/2" long on convex (center)</i>		<input checked="" type="checkbox"/>
<i>* Note: All indications are in land grease near shaft</i>			

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: \_\_\_\_\_ DATE: \_\_\_\_\_

*Continued on page 6*

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <u>Surry</u>	SYSTEM: <u>Turbine</u>	PROCEDURE: <u>NOT-MT-12.1</u>	DATE: <u>May 20, 78</u>
ITEM, COMPONENT INSPECTED: <u>Unit 1 "B" Rotor Gen. End L-3 Stage</u>			MAINTENANCE REPORT NO: <u>N/A</u>
MATERIAL: <u>Metal alloy</u>	SURFACE CONDITION: <u>Clean / Glass head blasted</u>		BATCH NO: <u>N/A</u>
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			
MANUFACTURER: <u>Magnaglyx</u>		TYPE: <u>20-A</u>	
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <u>2000</u> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input type="checkbox"/> CONTINUOUS <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> RESIDUAL <input type="checkbox"/> YOKE _____		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	

TEST PERFORMED BY: <u>David L. DeBano / Raymond P. Hamel</u>	LEVEL OF CERTIFICATION: <u>II &amp; I</u>
--	---

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<u>Steeple # 177</u>	<u>(1) ind. 1 1/2" long on convex outlet</u>		X
<u>" 179</u>	<u>(1) ind - full length of concave side</u>		X
<u>" 181</u>	<u>(1) ind. 1/8" on convex center</u>		X
<u>" 182</u>	<u>(1) ind. on concave outlet.</u>		X
<u>" 184</u>	<u>(1) ind. on concave side.</u>		X
<u>" 185</u>	<u>(1) ind. on concave side.</u>		X
<u>" 187</u>	<u>(1) ind. on concave side.</u>		X
<u>" 190</u>	<u>(1) ind. on concave side.</u>		X
<u>" 191</u>	<u>(1) ind. on concave side.</u>		X
<u>" 196</u>	<u>(1) ind. on concave &amp; convex</u>		X
<u>" 199</u>	<u>(1) ind. on concave &amp; convex side</u>		X
<u>" 201</u>	<u>(1) ind. on concave side</u>		X

\* Note: All indications are all in land groove floor shaft

DISPOSITION OF REJECTED INDICATIONS:	21

AUTHORIZED INSPECTOR: <u>Continued on page 7</u>	DATE: _____
--	-------------



MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>Gen</i>	SYSTEM: <i>Turbine</i>	PROCEDURE: <i>NDT - MT - 12.1</i>	DATE: <i>May 20, 78</i>
ITEM, COMPONENT INSPECTED: <i>Unit 1 "B" Rotor - Gen. End L-3 Stage</i>			MAINTENANCE REPORT NO: <i>N/A</i>
MATERIAL: <i>Metal alloy</i>	SURFACE CONDITION: <i>Clean / Glass bead blasted</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO: <i>N/A</i>
MANUFACTURER: <i>Magnaflex</i>	TYPE: <i>20-A</i>		
MAGNETIZATION: <input checked="" type="checkbox"/> COIL <i>2000</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> RESIDUAL <input type="checkbox"/> YOKE _____		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC	

TEST PERFORMED BY: <i>David L. DeBour / Donald P. Hurrell</i>	LEVEL OF CERTIFICATION: <i>I &amp; I</i>
---	--

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>Steeple # 205</i>	<i>(1) ind. 1/8" long on Convey Inlet</i>		<input checked="" type="checkbox"/>
<i>209</i>	<i>(1) ind. on concave side</i>		<input checked="" type="checkbox"/>
<i>217</i>	<i>(1) 1/2" ind. on concave outlet</i>		<input checked="" type="checkbox"/>
<i>218</i>	<i>(1) 1/2" ind. on concave Outlet</i>		<input checked="" type="checkbox"/>
<i>216</i>	<i>(1) 2" ind. on concave (center)</i>		<input checked="" type="checkbox"/>
<i>220</i>	<i>(1) ind. on concave outlet</i>		<input checked="" type="checkbox"/>
<i>225</i>	<i>(1) 1 1/4" ind. on convey Inlet</i>		<input checked="" type="checkbox"/>
<i>225</i>	<i>(1) 1/4" ind. on concave Outlet</i>		<input checked="" type="checkbox"/>
<i>226</i>	<i>(1) ind. on concave Outlet</i>		<input checked="" type="checkbox"/>
<i>Steeple # 192</i>	<i>(1) ind. 1/2" convey Outlet - Top of steeple chipped - ind. underneath</i>		<input checked="" type="checkbox"/>

\*Note: All indications except 192, are in landgroove upon shaft

DISPOSITION OF REJECTED INDICATIONS: \_\_\_\_\_

AUTHORIZED INSPECTOR: <i>End of report David L. Gooner MT level II</i>	DATE: <i>May 20, 1978</i>
PAGE <i>7</i> OF <i>7</i>	

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>SURRY</i>	SYSTEM: <i>TURBINE</i>	PROCEDURE: <i>NDT - MT - 12.1</i>	DATE: <i>20 MAY 1978</i>
ITEM, COMPONENT INSPECTED: <i>Unit #1 B rotor Gov. End 1-3 Stage STEEPLES</i>			MAINTENANCE REPORT NO: <i>51804200907</i>
MATERIAL: <i>metal alloy</i>	SURFACE CONDITION: <i>CLEAN / Glass bead blasted</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT		BATCH NO: <i>N/A</i>	
MANUFACTURER: <i>Magnaflex</i>	TYPE: <i>20 A</i>		
MAGNETIZATION:	CURRENT:		
<input checked="" type="checkbox"/> CONTINUOUS	<input type="checkbox"/> COIL <i>2000</i> AMPERE TURNS	<input type="checkbox"/> AC	
<input type="checkbox"/> RESIDUAL	<input type="checkbox"/> PROD _____ SPACING _____ AMPS	<input type="checkbox"/> DC	
	<input type="checkbox"/> CIRCULAR _____ AMPERES	<input checked="" type="checkbox"/> RWDC	
	<input type="checkbox"/> YOKE _____		

TEST PERFORMED BY: <i>Spooner &amp; Fowler</i>	LEVEL OF CERTIFICATION: <i>II &amp; I</i>
---	--

17	18	19	20
AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>STEEPLES # 80</i>	<i>indication - CONCAVE SIDE</i>		<input checked="" type="checkbox"/>
<i># 129</i>	<i>INDICATION - CONCAVE SIDE</i>		<input checked="" type="checkbox"/>
<i># 136</i>	<i>INDICATION - CONCAVE SIDE</i>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: <i>David L. Spooner</i>	DATE: <i>May 20, 1978</i>
--	------------------------------

MAGNETIC PARTICLE INSPECTION REPORT  
 MPT-101 - FORM 1  
 FEDERAL ELECTRIC AND POWER COMPANY

STATION: Section 1 UNIT: LPTURBINE PROCESSED: 12-1 DATE: 5-8-80

ITEM OR WEIGHT INSPECTED: LP #1 Roots L-4 General Inlet Blading INSPECTED BY: S/RODZ

GATEWAY: Allen Corbin 570 SURFACE CONDITION: Smooth / Clean / Smooth

TYPE OF PARTICLES: 56002

MANUFACTURER: MAGNETIC FLUX TYPE: 200

INSPECTION METHOD:  VISUAL  MAGNETIC  PERMANENT

TEST CONDITIONS:  1000 AMPERE TURNS  5000 AMPERE TURNS  10000 AMPERE TURNS

CONTINUOUS  CIRCULAR  RECTANGULAR  OTHER

INITIAL  RECHECK

LEVEL OF IDENTIFICATION:  I  II  III

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	REPORT	REMARKS
L-4 TURBINE ROOTS AND STAIRS	BLADE ROOT # 29 INLET - LOWER	✓	
	BLADE ROOT # 32 OUTLET - LOWER	✓	
	OUTLET STAIRS BETWEEN # 37 & 40 - LOWER	✓	
	INLET STAIRS BETWEEN # 31 & 35 - LOWER	✓	
	INLET STAIRS BETWEEN # 27 & 30 - LOWER	✓	
	OUTLET STAIRS BETWEEN # 31 & 35 - LOWER	✓	
	OUTLET STAIRS BETWEEN # 127 & 130 - LOWER	✓	
	OUTLET STAIRS BETWEEN # 141 & 145 - LOWER	✓	
	OUTLET STAIRS BETWEEN # 150 & 151 - LOWER	✓	
	OUTLET STAIRS BETWEEN # 154 & 155 - LOWER	✓	
	OUTLET STAIRS BETWEEN # 164 & 165 - LOWER	✓	
	OUTLET STAIRS BETWEEN # 170 & 170 - LOWER	✓	

REPRODUCTION OF REJECTED INDICATIONS

*Curtis Necessary*

APPROVED INSPECTOR: [Signature] DATE: 5-8-80

MAGNETIC PARTICLE INSPECTION REPORT  
 (NPT-NI-FORM I (SUPPLEMENT))  
 VICTORIA ELECTRIC AND POWER CORP.

STATION: SUDDI 1 SYSTEM: L4 TURBINE PROCEDURE: NPT-NI-12.1 DATE: 3-8-80

ITEM, COMPONENT INSPECTED: L4 ROTOR L4 GENERATOR END BLADING MAINTENANCE REPORT NO: S1002210414

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
L4 BLADE ROOTS END			
STAPLES	OUTLET STAPLE BETWEEN #12-#13 - L4 ROTOR		X
	INLET STAPLE BETWEEN #212-#213 - L4 ROTOR		X
RHS AREA	NFI		X

DESCRIPTION OF REJECTED INDICATIONS:

*Curtis Messing*

APPROVED INSPECTOR: *William Lee* DATE: 3-8-80

**MAGNETIC PARTICLE INSPECTION REPORT**  
**MT-PT-FORM 1**  
**VIRGINIA ELECTRIC AND POWER COMPANY**

STATION: **Sorry I**     UNIT: **LP TURBINE**     PROCEDURE: **MT-PT-12.1**     DATE: **3-8-50**

ITEM COMPONENT INSPECTED: **LP #2 & #3 & #4 Row Governor Van Bearings**     PARTS DRAWING NO: **310221044**

MATERIAL: **ALLOY CARBON STEEL**     SURFACE CONDITION: **SAND BLASTED / OILED / SMOOTH**

TYPE OF PARTICLES:     BATCH NO:

FET     FAT     WHEEL     DISPERSED

MANUFACTURER: **MAGNA FLUX**     TYPE: **20A**

MAGNETIZATION:     COMMENTS:

CONTINUOUS      COIL      DC

PULSED      CIRCULAR      AC

TEST      TWT      TEST

TEST PERFORMED BY: **T. B. Smith B. Fong**     LEVEL OF CERTIFICATION: **II / II**

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
1-4 BLADE ROOTS AND STEEL INLET & OUTLET	<b>NR1</b>	<b>X</b>	
Rim area	<b>NR1</b>	<b>X</b>	

IDENTITY OF DETECTED INDICATIONS: **N/A**

*To: Curtis Messersmith  
11th floor     10 pages*

APPROVED BY INSPECTOR: **[Signature]**     DATE: **3-8-50**

10-6522

MAGNETIC PARTICLE INSPECTION REPORT

NP-INT-FORM 1

VERMONT ELECTRIC AND POWER COMPANY

STATION <b>Supply 1</b>	SYSTEM <b>LP TURBINE</b>	PROJECT NO. <b>NP-INT-12.1</b>	DATE <b>3-8-80</b>
ITEM COMPONENT INSPECTED <b>LP #1 Blade L-3 Generator End Blowing</b>		MANUFACTURER REPORT NO. <b>510221044</b>	
MATERIAL <b>ALLOY CARBON STEEL</b>		SURFACE CONDITION <b>5000 ALUSTAN</b>	
TYPE OF PARTICLES <input type="checkbox"/> DIRT <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLOUORESCENT		PARTICLE SIZE <b>36002</b>	
MANUFACTURER <b>MAGNA FLOX</b>		TYPE <b>20A</b>	
MAGNETIZATION <input checked="" type="checkbox"/> From 1500 AMPERE TURN		CURRENT <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> WIRE	
<input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> CIRCULAR <input type="checkbox"/> Yoke			

TEST PERFORMED BY <b>T. B. BOMBACH W. FONG</b>	LEVEL OF CERTIFICATION <b>1/SE</b>
---	---------------------------------------

AREA INSPECTED	SIZE AND LOCATION OF INDICATION	ACCEPT	REJECT
L-3 BLADE ROOTS AND STEPPLES			
	BLADE ROOT #11 INLET - LINING		X
	BLADE ROOT #4 INLET - LINING		X
	BLADE ROOT #16 INLET - LINING		X
	BLADE ROOT #100 INLET - LINING		X
	INLET STEPPLE BETWEEN #9 & #10 - LINING		X
	INLET STEPPLE BETWEEN #16 & #17 - LINING		X
	INLET STEPPLE BETWEEN #20 & #21 - LINING		X
	INLET STEPPLE BETWEEN #31 & #32 - LINING		X
	INLET STEPPLE BETWEEN #70 & #71 - LINING		X
	INLET STEPPLE BETWEEN #80 & #81 - LINING		X
	INLET STEPPLE BETWEEN #81 & #82 - LINING		X
	INLET STEPPLE BETWEEN #85 & #86 - LINING		X

DISPOSITION OF SELECTED INDICATIONS

*Curts necessary*

APPROVED INSPECTOR <i>[Signature]</i>	DATE <b>3-8-80</b>
--	-----------------------

**MAGNETIC PARTICLE INSPECTION REPORT**  
 (OY - AT - FORM 1 (SUPPLEMENT))  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <b>Supply 1</b>	SYSTEM: <b>LP TURBINE</b>	PROCEDURE: <b>MT - AT - 12.1</b>	DATE: <b>3-5-80</b>
ITEM COMPONENT INSPECTED: <b>LP #1 ROTOR L-3 Generator Building</b>		MAINTENANCE REPORT NO: <b>51022104W</b>	

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<b>L-3 BLADE ROOTS AND</b>			
<b>STEMS</b>	<b>INLET</b>		
	<b>STEMBLE BETWEEN #117 - #119 - 1/2" DIA</b>	<b>X</b>	
	<b>INLET</b>		
	<b>STEMBLE BETWEEN #130 - #131 - 1/2" DIA</b>	<b>X</b>	
	<b>INLET</b>		
	<b>STEMBLE BETWEEN #142 - #143 - 1/2" DIA</b>	<b>X</b>	
<b>Rim Area</b>	<b>NAL</b>	<b>X</b>	

DISPOSITION OF SUSPECTED INDICATIONS

*Accept Necessary*

INSPECTOR: <i>[Signature]</i>	DATE: <b>3-8-80</b>
----------------------------------	------------------------

MAGNETIC PARTICLE INSPECTION REPORT

MT-87-FORM 1

VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>SUNNY I</i>	SYSTEM: <i>LP TURBINE</i>	PROCEDURE: <i>MT-87-01</i>	DATE: <i>8-7-50</i>
----------------------------	------------------------------	-------------------------------	------------------------

ITEM COMPONENT INSPECTED: <i>LP #1 L-2 CONTROL VALVE</i>	MAINTENANCE REPORT NO: <i>5102210414</i>
---	---

MATERIAL: <i>SAE 5140 STEEL</i>	SURFACE CONDITION: <i>SAE BLASSED - 2500</i>
------------------------------------	---

TYPE OF PARTICLES: <input type="checkbox"/> DUST <input type="checkbox"/> DIRT <input type="checkbox"/> WIRE <input type="checkbox"/> FLAKES	WATER NO: <i>500000</i>
---	----------------------------

MANUFACTURER: <i>GENERAL</i>	TYPE: <i>301</i>
---------------------------------	---------------------

MAGNETIC Yoke	<input type="checkbox"/> LINE <i>200</i> <small>APPROX TURNS</small> <input type="checkbox"/> PICO <small>SPACING</small> <i>1/2" IN</i> <small>APPROX</small> <input type="checkbox"/> CIRCULAR <small>APPROX</small> <input type="checkbox"/> TEST	<input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> WET
---------------	---	---

TEST PERFORMED BY: <i>J. [unclear] / W. [unclear]</i>	LEVEL OF CERTIFICATION: <i>[unclear]</i>
--	---

AREA INSPECTED	DEFECTS AND LOCATION OF DEFECTS	ACCEPT	REJECT
<i>ROTS AND STEPPLES</i>	<i>1/2" LINEAR DEFECTS AT SECTIONS</i>		
	<i>1/4" RADIAL DEFECTS (IN AREA OF BRAKE PLATE)</i>		<input checked="" type="checkbox"/>
<i>BRK PCD</i>	<i>1/8"</i>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED PROPERTY:

*Curio Necessary*

AUTHORIZED INSPECTOR: <i>William [unclear]</i>	DATE: <i>8-7-50</i>
---	------------------------



MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 **SURRY 1** SYSTEM: 2 **TURBINE** PROCEDURE: 3 **NOT - MT - 12.1** DATE: 4 **3-14-80**

ITEM, COMPONENT INSPECTED: 5 **ROTOR END** MAINTENANCE REPORT NO: 6 **S1002210414**

MATERIAL: 7 **ALLOY CARBON STEEL** SURFACE CONDITION: 8 **GLASS BEAD BLASTED**

TYPE OF PARTICLES: 9 **WET**  **DRY**  **VISIBLE**  **FLUORESCENT**  BATCH NO: 10 **56002**

MANUFACTURER: 11 **MAGNAFLUX** TYPE: 12 **20 A**

MAGNETIZATION: 13  **COIL 2400** AMPERE TURNS  **PROD** SPACING  **CIRCULAR** AMPERES  **YOKE**  **AC**  **DC**  **HWOC**

*NOTED MAR 1 1980*

TEST PERFORMED BY: 15 **T. GIBSON / G. HERRERA / P. COLBY / W. FONG** LEVEL OF CERTIFICATION: 16 **A / I / II / III**

17	18	19	20
AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<b>STEEPLE # 2</b>	<b>3/16" LINEAR CONVEX SIDE SEE ATTACHED DRAWING # 43</b>		<input checked="" type="checkbox"/>
<b># 7</b>	<b>1/16" LINEAR CONVEX SIDE SEE ATTACHED DRAWING # 45</b>		<input checked="" type="checkbox"/>
<b># 10</b>	<b>CONCAVE SIDE SEE ATTACHED 5 LINEAR INDICATION 1/4" LINEAR DRAWING # 42</b>		<input checked="" type="checkbox"/>
<b># 12</b>	<b>1/8" LINEAR CONVEX SIDE SEE ATTACHED DRAWING # 41</b>		<input checked="" type="checkbox"/>
<b># 14</b>	<b>CONVEX SIDE SEE ATTACHED 4 LINEAR 1/4" &amp; SMALLER DRAWING # 39</b>		<input checked="" type="checkbox"/>
<b># 15</b>	<b>PREVIOUSLY EXAMINED CONCAVE SIDE SEE ATTACHED LINEAR 1/2 LENGTH OF STEEPLE DRAWING # 38</b>		<input checked="" type="checkbox"/>
<b># 22</b>	<b>CONVEX SIDE &amp; CONCAVE SIDE SEE ATTACHED 1/8" LINEAR &amp; THREE 1/16" LINEAR DRAWING # 37 &amp; # 40</b>		<input checked="" type="checkbox"/>
<b># 59</b>	<b>CONCAVE SIDE SEE ATTACHED 3 LINEAR 1/8", 1/16" &amp; 1/16" DRAWING # 46</b>		<input checked="" type="checkbox"/>
<b># 61</b>	<b>CONCAVE SIDE 1/16" LINEAR SEE ATTACHED DRAWING # 36</b>		<input checked="" type="checkbox"/>
<b># 62</b>	<b>CONCAVE SIDE 1/8" &amp; 1/4" LINEAR SEE ATTACHED DRAWING # 35</b>		<input checked="" type="checkbox"/>
<b># 64</b>	<b>CONVEX SIDE 1/2" LINEAR SEE ATTACHED DRAWING # 34</b>		<input checked="" type="checkbox"/>
<b># 85</b>	<b>CONCAVE SIDE 1/16" LINEAR SEE ATTACHED DRAWING # 30</b>		<input checked="" type="checkbox"/>
<b># 87</b>	<b>CONVEX SIDE TWO 1/16" LINEAR SEE ATTACHED DRAWING # 31</b>		<input checked="" type="checkbox"/>

DISPOSITION OF REJECTED INDICATIONS: 21

AUTHORIZED INSPECTOR: 22 **William Fong II** DATE: 23 **3-14-80**

MAGNETIC PARTICLE INSPECTION REPORT  
 NDT - MT - FORM 1 (SUPPLEMENT)  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 SURREY 1	SYSTEM: 2 TURBINE	PROCEDURE: 3 NDT - MT - 12.1	DATE: 4 3-14-80
ITEM, COMPONENT INSPECTED: 5 <del>1. Rotor</del> <del>Generator</del> <del>End</del>			MAINTENANCE REPORT NO: 6 SI002210414

7 AREA INSPECTED	8 SIZE AND LOCATION OF INDICATIONS	9 ACCEPT	10 REJECT
STEEPLE # 99	CONVEX SIDE 1/8" LINEAR SEE DRAWING # 32		✓
# 124	CONCAVE SIDE 1/16" LINEAR SEE ATTACHED DRAWING # 29		✓
# 129	METAL AT TOP OF STEEPLES IS TORN AWAY AND FOLDED OUT. NRI SEE DRAWING # 28	*	*
# 130	METAL AT TOP OF STEEPLES IS TORN AWAY AND FOLDED OUT. NRI SEE DRAWING # 28	*	*
# 137	CONVEX SIDE 1/16" LINEAR SEE DRAWING # 25		✓
# 138	CONCAVE SIDE THREE 1/4" LINEAR SEE DRAWING # 24		✓
# 142	CONVEX SIDE 1/2" LINEAR SEE DRAWING # 27		✓
# 150	CONCAVE SIDE - LINEAR 1/2 LENGTH OF STEEPLE 3/16" LINEAR INDICATIONS AT BASE SEE DRAWING # 22 + # 23		✓
# 151	CONCAVE SIDE 1" 3/4" L SMALL LINEAR SEE DRAWING # 21		✓
# 159	CONCAVE SIDE 3/16" LINEAR SEE DRAWING # 20		✓
# 160	CONCAVE SIDE PREVIOUSLY GROUND 3 LINEAR 1/2", 1/4" - 3/8" SEE DRAWING # 14		✓
# 161	CONCAVE + CONVEX SIDE 1/4", 1/16" - SMALLER INDICATIONS SEE DRAWINGS # 19 + # 26		✓
# 162	CONCAVE SIDE 3 LINEAR 1/4" - SMALLER SEE DRAWING # 18		✓
# 163	CONCAVE SIDE 1/4" LINEAR SEE DRAWING # 17		✓
# 164	CONCAVE SIDE 2 LINEAR 1/2" + 1/4" SEE DRAWING # 16		✓
# 165	CONCAVE SIDE 1/4" LINEAR SEE DRAWING # 15		✓
# 167	CONCAVE SIDE 1/4" + 3/4" LINEAR SEE DRAWING # 13		✓
# 168	CONCAVE SIDE PREVIOUSLY GROUND 3/16" LINEAR SEE DRAWING # 10		✓
# 174	CONCAVE SIDE 1/4" LINEAR SEE DRAWING # 9		✓
# 189	CONVEX SIDE + CONCAVE SIDE 3/16" LINEAR SEE DRAWING # 8 + # 7		✓

DISPOSITION OF REJECTED INDICATIONS:

\*\* DEFERRED TO (C) ENGINEERING

AUTHORIZED INSPECTOR: William Fong II	DATE: 13 3-14-80
--	---------------------



SURRY POWER STATION

ROTOR NO.

60W

1  
L-3

ROW NO.

2

STEEPLE NO.

43


DRAWING NO.

14/MAR/81

DATE

High Cycle Fatigue Cracking

CONVEX  
SIDE



LAND #1

GROOVE #1

L #2

G #2

L #3

G #3

LINEAR INDICATIONS 3/16"

SURRY POWER STATION

ROTOR NO. 1


RDW NO. 622

STEEPLE NO. 7

DRAWING NO. 45

DATE 14/MAR/82

CONCAVE  
SIDE



$\frac{1}{16}$ " LINEAR INDICATION

CONCAVE  
SIDE


ROTOR NO. \_\_\_\_\_

ROW NO. <sup>GEN.</sup> L-3

STEEPLE NO. 10

DRAWING NO. 42

DATE 14/MAR/80




5 LINEAR INDICATIONS  
1/4" + SMALLER

SURRY POWER STATION

CONVEX  
SIDE

ROTOR NO. 1  
ROW NO. 60W 2-3  
STEEPLE NO. 12  
DRAWING NO. 41  
DATE 14/MAR/85



1/8" LINEAR INDICATION

SURRY POWER STATION

ROTOR NO.

CON

1  
L-3

ROW NO.

14

STEEPLE NO.


39

DRAWING NO.

14/MAR/80

DATE

CONVEX  
SIDE



4 LINEAR INDICATIONS  
1/4" + SMALLER



SURRY POWER STATION

ROTOR NO. 1


ROW NO. <sup>CON</sup> L-3

STEEPLE NO. 15

DRAWING NO. 38

DATE 14/MAR/

CONCAVE  
SIDE



LINEAR INDICATIONS  
1/2 LENGTH OF STEEPLE

SURRY POWER STATION

ROTOR NO. 1


ROW NO. <sup>CON</sup> L-3

STEEPLE NO. 22

DRAWING NO. 40

DATE 14/May/80

Convex Side



$\frac{1}{8}$ " long Linear indication

SURRY POWER STATION

ROTOR NO. 1

ROW NO. 6PW L-3


STEEPLE NO. 22

DRAWING NO. 37

DATE

1/11/80

Concave Side



Three  $\frac{1}{16}$  linear indications

SURRY POWER STATION

CONCRETE BASE


ROTOR NO. 1

ROW NO. 620

STEEPLE NO. 59

DRAWING NO. 4

DATE 3-14-80



3 1/8" DIA. 1/8" 1/16" 1/16"

SURRY POWER STATION

ROTOR NO.

1  
COR.  
2-3

ROW NO.

STEEPLE NO.

61


DRAWING NO.

36

DATE

14/MAR/80

CONCAVE  
SIDE



$\frac{1}{16}$  LINEAR INDICATION

SURRY POWER STATION

ROTOR NO.

1

ROW NO.

600.  
2-3

STEEPLE NO.

62


DRAWING NO.

35

DATE

4/11/18

CONCAVE  
SIDE



1/4" LINEAR INDICATION  
1/8" LINEAR INDICATION

SURRY POWER STATION

CONVEX  
SIDE

ROTOR NO.

1

ROW NO.

<sup>CON.</sup>  
2-3

STEEPLE NO.


64

DRAWING NO.

34

DATE

18 MAR 63




$\frac{1}{2}$ " LINEAR INDICATION

SURRY POWER STATION

ROTOR NO. 1  
60N.  
ROW NO. L-3  
STEEPLE NO. 85  
DRAWING NO. 30  
DATE 13/Mar/80

Concave Side



1/16" Linear Indication



SURRY POWER STATION

ROTOR NO. 1


ROW NO. 600 L-3

STEEPLE NO. 87

DRAWING NO. 31

DATE 13/May/80

Convex Side



Two  $\frac{1}{16}$ " Linear Indicators

SURRY POWER STATION

ROTOR NO.

1  
60W.  
L-3

ROW NO.

99

STEEPLE NO.


32

DRAWING NO.

13/11/80

DATE

Convex Side



One 1/8" Linear indication.

CONCAVE  
SIDE

SURRY POWER STATION

ROTOR NO.

ROW NO.

STEEPLE NO.

DRAWING NO.


DATE

1  
L-3

124

29

13/MAR/8




1/16" LINEAR INDICATION AT BASE

11 NO. 1

SURRY POWER STATION

ROTOR NO. 1  
CAN. L-3  
ROW NO. L-3  
STEEPLE NO. 130-129  
DRAWING NO. 28  
DATE 13/MAR/80



METAL AT TOP OF STEEPLES  
IS TORN AWAY AND FOLDED  
OUT

SURRY POWER STATION

ROTOR NO.

1  
622

ROW NO.

2-3

STEEPLE NO.

137


DRAWING NO.

25

DATE

13/MAR/60

CONVEX  
SIDE



1/16" LINEAR INDICATIONS IN BASE METAL  
UP TO BOTTOM GROOVE

SURRY POWER STATION

ROTOR NO. 1


ROW NO. 602  
L-3

STEEPLE NO. 138

DRAWING NO. 24

DATE 13/MAR/82

CONCAVE  
SIDE



3 LINEAR INDICATIONS  $\frac{1}{4}$ "

SURRY POWER STATION

ROTOR NO.

ROW NO.


STEEPLE NO.

DRAWING NO.

DATE

1  
          
Gen L-3  
          
142  
          
27  
          
13/MAR/80

CONVEX SIDE



1/2" LINEAR INDICATION

SURRY POWER STATION

CONCAVE  
SIDE


ROTOR NO. 1

ROW NO. <sup>GEN</sup> L-3

STEEPLE NO. 150

DRAWING NO. 23

DATE 13/MAR/80



$\frac{3}{16}$ " LINEAR INDICATION

LINEAR INDICATIONS APPROX  $\frac{1}{4}$ "



UNIT No. 1

SURRY POWER STATION

CONCAVE  
SIDE

ROTOR NO.

1

ROW NO.

2-3

STEEPLE NO.


151-150

DRAWING NO.

22

DATE

13/MAR/80



LINEAR INDICATIONS ON BASE METAL  
BETWEEN STEEPLES.

SURRY POWER STATION

CONCAVE  
SIDE

ROTOR NO.

<sup>CON</sup> 1

ROW NO.

2-3

STEEPLE NO.


151

DRAWING NO.

21

DATE

13/MAR/80



LINEAR INDICATIONS

1", 3/4", 1/2"

SURRY POWER STATION

CONCAVE  
SIDE

ROTOR NO.

1

ROW NO.

622  
L-3

STEEPLE NO.


159

DRAWING NO.

20

DATE

13/MAR/81



LINEAR INDICATION  
3/16"

CONCAVE  
SIDE

SURRY POWER STATION

ROTOR NO.

1  
GEN

ROW NO.

L-3

STEEPLE NO.


150

DRAWING NO.

14

DATE

13/MAR/80



3 LINEAR INDICATIONS

$\frac{1}{2}$ "  $\frac{1}{4}$ "  $\frac{3}{16}$ "

SURRY POWER STATION

ROTOR NO.

1  
<sup>GEN</sup>L-3

ROW NO.

161

STEEPLE NO.


26

DRAWING NO.

DATE

13/MAR/72

CONVEX  
SIDE



LINEAR INDICATIONS AT BASE METAL  
 $\frac{1}{16}$ " & SMALLER

CONCAVE  
SIDE

SURRY POWER STATION

ROTOR NO.

1

ROW NO.

60W  
2-3

STEEPLE NO.


161

DRAWING NO.

19

DATE

13/MAR/8



4 LINEAR INDICATIONS  
1/4" + SMALLER

CONCAVE  
SIDE

SURRY POWER STATION


ROTOR NO. 1

ROW NO. 2-3

STEEPLE NO. 162

DRAWING NO. 18

DATE 13/MAR/80



3 LINEAR INDICATIONS

$\frac{1}{4}$ " + SMALLER

CONCAVE  
SIDE

SURRY POWER STATION

ROTOR NO.

ROW NO.

STEEPLE NO.

DRAWING NO.


DATE

1  
2-3

162

17

13/MAR/82



1/4" LINER INDICATION



CONCAVE  
SIDE

SURRY POWER STATION


ROTOR NO. 1

ROW NO. 625  
L-3

STEEPLE NO. 164

DRAWING NO. 16

DATE 13/MAR/1



2 LINEAR INDICATIONS  
 $\frac{1}{2}$ " &  $\frac{1}{4}$ "

CONCAVE  
SIDE

SURRY POWER STATION

ROTOR NO.

1

ROW NO.

602  
L-3

STEEPLE NO.


165

DRAWING NO.

15

DATE

13/MAR/6



1/4" LINEAR INDICATIONS

CONCAVE  
SIDE

SURRY POWER STATION

ROTOR NO.

1  
692  
L-3

ROW No.

STEEPLE No.


167

DRAWING No.

13

DATE

13/MAR/1



3/4" LINE & INDICATED  
1/4" " "

SURRY POWER STATION


ROTOR NO. 1

ROW NO. 60A

STEEPLE NO. 168

DRAWING NO. 11

DATE 01-27



CONCRETE SIDE  
3/16" LINEAR  
(PREVIOUSLY GRADED)

SURRY POWER STATION

ROTOR NO.

ROW NO.

STEEPLE NO.

DRAWING NO.


DATE

Ben

174

9

3-17-80



CONCAVE SIDE  
1/4" HORIZONTAL

UNIT NO. 1

SURRY POWER STATION


ROTOR NO. 1  
GEN

ROW NO. L-3

STEEPLE NO. 189

DRAWING NO. 8

DATE 3-13-80



CONVEX SIDE.

$\frac{3}{16}$ " LINEAR INDICATION

SURRY POWER STATION


ROTOR NO. 1

ROW NO. 62J  
~~189A~~

STEEPLE NO. 189

DRAWING NO. 7

DATE 3-13-80



CONCAVE SIDE  
3/16" LINEAR INDICATION

SURRY POWER STATION

ROTOR NO.

1  
622

ROW NO.

13

STEEPLE NO.


190

DRAWING NO.

6

DATE

5-18-80



CONCRETE SIDE  
7/8" LINEAR TOLERANCE  
PREVIOUSLY CONSIDERED



UNIT No. 1

SURRY POWER STATION


ROTOR NO. 1  
602

ROW No. L-3

STEEPLE No. 195

DRAWING No. #5

DATE 3-15-80




CONVEY. SIDE  
1/4" LINEAR UNITS

UNIT No. 1

SURRY POWER STATION

ROTOR NO. 1  
Gen  
ROW NO. L-5  
STEEPLE NO. 204  
DRAWING NO. 2  
DATE 3-13-80



CONCAVE SIDE  
1/4" DEEP INDICATION  
PROVIDE HATCHING

UNIT NO. 1

SURRY POWER STATION

ROTOR NO.

620

ROW NO.


STEEPLE NO.

108

DRAWING NO.

3

DATE



UNIT NO. 1  
SURRY POWER STATION

14

NO SPACE

UNIT NO. 1

SURRY POWER STATION


ROTOR NO. 1  
60W

ROW NO. 2-5

STEEPLE NO. 207

DRAWING NO. 4

DATE 5-15-80



CONCAVE SIDE

1/4" THICK IN WEIGHT 300

SURRY POWER STATION

ROTOR NO.

1

ROW NO.

CON  
6-3

STEEPLE NO.


223

DRAWING NO.

1

DATE

3-13-8



Concave Side

2 Linear Indications

1/4  
1/6

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

STATION: <i>SURRY 1</i>	SYSTEM: <i>LP TURBINE</i>	PROCEDURE: <i>NDT - MT - 12.1</i>	DATE: <i>3-15-80</i>
ITEM, COMPONENT INSPECTED: <i>LP #1 ROTOR L-4 GENERATOR END</i>			MAINTENANCE REPORT NO.: <i>S1002210414</i>
MATERIAL: <i>ALLOY STEEL (CARBON)</i>	SURFACE CONDITION: <i>GLASS BEAD BLAST CLEAN</i>		
TYPE OF PARTICLES: <input checked="" type="checkbox"/> WET <input type="checkbox"/> DRY <input type="checkbox"/> VISIBLE <input checked="" type="checkbox"/> FLUORESCENT			BATCH NO.: <i>5 G 002</i>
MANUFACTURER: <i>MAGNARUX</i>	TYPE: <i>20A</i>		
MAGNETIZATION: <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> RESIDUAL	<input checked="" type="checkbox"/> COIL <i>2200-3800</i> AMPERE TURNS <input type="checkbox"/> PROD _____ SPACING _____ AMPS <input type="checkbox"/> CIRCULAR _____ AMPERES <input type="checkbox"/> YOKE _____		CURRENT: <input type="checkbox"/> AC <input type="checkbox"/> DC <input checked="" type="checkbox"/> HWDC

TEST PERFORMED BY: <i>T. GIBSON / G. HERRERA / P. COLBY / W. FONG</i>	LEVEL OF CERTIFICATION: <i>A / I / II / II</i>
--	---

AREA INSPECTED	SIZE AND LOCATION OF INDICATIONS	ACCEPT	REJECT
<i>STEEPLE # 184</i>	<i>STEEPLE BROKEN ALL THE WAY THROUGH</i>		
	<i>SEE DRAWING # 1</i>		<input checked="" type="checkbox"/>
<i># 185</i>	<i>STEEPLE BROKEN, 3/4" SECTION MISSING</i>		
	<i>SEE DRAWING # 2</i>		<input checked="" type="checkbox"/>
<i>DISC AREA</i>	<i>NRI</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS:

AUTHORIZED INSPECTOR: <i>William Fong II</i>	DATE: <i>3-15-80</i>
---	-------------------------

UNIT No. 1

SURRY POWER STATION

ROTOR NO. 1


ROW NO. L-4

STEEPLE No. 184

DRAWING No. 1

DATE 3-14-80

ROTOR STEEPLE  
GEN. END



STEEPLE BROKEN ALL THE WAY THROUGH

UNIT No. 1  
SURRY POWER STATION

ROTOR NO. 1


ROW NO. L-4

STEEPLE NO. 185

DRAWING NO. 2

DATE 3-14-80

ROTOR STEEPLE  
GEN. END



$\frac{3}{4}$ " SECTION OF STEEPLE MISSING



**LIQUID PENETRANT INSPECTION REPORT**  
**NDT - PT - FORM 1**  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 *SURRY 1* SYSTEM: 2 *TURBINE* PROCEDURE: 3 *NDT-PT-13.1* DATE: 4 *3-18-80*

ITEM, COMPONENT INSPECTED: 5 *LP #2 ROTOR L-4 GENERATOR + GOVERNOR ENDS* MAINTENANCE REPORT NO: 6 *51002210414*

MATERIAL: 7 *ALLOY CARBON STEEL* SURFACE CONDITION: 8 *EMERY CLOTH - CLEAN*

	9 MANUFACTURER	10 TYPE	11 BATCH NO.	12 TYPE OF PENETRANT:
CLEANER	<i>SHERWIN</i>	<i>DR 60</i>	<i>4F915</i>	<input checked="" type="checkbox"/> WATER SOLUBLE
PENETRANT	<i>SHERWIN</i>	<i>DP 51</i>	<i>47 C813 H</i>	<input type="checkbox"/> FLUORESCENT
EMULSIFIER	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<input checked="" type="checkbox"/> VISIBLE RED DYE
REMOVER	<i>WATER</i>	<i>N/A</i>	<i>N/A</i>	<input type="checkbox"/> SOLVENT REMOVABLE
DEVELOPER	<i>SHERWIN</i>	<i>D 100</i>	<i>60 824 C</i>	<input type="checkbox"/> POST EMULSIFIABLE

PENETRANT APPLICATION: 13  DIPPING  SPRAYING  BRUSHING PENETRANT DWELL TIME: 14 *10* MIN. TEMP: 15 *60°* OF EMULSIFIER DWELL TIME: 16 *N/A* MIN.

REMOVAL TECHNIQUE FOR EXCESS PENETRANT: 17  FLOWING WATER  WIPED SOLVENT  WIPED WATER  DIP CLEANING DRYING TIME: 18 *10* MIN. TEMP: 19 *60°* OF

DEVELOPER APPLICATION: 20  DIPPING  SPRAYING  BRUSHING DEVELOPING TIME: 21 *15* MIN. TEMP: 22 *60°* OF

TEST PERFORMED BY: 23 *G. HERRERA / P. COLBY / T. GIBSON / W. FONG* LEVEL OF CERTIFICATION: 24 *I / II / I / II*

25 AREA INSPECTED	26 SIZE AND LOCATION OF INDICATIONS	27 ACCEPT	28 REJECT
<i>WELD AREA ON SHAROUD ON L-4 GENERATOR AND GOVERNOR END</i>	<i>NR1</i>	<input checked="" type="checkbox"/>	

DISPOSITION OF REJECTED INDICATIONS: 29

NOTE: PENETRANT INSPECTION WAS PERFORM AND DETERMINED MAGNETIC PARTICLE INDICATIONS TO BE NON-RELEVANT. MAGNETIC PARTICLES INDICATIONS WAS DUE TO DISSIMILAR MATERIAL.

AUTHORIZED INSPECTOR: *William Fong II* 30 DATE: *3-18-80* 31

MAGNETIC PARTICLE INSPECTION REPORT  
NDT - MT - FORM 1  
VIRGINIA ELECTRIC AND POWER COMPANY

1 LOCATION: **HURRY 1** 2 SYSTEM: **TURBINE** 3 PROCEDURE: **NDT - MT - 12.1** 4 DATE: **3-15-80**

5 ITEM, COMPONENT INSPECTED: **LP #2 ROTOR L-4 GOVERNOR** 6 MAINTENANCE REPORT NO: **S1002210414**

7 MATERIAL: **ALLOY CARBON STEEL** 8 SURFACE CONDITION: **GLASS BEAD BLAST CLEAN**


9 TYPE OF PARTICLES:  WET  DRY  VISIBLE  FLUORESCENT 10 BATCH NO: **56002**

11 MANUFACTURER: **MAGNAFLUX** 12 TYPE: **20A**

13 MAGNETIZATION:  COIL **2400** AMPERE TURNS 14 CURRENT:  AC  DC  RWDC  
 CONTINUOUS  PROD \_\_\_\_\_ SPACING \_\_\_\_\_ AMPS  
 RESIDUAL  CIRCULAR \_\_\_\_\_ AMPERES  
 YOKE \_\_\_\_\_

15 TEST PERFORMED BY: **T. GIBSON / J. DALTON / W. FONG** 16 LEVEL OF CERTIFICATION: **A/A/II**

17 AREA INSPECTED	18 SIZE AND LOCATION OF INDICATIONS	19 ACCEPT	20 REJECT
<b>BLADE END SHROUD # 19</b>	<b>LINEAR ON WELD AREA BETWEEN</b>		
<b># 20</b>	<b>BLADE # 19 &amp; # 20</b>		<input checked="" type="checkbox"/>
<b># 51</b>	<b>LINEAR ON WELD AREA BETWEEN</b>		
<b>52</b>	<b>BLADE # 51 &amp; # 52</b>		<input checked="" type="checkbox"/>
<b># 85</b>	<b>LINEAR ON WELD AREA BETWEEN</b>		
<b># 86</b>	<b>BLADE # 85 &amp; # 86</b>		<input checked="" type="checkbox"/>
<b># 119</b>	<b>LINEAR ON WELD AREA BETWEEN</b>		
<b># 120</b>	<b>BLADE # 119 &amp; # 120</b>		<input checked="" type="checkbox"/>
<b># 151</b>	<b>LINEAR ON WELD AREA BETWEEN</b>		
<b># 152</b>	<b>BLADE # 151 &amp; # 152</b>		<input checked="" type="checkbox"/>
<b># 185</b>	<b>LINEAR ON WELD AREA BETWEEN</b>		
<b># 186</b>	<b>BLADE # 185 &amp; # 186</b>		<input checked="" type="checkbox"/>

21 DISPOSITION OF REJECTED INDICATIONS:  21 P.T. ON SHROUD AREA IS ACCEPTABLE - see P.T. REPORT 3-18-80 JFM

22 AUTHORIZED INSPECTOR: **William Fong II** 23 DATE: **3-15-80**