

**Vepco**

USNRC REGIONAL  
ATLANTA, GEORGIA

79 AUG 24 4:08:03

VIRGINIA ELECTRIC AND POWER COMPANY

Surry Power Station  
P.O. Box 315  
Surry, Virginia 23883

August 23, 1979

REGULATORY DOCKET FILE COPY

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
Nuclear Regulatory Commission  
Region II,  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Docket: 50-281

Dear Mr. O'Reilly:

In accordance with the provisions of IE Bulletin 79-13, VEPCO submits the following report for Surry Unit 2.

"A" Steam Generator - Line 14" - WFPD-117-601 Weld 5 - Rejectable porosity, Weld 7 - Rejectable connected porosity.

Radiography of Unit 2 Feedwater Lines is about 7% complete, Unit 1 results have been submitted previously.

Very truly yours,

  
W. L. Stewart

7909240848  
KB  
H02  
790471  
OFFICIAL COPY