



Tennessee Valley Authority, Sequoyah Nuclear Plant, P.O. Box 2000, Soddy Daisy, Tennessee 37384

May 15, 2018

10 CFR 50.4

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Sequoyah Nuclear Plant, Unit 1
Renewed Facility Operating License Nos. DPR-77
NRC Docket Nos. 50-327

Subject: Sequoyah Unit 1 Pressure Temperature Limits Report, Revision 6

In accordance with Sequoyah Nuclear Plant (SQN) Unit 1 Technical Specification (TS) 5.6.4.c, enclosed is the Pressure Temperature Limits Report (PTLR), Revision 6. The PTLR has been revised for license renewal actions including: an updated neutron fluence evaluation to extend pressure-temperature (P-T) limits from 32 effective full power years (EFPY) to 52 EFPY; to document the evaluation of the reactor vessel materials in the extended beltline region; and to provide a revision to the surveillance capsule withdrawal schedule. The low temperature overpressure protection system setpoints have been revised for the pressurizer power operated relief valve (PORV) digital control system upgrade. The PORV digital control system upgrade was implemented on April 27, 2018, during the Unit 1 Cycle 22 Refueling Outage. Associated administrative changes were made for report consistency.

There are no new regulatory commitments in this letter. If you have any questions, please contact Michael McBrearty, SQN Site Licensing Manager at (423) 843-7170.

Respectfully,

A handwritten signature in black ink, appearing to read 'Anthony L. Williams', written over a circular scribble.

Anthony L. Williams
Site Vice President
Sequoyah Nuclear Plant

Enclosure

Sequoyah Unit 1 Pressure Temperature Limits Report, Revision 6

U.S. Nuclear Regulatory Commission
Page 2
May 15, 2018

ZTK:STB

Enclosure

cc (Enclosure):

NRC Regional Administrator – Region II

NRC Senior Resident Inspector – SQN

ENCLOSURE

**SEQUOYAH UNIT 1
PRESSURE TEMPERATURE LIMITS REPORT, REVISION 6**

PRESSURE TEMPERATURE LIMITS REPORT

QA Record

B88 180430 800

APPROVED	
This approval does not relieve the Contractor from any part of his responsibility for the correctness of design, details and dimensions.	
Letter No. N10810	
Date:	April 30, 2018
TENNESSEE VALLEY AUTHORITY	
SQEP (P)	BY: W. Chris Reneau

Tennessee Valley Authority
Sequoyah Unit 1

Pressure Temperature Limits Report
Revision 6, September 2017


PROJECT Sequoyah DISCIPLINE N
 CONTRACT 4411 UNIT 1
 DESC. RCS Pressure-Temperature Limit Report
 DWG/DOC NO. PTLR-1
 SHEET - OF - REV. 06
 DATE 04/30/18 ECN/DCN - FILE N2N-081

EDMS, WT CA-K

PRESSURE TEMPERATURE LIMITS REPORT

QA Record

B88 180430 800



**Tennessee Valley Authority
 Sequoyah Unit 1**

**Pressure Temperature Limits Report
 Revision 6, September 2017**

PROJECT Sequoyah DISCIPLINE N
 CONTRACT 4411 UNIT 1
 DESC. RCS Pressure-Temperature Limit Report
 DWG/DOC NO. PTLR-1
 SHEET - OF - REV. 06
 DATE 04/30/18 ECN/DCN - FILE N2N-081

EDMS, WT CA-K

Table of Contents

List of Tables	iv
List of Figures	v
1.0 RCS Pressure Temperature Limits Report (PTLR)	1
2.0 Operating Limits	1
2.1 RCS Pressure/Temperature (P/T) Limits (TS 3.4.3).....	1
3.0 Low Temperature Overpressure Protection System (TS 3.4.12)	2
3.1 Pressurizer PORV Lift Setting Limits.....	2
3.2 Arming Temperature.....	2
4.0 Reactor Vessel Material Surveillance Program	2
5.0 Supplemental Data Tables	3
6.0 References	23

PRESSURE TEMPERATURE LIMITS REPORT

List of Tables

Table 2-1	Sequoyah Unit 1 Heatup Limits at 52 EFPY (with Uncertainties for Instrumentation Errors of 10°F and 60 psig).....	6
Table 2-2	Sequoyah Unit 1 Cooldown Limits at 52 EFPY (with Uncertainties for Instrumentation Errors of 10°F and 60 psig).....	8
Table 3-1	Selected Setpoints, Sequoyah Unit 1	10
Table 4-1	Sequoyah Unit 1 Reactor Vessel Surveillance Capsule Withdrawal Schedule	12
Table 5-1	Comparison of the Sequoyah Unit 1 Surveillance Material 30 ft-lb Transition Temperature Shifts and Upper Shelf Energy Decreases with Regulatory Guide 1.99, revision 2, Predictions.....	13
Table 5-2	Calculation of Chemistry Factors using Sequoyah Unit 1 Surveillance Capsule Data.....	14
Table 5-3	Reactor Vessel Beltline and Extended Beltline Material Unirradiated Toughness Properties for Sequoyah Unit 1	15
Table 5-4	Peak Neutron Fluence Projections on the Reactor Vessel Clad/Base Metal Interface for Sequoyah Unit 1 ($\times 10^{19}$ n/cm ² , E > 1.0 MeV)	17
Table 5-5	Sequoyah Unit 1 Calculation of the ART Values for the 1/4T Location at 52 EFPY	18
Table 5-6	Sequoyah Unit 1 Calculation of the ART Values for the 3/4T Location at 52 EFPY	19
Table 5-7	Summary of the Sequoyah Unit 1 Reactor Vessel Beltline and Extended Beltline Material ART Values	20
Table 5-8	Sequoyah Unit 1 Calculation of the ART Values for the Inlet and Outlet Nozzles at 52 EFPY	21
Table 5-9	Summary of the Sequoyah Unit 1 Nozzle Material ART Values at 52 EFPY.....	21
Table 5-10	RT _{PTS} Calculations for Sequoyah Unit 1 Beltline and Extended Beltline Materials at 52 EFPY	22

PRESSURE TEMPERATURE LIMITS REPORT

List of Figures

Figure 2-1	Sequoyah Unit 1 Reactor Coolant System Heatup Limitations (Heatup Rate of 100°F/hr) Applicable for the First 52 EFPY (w/ Margins for Instrumentation Errors of 10°F and 60 psig)	4
Figure 2-2	Sequoyah Unit 1 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for the First 52 EFPY (w/ Margins for Instrumentation Errors of 10°F and 60 psig)	5
Figure 3-1	Sequoyah Unit 1 Selected LTOPS Setpoints	11

PRESSURE TEMPERATURE LIMITS REPORT

1.0 RCS Pressure Temperature Limits Report (PTLR)

This PTLR for Sequoyah Unit 1 has been prepared in accordance with the requirements of Technical Specification (TS) 5.6.4. Revisions to the PTLR shall be provided to the NRC after issuance.

This report affects TS 3.4.3, RCS Pressure/Temperature Limits (P/T) Limits, TS 3.4.12, Low Temperature Over Pressure Protection (LTOP) System and TS 3.5.2, ECCS - Operating.

2.0 RCS Pressure and Temperature Limits

The limits for TS 3.4.3 are presented in the subsections which follow and were developed using the NRC approved methodologies specified in TS 5.6.4 with exception of ASME Code Case N-640^[13] (Use of K_{Ic}), WCAP-15984-P^[14] (Elimination of the Flange Requirement), 1996 Version of Appendix G^[4] and the revised fluences^[15]. The operability requirements associated with LTOPS are specified in TS 3.4.12 and were determined to adequately protect the RCS against brittle fracture in the event of an LTOP Transient in accordance with the methodology specified in TS 5.6.4.

2.1 RCS Pressure/Temperature (P/T) Limits (TS 3.4.3)

2.1.1 The minimum boltup temperature is 50°F

2.1.2 The RCS temperature rate-of-change limits are:

- a. A maximum heatup rate of 100°F in any one hour period.
- b. A maximum cooldown rate of 100°F in any one hour period.
- c. A maximum temperature change of less than or equal to 10°F in any one hour period during inservice hydrostatic and leak testing operations above the heatup and cooldown limit curves.

2.1.3 The RCS P/T limits for heatup, cooldown, inservice hydrostatic and leak testing, and criticality are specified by Figures 2-1 and 2-2. These P/T limit curves were originally documented in WCAP-15293, Revision 2^[10] and were applicable to 32 Effective Full-Power Years (EFPY). The applicability of the 32 EFPY P-T limit curves for Sequoyah Unit 1 was extended to 52 EFPY as a part of the technical evaluations documented in WCAP-17539-NP, Revision 1^[15].

2.1.4 Nozzle P/T limit curves were developed at 52 EFPY as a part of the evaluations contained in MCOE-LTR-16-12-NP^[16] to satisfy NRC Regulatory Issue Summary (RIS 2014-11)^[17]. The nozzle curves are compared to the cylindrical shell P/T limit curves (developed using Reference 9 methodology) with a revised applicability of 52 EFPY in Reference 16, which shows that the nozzle P/T limit curves are bounded by the cylindrical shell P/T limit curves.

3.0 Low Temperature Overpressure Protection System (TS 3.4.12)

The lift setpoints for the pressurizer Power Operated Relief Valves (PORVs) are presented in the subsections which follow. These lift setpoints have been developed using the NRC-approved methodologies specified in TS 5.6.4.

3.1 Pressurizer PORV Lift Setting Limits

The pressurizer PORV lift setpoints are specified by Figure 3-1 and Table 3-1 (Ref. 10). The limits for the LTOPS setpoints are contained in the 52 EFPY steady-state curves (Table 2-2), which are beltline conditions and are not compensated for pressure differences between the pressurizer transmitter and the reactor midplane/beltline. However, these curves are adjusted for instrument inaccuracies. The pressure difference between the pressurizer transmitter and the reactor vessel midplane/beltline with four reactor coolant pumps in operation is 68.3 psi (Ref. 11).

Note: These setpoints include allowance for the pressure difference between the pressurizer transmitter and the reactor vessel midplane/beltline and the 50°F thermal transport effect for heat injection transients. A demonstrated accuracy calculation (Reference 12) has been performed to confirm that the setpoints will maintain the system pressure within the established limits when the pressure difference between the pressure transmitter and reactor midplane and maximum temperature/pressure instrument uncertainties are applied to the setpoints.

3.2 Arming Temperature

The LTOPS arming temperature is based upon the methodology defined in the Sequoyah Nuclear Plant Unit 1 Technical Specifications Administrative Controls Section 5.6.4. The arming temperature shall be $\leq 350^{\circ}\text{F}$.

4.0 Reactor Vessel Material Surveillance Program

The reactor vessel material irradiation surveillance specimens shall be removed and examined to determine changes in material properties. The removal schedule is provided in Table 4-1. The results of these examinations shall be used to update Figures 2-1, 2-2 and 3-1.

The pressure vessel steel surveillance program (WCAP-8233^[1]) is in compliance with Appendix H to 10 CFR 50, "Reactor Vessel Material Surveillance Program Requirements^[2]." The material test requirements and the acceptance standard utilize the reference nil-ductility temperature RT_{NDT} , which is determined in accordance with ASTM E23^[3]. The empirical relationship between RT_{NDT} and the fracture toughness of the reactor vessel steel is developed in accordance with Code Case N-640 of Section XI of the ASME Boiler and Pressure Vessel Code, Appendix G, "Fracture Toughness Criteria for Protection Against Failure^[4]." The surveillance capsule removal schedule meets the requirements of ASTM E185-82^[5]. The removal schedule is provided in Table 4-1.

PRESSURE TEMPERATURE LIMITS REPORT

5.0 Supplemental Data Tables

Table 5-1 contains a comparison of measured surveillance material 30 ft-lb transition temperature shifts and upper shelf energy decreases with Regulatory Guide 1.99, Revision 2^[6], predictions.

Table 5-2 shows calculations of the surveillance material chemistry factors using surveillance capsule data. Note that in the calculation of the surveillance weld chemistry factor, the ratio procedure from Regulatory Guide 1.99, Revision 2 was followed. The ratio in question is equal to 0.90.

Table 5-3 provides the required Sequoyah Unit 1 reactor vessel toughness data.

Table 5-4 provides a summary of the fluence values used in the generation of the heatup and cooldown limit curves and the PTS evaluation.

Table 5-5 and 5-6 show the calculation of the 1/4T and 3/4T adjusted reference temperature at 52 EFPY for each beltline material and extended beltline material in the Sequoyah Unit 1 reactor vessel. The limiting beltline material was the Lower Shell Forging 04.

Table 5-7 provides a summary of the adjusted reference temperature (ART) values of the Sequoyah Unit 1 reactor vessel beltline materials and extended beltline materials at the 1/4T and 3/4T locations for 52 EFPY.

Table 5-8 shows the maximum ART value at 52 EFPY for each inlet and outlet nozzle in the Sequoyah Unit 1 reactor vessel.

Table 5-9 provides a summary of the limiting ART values of the Sequoyah Unit 1 inlet and outlet nozzles at 52 EFPY.

Table 5-10 provides RT_{PTS} values for Sequoyah Unit 1 at 52 EFPY.

PRESSURE TEMPERATURE LIMITS REPORT

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: LOWER SHELL FORGING 04

LIMITING ART VALUES AT 52 EFPY: 1/4T, 216°F
 3/4T, 186°F




Figure 2-1 Sequoyah Unit 1 Reactor Coolant System Heatup Limitations (Heatup Rate of 100°F/hr)
Applicable for the First 52 EFPY (w/Margins for Instrumentation Error of 10°F and 60 psig)
(Plotted Data provided on Table 2-1)

PRESSURE TEMPERATURE LIMITS REPORT

MATERIAL PROPERTY BASIS

LIMITING MATERIAL: LOWER SHELL FORGING 04

LIMITING ART VALUES AT 52 EFPY: 1/4T, 216°F
 3/4T, 186°F




Figure 2-2 Sequoyah Unit 1 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 100°F/hr) Applicable for the First 52 EFPY (w/Margins for Instrumentation Error of 10°F and 60 psig) (Plotted Data provided on Table 2-2)

PRESSURE TEMPERATURE LIMITS REPORT

Table 2-1
 Sequoyah Unit 1 Heatup Limits at 52 EFPY
 (with Uncertainties for Instrumentation Errors of 10°F and 60 psig)

100 Heatup		100 Critical Limit		Leak Test Limit	
T	P	T	P	T	P
50	0	288	0	272	2000
50	477	288	477	288	2485
55	477	288	477		
60	477	288	477		
65	477	288	477		
70	477	288	478		
75	477	288	478		
80	477	288	480		
85	477	288	481		
90	477	288	483		
95	477	288	485		
100	477	288	487		
105	477	288	490		
110	477	288	493		
115	477	288	497		
120	477	288	500		
125	477	288	505		
130	477	288	508		
135	477	288	515		
140	477	288	517		
145	477	288	527		
150	477	288	528		
155	478	288	541		
160	480	288	541		
165	483	288	555		
170	487	288	557		
175	493	288	571		
180	500	288	575		
185	508	288	589		
190	517	288	609		
195	528	288	631		
200	541	288	656		
205	555	288	684		
210	571	288	714		
215	589	288	748		
220	609	290	786		
225	631	295	828		

PRESSURE TEMPERATURE LIMITS REPORT

Table 2-1 - (Continued)
Sequoyah Unit 1 Heatup Limits at 52 EFPY
(with Uncertainties for Instrumentation Errors of 10°F and 60 psig)

100 Heatup		100 Critical Limit		
T	P	T	P	
230	656	300	874	
235	684	305	925	
240	714	310	981	
245	748	315	1044	
250	786	320	1112	
255	828	325	1188	
260	874	330	1272	
265	925	335	1364	
270	981	340	1466	
275	1044	345	1578	
280	1112	350	1702	
285	1188	355	1838	
290	1272	360	1988	
295	1364	365	2154	
300	1466	370	2337	
305	1578			
310	1702			
315	1838			
320	1988			
325	2154			
330	2337			

PRESSURE TEMPERATURE LIMITS REPORT

Table 2-2
Sequoyah Unit 1 Cooldown Limits at 52 EFPY
(with Uncertainties for Instrumentation Errors of 10°F and 60 psig)

Steady State		20F		40F		60F		100F	
T	P	T	P	T	P	T	P	T	P
50	0	50	0	50	0	50	0	50	0
50	552	50	503	50	457	50	408	50	305
55	553	55	505	55	458	55	409	55	306
60	555	60	507	60	459	60	410	60	307
65	556	65	509	65	460	65	411	65	308
70	558	70	510	70	462	70	412	70	309
75	560	75	512	75	464	75	414	75	311
80	561	80	514	80	465	80	416	80	313
85	564	85	516	85	468	85	418	85	315
90	566	90	518	90	470	90	420	90	318
95	569	95	521	95	473	95	423	95	321
100	571	100	524	100	476	100	426	100	325
105	575	105	527	105	479	105	430	105	329
110	578	110	531	110	483	110	434	110	333
115	582	115	535	115	487	115	438	115	338
120	586	120	540	120	492	120	443	120	344
125	591	125	545	125	497	125	449	125	351
130	596	130	550	130	503	130	456	130	358
135	602	135	556	135	510	135	463	135	367
140	608	140	563	140	517	140	471	140	376
145	616	145	571	145	525	145	479	145	387
150	623	150	579	150	534	150	489	150	399
155	632	155	588	155	544	155	500	155	412
160	642	160	599	160	556	160	512	160	427
165	652	165	610	165	568	165	526	165	443
170	664	170	623	170	582	170	541	170	461
175	677	175	637	175	597	175	558	175	482
180	691	180	652	180	614	180	577	180	505
185	707	185	669	185	633	185	597	185	530
190	724	190	688	190	654	190	620	190	558
195	743	195	709	195	677	195	646	195	590
200	764	200	733	200	702	200	674	200	624
205	788	205	759	205	731	205	705	205	663
210	814	210	787	210	762	210	740	210	706
215	843	215	819	215	797	215	779	215	754

PRESSURE TEMPERATURE LIMITS REPORT

Table 2-2 - (Continued)
 Sequoyah Unit 1 Cooldown Limits at 52 EFPY
 (with Uncertainties for Instrumentation Errors)

Steady State		20F		40F		60F		100F	
T	P	T	P	T	P	T	P	T	P
220	874	220	853	220	836	220	821	220	806
225	909	225	892	225	878	225	869	225	865
230	948	230	935	230	925	230	921		
235	991	235	982	235	978				
240	1038	240	1034						
245	1090								
250	1148								
255	1212								
260	1283								
265	1360								
270	1447								
275	1542								
280	1647								
285	1763								
290	1892								
295	2034								
300	2191								
305	2364								

PRESSURE TEMPERATURE LIMITS REPORT

Table 3-1
Selected Setpoints^(a), Sequoyah Unit 1

Indicated RCS Temperature (°F)	PCV-456^(b) Setpoint (psig)	PCV-455A^(c) Setpoint (psig)
50	450	406
73	450	406
123	474	430
148	498	455
223	584	525
277	715	626
373	715	626
500	2335	2335

Notes:

- (a) From Reference 18 and confirmed per Reference 19.
- (b) PCV-456 is PORV#2.
- (c) PCV-455A is PORV#1.

PRESSURE TEMPERATURE LIMITS REPORT




Figure 3-1 Sequoyah Unit 1 - COMS PORV Setpoints vs. Indicated RCS Temperature^[18]
(Includes Pressure and Temperature Instrument Uncertainties. *Plotted Data provided on Table 3-1*)

PRESSURE TEMPERATURE LIMITS REPORT

Table 4-1
Sequoyah Unit 1 Reactor Vessel Surveillance Capsule Withdrawal Schedule

Capsule	Location	Lead Factor^(a)	Removal Time (EFPY)^(b)	Fluence (n/cm², E>1.0 MeV)^(a)
T	40°	3.15	1.07	2.41 x 10 ¹⁸ (c)
U	140°	3.23	2.85	6.93 x 10 ¹⁸ (c)
X	220°	3.22	5.26	1.16 x 10 ¹⁹ (c)
Y	320°	3.18	10.02	1.97 x 10 ¹⁹ (c,d)
S	4°	0.90	(e)	(e)
W	184°	0.90	(e)	(e)
V	176°	0.90	(f)	(f)
Z	356°	0.90	(g)	(g)

Notes:

- (a) Updated in the time-limiting aging analysis (TLAA) fluence evaluation (WCAP-17539-NP Revision 1^[15]).
- (b) Effective Full Power Years (EFPY) from plant startup.
- (c) Plant specific evaluation.
- (d) This fluence is not less than once or greater than twice the peak end of license (32 EFPY) fluence.
- (e) Capsules S and W, which were relocated during the 1R19 outage, were found to be severely damaged during the 1R20 outage. Thus, they are no longer available to be used to satisfy the requirements of 10 CFR 50, Appendix H with consideration of license renewal to 60 total years of plant operation.
- (f) Capsules V and Z are the only capsules currently remaining in the Sequoyah Unit 1 reactor vessel. Either Capsule V or Z should be withdrawn so that the capsule fluence corresponds to at least one times the 60-year EOL vessel fluence (2.66 x 10¹⁹ n/cm²), but less than two times the 60-year EOL vessel fluence (5.32 x 10¹⁹ n/cm²). However, neither of these two remaining capsules are predicted to experience a neutron fluence of 2.66 x 10¹⁹ n/cm² prior to EOLE in their current locations. Therefore, TVA has elected to relocate Capsule V (or Capsule Z, which is radiologically equivalent to Capsule V, and could be alternatively selected) to a higher lead factor location, specifically the former Capsule U Location (140°), in order to achieve higher capsule fluence data. Note that Capsule V or Capsule Z could alternatively be moved to any open 40° capsule location, as they are all radiologically equivalent. Assuming Capsule V was relocated at the end of cycle 21, 22, or 23, the EFPY that corresponds to the time when the capsule experiences the peak EOLE vessel fluence value (2.66 x 10¹⁹ n/cm²) is approximately 35.4, 36.4, or 37.3 EFPY, respectively. See Appendix B of Reference 15 for further details on capsule relocation recommendations^[15].
- (g) TVA has elected, for now, to leave Capsule Z in the reactor vessel at its current 356° capsule location. This capsule could be relocated to a higher lead factor location in the future if additional metallurgical data is needed in support of a potential second license renewal to 80 total years of plant operation. Note that Capsule Z would follow an equivalent subsequent withdrawal schedule to Capsule V if it is relocated to any 40° capsule location during EOC 21, 22 or 23, since Capsule Z and Capsule V are both currently at 4° effective azimuthal locations and are thus radiologically equivalent.

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-1

Comparison of the Sequoyah Unit 1 Surveillance Material 30 ft-lb Transition Temperature Shifts and Upper Shelf Energy Decreases with Regulatory Guide 1.99, Revision 2, Predictions

Material	Capsule	Fluence (x 10 ¹⁹ n/cm ²)	30 ft-lb Transition Temperature Shift		Upper Shelf Energy Decrease	
			Predicted (°F) ^(a)	Measured (°F) ^(b)	Predicted (%) ^(a)	Measured (%) ^(c)
Lower Shell Forging 04 (Tangential) (Heat # 980919 / 281587)	T	0.241	59.85	67.52	16	16
	U	0.693	89.3	109.7	20.5	21
	X	1.16	102.6	145.12	23	8
	Y	1.97	114.95	129.87	26.5	23
Lower Shell Forging 04 (Axial) (Heat # 980919 / 281587)	T	0.241	59.85	50.59	16	0
	U	0.693	89.3	67.59	20.5	19
	X	1.16	102.6	103.34	23	22
	Y	1.97	114.95	133.35	26.5	19
Weld Metal (Heat # 25295) ^(d)	T	0.241	111.13	127.79	35	30
	U	0.693	165.82	144.92	42	26
	X	1.16	190.51	159.02	45	21
	Y	1.97	213.44	163.8	48	28
HAZ Metal	T	0.241	--	45.48	--	20
	U	0.693	--	78.94	--	26
	X	1.16	--	95.89	--	3
	Y	1.97	--	73.3	--	10

Notes:

- (a) Based on Regulatory Guide 1.99, Revision 2, methodology using the mean weight percent values of copper and nickel of the surveillance material.
- (b) Calculated using measured Charpy data plotted using CVGRAPH, Version 4.1^[8].
- (c) Values are based on the definition of upper shelf energy given in ASTM E185-82.
- (d) Surveillance Weld was fabricated from weld wire type SMIT 40, Heat # 25295, Flux type SMIT 89, Lot # 1103.

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-2
Calculation of Chemistry Factors using Sequoyah Unit 1 Surveillance Capsule Data

Material	Capsule	Capsule f ^(a)	FF ^(b)	ΔRT_{NDT} ^(c)	FF* ΔRT_{NDT}	FF ²
Lower Shell Forging 04 (Tangential) (Heat # 980919 / 281587)	T	2.41E+18	0.615	67.52°F	41.52°F	0.378
	U	6.93E+18	0.897	109.70°F	98.42°F	0.805
	X	1.16E+19	1.041	145.12°F	151.13°F	1.085
	Y	1.97E+19	1.185	129.87°F	153.92°F	1.405
Lower Shell Forging 04 (Axial) (Heat # 980919 / 281587)	T	2.41E+18	0.615	50.59°F	31.11°F	0.378
	U	6.93E+18	0.897	67.59°F	60.64°F	0.805
	X	1.16E+19	1.041	103.34°F	107.62°F	1.085
	Y	1.97E+19	1.185	133.35°F	158.04°F	1.405
	SUM:					802.39°F
$CF_{04} = \sum(FF * RT_{NDT}) \div \sum(FF^2) = (802.39) \div (7.344) = 109.3^\circ F$						
Surveillance Weld Material ^(d) (Heat # 25295) ^(e)	T	2.41E+18	0.615	115.01°F (127.79°F)	70.72°F	0.378
	U	6.93E+18	0.897	130.43°F (144.92°F)	117.01°F	0.805
	X	1.16E+19	1.041	143.12°F (159.02°F)	149.05°F	1.085
	Y	1.97E+19	1.185	147.42°F (163.80°F)	174.72°F	1.405
	SUM:					511.50°F
$CF_{Surv. Weld} = \sum(FF * RT_{NDT}) \div \sum(FF^2) = (511.50^\circ F) \div (3.672) = 139.3^\circ F$						

Notes:

- (a) f = Calculated fluence, (n/cm², E > 1.0 MeV), updated per TLAA, WCAP-17539-NP, Revision 1^[15].
- (b) FF = fluence factor = $f^{(0.28 - 0.1 * \log f)}$.
- (c) ΔRT_{NDT} values are the measured 30 ft-lb shift values taken from Table 5-10 of WCAP-15224^[7].
- (d) The surveillance weld metal ΔRT_{NDT} values have been adjusted by a ratio factor of 0.90.
- (e) Surveillance Weld was fabricated from weld wire type SMIT 40, Heat # 25295, Flux type SMIT 89, Lot # 1103.

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-3
Reactor Vessel Beltline and Extended Beltline Material
Unirradiated Toughness Properties for Sequoyah Unit 1

Material Description	Chemical Composition				Fracture Toughness Properties	
	Cu (Wt. %)	Ni (Wt. %)	P (Wt. %)	Mn (Wt. %)	Initial RT _{NDT} ^(a) (°F)	Initial Upper-Shelf Energy (ft-lb)
Reactor Vessel Beltline Materials ^(b)						
Intermediate Shell Forging 05 (Heat # 980807/281489)	0.15	0.86	0.011	0.70	40	79
Lower Shell Forging 04 (Heat # 980919/281587)	0.13	0.76	0.015	0.62	73	72
Intermediate to Lower Shell Forging Circumferential Weld Seam W05 (Heat # 25295) ^(c, e)	0.35	0.11	0.021	1.47	-40	113
Surveillance Weld ^(d, e) (Heat # 25295)	0.39	0.11	0.021	1.40	---	---
Reactor Vessel Extended Beltline Materials						
Upper Shell Forging 06 (Heat # 980950/282758) ^(f)	0.16	0.89	0.011	0.70	23	83
Bottom Head Ring 03 (Heat # 981177/288872) ^(f)	0.16	0.77	0.016	0.73	5	64
Upper Shell to Intermediate Shell Circumferential Weld W06 (Heat # 25006)	0.17 ^(g)	1.0 ^(g)	0.013 ^(g)	1.90 ^(g)	10 ^(h)	78 ^(h)
Lower Shell to Bottom Head Ring Weld W04 (Heat # 25295) ⁽ⁱ⁾	0.35	0.11	0.021	1.47	-40	113

Notes:

- (a) The Initial RT_{NDT} values are measured values
- (b) Except for the best-estimate P and Mn weight percent values, the beltline material properties were taken from WCAP-15293, Revision 2^[10]. The weight percent P and Mn values for the beltline forging materials are based on Sequoyah Unit 1 CMTR data. The weight percent P and Mn values for the beltline and surveillance weld materials were determined using Rotterdam weld certification records as well as WCAP-8233^[1]
- (c) The surveillance weld and the three Rotterdam tests are averaged together for the Best Estimate of the Intermediate to Lower Shell Forging Circumferential Weld Seam Cu wt. % value. The three Rotterdam test results were: 0.30, 0.25 and 0.46 % copper, as referenced from the NRC Reactor Vessel Integrity Database (RVID) and ultimately from Rotterdam Weld Certifications. The Ni wt. % value is identical to the Ni wt. % value of the surveillance weld.
- (d) These copper and nickel values are best estimate values for only the surveillance weld metal and are the average of three data points [0.424 (WCAP-10340, Rev.1), 0.406 (WCAP-10340, Rev.1), 0.33 (WCAP-8233) copper and 0.084 (WCAP-10340, Rev.1), 0.085 (WCAP-10340, Rev.1), 0.17 (WCAP-8233) nickel.]. These values are

PRESSURE TEMPERATURE LIMITS REPORT

treated as one data point in the calculation of the best estimate average for the inter. to lower shell circ. weld shown above. Originally the 0.424 / 0.406 and 0.084 / 0.085 values were reported as single points, 0.41 - 0.42 and 0.08 (Per WCAP-10340, Rev. 1^[7d]), but it is actually made up of two data points. Sample TW58 from Capsule T was broken into two samples, TW58a and TW58b, thus providing the two data points.

- (e) Circumferential Weld Seam W05 was fabricated with weld wire type SMIT 40, Heat # 25295, Flux type SMIT 89, Lot # 2275. The surveillance weld was fabricated with weld wire type SMIT 40, Heat # 25295, Flux type SMIT 89, Lot # 1103 and is representative of the intermediate to lower shell circumferential weld.
- (f) The chemical compositions for the extended beltline forging materials are based on Sequoyah Unit 1 certified data, except for the weight percent copper values. The maximum weight percent copper value for A508 Class 2 forging materials is conservatively applied, as described in WCAP-17539-NP, Revision 1^[15].
- (g) Except for the weight percent nickel, the chemical compositions were taken from a chemical analysis performed on the weld wire (heat # 25006) included in the Rotterdam weld certification records. A value of 1.0 was conservatively assumed, as described in WCAP-17539-NP, Revision 1^[15].
- (h) The initial RT_{NDT} was determined using all available measured data for heat # 25006 as described in WCAP-17539-NP, Revision 1^[15]. In absence of USE data for weld heat # 25006, weld heat # 25295 test results from the first surveillance capsule withdrawn from Sequoyah Unit 1 were used, also as described in WCAP-17539-NP, Revision 1^[15].
- (i) The Lower Shell to Bottom Head Ring Weld was fabricated using the same weld wire heat number and flux type as the Intermediate Shell to Lower Shell Circumferential Weld.

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-4
 Peak Neutron Fluence Projections on the Reactor Vessel Clad/Base
 Metal Interface for Sequoyah Unit 1 ($\times 10^{19}$ n/cm², E > 1.0 MeV)

Reactor Vessel Material	Fluence ^(a)	
	32 EFPY	52 EFPY
Upper Shell Forging 06	0.0369	0.0584
Intermediate Shell Forging 05	1.73	2.66
Lower Shell Forging 04	1.73	2.66
Bottom Head Ring 03	0.215	0.336
Upper Shell to Intermediate Shell Circumferential Weld W06	0.0369	0.0584
Intermediate Shell to Lower Shell Circumferential Weld W05	1.72	2.65
Lower Shell to Bottom Head Ring Weld W04	0.215	0.336

Note:

- (a) Fluence was updated per TLAA, WCAP-17539-NP, Revision 1 Tables 2-1 and 2-2^[15].

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-5
Sequoyah Unit 1 Calculation of the ART Values for the 1/4T Location at 52 EFPY^(a)

Material	RG 1.99 R2 Method	CF (°F)	FF	IRT _{NDT} ^(b) (°F)	ΔRT _{NDT} ^(c) (°F)	Margin ^(d) (°F)	ART ^(e) (°F)
Reactor Vessel Beltline Materials							
Intermediate Shell Forging 05	Position 1.1	115.6	1.1301	40	130.6	34.0	204.6
Lower Shell Forging 04	Position 1.1	95.0	1.1301	73	107.4	34.0	214.4
	Position 2.1	109.3	1.1301	73	123.5	17.0 ^(f)	213.5
Intermediate to Lower Shell Circumferential Weld Seam	Position 1.1	161.3	1.1291	-40	182.1	56.0	198.1
	Position 2.1	139.3	1.1291	-40	157.3	28.0 ^(f)	145.3
Reactor Vessel Extended Beltline Materials							
Upper Shell Forging 06	Position 1.1	123.9	0.2408	23	29.8	29.8	82.7
Bottom Head Ring 03	Position 1.1	122.3	0.5722	5	70.0	34.0	109.0
Upper Shell to Intermediate Shell Circumferential Weld W06 (Heat #25006)	Position 1.1	207.0	0.2408	10	49.8	49.8	109.7
Lower Shell to Bottom Head Ring Weld W04 (Heat #25295)	Position 1.1	161.3	0.5722	-40	92.3	56.0	108.3
	Position 2.1	139.3	0.5722	-40	79.7	28.0 ^(f)	67.7

Notes:

- (a) Neutron fluence values used for all materials obtained from Table 5-4 for 52 EFPY.
- (b) Initial RT_{NDT} values are measured values.
- (c) $\Delta RT_{NDT} = CF * FF$
- (d) $Margin = 2 * (\sigma_i^2 + \sigma_\Delta^2)^{1/2}$
- (e) $ART = Initial RT_{NDT} + \Delta RT_{NDT} + Margin$ (°F)
- (f) Data deemed credible (See Reference 15), thus the reduced σ_Δ will be used to determine margin for the surveillance forging and surveillance weld material.

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-6
Sequoyah Unit 1 Calculation of the ART Values for the 3/4T Location at 52 EFPY^(a)

Material	RG 1.99 R2 Method	CF (°F)	FF	IRT _{NDT} ^(b) (°F)	ΔRT _{NDT} ^(c) (°F)	Margin ^(d) (°F)	ART ^(e) (°F)
Reactor Vessel Beltline Materials							
Intermediate Shell Forging 05	Position 1.1	115.6	0.8481	40	98.0	34.0	172.0
Lower Shell Forging 04	Position 1.1	95.0	0.8481	73	80.6	34.0	187.6
	Position 2.1	109.3	0.8481	73	92.7	17.0 ^(f)	182.7
Intermediate to Lower Shell	Position 1.1	161.3	0.8471	-40	136.6	56.0	152.6
Circumferential Weld Seam	Position 2.1	139.3	0.8471	-40	118.0	28.0 ^(f)	106.0
Reactor Vessel Extended Beltline Materials							
Upper Shell Forging 06	Position 1.1	123.9	0.1291	23	16.0	16.0	55.0
Bottom Head Ring 03	Position 1.1	122.3	0.3579	5	43.8	34.0	82.8
Upper Shell to Intermediate Shell Circumferential Weld W06 (Heat #25006)	Position 1.1	207.0	0.1291	10	26.7	26.7	63.4
Lower Shell to Bottom Head Ring Weld W04 (Heat #25295)	Position 1.1	161.3	0.3579	-40	57.7	56.0	73.7
	Position 2.1	139.3	0.3579	-40	49.9	28.0 ^(f)	37.9

Notes:

- (a) Neutron fluence values used for all materials obtained from Table 5-4 for 52 EFPY.
- (b) Initial RT_{NDT} values are measured values.
- (c) $\Delta RT_{NDT} = CF * FF$
- (d) $Margin = 2 * (\sigma_i^2 + \sigma_\Delta^2)^{1/2}$
- (e) $ART = Initial RT_{NDT} + \Delta RT_{NDT} + Margin$ (°F)
- (f) Data deemed credible (See Reference 15), thus the reduced σ_Δ will be used to determine margin for the surveillance forging and surveillance weld material.

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-7
Summary of the Sequoyah Unit 1 Reactor Vessel Beltline and Extended Beltline
Material ART Values

Material	RG 1.99 R2 Method	1/4 ART (°F)	3/4 ART (°F)
Reactor Vessel Beltline Materials			
Intermediate Shell Forging 05	Position 1.1	204.6	172.0
Lower Shell Forging 04	Position 1.1	214.4	187.6
	Position 2.1	213.5	182.7
Intermediate to Lower Shell Circumferential Weld Seam	Position 1.1	198.1	152.6
	Position 2.1	145.3	106.0
Reactor Vessel Extended Beltline Materials			
Upper Shell Forging 06	Position 1.1	82.7	55.0
Bottom Head Ring 03	Position 1.1	109.0	82.8
Upper Shell to Intermediate Shell Circumferential Weld W06	Position 1.1	109.7	63.4
Lower Shell to Bottom Head Ring Weld W04	Position 1.1	108.3	73.7
	Position 2.1	67.7	37.9

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-8

Sequoyah Unit 1 Calculation of the ART Values for the Inlet and Outlet Nozzles at 52 EFPY^(a)

Material	Heat #	Fluence ($\times 10^{19}$ n/cm ² , E > 1.0 MeV)	IRT _{NDT} ^(b) (°F)	Δ RT _{NDT} (°F)	Margin ^(c) (°F)	ART ^(d) (°F)
Inlet Nozzle 11	4846	0.00358	-15	0	0	-15
Inlet Nozzle 12	4849	0.00358	-1	0	0	-1
Inlet Nozzle 13	4863	0.00358	-22	0	0	-22
Inlet Nozzle 14	4865	0.00358	-31	0	0	-31
Outlet Nozzle 15	4845	0.00358	-19	0	0	-19
Outlet Nozzle 16	4850	0.00358	-10	0	0	-10
Outlet Nozzle 17	4862	0.00358	-24	0	0	-24
Outlet Nozzle 18	4864	0.00358	-40	0	0	-40

Notes:

- (a) Neutron fluence value for the inlet nozzle to upper shell welds at 52 EFPY was used for all nozzle materials per MCOE-LTR-16-12-NP^[16].
- (b) Initial RT_{NDT} values are measured values.
- (c) Margin = $2 * (\sigma_i^2 + \sigma_\Delta^2)^{1/2} = 0$ for materials with measured IRT_{NDT} values and fluence values less than 1×10^{17} n/cm² (E > 1.0 MeV).
- (d) ART = Initial RT_{NDT} + Δ RT_{NDT} + Margin (°F); Δ RT_{NDT} = 0 for fluence values less than 1×10^{17} n/cm² (E > 1.0 MeV) per Reference 17.

Table 5-9

Summary of the Sequoyah Unit 1 Nozzle Material ART Values at 52 EFPY

Nozzle Material	Limiting ART Value (°F)
Inlet Nozzle 12 Heat # 4849	-1
Outlet Nozzle 16 Heat # 4850	-10

PRESSURE TEMPERATURE LIMITS REPORT

Table 5-10
 RT_{PTS} Calculations for Sequoyah Unit 1 Beltline and Extended Beltline
 Materials at 52 EFPY^(a)

Material	Fluence (x 10 ¹⁹ n/cm ² , E>1.0 MeV)	FF	CF (°F)	ΔRT _{PTS} ^(b) (°F)	Margin (°F)	RT _{NDT(U)} ^(c) (°F)	RT _{PTS} ^(d) (°F)
Reactor Vessel Beltline Materials							
Intermediate Shell Forging 05	2.66	1.2616	115.6	145.8	34.0	40	219.8
Lower Shell Forging 04	2.66	1.2616	95.0	119.8	34.0	73	226.8
Lower Shell Forging 04 (Using S/C Data)	2.66	1.2616	109.3	137.9	17.0 ^(e)	73	227.9
Circumferential Weld Metal	2.65	1.2607	161.3	203.3	56.0	-40	219.3
Circumferential Weld Metal (Using S/C Data)	2.65	1.2607	139.3	175.6	28.0 ^(e)	-40	163.6
Reactor Vessel Extended Beltline Materials							
Upper Shell Forging 06	0.0584	0.3180	123.9	39.4	34.0	23	96.4
Bottom Head Ring 03	0.336	0.6997	122.3	85.6	34.0	5	124.6
Upper Shell to Intermediate Shell Circumferential Weld W06	0.0584	0.3180	207.0	65.8	56.0	10	131.8
Lower Shell to Bottom Head Ring Weld W04	0.336	0.6997	161.3	112.9	56.0	-40	128.9
Lower Shell to Bottom Head Ring Weld W04 (Using S/C Data)	0.336	0.6997	139.3	97.5	28.0 ^(e)	-40	85.5

Notes:

- (a) Neutron fluence values used for all materials obtained from Table 5-4 for 52 EFPY.
- (b) $\Delta RT_{PTS} = CF * FF$
- (c) Initial RT_{NDT} values are measured values
- (d) $RT_{PTS} = RT_{NDT(U)} + \Delta RT_{PTS} + \text{Margin (°F)}$
- (e) Data deemed credible (See Reference 15), thus the reduced σ_{Δ} will be used to determine margin for the surveillance forging and surveillance weld material.

PRESSURE TEMPERATURE LIMITS REPORT

6.0 References

1. WCAP-8233, *Tennessee Valley Authority Sequoyah Unit No. 1 Reactor Vessel Radiation Surveillance Program*, S. E. Yanichko, et. al., December 1973.
2. Code of Federal Regulations, 10CFR50, Appendix H, *Reactor Vessel Material Surveillance Program Requirements*, U.S. Nuclear Regulatory Commission, Washington, D.C.
3. ASTM E23 *Standard Test Method Notched Bar Impact Testing of Metallic Materials*, in ASTM Standards, American Society for Testing and Materials, Philadelphia, PA.
4. Section XI of the ASME Boiler and Pressure Vessel Code, Appendix G, *Fracture Toughness Criteria for Protection Against Failure*
5. ASTM E185-82, Annual Book of ASTM Standards, Section 12, Volume 12.02, *Standard Practice for Conducting Surveillance Tests for Light-Water Cooled Nuclear Power Reactor Vessels*.
6. Regulatory Guide 1.99, Revision 2, *Radiation Embrittlement of Reactor Vessel Materials*, U.S. Nuclear Regulatory Commission, May 1988.
- 7a. WCAP-15224, *Analysis of Capsule Y from the Tennessee Valley Authority Sequoyah Unit 1 Reactor Vessel Radiation Surveillance Program*, T.J. Laubham, et. al., June 1999.
- 7b. WCAP-13333, *Analysis of Capsule X from the Tennessee Valley Authority Sequoyah Unit 1 Reactor Vessel Radiation Surveillance Program*, M.A. Ramirez, S. L. Anderson, L. Albertin, June 1992.
- 7c. SwRI Project 06-8851, *Reactor Vessel Material Surveillance Program for Sequoyah Unit No. 1: Analysis of Capsule U*, P. K. Nair, et al., October 1986.
- 7d. WCAP-10340, Revision 1, *Analysis of Capsule T from the Tennessee Valley Authority Sequoyah Unit 1 Reactor Vessel Radiation Surveillance Program*, S.E. Yanichko, et. al., February 1984.
8. CVGRAPH, Hyperbolic Tangent Curve-Fitting Program, Version 4.1, developed by ATI Consulting, March 1999.
9. WCAP-14040-NP-A, Revision 2, *Methodology Used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves*, J.D. Andrachek, et. al., January 1996.
10. WCAP-15293, Revision 2, *Sequoyah Unit 1 Heatup and Cooldown Limit Curves for Normal Operation and PTLR Support Documentation*, J.H. Ledger, July 2003.
11. Westinghouse Letter to TVA, TVA-93-105, *Cold Overpressure Mitigation System Code Case and Delta-P Calculation*, dated May 19, 1993.
12. Calculation SQN-IC-014, *Demonstrated Accuracy Calculation for Cold Overpressure Protection System*.

PRESSURE TEMPERATURE LIMITS REPORT

13. ASME Code Case N-640, *Alternative Reference Fracture Toughness for Development of P-T Limit Curves for Section XI, Division 1*, dated February 26, 1999.
14. WCAP-15984-P, Revision 01, *Reactor Vessel Closure Head/Vessel Flange Requirements Evaluation for Sequoyah Units 1 and 2*, W. Bamford, et.al., April 2003.
15. WCAP-17539-NP, Revision 1, *Sequoyah Units 1 and 2 Time-Limited Aging Analysis on Reactor Vessel Integrity*, E.J. Long, May 2015.
16. MCOE-LTR-16-12-NP, Revision 0, *Pressure-Temperature Limit Curve Development for Extended Plant Operation for Sequoyah Units 1 and 2 Reactor Vessel Nozzles*, E.M. Ruminski, A.M. Carolan, August 2016.
17. U.S. NRC Regulatory Issue Summary (RIS) 2014-11, *Information on Licensing Applications for Fracture Toughness Requirements for Ferritic Reactor Coolant Pressure Boundary Components*, dated October 14, 2014.
18. LTR-SCS-16-25, Revision 0, *Cold Overpressure Mitigation System (COMS) Setpoint Analysis for Sequoyah Units 1 and 2 PORV Replacement*, R.A. Freund, B.D. Jaskiewicz, November 2016.
19. LTR-SCS-17-43, Revision 0, *Sequoyah LTOPS Setpoint Implementation for PORV Replacement Program Delay*, R.A. Freund, September 2017.