



ATTACHMENT 1  
SUPPLY POWER STATION, UNIT  
DOCKET NO: 50-281  
REPORT NO: 80-008/03L-0  
EVENT DATE: 06-23-80

TITLE OF REPORT: RADIATION MONITOR (RM-SV-211) SET POINT DRIFT

1. Description of Event:

While performing Periodic Test 26.1 the Air Ejector Radiation Monitor Alarm Setpoint was found to be higher than allowed by Technical Specification 3.7.E Table 3.7.5. This is reportable as per Technical specification 6.6.2.b.(4.

2. Probable Consequences and Status of Redundant Systems:

The Air Ejectors for Unit two were not in service, therefore, there was no release and the health and safety of the public were not affected.

3. Cause:

The high alarm setpoint was caused by instrument drift in the Radiation Monitor (RM-SV-211).

4. Immediate Corrective Action:

Recalibrated high Alarm Setpoint.

5. Subsequent Corrective Action:

None required

6. Actions Taken to Prevent Recurrence

No further action required. The Periodic Testing program is designed to locate this type of failure.

7. Generic Implications

None