


VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

April 28, 1981



JACK H. FERGUSON
EXECUTIVE VICE PRESIDENT

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Serial No. 261
NO/WRM:jmj
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

AMENDMENT TO OPERATING LICENSES DPR-32 AND DPR-37
SURRY POWER STATION UNITS NO. 1 AND NO. 2
SUPPLEMENT TO PROPOSED TECHNICAL SPECIFICATION CHANGE

By a letter dated September 20, 1978 (Serial No. 516), we proposed changes to the Technical Specifications for Surry Power Station, Units No. 1 and No. 2 to reflect revisions to Table 4.17-1 and Table 4.17-2. These tables list hydraulic suppressor data for each unit. The proposed changes enclosed in Attachment 1 supplement our September 20, 1978 license amendment application.

By a letter from Mr. Darrell G. Eisenhut to all power reactor licenses dated November 20, 1980, we were requested to submit a license amendment application to incorporate applicable portions of the revised inservice surveillance requirements for snubbers into the Technical Specifications for Surry Units 1 and 2. The revisions, which were in the form of revised Standard Technical Specifications, have been reformatted to correspond with the Surry Technical Specifications format.

The changes which are enclosed include revised surveillance requirements for visual inspections and for functional tests, both for hydraulic snubbers and mechanical snubbers. Included in this request is a revised listing of all safety-related hydraulic and mechanical snubbers for each unit. Table 4.17-1 and Table 4.17-2 list hydraulic snubbers for Unit 1 and Unit 2, respectively. Table 4.17-3 and Table 4.17-4 list mechanical snubbers for Unit 1 and Unit 2, respectively. The use of separate tables for hydraulic and mechanical snubbers for each unit will facilitate future updates of the safety-related snubber listing. The changes also include a proposed revision to Specification 6.5-B to require the maintenance of records of the service lives of all hydraulic and mechanical snubbers for the duration of the Operating Licenses.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the System Nuclear Safety and Operating Committee. It has been determined that this request does not pose an unreviewed safety question.

A001
S
3/40

8105040168
P

We have reviewed this request in accordance with the criteria in 10 CFR 170.22. Since this request supplements our previous license amendment application referenced above, no additional license amendment fee is required.

Very truly yours,



J. H. Ferguson
Executive Vice President - Power

Attachments:

1. Proposed Technical Specification Change

cc: Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
Region II

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by J. H. Ferguson, who is Executive Vice President-Power, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 28th day of April, 19 81.

My Commission expires: 2-26, 19 85.

Ann C. Morse

Notary Public

(SEAL)