

ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED
ELECTRICAL EQUIPMENT
IEB 79-01B

TECHNICAL EVALUATION REPORT
DOCKET NO. 50-280
PLANT: Surry
DATED: November 25, 1980

Licensee: Virginia Electric and Power Company

Type Reactor: Westinghouse PWR

V. L. Brownlee
Prepared by V. L. Brownlee
11/26/80

Engineering Support Section
Reactor Construction and Engineering
Support Branch, RII

8106010 776

TABLE OF CONTENTS

	<u>PAGE NO.</u>
1. INTRODUCTION	1
1.1 General	1
2. BACKGROUND AND DISCUSSION	1
2.1 General	1
2.2 On-Site Inspection	2
2.3 Evaluation of Licensee's Report	2
3. GENERAL INFORMATION	3
3.1 Identification of Class 1E Electrical Systems.....	3
3.2 Service Conditions	4
3.3 Qualification Documentation	4
4. EQUIPMENT DATE REVIEW	4
4.1 Qualified Equipment	4
4.2 Equipment With Aging Less Than Plant Life	4
4.3 Equipment to be Replaced, Modified, or Relocated - Licensee Identified	5
4.4 Equipment with Unresolved Qualification Items	5
4.5 Equipment Not Qualified	5
4.6 Outstanding Items - Licensee Identified	5
4.7 Discussion of On-Site Inspection	6
5. CONCLUSIONS	6

Attachment 1	Review Tabulation Sheets Used in Evaluation of Licensee's Report
Attachment 2	List of Standard Systems
Attachment 3	List of Documents That Support Environmental Qualification of Licensee's Equipment
Attachment 4	Outstanding Items (Licensee Identified)

1. INTRODUCTION

1.1 General

The NRC Office of Inspection and Enforcement (I/E) issued Bulletin 79-01B, "Environmental Qualification of Class 1E Equipment" in January 1980. This bulletin required the licensee to perform a detailed evaluation of the environmental qualification on Class 1E electrical equipment required to function under postulated accident conditions and to submit a report on this action.

This document is a report on the evaluation of the licensee's response to this bulletin.

2. BACKGROUND AND DISCUSSION

2.1 General

The evaluation of the licensee's response was accomplished by performing an on-site inspection of selected class 1E equipment and by examining the licensee's report for completeness and technical accuracy. The licensee's report used in this evaluation is dated November 1, 1980. The November 1, 1980 report includes the responses to the bulletin supplements with the exception of IE Supplement 3 issued on October 24, 1980.

2.2 On-Site Inspections

The on-site inspection, made on selected 1E equipment, verified proper installation of equipment, overall interface integrity, location with respect to flood level for equipment inside the containment, and manufacturers nameplate data. The manufacturer and model number from the nameplate data was compared to information given in the Component Evaluation Work Sheets (CES) of the licensee's report.

Components that were examined during the field inspection are identified by an asterisk (*) in Attachment 1. If any discrepancies were noted between the installed equipment and the correspondent equipment addressed in the licensee's report, they are discussed in Section 4 of this report. The site inspection is documented by report number 50-280/80-14 of May 2, 1980.

2.3 Evaluation of Licensee's Report

Each component as addressed on the Component Evaluation Work Sheets (CES) of the licensee's report was examined for completeness and accuracy to the criteria given in the bulletin. This examination assumed qualification documents (analysis, test reports, etc.) referenced by the licensee in their submittal are acceptable.

The results of this examination are documented in Attachment 1. The CES page numbers in column 1 of Attachment 1 is the same CES page found in the licensee's report.

3. GENERAL INFORMATION

3.1 Identification Of Class 1E Electrical Equipment

The licensee's list of systems was compared to the systems listed on Attachment 2. This list is considered to be a standard list for Westinghouse, NSSS, PWR reactors.

It is recognized that there are differences in nomenclature of systems because of plant vintage and engineering design, therefore, many of these systems may not exist for Surry 1 plant or the function of these systems for the Surry 1 plant may be performed by comparable systems with different names. In any case, all the systems of Attachment 2 were not addressed or listed in the licensee's report. The systems described in the licensee's report are denoted by a check(✓) next to the systems listed on Attachment 2. The systems that were not addressed in the licensee's report are denoted by an asterisk (*). The licensee's representative informs IE:II that the asterisked (*) systems on Attachment 2 will be addressed in the VEPCO response due February 1, 1981.

3.2 Service Conditions

The service condition accident environment, HELB/LOCA inside containment and HELB outside containment are indicated or discussed in the licensee's report and are based on the FSAR accident analysis.

3.3 Qualification Documentation

Attachment 3 is list of documents (test reports, analysis, letters, etc.) used by the licensee in determining the environmental qualification of plant equipment for Surry 1. These references have been tabulated and are indicated on the applicable CES of their report.

4. EQUIPMENT DATA REVIEW

4.1 Equipment that is considered to meet IEB 79-01B requirements are categorized as 1 in the last column of Attachment 1.

4.2 Equipment whose qualified life (Aging) is less than the life of the plant is categorized as 2 in the last column of Attachment 1.

4.3 The licensee has identified specific equipment which has been or is being replaced, modified or relocated as a result of their IEB 79-01B efforts. This equipment is categorized as 3 in the last column of Attachment 1.

4.4. Equipment whose qualification is unresolved (such as, a qualification record search is still in process, tests are scheduled to determine qualification, additional information is needed by the NRC reviewer to satisfy him that equipment is qualified, etc.) is categorized as 4 in the last column of Attachment 1.

- 4.5 Equipment that the licensee has identified as not being qualified required an LER with justification for continued plant operation.

No LER's were received in Region II.

- 4.6 Equipment whose qualification (Aging exempted to a certain degree - see DOR guideline Section 4) is unresolved, as identified by the licensee is listed in Attachment 4 as Outstanding Items.

The licensee has provided justification for continued plant operation for many, if not all, of these outstanding items in their report. In many cases, this is provided on their CES or in a special section of the report. In some cases the licensee states that this justification is by Engineering Analysis that are available at their office.

- 4.7 The component data obtained during the on-site inspection could not be compared with the information submitted on several of the licensee's Component Evaluation Sheets. This comparison could not be made because the licensee had not yet determined the component model. The licensee has committed to supplying the component model data during the present steam generator outage. Asterisked items in Attachment 1 are components examined during the on-site inspection.

5. CONCLUSIONS

Due to the time constraints imposed by the Commission Memo and Order of 5/28/80 this evaluation is based on the licensee submittal dated November 1,

1980. This licensee's report does not address all items that may be pertinent to Surry 1 plant as a result of a bulletin supplement issued on 9/30/80 and 10/24/80 respectively. Specifically, information on cold shutdown and TMI Lessons Learned related equipment which is received subsequent to 11/1/80 will be evaluated by the EQB of NRR.

The licensee's actions meet the requirements of the Commission Memo and Order of 5/23/80 and justification for continued plant operation with many of the components that have unresolved qualification items is indicated in Section 4.6. Based on the information available, the Region II reviewer considers that the justification is commensurate for the areas identified, that the proposed corrective action meets requirements of the Commission Memo and Order of 5/23/80 and, therefore, plant operation can continue until these items are resolved as committed to by the licensee.

This evaluation is based on the on-site inspections, the information supplied by the licensee in their submittal, telephone conversations with the licensee's representatives, their FSAR, and the assumption that the Qualification Documents (Test Reports, Analysis, Letter, etc.) are acceptable.

The results of this evaluation does not necessarily imply that the equipment is unreliable, unsafe or represents a significant safety issue; it does imply that additional information is required. This is indicated by the applicable categorization indicated in the last column of Attachment 1.

RECEIVED DATE 11/15/86 LIBRARY

Digitized by srujanika@gmail.com

- B** - Indicate the item is below the blood level
C - Indicate the item is above the blood level
D - Indicate the item is not applicable
E - Indicate the item is not applicable
F - Indicate the item is not applicable
G - Indicate the item is not applicable
H - Record date last used
I - Equine last used
J - Aging is less than life of plant left
K - Equine last used
L - Equine last used
M - Equine last used
N - Equine last used
O - Indicate the category
P - Indicate the item is not applicable
Q - Indicate the item is not applicable
R - Indicate the item is not applicable
S - Indicate the item is not applicable
T - Indicate the item is not applicable
U - Indicate the item is not applicable
V - Proprietary
W - Lichenous dermatitis
X - Record date last used
Y - Equine last used
Z - Aging is less than life of plant left

Condenser air flow measured to determine load

FACILITY

SYSTEM

Survey 1
Chancery of Volume Control

ATTACHMENT 1
FOR IED 79-018
TER

PAGE

OF

2

CES. Page No.	Equip. I. D. #	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual.		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items
					Inside	Outside					Replace	Relocate		
6-2	1275A	MOV	✓	4C	-	✓	4b	-	-	-	-	-	R, L	4b,c
6-3	1275B	MOV	✓	4C	-	✓	4b	-	-	-	-	-	R, L	4b,c
6-4	1275C	MOV	4C	4C	-	✓	4b	-	-	-	-	-	R, L	4b,c
6-5	1373	MOV	✓	4C	-	✓	4b,c	-	-	-	-	-	R, L	4b,c
6-6	1381	MOV	✓	4C	-	✓	4b,c	-	-	-	-	-	R, L	4b,c
6-7	P-1A	MTR	✓	4C	-	✓	4b,c	-	-	-	-	-	R, L	4b,c
6-8	P-1B	MTR	✓	4C	-	✓	4b,c	-	-	-	-	-	R, L	4b,c
6-9	P-1C	MTR	✓	4C	-	✓	4b,c	-	-	-	-	-	R, L	4b,c
6-10	1122	FCV	✓	4C	-	✓	4b,c	-	-	-	-	-	R, L	4b,c
6-11	1122	FT									yes		L	3
6-12	1311	SV									yes		L	3
6-13	1115B	MOV	✓	4C	-	✓	4b,c	-	-	-	-	-	R, L	4b,c

Code:

- B = Indicates the item is below the flood level
- ✓ or S = Indicates the item is Satisfactory
- or N = Indicates the item is Not Applicable
- UL = Indicates the item is Unresolved, Licensee Identified
- P = Proprietary
- L = Licensee Identified
- R = Reviewer Identified
- 1 = Equipment is qualified
- 2 = Aging is less than life of plant with licensee indicating periodic replacement

3 = Equipment requires modification (resolution, shielding, etc.)

4 = Qualification of equipment unresolved

- a) Testing schedule but not complete
- b) Reviewer needs additional information
- c) Qual. Record search still in process

5 = Equipment not qualified

6 = Item identified to EQB for resolution

REVIEWER

VL Brunelle

DATE 11/19/80

FACULTY Sixty One
SYSTEM Chemical & Volume Controls

**ATTACHMENT I
FOR IEB 79-01B
TER**

PAGE 2 OF

2

CES. Page No.	Equip. I. D. #	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual. Containment		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items
					Inside	Outside					Replace	Relocate		
6-14	1115C	MOV	✓	4C	—	✓	4b,c	—	—	—	—	—	R,L	4b,c
6-15	1115D	MOV	✓	4C	—	✓	4b,c	—	—	—	—	—	R,L	4b,c
6-16	1115E	MOV	✓	4C	—	✓	4b,c	—	—	—	—	—	R,L	4b,c
6-17	1289A	MOV	✓	4C	—	✓	4b,c	—	—	—	—	—	R,L	4b,c
6-18	1289B	MOV	✓	✓	—	✓	4b,c	—	—	—	—	—	R,L	4b,c
6-19	1204	SV									yes		L	3
6-20	1200A	SV	✓	4C	4C	—	4b,c	4C	—	—	—	—	R,L	4b,c
6-21	1200B	SV	✓	4C	4C	—	4b,c	4C	—	—	—	—	R,L	4b,c
6-22	1200C	SV	✓	4C	4C	—	4b,c	4C	—	—	—	—	R,L	4b,c

१०८

b = indicates the item is below the flood level

or S = Indicates the item is Satisfactory

- OF N - Indicates the item is Not Applicable

UL = Indicates the item is Unresolved, Licensees Identified

P = Proprietary

b - Licensee Identified

R = Reviewer identified

I = Evidence is qualified

- 1 - Equipment is qualified
- 2 - Aging is less than life of plant with licensee indicating periodic replacement

3 = Equipment requires modification (resolution, shielding, etc.)

4 - Qualification of equipment unresolved

a) Testing schedule but not complete

- b) Reviewer needs additional information

- b) Reviewer needs additional information
- c) Dual record search of all 10 programs

c) Qual. Records Sealed

6 = Item identified to EOB for resolution

6 - Item identified to EOA for resolution

SEVENTEEN V. Brouwer DATE 11/19/80

LLB/BSW/ML

DATE 11/19/60

REVIEWER

Initials/Signature Precedence Replaces Previous

- 2 - Adding to the chain list of plans which it contains
- 1 - Equilibrium is reached
- 3 - Replaces previous document
- 4 - Licensee identified
- 5 - Equipment not qualified
- 6 - Item identified to RPL for requalification

- 7 - Revocation of license is unexecuted, licensee identified
- 8 - Revocation before addendum issued to processor
- 9 - Qual. Record search recall to processor
- 10 - Initial action file Note Applicable
- 11 - Initial action file Note Applicable
- 12 - Qualification of equipment of a suitable type not completed
- 13 - Technical achievable but not completed
- 14 - Qualification of equipment unexecuted
- 15 - Qualification of equipment (residual, obsoleted, etc.)

CEB.	Page No.	Category	Item	Licensee	Action	Qual.	Method	Place	Inside	Outside	Qual.	Chems.	Subm.	Licensee Action	Outstanding	Item
6-23	1A-1-2 SOUTH	MCC	-	AC	-	AC	46C	-	-	-	R'L	46C				
6-24	1A-1-2 NORTH	MCC	-	AC	-	AC	46C	-	-	-	R'L	46C				
6-25	1A-1-2 WEST	MCC	-	AC	-	AC	46C	-	-	-	R'L	46C				
6-26	1A-1-2 EAST	MCC	-	AC	-	AC	46C	-	-	-	R'L	46C				
6-27	TYPE IIC	EPA	/	AC	/	-	46C	L	-	-	R'L	46C				
6-28	TYPE IIID	EPA	/	AC	/	-	46C	L	-	-	R'L	46C				
6-29	TYPE IIIA	EPA	L	AC	L	-	46C	L	-	-	R'L	46C				
6-30	TYPE IIIB	EPA	L	AC	L	-	46C	L	-	-	R'L	46C				
6-31	TYPE IIIC	EPA	L	AC	L	-	46C	L	-	-	R'L	46C				
6-32	TYPE IIID	EPA	L	AC	L	-	46C	L	-	-	R'L	46C				
6-33	NO. 3187 SPEC I	CBL	L	AC	L	-	46C	L	-	-	R'L	46C				
6-34	SPEC II	CBL	L	AC	L	-	46C	L	-	-	R'L	46C				

FACILITY Sunny I
SYSTEM Common electrical Equipment

ATTACHMENT 1
FOR IEB 79-01B
TER

PAGE 2 OF 4

CES. Page No.	Equip. I. D. #	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual. Containment		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items
					Inside	Outside					Replace	Relocate		
6-35	SPEC. NO. 439	CBL	L	L	L	-	4b	-	-	-	-	-	R	4b
6-36	SPEC. NO. 3190	CBL	L	L	L	-	4b,c	-	-	-	-	-	L	4b,c
6-37	SPEC. NO. 325	CBL	L	4b,c	L	-	4b,c	-	-	-	-	-	R,L	4b,c
6-38	SPEC. NO. 381C	CBL	L	4b,c	4b,c	-	4b,c	-	-	-	-	-	RL	4b,c
6-39	SPEC. NO. 381E	CLL	L	4b,c	4b,c	-	4c	-	-	-	-	-	R,L	4b,c
6-40	SPEC. NO. 381	CBL	L	4a	4b,c	-	4b,c	-	-	-	-	-	L	4b,c
6-41	SPEC. NO. 410	CBL	L	L	L	-	4b	-	-	-	-	-	R	4b
6-42	SPEC. NO. 420	CBL	L	4a	L	-	4a	-	-	-	-	-	L	4a
6-43	TYPE IA	EPA	L	4c	4c	-	4c	-	-	-	-	-	L	4c
6-44	TYPE IB	EPA	L	4c	4c	-	4c	-	-	-	-	-	L	4c
6-45	TYPE IC	EPA	L	4c	4c	-	4c	-	-	-	-	-	L	4c
6-46	TYPE II	EPA	L	4c	4c	-	4c	-	-	-	-	-	L	4c

Code:

- B = Indicates the item is below the flood level
- ✓ or S = Indicates the item is Satisfactory
- or N = Indicates the item is Not Applicable
- UL = Indicates the item is Unresolved, Licensee Identified
- P = Proprietary
- L = Licensee Identified
- R = Reviewer Identified
- 1 = Equipment is qualified
- 2 = Aging is less than life of plant with licensee indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
- 4 = Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. Record search still in process
- 5 = Equipment not qualified
- 6 = Item identified to EQB for resolution

REVIEWER

V.Brounlee
DATE 11/12/80

REVIEWER: LL Brown
DATE: 11/19/82

3 - Equilibrium reequilibration model classification (residual load level)

- 3 - Equilibrium requirement reduces model specification (restricts)
 - 4 - Qualitative reduction of equilibrium model
 - 5 - Equilibrium requirement does not qualify model
 - 6 - It can be difficult to find one equilibrium

TEH
FOR IER 79-018
ATTACHMENT 1

Principles of Geophysics

Page 3 of 4

卷之三

SYSTEM

Survey I Common Electrical Experiment

ATTACHMENT I
FOR IEB 79-01B
TEN

PAGE _____ OF _____

4 08 4

Coupe:

- B - Indicates the item is below the flood level
 ✓ or S - Indicates the item is Satisfactory
 - or N - Indicates the item is Not Applicable
 UL - Indicates the item is Unresolved, Licensee Identif
 P - Proprietary
 L - Licensee Identified
 R - Reviewer Identified
 1 - Equipment is qualified
 2 - Aging is less than life of plant with licensee
 indicating periodic replacement

- 3 - Equipment requires modification (resolution, shielding, etc.)
 - 4 - Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. Record search still in process
 - 5 - Equipment not qualified
 - 6 - Item identified to EQB for resolution

REVIEW

V. Borenstein DA

DATE 11/17/14

28/5/11 DATE - REVIEWER Ullaswamy

Digitized by srujanika@gmail.com

- 8 - Thrombocytopenia can occur as below the ESR and level
 9 - Inflammation can cause tissue damage to Sclerotic category
 10 - N - Inflammation can cause tissue damage to bone Alveolar cavity
 11 - Inflammation can cause tissue damage to bone Alveolar cavity
 12 - Prostaglandin P
 13 - Lymphocytes increase in number
 14 - Neutrophils increase in number
 15 - Eosinophils decrease in number
 16 - Basophils decrease in number

TR
810-6238-08
AEROMARINE

SYSTEM

11/19/88

REVIEWER

INITIALS OF REVIEWER PERIODIC EXPLANATION

- 2 - Aging is more than 1/2 life of plane which license
- 1 - Equipment is deteriorated
- 3 - Revolving record not updated
- 4 - Equipment not used
- 5 - Equipment not qualified
- 6 - Item identified to EOB for resolution

- P - Proprietary item is unreviewed. Licensee identified
- Q - Item is the same item is Not Applicable
- R - Item is the same item is Not Applicable
- S - Item is the same item is Not Applicable
- T - Item is the same item is Not Applicable
- U - Item is the same item is Not Applicable
- V - Item is the same item is Not Applicable
- W - Item is the same item is Not Applicable
- X - Item is the same item is Not Applicable
- Y - Item is the same item is Not Applicable
- Z - Item is the same item is Not Applicable

B - Indicate the item is below the level of equipment unreviewed

C - Equipment qualification of equipment unreviewed

D - Qualifying schedule but not complete

E - Revolving record additional information

F - Item identified to EOB for resolution

G - Equipment not qualified

H - Revolving record not updated

I - Equipment not used

J - Revolving record not updated

K - Revolving record not updated

L - Revolving record not updated

M - Revolving record not updated

N - Revolving record not updated

O - Revolving record not updated

P - Proprietary item is unreviewed

Q - Item is the same item is Not Applicable

R - Item is the same item is Not Applicable

S - Item is the same item is Not Applicable

T - Item is the same item is Not Applicable

U - Item is the same item is Not Applicable

V - Item is the same item is Not Applicable

W - Item is the same item is Not Applicable

X - Item is the same item is Not Applicable

Y - Item is the same item is Not Applicable

Z - Item is the same item is Not Applicable

CES. PAGE No.	Equip. I. D.	Generic Acc'd.	Name Model, Manufact Date	Protective Coat	Qual. Quant Unit	Licensee Action	Subm. Date	Method Clima. Spray	Accur. Method Outdated	Helps Locate Identified by Items	Location Identified by Items	Identified by Items	Category of Equipment
6-72	101A	MOL	L	-	-	46	R	-	-	46	R	46	6-72
6-73	101B	MOL	L	-	-	43	R	-	-	43	R	46	6-73
6-74	101C	MOL	L	-	-	43	R	-	-	43	R	46	6-74
6-75	101D	MOL	L	-	-	2	L	-	-	2	L	2	6-75
6-76	102A	MOL	L	-	-	-	L	-	-	-	L	1	6-76
6-77	102B	MOL	L	-	-	-	L	-	-	-	L	1	6-77

PAGE 1 of 1

ATTACHMENT 1
FOR JES 79-018
TER

Comments
Serial
Comments

SYSTEM

ACCURACY

REVIEWS 11/19/60 DATE 11/19/60

Digitized by srujanika@gmail.com

TEK
F08 11E 8 79-018
ATTACHMENT 1

Concurrent Vacuum SYSTEM

— 7 — PAGE

REVIEWER Ulrichs DATE 11/19/82

દર્શાવાની પત્ર

- 3 - Equilibrium reagention model classification (reactions, substitutions, etc.)
 4 - Qualitative reagention of aqueous uncomplexed
 5 - Reversing equilibrium reactions and ionization in presence
 6 - Equilibrium not quantified to help for discussion

- H - Thrombocytes che tiene la beta-2m che il blood levels
 - or S - Thrombocytes che tiene la beta-2m che il satofactory
 - or N - Thrombocytes che tiene la beta-2m che il sato acceptable
 - UL - Thrombocytes che tiene la beta-2m che il sato acceptable
 - P - Propylene glycol
 - L - Lecithine idenctified
 - K - Kovalente idenctified
 - I - Polypropylene idenctified
 - 2 - Afling la gara che ille of planti with zinc acetate
 - 3 - Zinc acetate che produce zinc acetate

TEA
FOR TEA 79-018
ATTACHMENT 1

— 1615A —

גָּמְבָּרֶדְּגָן

FACILITY Sunny
SYSTEM Feedback

**AFTACHMENT I
FOR IED 79-018
TER**

PAGE 2 OF 2

Cause:

- B = Indicates the item is below the flood level
 - or S = Indicates the item is Satisfactory
 - or N = Indicates the item is Not Applicable
 - UL = Indicates the item is Unresolved, Licenses Identified
 - P = Proprietary
 - L = Licenses Identified
 - R = Reviewer Identified
 - 1 = Equipment is qualified
 - 2 = Aging is less than life of plant with licensee indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
 - 4 = Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. record search still in process
 - 5 = Equipment not qualified
 - 6 = Item identified to EQB for resolution

REVIEWER

VLBrouwer DATE 11/19/80

RELEASE DATE 11/19/2014 BY 1437

Digitized by srujanika@gmail.com

10 - Indicates the area in which the selected
category is located

9 - Indicates the area in which the selected
category is located

8 - Indicates the area in which the selected
category is located

7 - Indicates the area in which the selected
category is located

6 - Indicates the area in which the selected
category is located

5 - Indicates the area in which the selected
category is located

4 - Indicates the area in which the selected
category is located

3 - Indicates the area in which the selected
category is located

2 - Indicates the area in which the selected
category is located

1 - Indicates the area in which the selected
category is located

CIS.	Equipp.	I. D.	Name	Category of Page	Quotient		Quotient		Quotient		Quotient		Quotient		Quotient		Quotient		
					Subm.	Accurate.	Chines.	Sprav.	Hectad.	Decade	Place	Decade	Place	Decade	Decade	Decade	Decade	Decade	Decade
6-102	HC-2A	HC	L HC	-	46c	46c	-	-	R,L	46c	L	46c	-	46c	46c	46c	46c	46c	46c
6-103	HC-3B	HC	L HC	-	46c	46c	-	-	R,L	46c	L	46c	-	46c	46c	46c	46c	46c	46c
6-104	HA-103	HA	L	46c	46c	-	-	-	R,L	46c	L	46c	-	46c	46c	46c	46c	46c	46c
6-105	HC-2A	PUR	L PUR	-	46c	46c	-	-	R,L	46c	L	46c	-	46c	46c	46c	46c	46c	46c
6-106	HC-2B	PUR	L PUR	-	46c	46c	-	-	R,L	46c	L	46c	-	46c	46c	46c	46c	46c	46c

FACILITY SYSTEM

SURVEY 1

INF. BLDG. VENTILATION

**ATTACHMENT I
FOR IEB 79-011
TEX**

PAGE 1

DP

Code:

- ✓ or S = Indicates the item is below the flood level
 - or N = Indicates the item is Satisfactory
 - or U = Indicates the item is Not Applicable
 UL = Indicates the item is Unresolved, Licensee Identified
 P = Proprietary
 L = Licensee Identified
 R = Reviewer Identified
 1 = Equipment is qualified
 2 = Aging is less than life of plant with licensee
 indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
 4 = Qualification of equipment unresolved
 a) Testing schedule but not complete
 b) Reviewer needs additional information
 c) Qual. Record search still in process
 5 = Equipment not qualified
 6 = Item identified to EQB for resolution

REVIEWS

V.Bronner DATE 11/19/82

FACILITY Surve

SYSTEM Inside Peoria. Every

ATTACHMENT 1
FOR IEB 79-01B
TER

PAGE OF

Code: [View](#) | [Edit](#) | [Delete](#) | [Check-in](#) | [Check-out](#) | [Check-in/Check-out](#) | [Check-in/Check-out](#)

- B - Indicates the item is below the flood level
 - or S - Indicates the item is Satisfactory
 - or N - Indicates the item is Not Applicable
 - U - Indicates the item is Unresolved, Licenses Identified
 - P - Proprietary
 - L - Licensee Identified
 - R - Reviewer Identified
 - 1 - Equipment is qualified
 - 2 - Aging is less than life of plant with licensee indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
 - 4 = Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. record search still in process
 - 5 = Equipment not qualified
 - 6 = Item identified to EQB for resolution

REVIEWER V.Brownlee DATE 11/19/82

FACILITY Sunray
SYSTEM INST. AIR

ATTACHMENT A
FOR IEB 79-01B
TER

PAGE _____ OF _____

Code:

- B - Indicates the item is below the flood level
 ✓ or S - Indicates the item is Satisfactory
 - or N - Indicates the item is Not Applicable
 UL - Indicates the item is Unresolved, Licensee Identified
 P - Proprietary
 L - Licensee Identified
 R - Reviewer Identified
 1 - Equipment is qualified
 2 - Aging is less than life of plant with licensee
 indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
 - 4 = Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. Record search still in process
 - 5 = Equipment not qualified
 - 6 = Item identified to EQB for resolution

REVIEWER VGBrownlee DATE 14/19/80

REVIEWS
VULNERABILITY DATE 11/19/88

- 2 - Applying is been than little or place which license
 1 - Equipment is qualified
 K - Equipment is qualified
 L - License is qualified
 P - Proprietary
 UU - Information is the been to Unpublished, license is denied
 - OR N - Indication is Note applicable
 ✓ - Indication is Note is Note applicable
- 6 - Item identified to Bill for resolution
 5 - Equipment not qualified
 C) Qual. Record search still in process
 b) Recovery needs addit. note complete
 a) Testing schedule has not complete
 4 - Qualification of equipment unassessed
 3 - Equipment regular maintenance level

Catagory No.	Page	Equip. I. D.	Genetic Accid.	Qual.	Kidnapping Qual.	Protective Qual.	Protective Chem.	Method	Device	Place	Relocate	Identified by	Item
6-116	1004	PT	L	3	4cs								
6-117	1008	PT											
6-118	100C	PT											
6-119	100A	PT											
6-120	100A	SV											
6-121	100B	SV											
6-122	100C	SV											
6-123	100D	SV											
6-124	100E	SV											
6-125	100F	SV											
6-126	100G	SV											
6-127	100H	SV											

PAGE 1 of 2

TEK
FOR TEE 79-018
ATTACHMENT 1

SYSTEM
Facility Survey 1

REVISED DATE 11/1/98

THE VETERAN

- 3 - Equilibrium requirement of equilibration (residualized)
 4 - Equilibrium requirement of equilibration (residualized, shledding, etc.)
 5 - Equilibrium note qualified
 6 - Item identified to ECR for resolution

- 2 - Aging is more than little of plane which becomes
 1 - Equilibrium is disturbed
 0 - Reversible changes
 1 - Irreversible changes
 2 - Properly
 0 - Irreversible changes which occur in unprovoked, chronic disease
 0 or 1 - Irreversible changes which occur in acute progressive
 0 or 2 - Irreversible changes which occur in acute reversible
 2 - Irreversible changes which occur in the blood leaving

TEH
010-28187988
ATTACHMENT 1

~~System~~ ~~Quality~~ ~~Management~~ SYSTEM
QUALITY MANAGEMENT

University Library

ଶ୍ରୀମଦ୍ଭଗବତ

- 6 - Equilibrium reductase model calculation (monolayer)
 7 - Qualitative reduction of equilibrium unarrested
 8 - Terrelling mechanism which is not complete
 9 - Reviewer needs additional information
 10 - Overall mechanism not yet clear

Page 10

TEK
F0UR JEW 75-018
ATTACHMENT 1

John G. Smith
SYSTEMS
ENGINEERING

REVIEWER DATE 11/19/80

Digitized by srujanika@gmail.com

- B - Indications that there is a need to blood level
C - Indicators that there is a Subacute toxicity
D - Indicators that there is No Applicable
E - Indicators that there is Unpredicted, Uncommon side effect
F - Predictability of side effect
G - Newer drugs
H - Older drugs

1 - Equilibrium regulation of equilibrium unregulated
2 - Equilibrium regulation of equilibrium (residualing, etc.)
3 - Equilibrium regulation at the blood level
4 - Qualitative regulation of qualitative unregulated
5 - Equilibrium not qualified
6 - Equilibrium not qualified to be for residualization

TER
F08 IEE 79-018
ATTACHMENT 1

א. ש. א. ס. ת. א.

RECEIVER LLD LLD LLD LLD LLD

ପ୍ରକାଶକ ମେଳା

- 3 - Equilibrium requirements of aqueous and organic solvents
 - 4 - Quality of extraction of aqueous and organic solvents
 - 5 - Equilibrium distribution of solutes between two immiscible solvents
 - 6 - Total equilibrium related to EPR for separation

1 - Intercellular gap junction is located between two adjacent epithelial cells

2 - Applig is layer of epithelial tissue which covers the outer surface of body

3 - Epithelial tissue is quarified as

4 - Keratinocyte is differentiated cell

5 - Epithelial tissue is differentiated cell

6 - Propagatory
7 - Intercellular gap junction is unpermeable, licensurable idea

8 - Intercellular gap junction is unpermeable
9 - Intercellular gap junction is unpermeable
10 - Intercellular gap junction is unpermeable

11 - Intercellular gap junction is unpermeable

12 - Intercellular gap junction is unpermeable

13 - Intercellular gap junction is unpermeable

14 - Intercellular gap junction is unpermeable

15 - Intercellular gap junction is unpermeable

16 - Intercellular gap junction is unpermeable

17 - Intercellular gap junction is unpermeable

18 - Intercellular gap junction is unpermeable

19 - Intercellular gap junction is unpermeable

20 - Intercellular gap junction is unpermeable

3 PAGE

મનો
૮૧૦-૯૮૮૧૪૦૫
ATTACHMENT I

~~SYSTEM~~ SYSTEMS

FACILITY Sewer 1
SYSTEM outside Recirculation Pump

ATTACHMENT I
FOR IEB 79-01
TER

PAGE 1 OF 1

Cuje;

B = Indicates the item is below the flood level

or S = Indicates the item is Satisfactory

- or N - indicates the item is Not Applicable

UL = Indicates the item is Unresolved, Licenses identified

P = Proprietary

L = Licensee Identified

R = Reviewer Identified

I - Equipment is qualified

2 - Aging is less than life of plant with licensed indicating periodic replacement

3 - Equipment requires modification (resolution, shielding, etc.)

4 - Qualification of equipment unresolved

a) Testing schedule but not complete

- b) Reviewer needs additional information

c) Qual. record search still in process

S = EQUIPMENT NOT QUALIFIED

6 = Item identified to EOB for resolution

REVIEWS

VL Brownell DATZ 11/19/80

28/5/1971 Urgent Mr. B. L. V. Iyer

REVIEWER DATE 1971-10-12

Category	Item No.	Barcode	Quantity	Description	Unit	Place	Location	Owner	Remarks
				Licensee Acc'tion	Cham.	Shelf.	Shelved	Outside	Inside
6-162 100A	AS	925	1	7	425				
6-163 100B	AS	925	1	7	425				
6-164 108A	AS	925	1	7	425				
6-165 168B	AS	925	1	7	425				
6-166 109A	AS	925	1	7	425				
6-167 1061	SV	925	1	7	425				

REVIEWER LL Brown DATE 11/19/60

- 6 - Item identified to PDR for resolution
- 5 - Equipment not qualified
- 4) Quality record search failed to process
- 3 - Equipment needs additional information
- 2) Testing schedule but not complete
- 1) Test item needs additional information

- 2 - Aging is more than life of plane which it carries
- 1 - Equipment is unlisted
- 0 - Equipment is defective
- 5 - Properitary

or S - Indicate the item is not applicable

B - Indicate the item is below the load level

C/S.	Equip.	Genetic	Name	Team	Documenting	Licensee Action	Subm.	Accuse.	Spray	Heated	Protect.	Insist	Documented by	Items	Category	Page No.																	
															Qual.	Qual.	Chim.	Heads	Locate	Heads	Locate	Qual.	Subm.	Accuse.	Spray	Heated	Protect.	Insist	Documented by	Items	Category	Page No.	
6-170	100A	SV	AC	AC	-	-	-	-	-	-	-	-	-	-	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC
6-169	100C	SV	AC	AC	-	-	-	-	-	-	-	-	-	-	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC
6-168	100B	SV	AC	AC	-	-	-	-	-	-	-	-	-	-	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC	AC
E 3	L	525																															
E 3	L	525																															

Page 1 of 1

ATTACHMENT 1
FOR IEC 79-01B
SYSTEM

Initials Initials Initials

Page 111111
SYSTEM

FACILITY
SYSTEMSierra
Reactor coolantATTACHMENT I
FOR IEB 79-01B
TER

PAGE 1 OF 3

CES. Page No.	Equip. I. D. #	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual. Containment		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items
					Inside	Outside					Replace	Relocate		
6-171	1459	LT									YES		L	3
6-172	1460	LT										↓	↓	↓
6-173	1461	LT										↓	↓	↓
6-174	1455	PT									YES		L	3
6-175	1456	PT										↓	↓	↓
6-176	1457	PT										↓	↓	↓
6-177	1410	TE	4b	4C	✓	-	4C	-	✓	-	-	-	R.L	4b,C
6-178	1412B	TE	✓	✓	✓	-	✓	✓	✓	-			✓	✓
6-179	1412D	TE	✓	✓	✓	-	✓	✓	✓	-			✓	✓
6-180	1413	TE				-								
6-181	1412W	TE				-								
6-182	1422B	TE	✓	✓	✓	-	✓	✓	✓	-			✓	✓

Code:

- B = Indicates the item is below the flood level
- ✓ or S = Indicates the item is Satisfactory
- or N = Indicates the item is Not Applicable
- UL = Indicates the item is Unresolved; Licensee identified
- P = Proprietary
- L = Licensee Identified
- R = Reviewer Identified
- 1 = Equipment is qualified
- 2 = Aging is less than life of plant with licensee indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
- 4 = Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. Record search still in process
- 5 = Equipment not qualified
- 6 = Item identified to EQB for resolution

REVIEWER

VCPawarla
DATE 11/19/80

FACILITY Sunco 1
SYSTEM Reactor Coolant

ATTACHMENT 1
FOR IEB 79-01B
TER

PAGE 2 OF 3

CES. Page No.	Equip. I. D. #	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual. Containment		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items	
					Inside	Outside					Replace	Relocate			
6-183	1422D	TE	4b	4C	✓	-	4C	-	✓	-	-	-	R, L	4b,C	
6-184	1423	TE													
6-185	1430	TE													
6-186	1432D	TE													
6-187	1432D	TE													
6-188	1433	TE			↓	↓	↓		↓				↓	↓	
6-189	1519A	SV		4C	-	4C	4b,C	-	-	-	-	-	R, L	4b,C	
6-190	1455C-1	SV		✓	4C	4C	-	4b,C	-	-	-	-	-	R, L	4b,C
6-191	1455C-1	SV		✓			-		-	-	-	-			
6-192	1455C-3	SV		✓			-		-	-	-	-			
6-193	1456-1	SV		✓			-		-	-	-	-			
6-194	1456-2	SV		✓	↓	↓	-	↓	-	-	-	-	↓	↓	

Code:

✓ = Indicates the item is below the flood level

or S = Indicates the item is Satisfactory

- or N = Indicates the item is Not Applicable

UL = Indicates the item is Unresolved, Licensee Identified

P = Proprietary

L = Licensee Identified

R = Reviewer Identified

1 = Equipment is qualified

2 = Aging is less than life of plant with licensee indicating periodic replacement

3 = Equipment requires modification (resolution, shielding, etc.)

4 = Qualification of equipment unresolved

a) Testing schedule but not complete

b) Reviewer needs additional information

c) Qual. Record search still in process

5 = Equipment not qualified

6 = Item identified to EQB for resolution

REVIEWED

V. Brouwer
DATE 11/19/82

REVIEWER: LL Gramm Date: 11/19/86

REVIEWS

- 5) - Equilibrium reductase model reduction (reducing, neutralizing, etc.)
 6) - Quasi-reducation of aqueous organic compounds unassisted
 7) - Treating a schedule but not complete
 8) - Reversible needs additional information
 9) - Equilibrium not quantified
 10) - These need to be reduced to solution

- 1. ■ **Equilibrium** is **achieved**
- 2. ■ **After** **the** **change** **of** **plumus** **which** **occurred**
- 3. ■ **Regulation** **is** **achieved**
- 4. ■ **Homeostasis** **is** **achieved**
- 5. ■ **Proportionality**
- 6. ■ **Thermoregulation** **is** **achieved** **in** **homeostasis**.
- 7. ■ **Homeostasis** **is** **achieved** **in** **negative feedback**.
- 8. ■ **Homeostasis** **is** **achieved** **in** **positive feedback**.
- 9. ■ **Homeostasis** **is** **achieved** **in** **oscillation**.
- 10. ■ **Homeostasis** **is** **achieved** **in** **negative feedback**.

Ultraviolet REVIEWS date 11/19/80

- 6 - Item identified to ECR for resolution
- 5 - Equipment not qualified
- 4) Revolver needs additional information
- 3) Training schedule incomplete
- 2) Qualification of equipment unresolved
- 1) Accuracy action
- 0 - No applicable category

- 7 - Applying to gun license of plane with license
- 6 - Equipment not qualified
- 5 - Revolver needs additional information
- 4) Training schedule complete
- 3) Qualification of equipment unresolved
- 2) Accuracy action
- 1 - Application for qualification
- 0 - No applicable category

Category	Page No.	I. D.	Name	Product	Qual.	Qualification Qual.	Chim.	Method	Speedy	Tugide	Ducatide	HepPlace	Belocata	Item	Identified by	Code:		
																Code:		
6-198	91A	WTR	L	HCL	-	-	-	-	-	L	-	L	AC	-	AC	L	1865C	MNU
6-199	P1B	WTR	L	HCL	-	-	-	-	-	L	-	L	AC	-	AC	L	1865A	MNU
6-200	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1863B	MNU
6-201	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1862B	MNU
6-202	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1862A	MNU
6-203	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1862A	MNU
6-204	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1862B	MNU
6-205	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1863A	MNU
6-206	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1864	MNU
6-207	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1865A	MNU
6-208	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1865B	MNU
6-209	91C	R	-	-	-	-	-	-	-	L	-	L	AC	-	AC	L	1865C	MNU

FACILITY

Savoy I

SYSTEM

Safety injection

ATTACHMENT I
FOR IEB 79-01B
TER

PAGE 2 OF 4

CES. Page No.	Equip. I. D. #	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual. Containment		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items
					Inside	Outside					Replace	Relocate		
b-210	1867A	MOV	L	L	-	4C	4b	-	-	-	-	-	R, L	4b,c
b-211	1867B	MOV	L	L	-	4C	4b	-	-	-	-	-	R, L	4b,c
b-212	1867C	MOV	L	L	-	4C	4b	-	-	-	-	-	↓	↓
b-213	1867D	MOV	L	L	-	4C	4b	-	-	-	-	-	↓	↓
b-214	1867E	MOV	L	L	-	4C	4b	-	-	-	-	-	R, L	4b,c
b-215	1890A	MOV	L	L	-	4C	4b	-	-	-	-	-	R, L	4b,c
b-216	1890B	MOV	↓	↓	-	↓	↓	-	-	-	-	-	↓	↓
b-217	1890C	MOV	↓	↓	-	↓	↓	-	-	-	-	-	↓	↓
b-218	100	SV									yes		L	3
b-219	101A	SV	✓	✓	✓	-	4b	-	-	-	-	-	R	4b
b-220	101B	SV									yes		L	3
b-221	102A1	SV	L	L	-	✓	4b	-	-	-	-	-	R	4b

Code:

B = Indicates the item is below the flood level

✓ or S = Indicates the item is Satisfactory

- or N = Indicates the item is Not Applicable

UL = Indicates the item is Unresolved; Licensee Identified

P = Proprietary

L = Licensee Identified

R = Reviewer Identified

1 = Equipment is qualified

2 = Aging is less than life of plant with licensees indicating periodic replacement

3 = Equipment requires modification (resolution, shielding, etc.)

4 = Qualification of equipment unresolved

a) Testing schedule but not complete

b) Reviewer needs additional information

c) Qual. Record search still in process

5 = Equipment not qualified

6 = Item identified to EQB for resolution

REVIEWER

V. Brumell
DATE 11/19/80

28/6/91 ^{date} *U.S. Senate*

- 31 - 1977 REVISADA

- 3 - Budgeted requirements relative model classification (residual)
 4 - Quantitative classification of equivalent usage level
 5 - Technicalities that come in between the blood level
 6 - Qualitative factors not quantified
 7) Technicalities needed additional information to determine
 8) Technicalities which not comparable
 9) Quality, historical records etc in process

10) - Technicalities that come in between the blood level
 11) - Technicalities that come in between the blood level is unpredictable, licensees damaged

12) - AFIB is likely than that of plant which licensee

13) - Equipment used by qualified

14) - Heavywater denatured

15) - Heavywater denatured

16) - AFIB is likely than that of licensee

17) - AFIB is likely than that of licensee

18) - AFIB is likely than that of licensee

ATTACHMENT 1
FOR IEB 79-01A
TER

—
—
—

~~Software Engineering~~ ~~Software Engineering~~ SYSTEMS
Software Engineering

FACILITY Survey 1
SYSTEM Salt, Injections

**ATTACHMENT I
FOR IEB 79-01B
TER**

PAGE 4 OF 7

2000

- ✓ or S = Indicates the item is below the flood level
 - or N = Indicates the item is Satisfactory
 - or N = Indicates the item is Not Applicable
 UL = Indicates the item is Unresolved, Licensee Identified
 P = Proprietary
 L = Licensee Identified
 R = Reviewer Identified
 1 = Equipment is qualified
 2 = Aging is less than life of plant with licensee indicating periodic replacement
 3 = Equipment requires modification (resolution, shielding, etc.)
 4 = Qualification of equipment unresolved
 a) Testing schedule but not complete
 b) Reviewer needs additional information
 c) Qual. Record search still in process
 5 = Equipment not qualified
 6 = Item identified to EQB for resolution

REVIEWER VLBrowlee DATE 11/19/80

FACILITY Surry
SYSTEM Sampling

ATTACHMENT I
FOR IEB 79-01B
TER

PAGE 1 OF 1

CES. Page No.	Equip. I. D. #	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual. Containment		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items
					Inside	Outside					Replace	Relocate		
6-231	100A1	SV	L	4C	4C	-	4b,C	4C	-	-	-	-	L	4b,C
6-232	100B1	SV	L	-	-	L	4b	-	-	-	-	-	R	4b
6-233	101A1	SV	L	4b	4b	-	4b	-	-	-	-	-	R	4b
6-234	101C1	SV	L	4b	-	4b	4b	-	-	-	-	-	R	4b
6-235	102A1	SV	L	4b	4b	-	4b	-	-	-	-	-	R	4b
6-236	102B1	SV	L	4b	-	4b	4b	-	-	-	-	-	R	4b
6-237	103	SV	L	L	-	4b	4b	-	-	-	-	-	R	4b
6-238	104A	SV									yes		L	3
6-239	104B	SV	L	L	-	4b	4b	-	-	-	-	-	R	4b
6-240	106A1	SV									yes		L	3
6-241	106B	SV	L	L	-	4b	4b	-	-	-	-	-	R	R4b

Code:

- B = Indicates the item is below the flood level
- ✓ or S = Indicates the item is Satisfactory
- or N = Indicates the item is Not Applicable
- UL = Indicates the item is Unresolved, Licensee Identified
- P = Proprietary
- L = Licensee Identified
- R = Reviewer Identified
- 1 = Equipment is qualified
- 2 = Aging is less than life of plant with licensee indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
- 4 = Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. Record search still in process
- 5 = Equipment not qualified
- 6 = Item identified to EQB for resolution

REVIEWER

VJB
VERIFIED

DATE 11/19/82

FACILITY Savoy
SYSTEM Service Water

ATTACHMENT 8
FOR IEB 79-018
TER

PAGE 1 OF 1

CES. Page No.	Equip. I. D.	Generic Name	Accid. Profile	Qual. Profile	Radiation Qual. Containment		Qual. Method	Chem. Spray	Accur.	Subm.	Licensee Action		Outstanding Items Identified by	Category of Items
					Inside	Outside					Replace	Relocate		
6-242	104A	Mov	L	L	-	L	46	-	-	-	-	-	R	46
6-243	104B	Mov	L	L	-	L	45	-	-	-	-	-	R	46
6-244	104C	Mov	L	L	-	L	45	-	-	-	-	-	R	46
6-245	104D	Mov	L	L	-	L	45	-	-	-	-	-	R	46
6-246	105A	Mov	L	L	-	L	45	-	-	-	-	-	R	46
6-247	105B	Mov	L	L	-	L	46	-	-	-	-	-	R	46
6-248	105C	Mov	L	V	-	L	46	-	-	-	-	-	R	46
6-249	105D	Mov	L	L	-	L	46	-	-	-	-	-	R	46
6-250	P-5A	MTR									yes			3
6-251	P-5B	MTR									yes			3
6-252	P-5C	MTR									yes			3
6-253	P-5D	MTR									yes			3

Code:

- B = Indicates the item is below the flood level
- ✓ or S = Indicates the item is Satisfactory
- or N = Indicates the item is Not Applicable
- UL = Indicates the item is Unresolved, Licensee identified
- P = Proprietary
- L = Licensee Identified
- R = Reviewer Identified
- I = Equipment is qualified
- 2 = Aging is less than life of plant with licensee indicating periodic replacement

- 3 = Equipment requires modification (resolution, shielding, etc.)
- 4 = Qualification of equipment unresolved
 - a) Testing schedule but not complete
 - b) Reviewer needs additional information
 - c) Qual. Record search still in process
- 5 = Equipment not qualified
- 6 = Item identified to EQB for resolution

REVIEWER V.L.Brownell DATE 11/19/80

See pg
7-27

11/15/88

REVIEWS

- 6 - Item identified to EOB for resolution
 5 - Equipment not qualified
 c) Qual. Record search failed in process
 b) Testing schedule due not complete
 a) Testing schedule due not complete
- 4 - Equipment qualification of equipment unhandled
 3 - Equipment qualification (resolution, scheduling, etc.)

- 7 - Adding new line of plant with license
 2 - Equipment is qualified
 1 - Equipment is identified
 h) License issued
 g) Proprietary
 d) Licensee due to unresolved, license identified
 e) No - Qualification due to due applicable
 f) S - Qualification due to due to Safety category
 b - Indicate the item below the flood level

Category	Category	Accredited	Accredited	Subs.	Licensee Action	Licensee Action	Method	Method	Qual.	Qual.	Name	Equip.	No.
E	L	4cs	4cs										6-259 100E SL
E	L	4cs	4cs										6-258 100E SL
E	L	4cs	4cs										6-257 100D SL
E	L	4cs	4cs										6-256 100C SL
E	L	4cs	4cs										6-255 100B SL
E	L	4cs	4cs										6-254 100A SL

Surry 1

Attachment 4 Notes

1. Item to be replaced; licensee identified disposition schedule is identified on specific CES or Section 7 and the Response to Supplement 2, 79-01B Section of the report.
2. Testing scheduled but not complete, or qualification record search is still in progress; licensee identified.

Codes:

SV - Solenoid Valve
MOV - Motor Operated Valve
MTR - Motor
FCV - Flow Control Valve
FT - Flow Transmitter
MCC - Motor Control Center
EPA - Electrical Penetration Assembly
CBL - Cable
LT - Level Transmitter
HC - Hydrogen Combiner
HA - Hydrogen Analyzer
PWR SUP - Power Supply
DMPR - Damper
TE - Temperature Element
PT - Pressure Transmitter

ATTACHMENT 2
FUNCTIONS/SYSTEMS LIST

(W) PWR

Needed For Mitigation Of Consequences
Of LOCA Or MSLB

- * 1. Reactor Protection
- * 2. Safeguards Actuation
- * 3. Containment Isolation
- ✓ 4. Main and Auxiliary Steam Isolation
- ✓ 5. Main and Auxiliary Feedwater Isolation
- ✓ 6. Feedwater Control
- ✓ 7. Containment Spray
- ✓ 8. Containment Air Purification/Cleanup
- ✓ 9. Containment Ventilation/Cooling
- ✓ 10. Containment ~~Containment~~ Gas Control
- ✓ 11. High Pressure Injection
- ✓ 12. Low Pressure Injection
- * 13. Accumulators
- * 14. Residual Heat Removal
- ✓ 15. Chemical and Volume Control
- * 16. Pressurizer Spray
- * 17. Power Operated Relief Valves
- * 18. Steam Dump
- ✓ 19. Containment Radiation/Monitoring
- ✓ 20. Containment Radiation/Sampling
- ✓ 21. Component Cooling Water
- ✓ 22. Service Water
- ✓ 23. Emergency Power
- * 24. Containment Sump
- ✓ 25. Control Room Habitability (See unit 2 Report - Common System)
- ✓ 26. Safety Equipment Area Ventilation
- ✓ 27. Auxiliary Feedwater
- ✓ 28. Reactor Coolant
- ✓ 29. Condenser Air Removal to Containment
- ✓ 30. Containment Vacuum Control
- ✓ 31. Instrument Air
- ✓ 32. Steam Generator Blowdown

ATTACHMENT 3 (SURVYI)

SECTION 8

REFERENCES

1. Westinghouse Electric Corporation Report, WCAP-9175.
2. VEPCO submittal No. 855, November 1, 1979.
3. VEPCO submittal No. 855A, for North Anna Power Station Units 1 and 2, November 1, 1979.
4. Wyle Laboratory, Environmental Qualification Test Program on Components, Report No. 26304, Supplement to Wyle Test Report No. 25304, December 12, 1978, Revision A, April 4, 1979.
5. Learn, J.R., Boston Insulated Wire and Cable Company to Wright, R.D., Stone & Webster Engineering Corporation, 300 V Instrument Cables and 600 V Control Cables, January 17, 1972.
6. Limitorque Corporation, Nuclear Qualification Data for Safety Related Service, NQDS, November 1, 1979.
7. Anderson to Stolz, Westinghouse Electric Corporation, NS-TMA-1950.
8. Rath, J.E., Boston Insulated Wire and Cable Company to Wright, R.D., Stone & Webster Engineering Corporation, Radiation Resistance of Cross-Linked Polyethylene, December 14, 1971.
9. Anderson to Stolz, Westinghouse Electric Corporation, MB-TMA-2120.
10. Anderson to Stolz (Test), Westinghouse Electric Corporation.
11. Steigelmann, W.H., Witcher, L., Test of Electrical Cables Under Simulated Post-Accident Reactor Containment Service, Franklin Institute Research Laboratories, Final Report F-C2857, September 1970.
12. Chapman, L., Stone, J., Tests of Electric Cables After Simulated Post-Accident Reactor Containment Service, Cerro Wire and Cable Company, a Supplement to Franklin Institute Research Laboratories Final Report F-C2857, March 1970.
13. Marth, J.R., Qualification of Firewall III Class IE Electric Cables, Rockbestos Company, Rockbestos Report 13-10407-E058-13-2, June 22, 1978.
14. Nuclear Regulatory Commission, North Anna Power Station Units 1 and 2 Final Safety Analysis Report, Docket

Nos. 50-338 and 50-339, Appendix 3C and Response to Comment 7.17.

15. Rosemount Engineering Corporation, Qualification Test Report for Rosemount Pressure Transmitters Model 1153 Series A, RMT Report No. 3788.
16. Franklin Institute Research Laboratories - Final Report F-C2404-01, June 1969.
17. Raychem-Flamtrol, Qualification to IEEE Standard 383-1974, IEEE Standard for Type Test of Class IE Electric Cables, Field Splices, and Connections for Nuclear Power Generating Stations.
18. D.G. O'Brien Inc., Environmental Test Report, DGO Report No. C19QA061, February 28, 1972.
19. Isomedix Incorporated, Qualification Tests of Solenoid Valves by Environmental Exposure to Elevated Temperature, Radiation, Wear Aging, Seismic Simulation, Vibration Endurance, Accident Radiation and Loss-of-Coolant Accident (LOCA) Simulation, Automatic Switch Company, Test Report No. AQS21678/TR-Revision A, March 1978.
20. Isomedix Incorporated, Letter to Cerro Wire and Cable Company, February 3, 1978.
21. Conax Corporation, Prototype Test Report for C.N. DeAlmarez Power Station, IPS-137, October 14, 1976.
22. Conax Corporation, Maximum Emergency Environmental Test Report for Electrical Penetration Assemblies for North Anna Power Station Units 1 and 2, IPS-73.4, February 7, 1975, Revised through May 13, 1975.
23. Sheets, M.W., Topical Report on General Electric Vertical Induction Motors, Inside Containment Recirculation Spray Pump Motors - Surry Power Station - Second Addendum to Cover Heat Aging, Radiation Exposure, Vibration, and Steam/Chemical Spray Exposure Qualification Test, NRC Docket Nos. 50-280 and 50-281, June 12, 1973 and July 23, 1973.
24. General Electric Company, Inc., Vertical Motor Products Section, San Jose, California, June 12, 1973, pp 36-64.
25. Automatic Switch Company, 3- and 4-Way Solenoid Valves, Catalog No. NP-1, March 1978.
26. Westinghouse Electric Corporation, Westinghouse Electric Hydrogen Recombiner, Technical Manual.

Rev. 1
1/01/80

27. Collins, Y., Patterson, W.J., Rockbestos Company, to Moscardelli, J., Stone & Webster Engineering Corporation, subject: VEPCO, your Purchase Order... Qualification for LOCA Testing, a letter and attachment, Qualification Brochure of Class IE Electric Cables, February 21, 1979.
28. Institute of Electrical and Electronic Engineers, Class IE Cables for Nuclear Power Generating Stations, Transaction Paper T74 044 4.
29. McAvoy, F.M., Aging Exposure to 200 Megarads of Gamma Radiation and Accident Condition Qualification Testing of Power Cables, Control Cables, and Splices, Okonite Company, Engineering Report No. 141, February 29, 1972.
30. Franklin Institute Research Laboratories, Qualification Tests of Electrical Cables Under Simultaneous Exposure to Gamma Radiation, Steam and Chemical Spray, Report Outline F-C3694, January 1974.
31. Westinghouse Electric Corporation Report, WCAP-8754.
32. Westinghouse Electric Corporation Report, WCAP-7829.
33. Fischer and Porter Company, Specification 10B2495, File: Section 50, September 1972.
34. Fischer and Porter Company, Specification 50EP1000, File: Section 50, June 1973.
35. Steigelman, W.H., Witcher, L., Test of Electrical Cables Under Simulated Post-Accident Reactor Containment Service, Franklin Institute Research Laboratories, Final Report F-C2750, March 1970.
36. Chapman, L., Stone, J., Tests of Electrical Cables After Simulated Post-Accident Reactor Containment Service, Cerro Wire and Cable Company, a supplement to Franklin Institute Research Laboratories Final Report F-C2750, March 1970.
37. Cerro Wire and Cable Company, Qualification of Firewall III Class IE Electrical Cables, May 1976.
Cerro Wire and Cable Company, letter identifying cable supplied under this P.O. as Firewall III, dated April 30, 1976.
38. Schwencer, A., Nuclear Regulatory Commission, to Proffitt, W.L., Virginia Electric and Power Company, subject: Environmental Qualification of Continental Instrumentation Cable, dated July 25, 1979.

- . 1
- 01-80
- 39. Limitorque Corporation, Limitorque Valve Actuators for Class IE Service, Outside Primary Containment in Nuclear Power Station Service, Qualification Type Test Report No. B0003, Project No. 600461, May 28, 1976.
 - 40. Lasky, J.S., Okonite Company, to Bonner, J., Stone & Webster Engineering Corporation, dated October 15, 1980.
 - 41. Okonite Company, Qualification of Okonite Ethylene-Propylene Rubber Insulation for Nuclear Plant Service, Report No. NQRN-1.
 - 42. Ling, T.H., Anaconda Wire and Cable Company, to Bonner, J., Stone & Webster Engineering Corporation, dated October 28, 1980.
 - 43. Franklin Institute Research Laboratories, Tests of Electrical Cables Subjected to Thermal Aging, Gamma Radiation and a Loss-of-Coolant Accident Simulation, Report No. F-C4350-3, July 1976.
 - 44. Bell, C.E., General Electric, to Bonner, J., Stone & Webster Engineering Corporation, subject: Qualification of Inside Recirculation Pump Motors to Withstand a pH of 7-11, dated October 28, 1980.
 - 45. Drab, J.B., Limitorque Corporation, to Reilly, P., Stone & Webster Engineering Corporation, subject: Qualification Information for Limitorque Actuators - Surry Power Station Units 1 & 2, dated October 8, 1980.

Surry 1

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes	
		Replace	Modify	Ongoing Analysis	Other	
6-1	SV			✓		2
6-2	MOV			✓		2
6-3	MOV			✓		2
6-4	MOV			✓		2
6-5	MOV			✓		2
6-6	MOV			✓		2
6-7	HTR			✓		2
6-8	HTR			✓		2
6-9	HTR			✓		2
6-10	FCV			✓		2
6-11	FT	✓				1
6-12	SV	✓				1
6-13	MOV			✓		2
6-14	MOV			✓		2
6-15	MOV			✓		2
6-16	MOV			✓		2
6-17	MOV			✓		2

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-18	MOV			✓	2
6-19	SV	✓			1
6-20	SV			✓	2
6-21	SV			✓	2
6-22	SV			✓	2
6-23	MCC			✓	2
6-24	MCC			✓	2
6-25	MCC			✓	2
6-26	MCC			✓	2
6-27	EPA			✓	2
6-28	EPA			✓	2
6-29	EPA			✓	2
6-30	EPA			✓	2
6-31	EPA			✓	2
6-33	CBL			✓	2

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-36	CBL			✓	2
6-37	CBL			✓	2
6-38	CBL			✓	2
6-39	CBL			✓	2
6-40	CBL			✓	2
6-42	CBL			✓	2
6-43	EPA			✓	2
6-44	EPA			✓	2
6-45	EPA			✓	2
6-46	EPA			✓	2
6-47	TE			✓	2
6-48	CBL			✓	2
6-49	CBL			✓	2
6-50	CBL			✓	2
6-51	CBL			✓	2
6-52	CBL			✓	2
6-53	CBL			✓	2

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes	
		Replace	Modify	Ongoing Analysis	Other	
6-54	CCL			✓		2
6-58	CPL			✓		2
6-59	CBL			✓		2
6-60	CBL			✓		2
6-61	MTR	✓				1
6-62	MTR	✓				1
6-63	SV	✓				1
6-64	SV	✓				1
6-65	SV	✓				1
6-66	SV	✓				1
6-67	SV	✓				1
6-68	SV	✓				1
6-69	SV	✓				1
6-70	SV	✓				1
6-71	SV	✓				1
6-80	SV	✓				1
6-81	SV	✓				1

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-82	SU	✓			1
6-83	SU	✓			1
6-84	FT	✓			1
6-85	FT	✓			1
6-86	FT	✓			1
6-87	LT	✓			1
6-88	LT	✓			1
6-89	LT	✓			1
6-90	LT	✓			1
6-91	LT	✓			1
6-92	LT	✓			1
6-93	LT	✓			1
6-94	LT	✓			1
6-95	LT	✓			1
6-96	MOV			✓	2
6-97	MOV			✓	2
6-98	MOV			✓	2

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-99	MUV			✓	2
6-100	MUV			✓	2
6-101	MUD			✓	2
6-102	HC			✓	2
6-103	HC			✓	2
6-104	HA	✓			1
6-105	PS			✓	2
6-106	PS			✓	2
6-107	MTR-			✓	2
6-108	MTR			✓	2
6-109	DMTR			✓	2
6-110	DMTR			✓	2
6-113	SU	✓			1
6-114	SU			✓	2
6-115	SU	✓			1
6-116	PT	✓			1
6-117	PT	✓			1

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-118	PT	✓			1
6-119	PT	✓			1
6-120	SU	✓			1
6-121	SU	✓			1
6-122	SU	✓			1
6-123	SU	✓			1
6-124	SU	✓			1
6-125	SU	✓			1
6-126	SU	✓			1
6-127	SU	✓			1
6-128	SU	✓			1
6-129	SU	✓			1
6-130	FT	✓			1
6-131	FT	✓			1
6-132	FT	✓			1
6-133	FT	✓			1
6-134	FT	✓			1

Attachment 4

OUTSTANDING ITEMS

As Identified By
Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-135	FT	✓			1
6-136	PT	✓			1
6-137	PT	✓			1
6-138	PT	✓			1
6-139	PT	✓			1
6-140	PT	✓			1
6-141	PT	✓			1
6-142	PT	✓			1
6-143	PT	✓			1
6-144	PT	✓			1
6-145	PT	✓			1
6-146	PT	✓			1
6-147	PT	✓			1
6-148	SV	✓			1
6-149	SV	✓			1
6-150	SV	✓			1
6-151	SV	✓			1

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes	
		Replace	Modify	Ongoing Analysis	Other	
6-152	SV	✓				1
6-153	SV	✓				1
6-154	SV	✓				1
6-155	SV			✓		2
6-156	MTR			✓		2
6-157	MTR			✓		2
6-158	MOV			✓		2
6-159	MOV			✓		2
6-160	MOV			✓		2
6-161	MOV			✓		2
6-162	SV	✓				1
6-163	SV	✓				1
6-164	SV	✓				1
6-165	SV	✓				1
6-166	SV	✓				1
6-167	SV	✓				1
6-168	SV	✓				1
6-169	SV	✓				1

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-170	SV			✓	2
6-171	LT	✓			1
6-172	LT	✓			1
6-173	LT	✓			1
6-174	PT	✓			1
6-175	PT	✓			1
6-176	PT	✓			1
6-177	TG			✓	2
6-178	TG			✓	2
6-179	TE			✓	2
6-180	TE			✓	2
6-181	TE			✓	2
6-182	TE			✓	2
6-183	TE			✓	2
6-184	TG			✓	2
6-185	TG			✓	2
6-186	TE			✓	2

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes	
		Replace	Modify	Ongoing Analysis	Other	
6-187	TE			✓		2
6-188	TE			✓		2
6-189	SU			✓		2
6-190	SU			✓		2
6-191	SU			✓		2
6-192	SU			✓		2
6-193	SU			✓		2
6-194	SU			✓		2
6-195	SU			✓		2
6-196	MOV			✓		2
6-197	MOV			✓		2
6-198	MTR			✓		2
6-199	MTR			✓		2
6-201	MOV			✓		2
6-202	MOV			✓		2
6-203	MOV			✓		2
6-204	MOV			✓		2

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes
		Replace	Modify	Ongoing Analysis	
6-205	MOV			✓	2
6-206	MOV			✓	2
6-207	MOV			✓	2
6-208	MOV			✓	2
6-209	MOV			✓	2
6-210	MOV			✓	2
6-211	MOV			✓	2
6-212	MOV			✓	2
6-213	MOV			✓	2
6-214	MOV			✓	2
6-215	MOV			✓	2
6-216	MOV			✓	2
6-217	MOV			✓	2
6-218	SV	✓			1
6-220	SV	✓			1
6-222	SV			✓	2
6-224	SV			✓	2

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee

C E S Page No.	ITEM (See Code)	DISPOSITION			Disposition Schedule, Notes	
		Replace	Modify	Ongoing Analysis	Other	
6-225	SV			✓		2
6-226	SV			✓		2
6-227	SU			✓		2
6-228	MOV			✓		2
6-229	MOU			✓		2
6-230	MOV			✓		2
6-230a	MOV			✓		2
6-230b	MOV			✓		2
6-230c	MOV			✓		2
6-230d	MOV			✓		2
6-231	SV			✓		2
6-238	SV	✓				1
6-240	SV	✓				1
6-250	MTR	✓				1
6-251	MTR	✓				1
6-252	MTR	✓				1
6-253	MTR	✓				1

Attachment 4

OUTSTANDING ITEMS

As Identified By

Licensee