

APPENDIX A

NOTICE OF VIOLATION

Virginia Electric and Power Company
Surry Power Station

Docket Nos. 50-280, 50-281
License Nos. DPR-32, DPR-37

As a result of the inspection conducted on February 3-6, 1980, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified.

Technical Specification 4.9.E - as defined in Table 4.9-1 (Environmental Monitoring Program), requires, in part, that the following program parameters shall be monitored and analyzed at the indicated frequencies, viz.: (1) milk (monthly); (2) oysters and clams (quarterly); (3) James River water (semiannually); (4) and crabs (annually).

Contrary to the above, the following radiochemical analytical requirements were not implemented: (1) analysis of milk samples collected during the month of January, 1980; (2) analysis of oysters and clams collected during the second calendar quarter of 1980; (3) analysis of James River water samples collected during the first semiannual period of 1980; (4) analysis of annual crab samples collected during July, 1980.

This is a Severity Level V Violation (Supplement VII.E).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: _____

8106090 268