

DISTRIBUTION  
 Dockets JOlshinski  
 NRC PDR  
 L PDR  
 TERA  
 NSIC  
 ORB#1 Rdg  
 DEisenhut  
 CParrish  
 SVarga  
 DNeighbors  
 OELD  
 IE-3  
 ACRS-10  
 Gray File  
 THuang  
 JShea

SEP 23 1981

Docket Nos. 50-280  
 and 50-281

Mr. R. H. Leasburg  
 Vice President - Nuclear Operations  
 Virginia Electric and Power Company  
 Post Office Box 26666  
 Richmond, Virginia 23261

Dear Mr. Leasburg:

SUBJECT: TMI TOPIC II.F.2.3 - SURRY POWER STATION, UNIT NOS. 1 AND 2

We understand that you plan to install the Westinghouse Dp reactor vessel level instrument. Westinghouse has made a generic submittal to the NRC entitled "Summary Report, Westinghouse Reactor Vessel Level Instrumentation System for Monitoring Inadequate Core Cooling (7300 System), (UHI Plant), and (Microprocessor System)", dated December 1980.


Since the Westinghouse generic submittal has an option for three different levels of data processing, you should provide a plant specific submittal showing the option selected. Also, please respond to the enclosed request for additional information within 30 days.

Sincerely,

S. A. Varga  
 Original signed by:  
 Steven A. Varga, Chief  
 Operating Reactors Branch #1  
 Division of Licensing

Enclosure:  
 Request for Additional  
 Information

cc w/enclosure:  
 See next page



8110190153 810923  
 PDR ADOCK 05000280  
 PDR

OFFICE	ORB#1:DL	ORB#1:DL					
SURNAME	DNeighbors	SVarga					
DATE	9/27/81:ds	9/28/81					

Mr. R. H. Leasburg  
Virginia Electric and Power Company

cc: Mr. Michael W. Maupin  
Hunton and Williams  
Post Office Box 1535  
Richmond, Virginia 23213

Mr. J. L. Wilson, Manager  
P. O. Box 315  
Surry, Virginia 23883

Swem Library  
College of William and Mary  
Williamsburg, Virginia 23185

Donald J. Burke, Resident Inspector  
Surry Power Station  
U. S. Nuclear Regulatory Commission  
Post Office Box 166  
Route 1  
Surry, Virginia 23883

Mr. J. H. Ferguson  
Executive Vice President - Power  
Virginia Electric and Power Company  
Post Office Box 26666  
Richmond, Virginia 23261

ON SUMMARY REPORT  
"WESTINGHOUSE REACTOR VESSEL LEVEL INSTRUMENTATION SYSTEM  
FOR MONITORING INADEQUATE CORE COOLING"

---

1. Justify that the single upper head penetration meets the single failure requirement of NUREG-0737 and show that it does not negate the redundancy of the two instrument trains.
2. Describe the location of the level system displays in the control room with respect to other plant instrument displays related to ICC monitoring, in particular, the saturation meter display and the core exit thermocouple display.
3. Describe the provisions and procedures for on-line verification, calibration and maintenance.
4. Describe the diagnostic techniques and criteria to be used to identify malfunctioning components.
5. Estimate the in-service life under conditions of normal plant operations and describe the methods used to make the estimate, and the data and sources used.
6. Explain how the value of the system accuracy (given as  $\pm \epsilon\%$ ) was derived. How were the uncertainties from the individual components of the system combined? What were the random and systematic errors assumed for each component? What were the sources of these estimates?
7. Assume a range of sizes for "small break" LOCA's. What are the relative times available for each size break for the operator to initiate action to recover the plant from the accident and prevent damage to the core? What is the dividing line between a "small break" and a "large break"?
8. Describe how the system response time was estimated. Explain how the response times of the various components (differential pressure transducers, connecting lines and isolators) affect the response time.
9. There are indications that the TMI-2 core may be up to 95% blocked. Estimate the effect of partial blockage in the core on the differential pressure measurements for a range of values from 0 to 95% blockage.

10. Describe the effects of reverse flows within the reactor vessel on the indicated level.
11. What is the experience, if any, of maintaining Dp cells at 300% over-range for long periods of time?
12. Five conditions were identified which could cause the Dp level system to give ambiguous indications. Discuss the nature of the ambiguities for 1) accumulator injection into a highly voided downcomer, 2) when the upper head behaves as a pressurizer, 3) upper plenum injection, and 4) periods of void redistribution.
13. No recommendations are made as to the uncertainties of the pressure or temperature transducers to be used, but the choice appears to be left to the owner of AE. What is the upper limit of uncertainties that should be allowed? Describe the effect of these uncertainties on the measurement of level. What would be the effect on the level measurement should these uncertainties be exceeded?
14. Only single RTD sensors on each vertical run are indicated to determine the temperatures of the impulse lines. Where are they to be located? What are the expected temperature gradients along each line under normal operating conditions and under a design basis accident? What is the worst case error that could result from only determining the temperature at a single point on each line?
15. What is the source of the tables or relationships used to calculate density corrections for the level system?
16. The microprocessor system is stated to display the status of the sensor input. Describe how is this indicated and what this actually means with respect to the status of the sensor itself and the reliability of the indication.
17. Describe the provisions for preventing the draining of either the upper head of hot leg impulse lines during an accident. What would be the resultant errors in the level indications should such draining occur?
18. Discuss the effect of the level measurement of the release of dissolved, noncondensable gases in the impulse lines in the event of a depressurization.
19. In some tests at Semi-scale, voiding was observed in the core while the upper head was still filled with water. Discuss the possibility of cooling the core-exit thermocouples by water draining down out of the upper head during or after core voiding with a solid upper head.

20. Describe behavior of the level measurement system when the upper head is full, but the lower vessel is not.
21. One discussion of the microprocessor system states that water in the upper head is not reflected in the plot. Does this mean that there is no water in the upper head or that the system is indifferent to water in the upper head under these conditions?
22. Describe the details of the pump flow/Dp calculation. Discuss the possible errors.
23. Have tests been run with voids in the vessel? Describe the results of these tests.
24. Estimate the expected accuracy of the system after an ICC event.
25. Describe how the conversion of RTD resistance to temperature made in the analog level system.