


VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261



R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

December 31, 1981

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Serial No. 709
NO/GSS:acm
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

AMENDMENT TO OPERATING LICENSES DPR-32
AND DPR-37 SURRY POWER STATION UNIT NO. 1 & 2
PROPOSED TECHNICAL SPECIFICATION CHANGE

Pursuant to 10CFR50.90, the Virginia Electric and Power Company requests an amendment, in the form of changes to the Technical Specifications, to Operating Licenses DPR-32 and DPR-37 for the Surry Power Station, Unit No. 1 & 2. The proposed changes are enclosed.

The proposed change is to revise Specification 3.8.A.3 and Table 4.1.2A to add that the containment purge valves shall not be open above 200°F and also to add the containment purge MOV Leakage Test and the frequency of surveillance. This change is in accordance with our December 1, 1981 response to NRC generic letter dated October 8, 1981 concerning the Status of Generic item B-24 and completion of TMI Action item II.E.4.2.5. A Design Change is needed to conduct surveillance. Therefore, before the Technical Specification is issued, it is requested that the NRC Project Manager contact Mr. E. R. Smith, Jr. of our office regarding the schedule.

The requested change has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this request does not involve an unreviewed safety question.

We have evaluated this request in accordance with the criteria in 10CFR170.22 and it has been determined that a class III license amendment fee is required. A voucher check in the amount of \$4,400. is enclosed in payment of the required fee.

Very truly yours,

R. H. Leasburg
R. H. Leasburg

Attachments:

1. Proposed Technical Specification change.
2. Voucher Check No. 60415 for \$4,400.

cc: Mr. James P. O'Reilly, Regional Administrator
Office of Inspection and Enforcement
Region II

8201070114 811231
PDR ADOCK 05000280
PDR

*AOAG
5/11*

*w/check
\$4,400*

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart, who is Manager-Nuclear Operations and Maintenance, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 31st day of December, 19 81.

My Commission expires: 2-26, 19 85.

Ann C. Morse
Notary Public

(SEAL)

M004