

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS


February 19, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 093
NO/GSS:acm
Docket Nos. 50-280
50-281
License Nos. DPR-32

Gentlemen:

AMENDMENT TO OPERATING LICENSES DPR-32
AND DPR-37 SURRY POWER STATION UNIT NO. 1 & 2
PROPOSED TECHNICAL SPECIFICATION CHANGE



Pursuant to 10CFR50.90, the Virginia Electric and Power Company requests an amendment, in the form of changes to the Technical Specifications, to Operating Licenses DPR-32 and DPR-37 for the Surry Power Station, Unit No. 1 & 2. The proposed changes are enclosed.


The proposed change is to revise Specification 3.1.D.3 and 3.1 Bases, to permit the Surry Power Station to startup following shutdown, with the reactor coolant's specific activity greater than 1.0 $\mu\text{Ci/cc}$ DOSE EQUIVALENT I-131, to accommodate the possible iodine spiking phenomenon.

The startup and continued power operation under such conditions within 10 percent of the unit's total yearly operating time has received NRC concurrence for startup as indicated by their approval of its use in the Standardized Technical Specification and also represent the current Technical Specification requirement for continued power operation.

The requested change has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this request does not involve an unreviewed safety question.

We have evaluated this request in accordance with the criteria in 10CFR170.22 and it has been determined that a class III license amendment fee is required. A voucher check in the amount of \$4,400. is enclosed in payment of the required fee.

Very truly yours,


R. H. Leasburg

Attachments:

1. Proposed Technical Specification change
2. Voucher Check No. 9715 for \$4,400.

cc: Mr. James P. O'Reilly, Regional Administrator
Office of Inspection and Enforcement
Region II

8202250237 820219
PDR ADOCK 05000280
PDR

A001
s
//
w/check:
\$4000.00

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by R. H. Leasburg, who is Vice President-Nuclear Operations, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 19th day of Feb., 19 82.

My Commission expires: 2-26, 19 85.

Ann C. Morse
Notary Public

(SEAL)