

APPENDIX B

NOTICE OF DEVIATION

Virginia Electric and Power Company  
Surry Units 1 and 2

Docket Nos. 50-280 & 50-281  
License Nos. DPR-32 & DPR-37

Based on the results of the inspection conducted on December 7-11, 1981, certain of your activities appear to deviate from your commitments to the Commission as indicated below:

Virginia Electric and Power Company's Fire Protection Systems Review of July 1, 1977 Section III.C Fire Area 28C (Page III-147) states that initiation of the carbon dioxide system pneumatically closes the ventilation dampers in the fire walls enclosing the oil tank room.

Contrary to the above, initiation of the carbon dioxide system will not pneumatically close the ventilation fire dampers.

Date: ~~JAN 04 1982~~

8203020347 820223  
PDR ADOCK 05000280  
Q PDR