

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

June 23, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Serial No. 227B
NO/DWL/PSEC/EVF:ba
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNIT NOS. 1 AND 2
SUPPLEMENTAL RESPONSE FO GENERIC LETTER 82-05
NUREG-0737, ITEM II.F.1.6

As noted in our May 17, 1982 response to Generic Letter 82-05 (Serial No. 227), the Surry Hydrogen Monitors required by NUREG-0737, Item II.F.1 Part 6 are installed and tested. The associated sample supply and return lines for the Hydrogen Monitors are not installed. Accordingly, in our May 17, 1982 letter we requested an extension of the implementation schedule until January 1, 1983 for this item.

We are actively pursuing completion of this system by the January 1, 1983 date indicated in our Generic Letter 82-05 response. Based on the remaining scope of work, the above completion date appears credible, but in order to account for possible, though unanticipated, construction related difficulties during installation, we wish to extend the completion date until March 1, 1983. Possible delays would result from difficulties encountered during the placement of seismic pipe support baseplates as well as periodic inaccessibility of portions of the auxiliary building due to high radiation and contamination levels.

It is our intention to keep you advised of the ongoing progress of this project from now until completion. Please contact us if you have any questions.

Very truly yours,

R. H. Leasburg
R. H. Leasburg

A046

8206290079 820623
PDR ADOCK 05000280
PDR

cc: Mr. James P. O'Reilly
Regional Administrator - Region II
U.S. Nuclear Regulatory Commission
Atlanta, GA 30303

Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart, who is Manager-Nuclear Operations and Maintenance, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 23rd day of June, 19 82.

My Commission expires: 2-26, 19 85.

Ann C. Mize

Notary Public

(SEAL)

M004