

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

7/9  
~~S. Handover~~

R. H. LEASBURG  
VICE PRESIDENT  
NUCLEAR OPERATIONS

July 1, 1982

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Serial No. 395  
NO/JHL/ddp  
Docket Nos. 50-280  
50-281  
50-338  
50-339  
License Nos. DPR-32  
DPR-37  
NPF-4  
NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY  
EXCEPTIONS TO TECHNICAL SPECIFICATION REQUIREMENTS OF NUREG-0737

According to NUREG-0737, certain systems require submittal of Technical Specifications by July 1, 1982. Vepco will submit the Technical Specifications for the following systems by January 1, 1983, Sections: II.B.3 - Modifications on Post-Accident Sampling, II.F.1.1 - Noble Gas Effluent Monitors, II.F.1.2 - Sampling and Analysis of Plant Effluents, II.F.1.3 - Containment High-Range Radiation Monitors, and II.F.1.6 - Containment Hydrogen Monitors. In addition, Technical Specifications for Sections II.B.1 - Reactor Coolant System Vents and II.F.2 - Installation of Instrumentation for Detection of Inadequate Core Cooling will be submitted by January 1, 1983. The Reactor Vessel Level Indication System (Section II.F.2) has been installed and calibrated but it also requires a post-implementation review by the NRC Staff. The Reactor Coolant System Vents (Section II.B.2) are also installed and they also require post-implementation review but they are dependent on the NRC Staff approval of the Reactor Vessel Level Indication System (Section II.F.2).

Technical Specifications for Section II.F.1.4 Containment Pressure Monitors are installed but have open Equipment Qualification related items involved. Technical Specifications for this system will also be supplied by January 1, 1983.

The delay in submitting Technical Specifications for these systems will allow the coordination of Technical Specifications preparation along with the installation of these systems. Vepco will prepare Technical Specifications for the above systems using the guidance of the existing Technical Specifications for similar or related systems.


A046

VIRGINIA ELECTRIC AND POWER COMPANY TO

Harold R. Denton

If there are any questions regarding this information, please contact this office.

Very truly yours,

  
R. H. Leasburg

cc: Mr. Steven A. Varga, Chief  
Operating Reactor Branch No. 1  
Division of Licensing

Mr. Robert A. Clark, Chief  
Operating Reactor Branch No. 3  
Division of Licensing