

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

July 29, 1982

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 396
NO/GSS:acm
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

AMENDMENT TO OPERATING LICENSES DPR-32 AND DPR-37
SURRY POWER STATION UNITS NO. 1 AND 2
SUPPLEMENT TO PROPOSED TECHNICAL SPECIFICATION CHANGE

By the letter dated October 28, 1980 (Serial No. 862), we proposed changes to the Technical Specifications for Surry Power Station Units No. 1 and 2 to reflect changes to be made to the Auxiliary Ventilation System. The proposed changes supplement our October 28, 1980 license amendment application.

The enclosed revised Auxiliary Building Ventilation System Technical Specification reflects the modifications made to this system to upgrade the design, performance and functionality of this system through the various anticipated modes of operation. While these Technical Specifications are based on the model Technical Specifications provided in your transmittal of December 12, 1974, the format of the specifications has been modified to retain consistency with the existing station Technical Specifications. Also enclosed is the expanded Control Room Air Filtration System Technical Specification. These specifications are also based on the model specification provided to us but have been modified to reflect the existing Surry Technical Specification format and agreements made with your staff.

The Table of Contents is revised to reflect the additional sections added and to include the sections inadvertently omitted earlier. The title of the section 3.19 is changed to Main Control Room Bottled Air System to differentiate this from the separate section on Control Room Ventilation System. The Table 3.7-5 has been revised to reflect the existing system by deleting the exhaust fans. The containment purge exhaust fans were removed during the Auxiliary Building Ventilation System Modifications because, based on past experience, the containment was never purged without filtration; during the system modification, appropriate fans were installed with Category I filter train to purge the containment, hence the purge exhaust fans were not needed and deleted from the Table 3.7-5.

We also request a 30 day time period to implement the requested Technical Specification because of the time required to prepare the new procedures, and provide the necessary indoctrination for station personnel.

A034


8208030444 820729
PDR ADOCK 05000280
P PDR

VIRGINIA ELECTRIC AND POWER COMPANY TO Harold R. Denton

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this request does not involve an unreviewed safety question.

We have reviewed this request in accordance with the criteria in 10 CFR 170.22. Since this request supplements our previous license amendment applications referenced above, no additional license amendment fee is required.

Very truly yours,


R. H. Leasburg

Attachments:

1. Proposed Technical Specification Change

cc: Mr. James P. O'Reilly
Regional Administrator
Region II

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by R. H. Leasburg, who is Vice President-Nuclear Operations, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 29th day of July, 19 82.
My Commission expires: 2-26, 19 85.

Ann C. Morse
Notary Public

(SEAL)