

- D. All procedures described in A and B above shall be followed.
- E. Temporary changes to procedures described in A and B above which do not change the intent of the original procedure may be made, provided such changes are approved prior to implementation by the persons designated below based on the type of procedure to be changed:

1. Administrative	Cognizant Supervisor
2. Abnormal	Shift Supervisor or Assistant Shift Supervisor
3. Annunciator	Shift Supervisor or Assistant Shift Supervisor
4. Health Physics	*Assistant HP Supervisor or Health Physicists
5. Emergency	Shift Supervisor or Assistant Shift Supervisor
6. Maintenance	*Cognizant Supervisor
7. Operating	Shift Supervisor or Assistant Shift Supervisor
8. Periodic Test	*Cognizant Supervisor
9. Start-up Test	*Engineering Supervisor
10. Special Test	*Engineering Supervisor
11. Quality Assurance	Manager Quality Assurance or Supervisor Quality Control, O&M
12. Chemistry	*Chemist

*These procedures must have the approval of a licensed Senior Reactor Operator.

Such changes will be documented and subsequently reviewed by the Station Nuclear Safety and Operating Committee and approved by the Station Manager within fourteen days.