

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

January 12, 1983

Mr. Harold R. Denton  
Office of Nuclear Reactor Regulation  
Attn: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 713A  
NO/WDC:acm  
Docket Nos. 50-280  
50-281  
License Nos. DPR-32  
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY POWER STATION  
CLARIFICATION OF RVLIS AND RCS VENTS STATUS

In our letter dated December 28, 1982 (Serial No. 713), we state that the Reactor Vessel Level Indication System (NUREG-0737, Item II.F.2) has been installed and calibrated. We also state that the Reactor Coolant System Vents (NUREG-0737, Item II.B.2) have been installed. For Surry Power Station, the Reactor Vessel Level Indication System has been installed, but not calibrated. Due to faulty components being recalled by the vendor, however, the system is presently partially disassembled. The Reactor Coolant System Vents have been installed, but not electrically connected. System repairs and calibration for the Reactor Vessel Level Indication System and electrical hook-ups and testing for the Reactor Coolant System Vents are scheduled for the upcoming refueling outages in 1983.

The schedule for submitting the Technical Specifications for these systems remains as stated in our letter (Serial No. 713) referenced above.

Very truly yours,

*W. L. Stewart*  
W. L. Stewart

cc: Mr. Steven A. Varga, Chief  
Operating Reactor Branch No. 1  
Division of Licensing

Mr. Robert A. Clark, Chief  
Operating Reactor Branch No. 3  
Division of Licensing

A046

8301180391 830112  
PDR ADOCK 05000280  
P PDR