

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

March 14, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 139  
FR/NAS: du  
Docket No. 50-280  
License No. DPR-32

Gentlemen:

SUPPLEMENTAL INFORMATION FOR CYCLE 7 RELOAD  
SURRY NUCLEAR POWER STATION UNIT NO. 1

Surry Unit 1 completed its sixth cycle of operation on February 8, 1983. During Cycle 6 operation Vepco experienced levels of primary coolant radioactivity which were indicative of fuel element defects in the core. This information was reported to the NRC in LER 81-033/03L-0 dated September 15, 1981, and subsequent LER's.

As a result of the primary coolant activity Vepco began planning an extensive fuel examination program to identify the assemblies containing fuel failures. This program was initiated on March 5, 1983, and as a result of the first examination phase (binocular visual examination), Vepco has concluded that 3 assemblies, which were scheduled to be returned to the Cycle 7 core, contain fuel defects. As a result, we have instructed Westinghouse to proceed with the development and evaluation of an alternate core loading pattern for Cycle 7. This evaluation is scheduled to be complete in early April. You will be notified of the results of the evaluation in accordance with 10CF50.59.


In the event that Technical Specifications changes are required to support Cycle 7 operation with the revised core loading pattern, we will be contacting you to request expeditious review of the change request as we discussed with Mr. D. J. Neighbors on December 17, 1982. This accelerated review would be needed to support our current operating schedule, which calls for Cycle 7 startup by April 23, 1983.

8303170365 830314  
PDR ADOCK 05000280  
P PDR

Appl

This letter is provided for your information and planning. However, should you have any questions, please contact us at your earliest convenience.

Very truly yours,



W. L. Stewart  
Vice President  
Nuclear Operations

cc: Mr. James P. O'Reilly  
Regional Administrator  
Region II