

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

March 31, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 713C  
NO/WDC:acm  
Docket Nos. 50-280  
50-281  
License Nos. DRP-32  
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY POWER STATION UNIT NOS. 1 AND 2  
EXCEPTIONS TO TECHNICAL SPECIFICATION REQUIREMENTS OF NUREG-0737

In our letter dated December 28, 1982 (Serial No. 713), Veeco stated that Technical Specifications pertinent to NUREG-0737 items/systems will be submitted by April 1, 1983.

On March 31, 1983, Veeco proposed a Technical Specifications change to Technical Specification 3.7.F for Surry Units 1 and 2. This change adds the Reactor Vessel Coolant Level Monitoring System (NUREG-0737, Item II.F.2) to the tables for accident monitoring instrumentation and accident monitoring instrumentation surveillance requirements.

Veeco has contracted with the architectural engineer of the systems to supply the Technical Specifications for the NUREG-0737 items/systems. There will be a delay in the submittal of the Technical Specifications due to a delay in receipt of Technical Specifications from the architectural engineer.

Veeco will submit the Technical Specifications pertinent to the following NUREG-0737 items/systems by June 1, 1983, Items: II.F.1.1-Noble Gas Effluent Monitors, II.F.1.3-Containment High Range Radiation Monitors, II.F.1.4-Containment Pressure Monitors, II.F.1.5-Containment Water Level Monitor, II.F.1.6-Containment Hydrogen Monitors and II.B.1-Reactor Coolant System Vents. The Reactor Coolant System Vents (Item II.B.2) are installed. Electrical connections are being made for Unit 1 during the present outage. Similar electrical connections will be made for Unit 2 at the next refueling outage presently scheduled for May, 1983. The RCS vents require post-implementation review and are dependent on the NRC Staff approval of the Reactor Vessel Coolant Level Monitoring System (Item II.F.2).


A046

8304070249 830331  
PDR ADOCK 05000280  
PDR

VIRGINIA ELECTRIC AND POWER COMPANY TO Harold R. Denton

If there are any questions regarding this information, please contact this office.

Very truly yours,

A handwritten signature in cursive script, appearing to read "W. L. Stewart".

W. L. Stewart

cc: Mr. Steven A. Varga, Chief  
Operating Reactor Branch No. 1  
Division of Licensing

Mr. Robert A. Clark, Chief  
Operating Reactor Branch No. 3  
Division of Licensing