

JUN 15 1983

Distribution  
AEOD RF  
AEOD CF  
Cheltemes  
NRC PDR

MEMORANDUM FOR: Karl V. Seyfrit, Chief  
Reactor Operations Analysis Branch  
Office for Analysis and Evaluation  
of Operational Data

AEOD/T321

THRU: Wayne Lanning  
Reactor Operations Analysis Branch  
Office for Analysis and Evaluation  
of Operational Data

FROM: Dorothy Zukor  
Reactor Operations Analysis Branch  
Office for Analysis and Evaluation  
of Operational Data

SUBJECT: CHECK VALVE IN INSTRUMENT AIR LINE TO THE PORV  
INSTALLED BACKWARDS AT SURRY UNIT 1

This event may indicate a management deficiency at this plant and should be included in Surry's upcoming SALP review. It may also indicate that adequate consideration was not given to the implications of installing this valve incorrectly.

*Dorothy Zukor*  
Dorothy Zukor  
Reactor Operations Analysis Branch  
Office for Analysis and Evaluation  
of Operational Data

8307290414 830615  
PDR ADDCK 05000280  
S PDR

OFFICE	ROAB <i>DZ</i>	ROAB <i>WL</i>	C/ROAB <i>KS</i>				
SURNAME	DZukor	WLanning	KSeyfrit				
DATE	6/7/83	6/13/83	6/14/83				