

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

October 20, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 038A  
NO/DWL:acm  
Docket Nos. 50-280  
50-281  
50-338  
50-339  
License Nos. DPR-32  
DPR-37  
NPF-4  
NPF-7

Gentlemen:


VIRGINIA ELECTRIC AND POWER COMPANY  
SUPPLEMENTAL SER RESPONSE RE: NUREG-0737, ITEM II.B.3

On January 11, 1983, the NRC issued a request for additional information (in the form of four SER open items) for Item II.B.3 of NUREG-0737, "Post Accident Sampling". Veeco responded to this information request on March 25, 1983 (Serial No. 038).

Via subsequent phone conversations with Mr. Frank Witt of your staff. Veeco was requested to upgrade our efforts and response regarding implementation of a Core Damage Assessment Procedure. Specifically, we were requested to implement an interim procedure in place of our proposed "expertise pool approach".

Veeco has implemented an interim Core Damage Assessment Procedure. At this time, our Corporate Emergency Response Plan Implementing Procedures references the availability of an interim Core Damage Assessment Procedure which is located in the Corporate Emergency Response Center Reference Library. The interim procedure in place is the Duke Power Company, McGuire Core Damage Assessment Procedure. We recognize that the McGuire procedure generally addresses only Iodine isotopic concentrations and is therefore not adequate as a final procedure. Accordingly, as specified in our March 25, 1983 response, Veeco plans to utilize, when available, the Core Damage Assessment Methodology being developed by the Westinghouse Owners Group. This "Methodology" is expected to be completed by the end of 1983.

Very truly yours,

  
W. L. Stewart

8310270300 831020  
PDR ADOCK 05000280  
P PDR

A046  
1/0

VIRGINIA ELECTRIC AND POWER COMPANY TO Harold R. Denton

cc: Mr. James P. O'Reilly  
Regional Administrator  
Region II  
USNRC  
Atlanta, GA 30303

Mr. Steven A. Varga, Chief  
Operating Reactors Branch No. 1  
Division of Licensing

Mr. James R. Miller, Chief  
Operating Reactors Branch No. 3  
Division of Licensing

Mr. D. J. Burke  
NRC Resident Inspector  
Surry Power Station

Mr. M. B. Shymlock  
NRC Resident Inspector  
North Anna Power Station