



VIRGINIA ELECTRIC AND POWER COMPANY, RICHMOND, VIRGINIA 23261

February 9, 1984

IE FILE COPY

Mr. Ray R. Jenkins
Piedmont Regional Office
State Water Control Board
P. O. Box 6745
Richmond, Virginia 23230

Surry Power Station - Sewage Treatment Plant

Dear Mr. Jenkins:

This is to update you on the status of the chlorination system at our Surry Power Station sewage treatment plant.

My letter of February 3, 1984, reported that the chlorine gas feed system at the sewage treatment plant was discovered to be malfunctioning on February 1. The service representative was contacted and has corrected the problem. The chlorine gas feed system was returned to operation as of approximately 2:00 p.m. on February 3, 1984.

If you have any questions regarding this matter, please let us know.

Very truly yours,

John A. Taylor, Ph.D.
Manager
Water Quality

BWE/yo

cc: Mr. J. P. O'Reilly
Mr. Harold R. Denton ✓
Mr. Donald J. Burke

8402210095 840209
PDR ADDCK 05000280
S PDR

IE23
1/0