

VIRGINIA ELECTRIC AND POWER COMPANY

REVISIONS TO
SURRY POWER STATION
EMERGENCY PLAN IMPLEMENTING PROCEDURES

Enclosed are recently revised pages to the Surry Power Station Emergency Plan Implementing Procedures. Please take the following actions in order to keep your manual updated with the most recent revisions.

EPIP-1.01

EMERGENCY MANAGER CONTROLLING PROCEDURE

Remove and Destroy

Page 1 of 8, Rev. 09
and page 6 of 8, Rev.
08; Pages 6 of 39,
7 of 39, 8 of 39 and
9 of 39 of Attachment
1, all Rev. 08.

Enter

Pages 1 of 8 and
6 of 8; Pages 6 of 39,
7 of 39, 8 of 39 and
9 of 39 of Attachment 1
all Rev. 10.
Dated 02-02-84

8402240032 840202
PDR ADCK 05000280
F PDR

AGHS
1/1

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION
EMERGENCY PLAN IMPLEMENTING PROCEDURE

NUMBER	PROCEDURE TITLE	REVISION
EPIP-1.01	EMERGENCY MANAGER CONTROLLING PROCEDURE (With 1 Attachment)	10 PAGE 1 of 8

PURPOSE

To initially assess a potential emergency condition and initiate corrective actions.

USER

Shift Supervisor or Station Emergency Manager

ENTRY CONDITIONS

Any one of the following :




- Another station procedure directs initiation of this procedure

OR

- A potential emergency condition is reported to the Shift Supervisor.

REVISION RECORD

REV. 05	PAGE(S): 1 of 8, Att. 1 page 4, 22, and 23 of 39	DATE:03-10-83
REV. 06	PAGE(S): 1 of 8 and 4 of 8	DATE:03-11-83
REV. 07	PAGE(S): 1 Of 8, Att. 1 page 13 of 39	DATE:03-17-83
REV. 08	PAGE(S): 1, 5, 6 & 8; Att. 1, pgs. 2 through 13, 15, 17, 18, 20, and 23 through 38	DATE:11-10-83
REV. 09	PAGE(S): 1 of 8 and 5 of 8	DATE:01-13-84
REV. 10	PAGE(S): 1, 6; Att. 1, pgs. 6, 7, 8 and 9	DATE: FEB 02 1984

<p>APPROVAL RECOMMENDED</p> 	<p>APPROVED</p> 	<p>DATE</p>
<p>QC REVIEW</p> 	<p>CHAIRMAN STATION NUCLEAR SAFETY AND OPERATING COMMITTEE</p>	<p>FEB 2 1984</p>

NUMBER EPIP-1.01	PROCEDURE TITLE EMERGENCY MANAGER CONTROLLING PROCEDURE	REVISION 10
		PAGE 6 of 8

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
5.	(CONTINUED)	
	b) <u>IF</u> required, assign appropriate individual as interim Emergency Communicator	
	c) <u>IF</u> required, direct senior H.P. personnel on site to initiate EPIP-4.01, <u>Radiological Assessment Director Controlling Procedure</u>	
6.	DETERMINE EPIPS:	
	a) Event classification - NOTIFICATION OF UNUSUAL EVENT	a) <u>GO TO</u> Step <u>6b</u> of this instruction.
	1) <u>GO TO</u> EPIP-1.02, <u>Response to Notification of Unusual Event</u>	
	b) Event classification - ALERT	b) <u>GO TO</u> Step <u>6c</u> of this instruction.
	1) <u>GO TO</u> EPIP-1.03, <u>Response to Alert</u>	
	c) Event classification - SITE AREA EMERGENCY	c) <u>GO TO</u> Step <u>6d</u> of this instruction.
	1) <u>GO TO</u> EPIP-1.04, <u>Response to Site Area Emergency</u>	
	d) Event classification - GENERAL EMERGENCY	
	1) <u>GO TO</u> EPIP-1.05, <u>Response to General Emergency</u>	
7.	SECURE FROM EVENT:	
	a) Notify involved station personnel that emergency condition does not exist	

<p>NUMBER EPIP-1.01</p>	<p>ATTACHMENT TITLE EMERGENCY ACTION LEVEL TABLE (TAB B) REACTOR COOLANT SYSTEM EVENT</p>	<p>REVISION 10</p>
<p>ATTACHMENT 1</p>		<p>PAGE 6 of 39</p>

<u>CONDITION/ APPLICABILITY</u>	<u>INDICATION</u>	<u>CLASSIFICATION</u>
<p>1. Safety Limit-RCS Temperature/Pressure curve exceeded</p>	<p>Limits of T.S. Fig. 2.1-1 - EXCEEDED</p>	<p>Notification of Unusual Event</p>
<p>POWER & HSB</p>		
<p>2. RCS overpressure</p>	<p>2735 psig RCS Pressure limit- EXCEEDED</p>	<p>Notification of Unusual Event</p>
<p>ALL CONDITIONS</p>		
<p>3. Rx overpower</p>	<p>118% Rx thermal power limit - EXCEEDED</p>	<p>Notification of Unusual Event</p>
<p>POWER</p>		
<p>4. RCS leak rate exceeds 300 gpm</p>	<p>EP-2.00, <u>Loss of Reactor Coolant - IMPLEMENTED</u></p>	<p>Site Area Emergency</p>
<p>ABOVE CSD CONDITION</p>	<p><u>AND</u></p>	
	<p>Pressurizer level can not be maintained with two (2) Charging/SI Pumps in operation</p>	
<p>5. RCS leak rate exceeds 50 gpm</p>	<p>Unit in HSD or lower cond- ition as a result of actions required IAW AP-16, <u>Excessive Primary Plant Leakage</u></p>	<p>Alert</p>
<p>ABOVE CSD CONDITION</p>	<p><u>AND</u></p>	
	<p>RCS inventory balance indi- cates leakage-GREATER THAN <u>50 gpm</u></p>	

<p>NUMBER EPIP-1.01</p>	<p>ATTACHMENT TITLE EMERGENCY ACTION LEVEL TABLE (TAB B)</p>	<p>REVISION 10</p>
<p>ATTACHMENT 1</p>	<p>REACTOR COOLANT SYSTEM EVENT</p>	<p>PAGE 7 of 39</p>

<u>CONDITION/ APPLICABILITY</u>	<u>INDICATION</u>	<u>CLASSIFICATION</u>
<p>6. RCS leak rate requiring plant shutdown IAW T.S. 3.1.C</p> <p>POWER & HSB</p>	<p>Unit in HSD or lower as a result of any of the following:</p> <p>a) Unidentified RCS leakage- GREATER THAN <u>1</u> gpm</p> <p style="text-align: center;"><u>OR</u></p> <p>b) Identified leakage-GREATER THAN <u>10</u> gpm</p> <p style="text-align: center;"><u>OR</u></p> <p>c) Non-isolable fault of RCS pressure boundary</p>	<p>Notification of Unusual Event</p>
<p>7. RCP locked rotor leading to fuel damage</p> <p>POWER</p>	<p>All the following exist:</p> <p>a) Flow in one or more RC loops - LESS THAN <u>90%</u></p> <p style="text-align: center;"><u>AND</u></p> <p>b) RCP trip caused by Phase Overcurrent Relay - ACTUATION</p> <p style="text-align: center;"><u>AND</u></p> <p>c) High Range Letdown Radiation Monitor indication increases to-GREATER THAN <u>5x10⁵</u> cpm</p>	<p>Alert</p>

<p><i>NUMBER</i> EPIP-1.01</p>	<p><i>ATTACHMENT TITLE</i></p>	<p><i>REVISION</i> 10</p>
<p><i>ATTACHMENT</i> 1</p>	<p>EMERGENCY ACTION LEVEL TABLE (TAB B) REACTOR COOLANT SYSTEM EVENT</p>	<p><i>PAGE</i> 8 of 39</p>

<u>CONDITION/ APPLICABILITY</u>	<u>INDICATION</u>	<u>CLASSIFICATION</u>
<p>8. Gross Primary to Secondary leakage with loss of offsite power</p> <p>ABOVE CSD CONDITION</p>	<p>EP-4.00, <u>Steam Generator Tube Rupture</u> - IMPLEMENTED with SI in progress</p> <p><u>AND</u></p> <p>Condenser Air Ejector Exhaust - DIVERT to Containment</p> <p><u>AND</u></p> <p>Loss of offsite power indi- cated by zero volts on volt- meters for 4160V Buses D, E & F</p>	<p>Site Area Emergency</p>
<p>9. Excessive Primary to Secondary leakage with loss of offsite power</p> <p>ABOVE CSD CONDITION</p>	<p>Unit in HSD or lower condition as a result of actions required by T.S. 3.1.C.6</p> <p><u>AND</u></p> <p>Loss of offsite power indicated by zero volts on voltmeters for 4160V buses D, E & F.</p>	<p>Alert</p>

<u>NUMBER</u> EPIP-1.01	<u>ATTACHMENT TITLE</u> EMERGENCY ACTION LEVEL TABLE (TAB B) REACTOR COOLANT SYSTEM EVENT	<u>REVISION</u> 10
<u>ATTACHMENT</u> 1		<u>PAGE</u> 9 of 39

<u>CONDITION/ APPLICABILITY</u>	<u>INDICATION</u>	<u>CLASSIFICATION</u>
10. Gross Primary to Secondary leakage ABOVE CSD CONDITION	EP-4.00, <u>Steam Generator Tube Rupture</u> - IMPLEMENTED with SI in progress <u>AND</u> Condenser Air Ejector Exhaust - DIVERT to Containment	Alert
11. Primary to Secondary leakage-GREATER THAN 1 gpm ABOVE CSD CONDITION	Unit in HSD or lower condition as a result of actions required by T.S. 3.1.C.6	Notification of Unusual Event
12. Loss of 2 of 3 fission product barriers with potential loss of 3rd barrier ALL CONDITIONS	Any two of a),b) or c) exist and the third is imminent a) Fuel clad integrity failure as indicated by any of the following: 1) RCS specific activity - GREATER THAN OR EQUAL TO <u>300.0</u> uCi/gram dose equivalent I-131. 2) 5 or more core exit thermocouples reading-GREATER THAN <u>1200°</u> F <u>OR</u> b) Loss of RCS integrity as indicated by any of the following:	General Emergency

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

February 17, 1984

Mr. James P. O'Reilly
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 2900
Atlanta, Georgia 30303


Serial No. 081
NO/REB/vgv:EM1-17
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Dear Mr. O'Reilly:

REVISIONS TO
SURRY POWER STATION
EMERGENCY PLAN IMPLEMENTING PROCEDURES

Pursuant to 10CFR 50, Appendix E, paragraph 50.54 (q), revisions to the Surry Power Station Emergency Plan Implementing Procedures, numbers, and subjects as listed on enclosures are submitted.

Sincerely,


W. L. Stewart

Enclosures

cc: Document Control Desk (2)

w/o Enclosures

cc: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1

Mr. D. J. Burke - (NRC - Surry)

A045
11