

May 28, 1985

Docket Nos. 50-280  
and 50-281

Mr. W. L. Stewart  
Vice President - Nuclear Operations  
Virginia Electric and Power Company  
Post Office Box 26666  
Richmond, Virginia 23261

DISTRIBUTION

Docket File

L-PDR  
HThompson  
EJordan  
JPartlow  
ACRS 10  
Gray File

NRC PDR  
ORB#1 Rdg  
OELD  
BGrimes  
JDNeighbors  
CParrish

Dear Mr. Stewart:

We are reviewing the proposed Technical Specifications related to Inservice Inspection for the Surry Power Station submitted by your letter dated September 21, 1982. We find that we need additional information to continue our review.

It is requested that you provide the information listed in the enclosure within 30 days of receipt of this letter or provide us with your schedule for doing so.

The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

Enclosure:  
As stated

cc:  
See next page

ORB#1:DL ORB#1:DL BC-ORB#1:DL  
CParrish DNeighbors;ps SVarga  
5/27/85 5/27/85 5/27/85

97-052

3

Mr. W. L. Stewart  
Virginia Electric and Power Company

Surry Power Station

cc: Mr. Michael W. Maupin  
Hunton and Williams  
Post Office Box 1535  
Richmond, Virginia 23213

Attorney General  
Supreme Court Building  
101 North 8th Street  
Richmond, Virginia 23219

Mr. Robert F. Saunders, Manager  
Surry Power Station  
Post Office Box 315  
Surry, Virginia 23883

Donald J. Burke, Resident Inspector  
Surry Power Station  
U.S. Nuclear Regulatory Commission  
Post Office Box 166, Route 1  
Surry, Virginia 23883

Mr. Sherlock Holmes, Chairman  
Board of Supervisors of Surry County  
Surry County Courthouse  
Surry, Virginia 23683

W. T. Lough  
Virginia Corporation Commission  
Division of Energy Regulation  
Post Office Box 1197  
Richmond, Virginia 23209

Mr. J. H. Ferguson  
Executive Vice President - Power  
Virginia Electric and Power Company  
Post Office Box 26666  
Richmond, Virginia 23261

Dr. J. Nelson Grace  
Regional Administrator - Region II  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

James B. Kenley, M.D., Commissioner  
Department of Health  
109 Governor Street  
Richmond, Virginia 23219

## ADDITIONAL INFORMATION REQUESTED -

## PROPOSED TECHNICAL SPECIFICATION CHANGES, SURRY UNITS 1 AND 2

1. Provide a detailed description giving the reasons and justifications for your proposed changes. This could be similar to the "Description of Changes" provided with your February 14, 1979, request for Technical Specification (TS) changes.
2. With regard to your proposed wording for TSs 4.0.2 and 4.0.3, we encourage you to use instead the wording indicated in 4.0.2 and 4.0.5 of the Standard Technical Specifications (STSS) for Westinghouse Pressurized Water Reactors (NUREG-0452, Revision 4). Please indicate whether you have any objection to this STS wording as a modification to your proposed changes.
3. With regard to the bases you propose for TS 4.0, please indicate whether you have any objection to substituting, as a modification to your proposed changes, the wording of STS Bases 4.0.2 and 4.0.5.
4. For TS Table 4.1-2A, item 13, explain what effect the proposed changes will have on test frequency and type of stroking requirements (i.e., full versus partial stroking).
5. Verify that you will continue to maintain as permanent records the past Inservice Inspection (ISI) data that were generated in complying with TS Table 4.2-1.
6. Provide detailed justification for your deletion of most of TS Table 4.2-1, Section G, Miscellaneous Inspections.
7. Indicate whether the changes that you propose in pump test frequency require changes to your flushing requirements referred to in TS Table 4.1-3.
8. Provide detailed justification for your deletion of the special inspections of sensitized stainless steel piping in TS Table 4.2-1, Section H.
9. Explain the significance of the changes you propose in the pump flywheel inspection requirements.
10. With regard to your proposed changes to TS 4.3, explain and justify in detail, your deletion of the reactor coolant system leakage test in TS 4.3.0. Include an explanation of why this test was originally included in the TSs.
11. Provide a revised TS index identifying your proposed changes.

12. Check your submittal to assure that TS changes you proposed are still appropriate. You may wish to modify the your September 21, 1982, submittal in order to incorporate corrections that were proposed and accepted subsequent to the submittal. For example, compare your proposed TS Table 4.1-2A, Item 1 requirements, with the current requirements.