

June 21, 1985



VIRGINIA POWER

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 85-305A
NO/JDH:cfm
Docket No. 50-281
License No. DPR-37

Gentlemen:

VIRGINIA POWER
SURREY POWER STATION UNIT NO. 2
ASME SECTION XI RELIEF REQUEST - SUPPLEMENT

On May 3, 1985, we submitted a letter (Serial No. 85-305) requesting relief from certain ASME Section XI requirements concerning hydrostatic testing. During a subsequent telephone conversation with the NRC Surry Project Manager, we informed him that one of the two references cited in the letter was incorrect. The incorrect reference is a Virginia Power letter, W. L. Stewart to H. R. Denton, dated April 14, 1985, Serial No. 001B. The correct reference is a Virginia Power letter, W. L. Stewart to H. R. Denton, dated April 12, 1984, Serial No. 201, which requested relief from certain post-repair/replacement test requirements delineated in ASME Section XI. This relief request was approved by the NRC on May 17, 1984.

During the same discussion, the NRC Surry Project Manager requested that we specifically identify the several valves discussed in our May 3, 1985, request for which repairs or replacements involving welding on the pressure boundary are planned for non-isolable portions of the Blowdown System and Main Steam branch connections. These components do not exceed 2 inch nominal pipe size and are listed below:

Steam Generator Blowdown Root Valves

2-BD-1
2-BD-4
2-BD-11
2-BD-14
2-BD-21
2-BD-24

Main Steamline Drain Valves

2-MS-120
2-MS-266
2-MS-378
2-MS-379

8506270058 850621
PDR ADDCK 05000281
P PDR

ADAT
1/0

If you have any further questions or require additional information,
please contact us immediately.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'W. L. Stewart', with a stylized, cursive script.

W. L. Stewart

cc: Dr. J. Nelson Grace
Regional Administrator

Mr. D. J. Burke
NRC Resident Inspector
Surry Power Station