

309/20/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-244

REC: GRIER B H
NRC

ORG: WHITE L D
ROCHESTER GAS & ELEC

DOCDATE: 09/14/78
DATE RCVD: 09/22/78

DOCTYPE: LETTER NOTARIZED: NO COPIES RECEIVED
SUBJECT: LTR 1 ENCL 1

FORWARDING LICENSEE EVENT REPT (RO 50-244/78-007) ON 08/16/78 CONCERNING
DURING MONTHLY SURVEILLANCE BUS 16 BREAKER FROM B DIESEL EMERGENCY GENERATOR
DID NOT TRIP WHEN SWITCH WAS PLACED IN TRIP, DUE TO BAD CONNECTION AT CONTROL
PWR FUSE BLOCK STABS.

PLANT NAME: RE GINNA - UNIT 1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *[Signature]*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF ORB#2 BC**W/4 ENCL

INTERNAL:

- REG FILE**W/ENCL
- I & E**W/2 ENCL
- I & C SYSTEMS BR**W/ENCL
- NOVAK/CHECK**W/ENCL
- AD FOR ENG**W/ENCL
- HANAUER**W/ENCL
- AD FOR SYS & PROJ**W/ENCL
- ENGINEERING BR**W/ENCL
- KREGER/J. COLLINS**W/ENCL
- K SEYFRIT/IE**W/ENCL

- NRC PDR**W/ENCL
- MIPC**W/3 ENCL
- EMERGENCY PLAN BR**W/ENCL
- EEB**W/ENCL
- PLANT SYSTEMS BR**W/ENCL
- AD FOR PLANT SYSTEMS**W/ENCL
- REACTOR SAFETY BR**W/ENCL
- VOLLMER/BUNCH**W/ENCL
- POWER SYS BR**W/ENCL

EXTERNAL:

- LPDR'S
- ROCHESTER, NY**W/ENCL
- NSIC**W/ENCL
- ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 44 ENCL 44
SIZE: 1P+1P

CONTROL NBR: 780860164

***** THE END *****

A104
CCP



SS



RETURN TO REACTOR DOCKET FILES



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

September 14, 1978

REC'D
SERVICES
11 19 78
STRATEGIC

Mr. Boyce H. Grier, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Subject: LER 78-007/03L-0, Bus 16 circuit breaker for B emergency generator
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Grier:

In accordance with Technical Specifications, Article 6.9.2.b.(2) operation in a degraded mode permitted by a limiting condition for operation, the attached report of Reportable Occurrence 78-007, 30-day is hereby submitted. Two additional copies of this letter and the attachment are enclosed.

Very truly yours,

L D White Jr
L. D. White, Jr.

Attachment

cc: Director, IE, Washington (30)
Mr. William G. McDonald (3)

780860164

A002
S/1

1950

1950

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE NYREG1, LICENSE NUMBER 00-000000-000, LICENSE TYPE 41111, CAT 58

REPORT SOURCE L, DOCKET NUMBER 05000244, EVENT DATE 081678, REPORT DATE 091478

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES: During monthly surveillance bus 16 breaker from B Diesel emergency generator (EG) did not trip when switch was placed in trip. Control power fuses were replaced and breaker was successfully tripped. Attempts to reclose breaker to verify proper operation failed. (T.S. 6.9.2.b.2). B EG was declared inoperable and A EG was started.

SYSTEM CODE EE, CAUSE CODE E, CAUSE SUBCODE A, COMPONENT CODE CKTBKR, COMP. SUBCODE A, VALVE SUBCODE Z, LER/RO REPORT NUMBER 78, SEQUENTIAL REPORT NO. 007, OCCURRENCE CODE 03, REPORT TYPE L, REVISION NO. 0, ACTION TAKEN BZ, EFFECT ON PLANT Z, SHUTDOWN METHOD Z, HOURS 0000, ATTACHMENT SUBMITTED N, NPRD-4 FORM SUB. Y, PRIME COMP. SUPPLIER N, COMPONENT MANUFACTURER W120

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS: Bad connection at control power fuse block stabs. Stabs were spread to permit proper contact. Surveillance test was completed successfully. As this is an isolated case no additional corrective action was considered necessary. Circuit breaker is Westinghouse Model DB-75, 600 V A.C., 3000 amp.

FACILITY STATUS E, % POWER 100, OTHER STATUS NA, METHOD OF DISCOVERY B, DISCOVERY DESCRIPTION Monthly surveillance

ACTIVITY CONTENT RELEASED OF RELEASE Z, AMOUNT OF ACTIVITY NA, LOCATION OF RELEASE NA

PERSONNEL EXPOSURES NUMBER 000, TYPE Z, DESCRIPTION NA

PERSONNEL INJURIES NUMBER 000, DESCRIPTION NA

LOSS OF OR DAMAGE TO FACILITY TYPE Z, DESCRIPTION NA

PUBLICITY ISSUED N, DESCRIPTION NA