

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO: J.P.O'REILLY

FROM: ROCHESTER GAS & ELEC. CORP.
ROCHESTER, N.Y.
L.D. WHITE, JR.

DATE OF DOCUMENT
5/27/77

DATE RECEIVED
6/2/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED
100

DESCRIPTION
LTR. TRANS THE FOLLOWING:.....

(1P)

PLANT NAME: R.E. GINNA # 1
SAB

ENCLOSURE
UPDATE LICENSEE EVENT REPORT # 76-27, 30 DAY ON
12/16/76 CONCERNING LIQUID COMING THROUGH INSULAT-
ION ON 2" LETDOWN DIVERSION LINE.....
UPDATE LICENSEE EVENT REPORT # 76-30, 30 DAY ON
12/17/76 CONCERNING LIQUID LEAKING FROM THE "A"
MIXED BED SEMINERALIZER INLET PIPE.....

(2P) **DO NOT REMOVE**

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

BRANCH CHIEF:	SCHWENGER
W/3 CYS FOR ACTION	
LIC. ASST.:	SHEPPARD
W/ 1 CYS	
ACRS 16 CYS HOLDING/SENT	AS CAT B

INTERNAL DISTRIBUTION

REG FILE				
NRC PDR				
I & E (2)				
MIPC				
SCHROEDER/IPPOLITO				
HOUSTON				
NOVAK/CHECK				
GRIMES				
BUTLER				
HANAUER				
TEDESCO/MACCARY				
EISENHUT				
BAER				
SHAO				
VOLLMER/BUNGH				
KREGER/J. COLLINS				

INTERNAL DISTRIBUTION

LPDR: ROCHESTER NY			
TIC:			
NSIC:			

CONTROL NUMBER

771540052



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

LEON D. WHITE, JR.
VICE PRESIDENT

TELEPHONE
AREA CODE 716 546-2700

May 27, 1977

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

File Cy.



Subject: Supplemental reports on Reportable Occurrences:
76-27 (30-day report) Leak in letdown diversion line
76-30 (30-day report) "A" mixed bed demineralizer inlet
piping leak
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. O'Reilly:

The purpose of this letter is to provide you with corrected component manufacturer information in connection with the subject reports which were submitted January 4 and January 12, 1977 respectively. The attached update reports LER 76-27/30 and LER 76-30/30 provide this information.


Two additional copies of this letter and the attachments are enclosed to conform to the original submittal of LER 76-27/3L and LER 76-30/3L.


Very truly yours,

L. D. White, Jr.

cc: Dr. Ernst Volgenau (30)
Mr. William G. McDonald (3)

771540052





LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME:

01	N	Y	R	E	G	1
----	---	---	---	---	---	---

 LICENSE NUMBER:

0	0	-	0	0	0	0	0	-	0	0
---	---	---	---	---	---	---	---	---	---	---

 LICENSE TYPE:

4	1	1	1	1
---	---	---	---	---

 EVENT TYPE:

0	3
---	---

REPORT TYPE:

O

 REPORT SOURCE:

L

 DOCKET NUMBER:

0	5	0	-	0	2	4	4
---	---	---	---	---	---	---	---

 EVENT DATE:

1	2	1	7	7	6
---	---	---	---	---	---

 REPORT DATE:

0	5	2	7	7	7
---	---	---	---	---	---

EVENT DESCRIPTION

02 | During normal rounds an operator discovered liquid leaking from the "A" mixed bed
 03 | demineralizer inlet pipe. (Reportable Occurrence 76-30, 30-day).
 04 |
 05 |
 06 |

SYSTEM CODE:

C	G
---	---

 CAUSE CODE:

B

 COMPONENT CODE:

P	I	P	E	X	X
---	---	---	---	---	---

 PRIME COMPONENT SUPPLIER:

N

 COMPONENT MANUFACTURER:

B	1	3	0
---	---	---	---

 VIOLATION:

N

CAUSE DESCRIPTION

08 | Pinhole leak in weld between pipe and elbow. Hole was ground out and repaired using
 09 | proper welding procedure. The piping was visually inspected for leakage after return
 10 | to service. CAR 1114 was issued for this event.

FACILITY STATUS:

E

 % POWER:

1	0	0
---	---	---

 OTHER STATUS:

NA

 METHOD OF DISCOVERY:

b

 DISCOVERY DESCRIPTION:

Operator making rounds

 FORM OF ACTIVITY RELEASED:

Z

 CONTENT OF RELEASE:

Z

 AMOUNT OF ACTIVITY:

NA

 LOCATION OF RELEASE:

NA

PERSONNEL EXPOSURES

13 | NUMBER:

0	0	0
---	---	---

 TYPE:

Z

 DESCRIPTION:

NA

PERSONNEL INJURIES

14 | NUMBER:

0	0	0
---	---	---

 DESCRIPTION:

NA

OFFSITE CONSEQUENCES

15 |

NA

LOSS OR DAMAGE TO FACILITY

16 | TYPE:

Z

 DESCRIPTION:

NA

PUBLICITY

17 |

NA

ADDITIONAL FACTORS

18 |

NA

19 |

NAME: Dave Hamelink PHONE: 716/546-2700, ext. 291-215

1977 JUN 2 PM 2 35

RECEIVED DOCUMENT
PROCESSING UNIT