

Vogle PEmails

From: Hoellman, Jordan
Sent: Tuesday, May 22, 2018 7:05 AM
To: Kent, Lauren
Cc: Gaslevic, James; Klee, Edmund
Subject: SNC Response to Comment on UIN for ITAAC Index No. 613
Attachments: UIN 613 comment response final for NRC.PDF

Attached is SNC's response to the comment on UIN for ITAAC Index No. 613. If we want to discuss the response at a future public meeting, please let me know.

Thank you,
Jordan

Jordan Hoellman

Project Manager

NRO / DNRL / LB4

U.S. Nuclear Regulatory Commission

office: OWFN 08-C18

phone: (301) 415-5481

email: Jordan.Hoellman2@nrc.gov

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 278

Mail Envelope Properties (SN6PR09MB26085D4920EDF96114AAF35FD5940)

Subject: SNC Response to Comment on UIN for ITAAC Index No. 613
Sent Date: 5/22/2018 7:04:47 AM
Received Date: 5/22/2018 7:04:52 AM
From: Hoellman, Jordan

Created By: Jordan.Hoellman2@nrc.gov

Recipients:

"Gaslevic, James" <James.Gaslevic@nrc.gov>
Tracking Status: None
"Kleeh, Edmund" <Edmund.Kleeh@nrc.gov>
Tracking Status: None
"Kent, Lauren" <Lauren.Kent@nrc.gov>
Tracking Status: None

Post Office: SN6PR09MB2608.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	430	5/22/2018 7:04:52 AM
UIN 613 comment response final for NRC.PDF		340422

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

VOGTLE ICN/UIIN ISSUES TRACKING SHEET

Date	ITEM #	ICN UIN	TOPIC	ITAAC INDEX #	ISSUE	Licensee Comment
5/11	2	UIN	Ancillary generators cabling inspections	613	The UIN states that in-progress cable installation was inspected, but does not state that the final installation of cables was inspected. It should state that, to ensure that the final route of cables was the same as their in-progress route.	<p>In the same paragraph, the phrase “A review of the as-built circuit inspection records is performed to confirm ...” indicates that the final installation of cables is inspected.</p> <p>This wording is consistent with previously submitted UINs for ITAAC 789, 790, & 791 UINs.</p>