

**NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL**  
(TEMPORARY FORM)

CONTROL NO: 13503

FILE: \_\_\_\_\_

FROM: LeBoeuf, Lamb, Leiby & MacRae Washington, D.C. LeBoeuf, Lamb, Leiby & MacRae		DATE OF DOC 10-30-75	DATE REC'D 12-3-75	LTR XXX	TWX	RPT	OTHER
TO: NRC		ORIG NONE	CC 0	OTHER	SENT NRC PDR <u>XXX</u> SENT LOCAL PDR <u>XXXX</u>		
CLASS XXX	UNCLASS	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-244		

**DESCRIPTION:**

Ltr. trans the following....

PLANT NAME: RE Ginna # 1

**ENCLOSURES:**

"Request for Exemption" with attachment "A" and "B", and Fig. 1.....Notarized 10-28-75 Certificate of Service entitled "Request for Exemption" 10-30-75, served upon Chairman, Atomic Safety & Lic. Board Panel, U.S. NRC, Washington, D.C.....  
Rec'd on 12-3-75-(1 cy. Encl. Rec'd-)  
Rec'd no Orig. copy--

**FOR ACTION/INFORMATION**

VCR 12-3-75

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies	REID (L) W/ COPIES
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies	
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPIES W/ Copies	
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	LPM W/ Copies	

**INTERNAL DISTRIBUTION**

<b>REG FILE</b> NRC PDR LOG, ROOM P-506A GOSSICK/STAFF CASE GIAMBUSSO BOYD MOORE (L) DEYOUNG (L) SKOVHOLT (L) GOLLER (L) (Ltr) P. COLLINS DENISE REG OPR FILE & REGION (2) MIPC	<b>TECH REVIEW</b> SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO J. COLLINS LAINAS BENAROYA VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER  <b>ENVIRO</b> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR HARRLESS	<b>LIC ASST</b> R. DIGGS (L) H. GEARIN (L) E. GOULBOURNE (L) P. KREUTZER (E) J. LEE (L) M. RUSHBROOK (L) S. REED (E) M. SERVICE (L) S. SHEPPARD (L) M. SLATER (E) H. SMITH (L) S. TEETS (L) G. WILLIAMS (E) V. WILSON (L) R. INGRAM (L) M. DUNCAN (E)	<b>A/T IND.</b> BRAITMAN SALTZMAN MELTZ  <b>PLANS</b> MCDONALD CHAPMAN DUBE (Ltr) E. COUPE PETERSON HARTFIELD (2) KLECKER EISENHUT WIGGINTON
--	--	--	---	--

**EXTERNAL DISTRIBUTION**

- |   |                                |                        |
|---|--------------------------------|------------------------|
| 1 - LOCAL PDR <i>Dejans, NY + Rochester NY.</i> | 1 - NATIONAL LABS              | 1 - PDR-SAN/LA/NY      |
| 1 - TIC (ABERNATHY) (1)(2)(10)                  | 1 - W. PENNINGTON, Rm E-201 GT | 1 - BROOKHAVEN NAT LAB |
| 1 - NSIC (BUCHANAN)                             | 1 - CONSULTANTS                | 1 - G. ULRIKSON ORNL   |
| 1 - ASLB  | NEWMARK/BLUME/AGBABIAN         |                        |
| 1 - Newton Anderson                             |                                |                        |
| 16 ACRS HOLDING/SENT                            |                                |                        |

*Handwritten signatures and initials*

.....

.....

.....

.....

.....

LAW OFFICES OF  
LEBOEUF, LAMB, LEIBY & MACRAE  
1757 N STREET, N W  
WASHINGTON, D. C. 20036

10/30/75  
10/30/75  
10/30/75


ARVIN E. UPTON  
LEONARD M. TROSTEN  
WILLIAM O. DOUB  
EUGENE B. THOMAS, JR.  
HARRY H. VOIGT  
L. MANNING MUNTZING  
LEX K. LARSON  
HENRY V. NICKEL  
WASHINGTON PARTNERS

October 30, 1975

140 BROADWAY  
NEW YORK, N.Y. 10005

WASHINGTON TELEPHONE  
202-872-8668

CABLE ADDRESS:  
LALALU, WASHINGTON D.C.  
TELEX: 440274



Secretary  
U.S. Nuclear Regulatory  
Commission  
Washington, D.C. 20555

Re: Rochester Gas and Electric Corporation  
R. E. Ginna Nuclear Power Plant, Unit No. 1  
Docket No. 50-244

Dear Sir:

Pursuant to Section 50.12 of the regulations of the Nuclear Regulatory Commission, we hereby transmit on behalf of Rochester Gas and Electric Corporation an original of a document entitled "Request for Exemption" together with Attachments A and B. By this request, RG&E seeks relief from certain provisions of Appendix J to 10 C.F.R. Part 50. Two additional copies of this document are also transmitted for your convenience.

A Certificate of Service showing service of these documents upon the persons listed therein is also enclosed.

Very truly yours,

*LeBoeuf, Lamb, Leiby & MacRae*  
LeBoeuf, Lamb, Leiby & MacRae  
Attorneys for Rochester Gas  
and Electric Corporation

Enclosures

13503



BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION



In the Matter of )  
 )  
ROCHESTER GAS AND ELECTRIC )  
CORPORATION (R. E. Ginna )  
Nuclear Power Plant, Unit )  
No. 1) )

Docket No. 50-244

CERTIFICATE OF SERVICE

I hereby certify that I have served a document entitled "Request for Exemption" by mailing copies thereof of first class, postage prepaid, to each of the following persons this 30th day of October, 1975.

Chairman, Atomic Safety  
and Licensing Board Panel  
U.S. Nuclear Regulatory  
Commission  
Washington, D.C. 20555

C. John Clemente, Esq.  
New York State Department  
of Commerce  
99 Washington Avenue  
Albany, New York 12210

Atomic Safety and Licensing  
Appeal Board  
U.S. Nuclear Regulatory  
Commission  
Washington, D.C. 20555


L. Dow Davis, IV, Esq.  
Office of the Executive  
Legal Director  
U.S. Nuclear Regulatory  
Commission  
Washington, D.C. 20555

Mr. Michael Slade  
1250 Crown Point Drive  
Webster, New York 14580

Edward Luton, Esq.  
Atomic Safety and Licensing  
Board Panel

Warren B. Rosenbaum, Esq.  
One Main Street East  
707 Wilder Building  
Rochester, New York 14614

U.S. Nuclear Regulatory  
Commission  
Washington, D.C. 20555



Thomas W. Reilly, Esq.  
Atomic Safety and Licensing  
Board Panel  
U.S. Nuclear Regulatory  
Commission  
Washington, D.C. 20555

Dr. Franklin C. Daiber  
Department of Biological  
Sciences  
University of Delaware  
Newark, Delaware 19711

Dr. Emmeth A. Luebke  
Atomic Safety and Licensing  
Board Panel  
U.S. Nuclear Regulatory  
Commission  
Washington, D.C. 20555


Dr. A. Dixon Callihan  
Union Carbide Corporation  
P. O. Box Y  
Oak Ridge, Tennessee 37830

Mr. Robert N. Pinkney  
Supervisor, Town of Ontario  
107 Ridge Road West  
Ontario, New York 14519


*Hope M. Babcock*

Hope M. Babcock

LeBoeuf, Lamb, Leiby & MacRae  
Attorneys for Rochester Gas  
and Electric Corporation







UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the matter of )  
ROCHESTER GAS AND ELECTRIC CORPORATION ) Docket No. 50-244  
(R. E. Ginna Nuclear Power Plant, )  
Unit No. 1) )

REQUEST FOR EXEMPTION

Pursuant to Section 50.12 of the regulations of the Nuclear Regulatory Commission, Rochester Gas and Electric Corporation ("RG&E"), holder of Provisional Operating License No. DPR-18, hereby requests that it be exempted from certain provisions of Appendix J to 10 CFR Part 50. The specific exemptions requested are set forth in Attachment A to this application. A safety evaluation which demonstrates that the proposed exemptions will not endanger life and property or the common defense and security and are otherwise in the public interest is set forth in Attachment B. The proposed exemptions would not authorize any change in the types or any increase in the amounts of normal plant effluents or any change in the authorized power level of the facility.

WHEREFORE, Applicant respectfully requests that it be  
exempted from Appendix J to 10 CFR Part 50 as set forth in  
Attachment A.

ROCHESTER GAS AND ELECTRIC CORPORATION

By

Leon D. White, Jr.


Leon D. White, Jr.  
Vice President, Electric and Steam Production

Subscribed and sworn to before  
me this *28th* day of *OCTOBER* 1975.

Gary L. Reiss  
Notary Public

GARY L. REISS


NOTARY PUBLIC, State of N. Y. Monroe Co.  
My Commission Expires March 30, 19*77*.



## ATTACHMENT A

In 1969 Rochester Gas and Electric Corporation performed type A preoperational containment leak rate testing at Ginna Station. The results of that testing at 60 psig and at a reduced pressure of 35 psig are shown on figure 1. Given that  $L_{tm}$  and  $L_{am}$  are the preoperational reduced pressure and full pressure test leakage rates respectively, and that  $L_a$  is the maximum allowable leakage rate, current 10 CFR 50 Appendix J regulations require that the acceptance criteria for subsequent reduced pressure testing be  $L_a \left( \frac{L_{tm}}{L_{am}} \right)$ ; provided that  $\frac{L_{tm}}{L_{am}} \leq 0.7$ . In the event that  $\frac{L_{tm}}{L_{am}} > 0.7$ , the subsequent acceptance criteria is to be  $L_a \left( \frac{P_t}{P_a} \right)^{1/2}$  or the maximum allowable leakage rate times the square root of the ratio of the test pressures.

As seen on figure 1, our 1969 reduced pressure test yielded a negative leakage value. The value is small and its error band includes positive values as expected under nearly all circumstances for a valid test. Literal interpretation of the regulations, however, would require all of our successive reduced pressure tests to show a negative leakage result. Since this is clearly impossible, a more realistic approach to determine an acceptance criterion is to reduce the maximum allowable leakage rate by a linear factor derived from the slope of the



line between the preoperational test data points with no regard to their absolute value (see figure 1). Positive values for successive tests would then be permissible. For RG&E's case, the resulting acceptance criteria would be approximately equal to that calculated using the ratio of the test pressures formula. Therefore, RG&E requests that an exemption from paragraph III. A. 4. (a) (1) (iii) of Appendix J to 10 CFR Part 50 be granted which will allow use of the ratio of the test pressures acceptance formula,  $L_a \left( \frac{P_t}{P_a} \right)^{1/2}$ , where  $L_a$  is 0.2 weight percent per day,  $P_a$  is 60 psig, and  $P_t$  is the gauge test pressure. This relationship will allow positive leakage rates for successive tests but still will maintain acceptable offsite accident doses as shown in prior safety analyses.

Several points in the regulations appear to be subject to interpretation. As a result, inconsistencies may exist in the regulations or between the regulations and Ginna Station's approved Technical Specifications. To resolve the following points, exemptions are requested from Appendix J to 10 CFR Part 50 if the Nuclear Regulatory Commission believes such exemptions are required:

(1) Paragraph II. K. of the regulations defines  $L_a$  as "... the maximum allowable leakage rate at pressure  $P_a$ , as specified for preoperational tests in the technical specifications or associated bases, and as specified for periodic tests in the operating license." (emphasis added)

The value approved for periodic testing and appearing in Ginna Station's Technical Specifications is 0.20 weight percent at 60 psig. However, the acceptance

value used in preoperational testing was 0.1 weight percent at 60 psig. This was established with our supplier to ensure that the 0.20 percent leakage rate requirement would be conservatively met. Because our FSAR safety analyses assumed a 0.25 percent leakage, and the staff SER used a leakage rate of 0.20 percent with acceptable offsite doses resulting from the calculations and because Ginna Station Technical Specifications have used at least 0.20 percent for post operational tests, we intend to continue to use the 0.20 percent maximum allowable leakage rate appearing in Ginna Station Technical Specifications.

(2) Paragraph II. N. defines leakage rates that are "... obtained from testing the containment with components and systems in the state as close as practical to that which would exist under design basis accident conditions." Paragraph III. A. 1. (d), on the other hand, states that "[a]ll vented systems shall be drained of water or other fluids to the extent necessary to assure exposure of the system containment isolation valves to containment air test pressure ..." This paragraph also states that "[s]ystems that are normally filled with water and operating under post-accident conditions, such as the containment heat removal system, need not be vented."

In view of the differences in interpretation which may be



.....

.....

.....

.....

.....

.....

.....




attached to these regulations, and with no technical specification covering these points, RG&E intends to pursue the following course of action.

(a) Venting Outside Containment

Lines which penetrate the containment and which are open to the containment atmosphere as in (b), will be vented to the atmosphere outside of the containment. Where piping configurations outside containment exist such that the fluid in fluid carrying lines does not drain to expose the isolation valves to the atmosphere by opening existing vents and drains, the fluid will be left in the lines.

(b) Venting Inside Containment

Portions of the fluid systems that are part of the reactor coolant pressure boundary and are open directly to the containment atmosphere under post-accident conditions and become an extension of the boundary of the containment will be opened or vented to the containment atmosphere prior to and during the test. Portions of closed systems inside containment that penetrate containment and that also pass inside the primary shield wall near the broken leg, and which are postulated to rupture as a result of a loss of coolant accident will be vented to containment atmosphere. Lines which have never been postulated to rupture, consistent with the containment integrity analysis of section 14.3.4 of the FSAR, will not be vented. Where check valves or



piping configurations exist between the primary shield wall and the containment penetration or in places where damage to the piping system is not postulated to occur as a result of a LOCA such that fluid seals are formed as a result of normal operation and containment isolation, the fluid will be left undisturbed.

That is, those portions of systems not postulated to rupture as the result of a LOCA will not be drained unless they drain unaided to the postulated breaks in the systems.

(c) Isolation Valves

Where two isolation valves exist in a single line which are either check valves, or valves capable of automatic closure, or a combination thereof, no attempt will be made to vent to atmosphere from a point between the valves.

(3) Paragraph III. D. 2. of Appendix J to 10 CFR Part 50 states that "[a]ir locks shall be tested at 6 month intervals. However, air locks which are opened during such intervals, shall be tested after each opening."

Ginna Station Technical Specifications, on the other hand, require that "... the personnel air lock seals shall be tested at 4 month intervals, except when the air locks are




.....



not opened during the interval. In that case, the test is to be performed after each opening, except that no test interval is to exceed 12 months."

Because the regulations do not say specifically how the testing is to be performed, because extensive testing after each opening of the air lock when multiple openings may take place in short time spans is impractical, and because of the proven reliability of these air locks, RG&E intends to meet the intent of paragraph III. D. 2 of Appendix J to 10 CFR Part 50 by testing as follows...


The containment air locks are to be tested at intervals of no more than 6 months by pressurizing the space between the air lock doors. (An application for an appropriate amendment to Ginna Station Technical Specifications will be submitted at a later date.) In addition, following opening of the air lock door during the interval, a test will be performed by pressurizing between the dual seals of each door opened, within 48 hours of the opening, unless the reactor was in the cold shutdown condition at the time of the opening or has been subsequently brought to the cold shutdown condition. Thus, in the event that several openings occur within a short period of time, one test within 48 hours of the first opening will satisfy the requirements for leak testing.




(4) Paragraph III.B.1, gives those test methods which are acceptable means of performing periodic Type B tests. One of the methods is to measure "the rate of pressure loss of the test chamber of the containment penetration..." The method of testing preferred by RG&E is a measurement by means of a rotometer of the air flow to the test chamber which is required to maintain the chamber at the test pressure. We believe that this method produces accurate results and meets the intent of the regulations.

FIGURE 1

ENG. DEPT.	STATION: Ginna	DATE: 7/7/75	PAGE 1 OF 1
JOB: Containment Leak Rate Test		MADE BY: P. Wilkens	CK:







ATTACHMENT B

Safety Evaluation

The requested exemption will present no significant hazard to the health and safety of the public for the following reasons:

The proposed change in reduced pressure test acceptance criterion does not alter the maximum acceptable leakage rate. The leakage rates used in the Staff's Safety Evaluation Report and the FSAR were 0.20 and 0.25 percent per day respectively. Offsite dose calculations using these leakage rates demonstrated acceptable public exposures well below 10 CFR Part 100 values.

An appropriate factor is to be applied to reduce the acceptance criterion for reduced pressure testing. Although it is difficult to establish the relationship between leakage rates at different test pressures for a specific containment, mass flow through orifices will generally behave as a function of the square root of the differential pressure. Thus, in the absence of extensive test data, the square root relationship is believed to be valid and will reduce the maximum allowable leakage rate assumed in the Staff's Safety Evaluation Report by an appropriate amount for reduced pressure testing.

Therefore, the overall effect of the requested exemption is to provide an acceptance criterion which has already been found acceptable in accident analyses. The limit on containment leakage is such that there is no undue risk to the health and safety of the public.



2  
A

The proposed method of testing personnel air lock doors within the six month intervals after an opening of a door will adequately insure the integrity of the doors by detecting damage to the seals which may have resulted during the opening of the air lock. Testing the air locks by pressurizing between the seals will require approximately 15 minutes whereas testing by pressurizing the entire access hatch will require approximately 24 hours. By not inhibiting entry and inspections inside the containment, if they are required, the alternate procedure tends to augment the safe operation of the plant.

The regulations specify that lines which rupture as the result of a loss of coolant accident should be vented to the containment atmosphere prior to testing. The lines which will be vented are selected based upon assumptions made in the containment integrity analysis.

The proposed method of venting and draining systems penetrating the containment is consistent, we believe, with the intent of the regulations.

Thus, the test methods and procedures to be applied to meet the requirements of Appendix J to 10 CFR Part 50 will result in a valid test to determine the integrity of the reactor containment. The acceptance standards for this test have been shown to result in offsite doses, under postulated accident conditions, well within the requirements of 10 CFR Part 100.

