

C 05/09/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-244

REC: CASE E G
NRC

ORG: LARSON L K
~~LAWRENCE LIVERMORE LAB~~
LEBOUEF, LAMB, LEIBY, MACRAE

DOCDATE: 05/08/78
DATE RCVD: 05/09/78

DOCTYPE: LETTER NOTARIZED: YES
SUBJECT:

COPIES RECEIVED
LTR 3 ENCL 40

FORWARDING LIC NO DPR-18 APPL FOR AMEND: APPENDIX A TECH SPEC PROPOSED CHANGE
CONCERNING MODIFICATION TO REQUIREMENTS FOR TESTING THE NUC PWR RANGE
DETECTOR LOW PWR SETPOINT...NOTARIZED 05/05/78...W/ATT CERT, SAFETY
EVALUATION AND LIC FEES.

PLANT NAME: RE GINNA - UNIT 1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *W*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.
(DISTRIBUTION CODE A001)

FOR ACTION: BR CHIEF ~~ZIEMANN~~**W/7 ENCL

INTERNAL:	REG FILE**W/ENCL	NRC PDR**W/ENCL
	<u>I & E**W/2 ENCL</u>	OELD**LTR ONLY
	HANAUER**W/ENCL	CHECK**W/ENCL
	EISENHUT**W/ENCL	SHAO**W/ENCL
	BAER**W/ENCL	BUTLER**W/ENCL
	EEB**W/ENCL	J COLLINS**W/ENCL
	J. MCGOUGH**W/ENCL	

EXTERNAL: LPDR'S
ROCHESTER, NY**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

```


$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$
$ CHECK NBR: 46,195 $
$ AMOUNT: $1,200.00 $
$ CHECK AND COPY OF TRANSMITTAL LTR ADVANCED $
$ TO W. MILLER (LFMB) (05/09/78) UPON RECIEPT $
$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$$

```

DISTRIBUTION: LTR 40 ENCL 39
SIZE: 1P+2P+6P

CONTROL NBR: 781290031

***** THE END *****



LEBOEUF, LAMB, LEIBY, & MACRAE

1757 N STREET, N.W.

WASHINGTON, D. C. 20036

TELEPHONE 202-457-7500

CABLE ADDRESS

LEBWIN, WASHINGTON, D. C.

TELEX: 440274

TELECOPIER:

202-457-7543

RANDALL J. LeBOEUF, JR. 1929-1975

HORACE R. LAMB 1934-1977

ADRIAN C. LEIBY 1952-1976

LEON A. ALLEN, JR.
JOSEPH E. BACHELDER, III
ERNEST S. BALLARD, JR.
G. S. PETER BERGEN
GEOFFRY D. C. BEST
DAVID P. BICKS
TAYLOR R. BRIGGS
CHARLES N. BURGER
THOMAS E. BURKE
ROGER D. FELDMAN
EUGENE R. FIDELL
JACOB FRIEDLANDER
GERARD GIORDANO
DONALD J. GREENE
JAMES A. GREER, II
JOHN L. GROSE
DOUGLAS W. HAWES
CARL D. HOBELMAN
MICHAEL IOVENKO
JAMES F. JOHNSON, 4TH
RONALD D. JONES
LEX K. LARSON
GRANT S. LEWIS
KIMBA W. LOVEJOY

CAMERON F. MACRAE
CAMERON F. MACRAE, III
GERARD A. MAHER
SHEILA H. MARSHALL
JAMES G. McELROY
JAMES P. McGRANERY, JR.
PHILIP PALMER MCGUIGAN
HARVEY A. NAPIER
JAMES O'MALLEY, JR.
J. MICHAEL PARISH
WILLIAM W. ROSENBLATT
JOHN A. RUDY
PAUL G. RUSSELL
PATRICK J. SCOGNAMIGLIO
HAROLD M. SEIDEL
HALCYON G. SKINNER
JOSEPH S. STRAUSS
SAMUEL M. SUGDEN
EUGENE B. THOMAS, JR.
LEONARD M. TROSTEN
HARRY H. VOIGT
H. RICHARD WACHTEL
GERARD P. WATSON
THOMAS A. ZIERK

140 BROADWAY
NEW YORK, N.Y. 10005
TELEPHONE 212-269-1100

CABLE ADDRESS

LEBWIN, NEW YORK

TELEX: 423416

RECEIVED DISTRIBUTION SERVICES UNIT

May 8, 1978

* RESIDENT PARTNERS WASHINGTON OFFICE
* ADMITTED TO THE DISTRICT OF COLUMBIA BAR.

Mr. Edson G. Case
Acting Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Rochester Gas and Electric Corporation
R. E. Ginna Nuclear Power Plant, Unit No. 1
Docket No. 50-244

Dear Mr. Case:

As counsel for Rochester Gas and Electric Corporation, I enclose the following:

- (1) Three (3) originals and nineteen (19) copies of an Application for Amendment to Operating License; and
- (2) Forty (40) copies each of three (3) documents designated Attachments A, B, and C which set forth the requested change in the Technical Specifications, its technical basis, and technical information asserting this change is of no safety or environmental significance.

The proposed amendment to the Provisional Operating License has been evaluated and determined to fall within the definition of Class II of 10 C.F.R. Section 170.22; therefore, a check for the required fee in the amount of \$1,200.00 is also enclosed.

Very truly yours,


LeBOEUF, LAMB, LEIBY & MacRAE

781290031

By 
Lex K. Larson

Enclosures

A001
5/3/78
Report
LWR



BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
ROCHESTER GAS AND ELECTRIC)
CORPORATION) Docket No. 50-244
(R.E. Ginna Nuclear Power)
Station, Unit No. 1))

CERTIFICATE OF SERVICE

I hereby certify that I have served a document entitled "Application for Amendment to Operating License," along with Attachments, by mailing copies thereof first class, postage prepaid to each of the following persons this 8th day of May, 1978:

Mr. Michael L. Slade
1250 Crown Point Drive
Webster, New York 14580

Warren B. Rosenbaum, Esq.
One Main Street
707 Wilder Building
Rochester, New York 14614

Edward G. Ketchen, Esq.
Office of the Executive
Legal Director
U.S. Nuclear Regulatory
Commission
Washington, D. C. 20555

Mr. Robert N. Pinkney
Supervisor
Town of Ontario
107 Ridge Road West
Ontario, New York 14519



1. The first part of the document discusses the importance of maintaining accurate records of all transactions.

2. It is essential to ensure that all data is entered correctly and that the system is regularly updated.

3. The final section of the document provides a summary of the key findings and recommendations.

Jeffrey L. Cohen, Esq.
New York State Energy Office
Swan Street Building
Core 1, Second Floor
Empire State Plaza
Albany, New York 12223

Edward Luton, Esq.
Atomic Safety and Licensing
Board
U.S. Nuclear Regulatory
Commission
Washington, D. C. 20555

Dr. Dixon Callihan
Union Carbide Corporation
P. O. Box Y
Oak Ridge, Tennessee 37830



Lex K. Larson

LeBoeuf, Lamb, Leiby & MacRae
Attorneys for Rochester Gas
and Electric Corporation

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
Rochester Gas and Electric Corporation) Docket No. 50-244
(R.E. Ginna Nuclear Power Plant,)
Unit No. 1)

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission (the "Commission"), Rochester Gas and Electric Corporation ("RG&E"), holder of Provisional Operating License No. DPR-18, hereby requests that the Technical Specification 4.1 set forth in Appendix A to that license be amended to modify the requirements for testing the nuclear power range detector low power setpoint.

The proposed technical specification change is set forth in Attachment A to this Application. A safety evaluation is set forth in Attachment B. This evaluation also demonstrates that the proposed change does not involve a significant change in the types or a significant increase in the amounts of effluents or any change in the authorized power level of the facility. Justification for classification of the amendment pursuant to 10 C.F.R. Section 170.22 is included as Attachment C. A check for the appropriate fee accompanies this Application.



•
•
•
•

1

.

.

.

.

.

.

•
•
•
•

.

•

•

.

•

.

.

.

.

.

.

.

WHEREFORE, Applicant respectfully requests that Appendix A to Provisional Operating License No. DPR-18 be amended in the form attached hereto as Attachment A.

Rochester Gas and Electric Corporation

By L.D. White, Jr.
L.D. White, Jr.
Vice President,
Electric and Steam Production

Subscribed and sworn to before me

on this 5th day of May 1978

Stephen Kowba

STEPHEN KOWBA
NOTARY PUBLIC, State of N.Y., Monroe County
My Commission Expires March 30, 1980



11
12
13
14
15

16
17
18
19
20

21
22
23
24
25

26
27
28
29
30

31
32
33
34
35

36
37
38
39
40

41
42
43
44
45

46
47
48
49
50

51
52
53
54
55

56
57
58
59
60

61
62
63
64
65

66
67
68
69
70

71
72
73
74
75

76
77
78
79
80

81
82
83
84
85

86
87
88
89
90

91
92
93
94
95

96
97
98
99
100

Attachment A

Replace Technical Specification page 4.1-5
with revised page 4.1-5.

TABLE 4.1-1

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND
TEST OF INSTRUMENT CHANNELS

<u>Channel Description</u>	<u>Check</u>	<u>Calibrate</u>	<u>Test</u>	<u>Remarks</u>
1. Nuclear Power Range	S M* (3)	D (1) Q* (3)	B/W (2) (4) P (2) (5)	1) Heat balance calculation** 2) Signal to ΔT ; bistable action (permissive, rod stop, trips) 3) Upper & lower chambers for axial offset** 4) High setpoint ($\leq 109\%$ of rated power) 5) Low setpoint ($\leq 25\%$ of rated power)
2. Nuclear Intermediate Range	S (1)	N.A.	P (2)	1) Once/shift when in service 2) Log level; bistable action (permissive, rod stop, trip)
3. Nuclear Source Range	S (1)	N.A.	P (2)	1) Once/shift when in service 2) Bistable action (alarm, trip)
4. Reactor Coolant Temperature	S	R	M (1)	1) Overtemperature-Delta T 2) Overpower - Delta T
5. Reactor Coolant Flow	S	R	M	
6. Pressurizer Water Level	S	R	M	
7. Pressurizer Pressure	S	R	M	
8. 4 Kv Voltage & Frequency	N.A.	R.	M	Reactor Protection circuits only
9. Analog Rod Position	S (1,2)	R	M	1) With step counters. 2) Each six inches of rod motion when data logger is out of service

* by means of the movable in-core detector system.

** Not required during hot, cold, or refueling shutdown but as soon as possible after return to power

Attachment B

Technical Specifications Table 4.1-1 presently requires that the power range detectors be tested bi-weekly. These flux detectors have both high and low power setpoints (109% and 25% of rated power, respectively). The low power setpoint is used as a backup (to the intermediate range detectors) reactor protection means during startup. While at power, the Ginna safety analysis takes credit only for the high setpoint trip. Thus, while the reactor is at power, the low power setpoint is not required to perform a safety function.

The proposal to test the low power setpoint prior to startup, rather than bi-weekly, is consistent with the test schedule for the intermediate range detectors, which perform the same function. This testing will provide sufficient assurance of the accuracy of the setpoint at the time it might be needed to perform its safety function.

Attachment C

The proposed Amendment to the Provisional Operating License has been evaluated and determined to fall within the definition of Class II of 10 C.F.R. Section 170.22 thereby requiring a fee of \$1,200. The proposed amendment is a clarification of the Technical Specification requirement for testing of the power range detectors. The present Technical Specification could be interpreted to mean that the low power setpoint, which provides a trip at 25% power, must be tested during normal power operation. However, since this trip must be defeated during normal power operation in order to permit operation above 25% power, it is clear that such testing is superfluous. In addition, as described in Attachment B, since the low power trip will continue to be tested prior to startup so that it would perform its intended safety function if required, it is clear that this change has no safety or environmental significance.

