

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL.
(TEMPORARY FORM)

CONTROL NO: 1064

FILE: _____

FROM: Rochester Gas & Elec. Corp. Rochester, N.Y. K.W. Amish		DATE OF DOC 1-30-76	DATE REC'D 2-4-76	LTR XXX	TWX	RPT	OTHER
TO: R.A. Purple		ORIG 1 Signed	CC 0	OTHER	SENT NRC PDR SENT LOCAL PDR		XXX XXX
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50- 244		

DESCRIPTION:
Ltr. re their ltr. of 10-31-75.
Information providing additional info regarding final determination of the changes to be made related to water hammer.... W/attached Schedule for Installation in 1976....

ENCLOSURES:
ACKNOWLEDGED
DO NOT REMOVE

(1 Copy Received)

PLANT NAME: RE Ginna # 1

SAFETY	FOR ACTION/INFORMATION	ENVIRO	SAB 206-76
ASSIGNED AD.	ASSIGNED BRANCH CHIEF		
BRANCH CHIEF <u>Purple w/6</u>	PROJECT MANAGER <u>BEVAN</u>		
PROJECT MANAGER _____	LIC ASST. _____ W/ ACRS		
LIC. ASST. <u>SHEPPARD</u> W/6 CYS ACRS			

INTERNAL DISTRIBUTION

- | | | | |
|---------------------------|-----------------------|---------------------------|--|
| <u>REG FILES</u> | <u>SYSTEMS SAFETY</u> | <u>PLANT SYSTEMS</u> | <u>SITE SAFETY & ENVIRO ANALYSIS</u> |
| <u>NRC PDR</u> | HEINEMAN | <u>EDESCO</u> | DENTON |
| <u>FIELD</u> | SCHROEDER | <u>DEBAROYA</u> | MULLER |
| GOSSICK/STAFF | | LAINAS | <u>ENVIRO TECH.</u> |
| <u>I&E (2)</u> | <u>ENGINEERING</u> | IPPOLITO | ERNST |
| MFC | <u>HACCARY</u> | | BALLARD |
| | <u>KNIGHT</u> | <u>OPERATING REACTORS</u> | SPANGLER |
| <u>PROJECT MANAGEMENT</u> | SIHWEIL | STELLO | |
| BOYD | PAWLICKI | | <u>SITE TECH.</u> |
| P. COLLINS | | <u>OPERATING TECH.</u> | GAMMILL |
| HOUSTON | <u>REACTOR SAFETY</u> | <u>EISENHUT</u> | STEPR |
| PETERSON | ROSS | <u>SHAO</u> | HULMAN |
| MELTZ | NOVAK | <u>DAER</u> | |
| HELTEMES | ROSETOCZY | <u>SCHWENCER</u> | <u>MISCELLANEOUS</u> |
| | CHECK | <u>CRIMES</u> | <u>Ed. Reeves - 2</u> |
| | | | <u>Keller</u> |

EXTERNAL DISTRIBUTION

- | | | |
|---|-----------------------------|---------------------|
| <u>LOCAL PDR</u> <u>Lyons & Rochester, N.Y.</u> | NATIONAL LAB _____ W/ CYS | BROOKHAVEN NAT. LAB |
| <u>TIC</u> | REGION V-1&E-(WALNUT CREEK) | ULRIESON (ORNL) |
| <u>NSIC</u> | LA PDR | |
| ASLB | CONSULTANTS | |

[Handwritten signature]



The following information was obtained from the files of the
 Internal Security - Communist Division, New York Office, dated
 10/15/54.

[Illegible text block]

[Illegible text block]

[Illegible text block]




ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE

KEITH W. AMISH
EXECUTIVE VICE PRESIDENT

Regulatory


File Cya



January 30, 1976

Director of Nuclear Reactor Regulation
Attention: Robert A. Purple, Chief
Branch No. 1
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, DC 20555

50-244



Dear Mr. Purple:

In our letter of October 31, 1975, we provided information concerning secondary system fluid flow instabilities ("water hammer"). That information was requested in your letter of May 13, 1975. At the time we submitted our letter, final determination of the specific changes to be made at Ginna Station relative to "water hammer" had not been made. The purpose of this letter is to provide information concerning these changes.

Various administrative controls, steam generator mechanical modifications, and piping support modifications were evaluated to determine their effectiveness in either preventing the occurrence of "water hammer," or reducing its consequences should it occur. In evaluating these changes, we considered the effect of other changes to the plant which have been or are being made; and the overall reliability and integrity of the steam generators.

It is our determination that the best alternative currently available for precluding "water hammer" is administrative control of auxiliary feedwater flow. As discussed in our previous letter, "water hammer" has been found to occur during recovery of the steam generator feed rings while feedwater flows are above a threshold value of approximately 200 gpm per generator. The applicable operating procedures at Ginna Station have been revised to administratively limit auxiliary feedwater flow during recovery of the steam generator feed rings from normal and abnormal transients. In these situations, the auxiliary feedwater flow rate to either steam generator will be limited to a maximum of 150 gpm by manual operator action from the main control board. This limitation will apply whenever steam generator level is below the low-low level set point, 15% of narrow range, and until the level is recovered to 25%. The limitation will not be applied in the event of safety injection system actuation involving steam generator levels far below the feed ring.



1948

M

1. The first part of the document discusses the general situation of the country and the progress of the work. It mentions the importance of the work and the need for a thorough investigation. The document also mentions the need for a thorough investigation of the situation and the need for a thorough investigation of the situation.

2. The second part of the document discusses the specific details of the work. It mentions the need for a thorough investigation of the situation and the need for a thorough investigation of the situation. The document also mentions the need for a thorough investigation of the situation and the need for a thorough investigation of the situation.

3. The third part of the document discusses the results of the work. It mentions the need for a thorough investigation of the situation and the need for a thorough investigation of the situation. The document also mentions the need for a thorough investigation of the situation and the need for a thorough investigation of the situation.

4. The fourth part of the document discusses the conclusions of the work. It mentions the need for a thorough investigation of the situation and the need for a thorough investigation of the situation. The document also mentions the need for a thorough investigation of the situation and the need for a thorough investigation of the situation.

DATE January 30, 1976

TO Mr. Robert A. Purple


2

Also, the flow control instrumentation on the motor driven auxiliary feedwater pumps will continue to be set at a minimum of 200 gpm during normal plant operation. It is judged that these limitations will adequately preclude "water hammer" since the low-low level set point is approximately 2 inches below the bottom of the feed ring and the 25% level is approximately 1 inch above the top of the ring.

A schematic of the present auxiliary feedwater system at Ginna Station is shown in Attachment A. The system consists of three pumps, two motor driven and one turbine driven; and two separate, interconnected piping systems from the pumps to the main feedwater lines. The drawing shows the valves in the positions for normal plant operation.


Control of auxiliary feedwater flow rate is achieved either through motor operated valves 4007 and 4008 or pneumatically operated valves CV-54 and CV-55. All of these valves are normally in the full open position. Upon receipt of a signal for pump start, valves 4007 and 4008 are automatically throttled by the flow control system shown to a flow of 200 gpm or more. The flow control system can be manually over-ridden to achieve lower flow rates through valves 4007 and 4008 by a switch on the main control board. The flow rate through valves CV-54 and CV-55 can be varied manually from a control station on the main control board. The flow from the motor driven auxiliary feedwater pumps can be directed through valves CV-54 and CV-55 by opening valves 4000A or 4000B, and 4359 and 4360; and closing valves 4007 and 4008. The flow rate through all 4 auxiliary feedwater lines can be monitored by flow indicators on the main control board.


Very truly yours,



Keith W. Amish
Executive Vice President

KWA:af
Attachment






LOLO S.G. LEVEL
UNDER VOLTAGE
STEAM TO AUX F.W.
PUMP TURB.

* SCHEDULED FOR
INSTALLATION IN 1976

ATTACHMENT A

 ROCHESTER GAS AND ELECTRIC ROCHESTER, N.Y.	
GINNA STA. AUX. F.W. SYS. P & ID	

