

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

September 9, 1985

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 85-229A
NO/ETS:acm
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNIT NOS. 1 AND 2
PROPOSED TECHNICAL SPECIFICATION CHANGES

VEPCO letter, Serial 85-229, dated April 12, 1985, submitted a request for amendment, in the form of changes to the Technical Specifications to Operating License Nos. DPR-32 and DPR-37 for the Surry Power Station Units No. 1 and 2.

The proposed Technical Specification changes are to revise the Limiting Condition for Operation (LCO) and surveillance requirements for the reactor trip bypass breakers, undervoltage trip logic and shunt trip logic. These proposed changes are in accordance with Items 10 and 13 of the NRC review of Item 4.3 of Generic Letter 83-28, dated November 15, 1984.

This submittal modifies the change request to include the subsequent NRC staff guidance provided in Generic Letter 85-09, "Technical Specifications for Generic Letter 83-28, Item 4.3," for the Limiting Condition of Operation and surveillance requirements for the reactor trip and bypass breakers, the undervoltage and shut trip logic and the manual scram switches.

The supplemental proposed changes to the Technical Specifications for Unit 1 and 2 are included as Enclosure 1. The safety evaluation is included in Enclosure 2. The proposed changes and the safety evaluation have been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that this submittal request does not pose a significant hazard consideration as defined in 10 CFR 50.92 or an unreviewed safety question as defined in 10 CFR 50.59.

8509160360 850909
PDR ADDCK 05000280
P PDR

A055
11

Since this information supplements our previous submittal, which included the appropriate application fee, no additional application fee is included herein.

If you have any questions, or need additional information to process this request, please contact us immediately.

Very truly yours,



W. L. Stewart

Enclosures

- (1) Proposed Technical Specification Change - Unit 1 and Unit 2
- (2) Safety Evaluation for Proposed Changes

cc: Dr. J. Nelson Grace
Regional Administrator
Region II

Mr. D. J. Burke
NRC Resident Inspector
Surry Power Station


Mr. Charles Price
Department of Health
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart who is Vice President - Nuclear Operations, of Virginia Power. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 9 day of September, 19 85.

My Commission expires: February 10, 19 89.



Notary Public

(SEAL)

S/001