

October 11, 1985

Docket No. 50-281

Distribution w/o encl.

Docket file

MEMORANDUM FOR: Roger D. Walker, Director  
Division of Reactor Projects  
Region II

ORB#1 RDG  
NRC PDR LPDR  
Memo file  
HTompson  
CParrish  
T. Chan w/encl.

FROM: Hugh L. Thompson, Jr., Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

SUBJECT: LICENSING ACTION REVIEWS FOR SURRY POWER STATION,  
UNIT 2 - ASME XI INSPECTION RELIEF REQUEST (TAC 59754)

Your assistance is requested in conducting a review of the enclosed submittal from the Virginia Electric and Power Company (VEPCO), dated September 19, 1985, for Surry Power Station Unit 2. The product expected from you as a result of your review is a complete safety evaluation report. Your reviewers should use the Standard Review Plan (SRP) and Standard Technical Specifications (STS) as guidance in determining acceptance criteria, recognizing, of course, that for operating reactors, the criteria in these documents are not requirements.

In accordance with NRR Office Letter No. 44, each safety evaluation performed by a technical division shall have a separate SALP input. For purposes of these reviews, the Regional personnel involved are considered part of the technical divisions. Therefore, we are requesting that your forwarding memorandum contain a SALP input for the safety evaluation.

Work for the VEPCO submittal concerning the proposed changes has been discussed with D. Gruber of your staff. The TAC number for this review is 59754. The requested completion date is November 30, 1985. Contact with the licensee on this review effort or any significant additional information deemed necessary should be obtained through the NRR Project Manager or with his concurrence. The Project Manager for this plant is Terence Chan and he can be reached at 492-8460.

**Frank Miraglia/for**

Hugh L. Thompson, Jr., Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

CONTACT:  
T. Chan  
(301) 492-8460

8510190183 851011  
PDR ADOCK 05000281  
PDR

\*ORB#1:DL  
CParrish  
10/9/85

ORB#1:DL  
TChan;ps  
10/9/85

BC-ORB#1:DL  
SVarda  
10/9/85

AD-OR:DL  
GLainas  
10/11/85

HTompson  
10/11/85

\* See next page for concurrence

Docket No. 50-281

Distribution w/o encl.  
Docket file  
ORB#1 RDG  
NRC PDR LPDR  
Memo file  
HThompson  
CParrish  
T. Chan w/encl.

MEMORANDUM FOR: Roger D. Walker, Director  
Division of Reactor Projects  
Region II

FROM: Hugh L. Thompson, Jr., Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

SUBJECT: LICENSING ACTION REVIEWS FOR SURRY POWER STATION,  
UNIT 2 - ASME XI INSPECTION RELIEF REQUEST (TAC 59754)

Your assistance is requested in conducting a review of the enclosed submittal from the Virginia Electric and Power Company (VEPCO), dated September 19, 1985, for Surry Power Station Unit 2. The product expected from you as a result of your review is a complete safety evaluation report. Your reviewers should use the Standard Review Plan (SRP) and Standard Technical Specifications (STS) as guidance in determining acceptance criteria, recognizing, of course, that for operating reactors, the criteria in these documents are not requirements.

In accordance with NRR Office Letter No. 44, each safety evaluation performed by a technical division shall have a separate SALP input. For purposes of these reviews, the Regional personnel involved are considered part of the technical divisions. Therefore, we are requesting that your forwarding memorandum contain a SALP input for the safety evaluation.

Work for the VEPCo submittal concerning the proposed changes has been discussed with D. Gruber of your staff. The TAC number for this review is 59754. The requested completion date is November 30, 1985. Contact with the licensee on this review effort or any significant additional information deemed necessary should be obtained through the NRR Project Manager or with his concurrence. The Project Manager for this plant is Terence Chan and he can be reached at 492-8460.

Hugh L. Thompson, Jr., Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosure:  
As stated

CONTACT:  
T. Chan  
(301) 492-8460

ORB#1:DL  
CParrish  
10/a/85

ORB#1:DL  
TChan;ps  
10/9/85

BC-ORB#1:DL  
SVarga  
10/ /85

AD:OR:DL  
GLainas  
10/ /85

D:DL  
HThompson  
10/ /85

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8509240101      DUC. DATE: 85/09/19      NOTARIZED: NO      DOCKET #  
 FACIL: 50-281      Surry Power Station, Unit 2, Virginia Electric & Power      05000281  
 AUTH. NAME:      AUTHOR AFFILIATION  
 STEWART, W. L.      Virginia Power (Virginia Electric & Power Co.)  
 RECIP. NAME:      RECIPIENT AFFILIATION  
 DENTON, H. R.      Office of Nuclear Reactor Regulation, Director  
 VARGA, S. A.      Operating Reactors Branch 1

SUBJECT: Requests relief from certain ASME Boiler & Pressure Vessel Code, Section XI requirements, per 10CFR50.55(a), Bases for request discussed.

DISTRIBUTION CODE: A047D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 11  
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES: 1cy NMSS/FCAF/PM.  
 OL: 01/29/73

05000281

	RECIPIENT			RECIPIENT		
	ID CODE/NAME	COPIES		ID CODE/NAME	COPIES	
	NRN	ORB1	BC	01	LTR	ENCL
INTERNAL:	ACRS	16	10	10	ADM/LFMB	1 0
	ELD/HDS4		1	0	NRR/DE/MEB	15 1 1
	NRK/DE/MTEB	14	1	1	NRR/DL/TAPMG	1 1
	REG FILE	04	1	1	RGN2	1 1
EXTERNAL:	24X		1	1	LPDR	03 1 1
	NRC PDR	02	1	1	NSIC	05 1 1
NOTES:			1	1		

TOTAL NUMBER OF COPIES REQUIRED: LTR 29 ENCL 27

**VIRGINIA ELECTRIC AND POWER COMPANY**  
**RICHMOND, VIRGINIA 23261**

September 19, 1985

**W. L. STEWART**  
**VICE PRESIDENT**  
**NUCLEAR OPERATIONS**

Mr. Harold R. Denton, Director  
 Office of Nuclear Reactor Regulation  
 Attn: Mr. Steven A. Varga, Chief  
 Operating Reactors Branch No. 1  
 Division of Licensing  
 U.S. Nuclear Regulatory Commission  
 Washington, D. C. 20555

Serial No. 85-681  
 NO/WRB:cfm  
 Docket Nos. 50-281  
 Licensee Nos. DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY POWER STATION UNIT 2  
ASME XI - INSPECTION RELIEF REQUEST

Inservice inspection activities for Surry Unit 2 were conducted during the spring refueling outage as required by Section XI of the ASME Boiler and Pressure Vessel Codes. Pursuant to 10 CFR 50.55a paragraph g(5) relief is requested from certain code requirements. The following bases are provided.

1. The regenerative heat exchanger (2-CH-E-3) is classified ASME Class 1 in the first interval inspection plan (ASME XI 74 edition, Summer 75 addenda). The following items were scheduled per table IWB-2600 to be completed during the refueling outage on the regenerative heat exchanger (Regen Hx):

Table IWB-2600 Item No.	Table IWB-2500 Examination Category	Parts to be examined (attachment 1)	Method
B3.1	B-B	Head to shell weld(17)	Volumetric
B3.1	B-B	Shell to tube sheet weld(18)	Volumetric
B3.2	B-D	Nozzle to vessel welds(5,6,7,8,9,10,11,12,14, and 16)	*substituted surface

\* On February 28, 1984, Vepco was granted relief (letter Mr. Varga to Mr. Stewart) to substitute a surface exam for the required volumetric method due to the impractical joint configuration that exists.

~~8509240101~~ 850919  
 PDR ADDCK 05000281  
 G PDR

A047  
 11

VIRGINIA ELECTRIC AND POWER COMPANY TO Mr. Harold R. Denton

The seal water return filter (2-CH-FL-3) is classified ASME Class 2 in the first interval inspection plan (ASME XI 74 edition, Summer 75 addenda). The following items were scheduled per table IWC-2600 to be completed during the refueling outage on the seal water return filter:

Table IWC-2600 Item No.	Table IWC-2500 Examination Category	Parts to be examined (attachment 2)	Method
C1.1	C-A	1" head to shell weld(1)	*substituted surface and visual
C1.1	C-A	1" shell to flange weld(2)	*substituted surface and visual
C1.1	C-A	1" top head weld(3)	*substituted surface and visual
C1.3	C-C	Welded support (IWS)	surface

\* On February 28, 1984, Vepco was granted relief (letter Mr. Varga to Mr. Stewart) to substitute surface and visual exams for the required volumetric due to the thin structure of the associated materials, reducing the effectiveness of a volumetric exam.

Preinspection meetings with the Health Physics Department determined that unreasonable doses would result from completion of these examinations. The close quarters surrounding these components limit shielding and allow effective use of only one individual to remove insulation (Regen Hx only), perform necessary surface preparation, perform the inspection, and reinsulate (Regen Hx only). In addition surface preparation time can be extended significantly as a result of the limited preservice examination requirements associated with the earlier codes. In many cases this has left these type of welds in poor surface condition for examination.

The seal water return filter (2-CH-FL-3) is classified ASME Class 2 in the first interval inspection plan (ASME XI 74 edition, Summer 75 addenda). The following items were scheduled per table IWC-2600 to be completed during the refueling outage on the seal water return filter:

Table IWC-2600 Item No.	Table IWC-2500 Examination Category	Parts to be examined (attachment 2)	Method
C1.1	C-A	1" head to shell weld(1)	*substituted surface and visual
C1.1	C-A	1" shell to flange weld(2)	*substituted surface and visual
C1.1	C-A	1" top head weld(3)	*substituted surface and visual
C1.3	C-C	Welded support (IWS)	surface

\* On February 28, 1984, Vepco was granted relief (letter Mr. Varga to Mr. Stewart) to substitute surface and visual exams for the required volumetric due to the thin structure of the associated materials, reducing the effectiveness of a volumetric exam.

Preinspection meetings with the Health Physics Department determined that unreasonable doses would result from completion of these examinations. The close quarters surrounding these components limit shielding and allow effective use of only one individual to remove insulation (regen. only), perform necessary surface preparation, perform the inspection, and reinsulate (regen. only). In addition surface preparation time can be extended significantly as a result of the limited preservice examination requirements associated with the earlier codes. In many cases this has left these type of welds in poor surface condition for examination.



2. The residual heat removal return isolation valve (MOV-RH-2720B) is classified ASME Class 1 (attachment 3). A Table IWB-2600, (ASME XI 74 edition, Summer 75 addenda) item B6.7, category B-M-2, valve internal visual inspection was required this refueling outage. A substituted thickness measurement examination from the exterior wall was attempted. This alternative was approved by relief request on January 24, 1984 (letter Mr. Varga to Mr. Stewart), relief request SR-1.

As noted by the attached inspection form (attachement 4), accurate thickness readings could not be achieved. By previous agreement (phone conversation Mr. Neighbors et al, NRC and Mr. Hegner et al, Vepco, March 21, 1985) relief from the thickness measurement requirement would be addressed on an individual basis.

Therefore, it is requested that acceptance of the system hydrostatic pressure test be allowed as the alternative examination requirement. These tests (Class 1 to Class 2 boundary valve) were completed with the associated VT-2 examinations on July 1, 1983 and April 22, 1985 at test pressures of 600 psig and 750 psig, respectively.

It is our opinion that acceptance of this relief request provides the most practical resolution to the examination difficulties presented.

3. The current code edition, ASME Section XI 1980 edition, Winter 1980 addenda, states in paragraph IWA-7210(a) that replacement components shall meet the original construction code requirements or, alternatively, the requirement of IWA-7210(c). IWA-7210(c) states that replacements may meet the requirements of later editions of the construction code (in this case USAS B-31.1 - 1967), providing any additional requirements are met and that the later edition has been approved by the NRC.

No later editions of USAS B31.1 were approved by the NRC for nuclear work in 10 CFR 50.55a limiting Surry, under the rules of ASME Section XI, to the original code in power piping/component type replacement. It is requested that the use of ASME Section III be permitted in the same context that paragraph IWA-7210(c) above is intended for later editions of the original construction code for these types of replacements. Use of ASME Section III as approved by the NRC, allows the use of more "state of the art" requirements and provides more flexibility in our repair/replacement program.




VIRGINIA ELECTRIC AND POWER COMPANY TO Mr. Harold R. Denton

Specific use of this relief was already applied during the outage in the replacement of 2-SI-338, a 2 inch ASME Class 2 manual valve (attachment 5), used in setting flow for the high head safety injection system. Procurement of a valve meeting the original construction code and nuclear code cases could not be made, however the original manufacturer stocked a valve, which met ASME Section III NC requirements, except for stamping and met the requirements of ASME Section XI, IWA 7210 (c) as discussed.

It is our opinion that this request is administrative only, but acceptance is necessary to fully comply with the code requirements.

We also feel that adequate bases for the relief requested herein have been presented above, and that Surry will continue to meet, with the alternative proposals, the integrity assurance intended by the code.

Very truly yours,



W. L. Stewart

Attachments

cc: (w/attachment)


Mr. T. L. Chan  
NRC Project Manager - Surry  
Operating Reactors Branch No. 1  
Division of Licensing

Mr. D. J. Burke  
NRC Resident Inspector  
Surry Power Station

# REGENERATIVE HEAT EXCHANGER

01/01/84

Ref: 1-4507



Ref: 1-4507

Welds: 1, 2, 3 & 4: 17, 18, 19, 20, 22, 23, & 24  
 Material: .875" T A213 T0304SS

Dia.: 9.25"  
 Circ.: 28.86"

Welds: 5, 6 & 15 to  
 3" Sch. 160 A312 TP304SS

Welds: 7, 8, 9, 10, 11, 12, 13 & 14 to  
 3" Sch. 80 A312TP304SS

1/71

ILLUSTRATIVE ONLY


ATTACHMENT 2

VIR-2-1320


Rev. 0

01/01/84

# SEAL WATER RETURN FILTER




MATERIAL: 304 STAINLESS STEEL .188" T  
Welds 1, 2&3 : 16" Diameter  
50.24" Circumference  
SUPPORTS: 4 Welded Supports  
NOZZLE TO VESSEL WELDS: 3" diameter  
BOLTING: 8 bolts .75" diameter  
0 Reference : Centerline of 3" Inlet Nozzle



1/361

11548-FM-87A



FOR REFERENCE ONLY

- REFERENCED DRAWINGS
- VALVE OPERATING NUMBERS COMPONENT COOLING SPS FM-72A
- VALVE OPERATING NUMBERS SAMPLING SYSTEM FM-85A
- VALVE OPERATING NUMBERS VENTS BORAXINE S42 FM-85B
- VALVE OPERATING NUMBERS COOL SYSTEM ECONOMIC SHUT OFF FM-86A
- VALVE OPERATING NUMBERS REACTOR COOLANT SYSTEM FM-86B
- VALVE OPERATING NUMBERS SAFETY INJECTION SPS FM-87C
- FLOW DIAGRAM RESIDUAL HEAT REMOVAL SYSTEM FM-104A

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
---	---	---	---	---	---	---	---	---	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	----	-----

*Robert M. [Signature]*

**VALVE OPERATING NUMBERS  
RESIDUAL HEAT REMOVAL**

1972 REVISION: SAFETY SYSTEMS SECTION  
 VIRGINIA ELECTRIC AND POWER COMPANY  
 A DIVISION OF WESTINGHOUSE CORPORATION  
 NUMBER 11548-FM-87A

ULTRASONIC THICKNESS REPORT  
 NDE-UT-FORM 5  
 VIRGINIA ELECTRIC AND POWER COMPANY

STATION: 1 Surry UNIT: 2 II DATE: 3 5-24-85 PROCEDURE: 4 NDE-UT-4 SYSTEM: 5 Sonic MKI  
 ITEM COMPONENT INSPECTED: 6 Dwg. VIR-1-4302 ID NO.: 7 Value 2720B Loop 3 10" RHR Return

INSTRUMENT: 8 S/N 11221E COUPLANT: 9 Batch 8225 Sonotrace 40 CALIBRATION BLOCK: 10 VIR-1 TEST PERFORMED BY: 11 John S. Brode


TRANSDUCER: 12 1" FREQUENCY: 13 0.5 MHz SCANNING TECHNIQUE: 14 SPOT CONTINUOUS: CONTINUOUS LEVEL OF CERTIFICATION: 15 II

NOMINAL MATERIAL THICKNESS: 16 N/A MIN. THICKNESS ACCEPTABLE: 17 N/A MAX. THICKNESS ACCEPTABLE: 18 N/A SEE ATTACHED SKETCH FOR CHECK POINT LOCATIONS: N/A

LOCATION	READING	LOCATION	READING	LOCATION	READING
Valve # <sup>19</sup> 2720B	<sup>20</sup> Note: Unable to achieve backwall				
possibly due to	high attenuation of coarse grain				
structure	JB 5-24-85				

V E P C O  
 J.S. Brode  
 MJB  
 5/25/85

ATTACHMENT 4



ALL WIRING REFERENCED BY S.I.:

WIRING	1	2	3	4	5
WIRING					
WIRING					
WIRING					
WIRING					
WIRING					

DET. A  
 100% TRANSMISSION  
 100% ACCUMULATOR TRANS  
 (SEE 11548-FM-50E-1)

REFERENCE DRAWINGS  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-2)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-3)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-4)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-5)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-6)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-7)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-8)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-9)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-10)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-11)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-12)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-13)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-14)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-15)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-16)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-17)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-18)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-19)  
 VALVE OPERATING NUMBERS (SEE 11548-FM-50E-20)

**FOR REFERENCE**

**VALVE OPERATING NUMBERS  
 SAFETY INJECTION SHEET 2**

1922 EXTENSION SUBSTATION POWER STATION  
 VIRGINIA ELECTRIC AND POWER COMPANY  
 STONE & WEBSTER ENGINEERING CORPORATION  
 DRAFTSMAN  
 NUMBER  
 11548-FM-50E

NO.	REVISION	DATE	BY	CHKD.	APP'D.	DESCRIPTION
1						ORIGINAL ISSUE
2						REVISION
3						REVISION
4						REVISION
5						REVISION
6						REVISION
7						REVISION
8						REVISION
9						REVISION
10						REVISION

ATTACHMENT 5