

## NRR-DMPSPEm Resource

---

**From:** Wiebe, Joel  
**Sent:** Thursday, May 24, 2018 11:59 AM  
**To:** Sprengel, Ryan:(GenCo-Nuc)  
**Subject:** RE: B/B 50.69 RAI - Potential Typo

Ryan,

That is indeed a typo. RAI 6.e is only related to extreme winds and tornadoes. You need only address extreme winds and tornadoes under RAI 6.e.

Let me know if this confusion will cause any difficulty in meeting the 30 day response date.

Joel

---

**From:** Sprengel, Ryan:(GenCo-Nuc) [<mailto:Ryan.Sprengel@exeloncorp.com>]  
**Sent:** Wednesday, May 23, 2018 5:06 PM  
**To:** Wiebe, Joel <[Joel.Wiebe@nrc.gov](mailto:Joel.Wiebe@nrc.gov)>  
**Subject:** [External\_Sender] B/B 50.69 RAI - Potential Typo

Joel,

We've identified a potential typo in the questions, 6.e says "With regards to extreme wind or tornado hazard....:" Then in subpart ii, that if any SSCs are credited [for screening wind or tornado hazards] then explain... how the NEI guidance is applied to external flooding (see below). Can you verify what is meant or should 6.e.ii refer to extreme wind or tornado hazards?

- the categorization process.
- e) Attachment 4 of the LAR indicates that extreme wind or tornado hazards are screened. With regards to extreme wind or tornado hazards, address the following:
    - i. Identify what type of SSCs, if any, are credited in the screening of these hazards, such as passive or active features.
    - ii. If any SSCs are credited for screening, then explain and justify how the guidance in Figure 5-6 of NEI 00-04 will apply to external flooding hazards.

**Ryan Sprengel**  
Sr. Regulatory Engineer  
Corporate Licensing

4300 Winfield Rd, Suite 400, Warrenville, IL 60555  
Office: 630 657 2814 | Mobile: 765 532 7290  
[ryan.sprengel@exeloncorp.com](mailto:ryan.sprengel@exeloncorp.com) [www.exeloncorp.com](http://www.exeloncorp.com)

This Email message and any attachment may contain information that is proprietary, legally privileged, confidential and/or subject to copyright belonging to Exelon Corporation or its affiliates ("Exelon"). This Email is intended solely for the use of the person(s) to which it is addressed. If you are not an intended recipient, or the employee or agent responsible for delivery of this Email to the intended recipient(s), you are hereby notified

that any dissemination, distribution or copying of this Email is strictly prohibited. If you have received this message in error, please immediately notify the sender and permanently delete this Email and any copies. Exelon policies expressly prohibit employees from making defamatory or offensive statements and infringing any copyright or any other legal right by Email communication. Exelon will not accept any liability in respect of such communications. -EXCIP

**Hearing Identifier:** NRR\_DMPS  
**Email Number:** 388

**Mail Envelope Properties** (Joel.Wiebe@nrc.gov20180524115900)

**Subject:** RE: B/B 50.69 RAI - Potential Typo  
**Sent Date:** 5/24/2018 11:59:19 AM  
**Received Date:** 5/24/2018 11:59:00 AM  
**From:** Wiebe, Joel

**Created By:** Joel.Wiebe@nrc.gov

**Recipients:**  
"Spengel, Ryan:(GenCo-Nuc)" <Ryan.Spengel@exeloncorp.com>  
Tracking Status: None

**Post Office:**

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	2029	5/24/2018 11:59:00 AM
image001.jpg	23087	

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

- the categorization process.
- e) Attachment 4 of the LAR indicates that extreme wind or tornado hazards are screened. With regards to extreme wind or tornado hazards, address the following:
    - i. Identify what type of SSCs, if any, are credited in the screening of these hazards, such as passive or active features.
    - ii. If any SSCs are credited for screening, then explain and justify how the guidance in Figure 5-6 of NEI 00-04 will apply to external flooding hazards.