

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

September 25, 1986

| | | |
|--|--------------|--------|
| Mr. Harold R. Denton, Director | Serial No. | 86-509 |
| Office of Nuclear Reactor Regulation | NO/ETS/acm | |
| Attn: Mr. Lester S. Rubenstein, Director | Docket Nos. | 50-280 |
| PWR Project Directorate No. 2 | | 50-281 |
| Division of PWR Licensing-A | License Nos. | DPR-32 |
| U.S. Nuclear Regulatory Commission | | DPR-37 |
| Washington, D.C. 20555 | | |

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNIT NOS. 1 AND 2
PROPOSED TECHNICAL SPECIFICATIONS CHANGES

Pursuant to 10 CFR 50.90, Virginia Electric and Power Company requests an amendment, in the form of changes to the Technical Specifications, to Operating License Nos. DPR-32 and DPR-37 for Surry Power Station Units 1 and 2.

This Technical Specification change request supersedes our two previous submittals, dated September 9, 1985 (Serial No. 85-229A) and October 31, 1985 (Serial No. 85-211C). This change request combines those two requests and provides our Technical Specifications changes for Generic Letter 83-28, Item 4.3 and 4.5.3.

We are proposing changes to Section 3.7, Instrumentation Systems, and Section 4.1, Operational Safety Review. The proposed changes to Section 3.7 would reformat and upgrade Table 3.7-1, Reactor Trip Instrumentation Operating Conditions, to more closely conform to Standard Technical Specifications. The proposed changes to Section 4.1 would add a surveillance requirement for the reactor trip system interlocks and modify some of the surveillance requirements for portions of the reactor protection system instrumentation channels in accordance with Standard Technical Specifications and other appropriate source documents. Other minor changes are also being proposed for this section of the Technical Specifications.

The proposed changes to the Technical Specifications are provided in Attachment 1. A discussion of the proposed changes to the Technical Specifications is provided in Attachment 2. The application fee was previously submitted with our October 31, 1985 Technical Specification change request.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It


8609300413 860925
PDR ADDCK 05000280
P PDR

A001
3/40

has been determined that this change does not pose an unreviewed safety question as defined in 10 CFR 50.59 and does not pose a significant hazards consideration as defined in 10 CFR 50.92.

If you have any questions, or need additional information to process this request, please contact us.

Very truly yours,



W. L. Stewart

Attachments:

1. Proposed Technical Specification Changes for Surry Units 1 and 2
2. Discussion of Proposed Changes

cc: Dr. J. Nelson Grace
Regional Administrator
NRC Region II

Mr. Albert F. Gibson, Acting Director
Division of Reactor Projects
NRC Region II

Mr. W. E. Holland
NRC Senior Resident Inspector
Surry Power Station

Mr. Charles Price
Department of Health
109 Governor Street
Richmond, Virginia 23219

Mr. Chandu P. Patel
NRC Surry Project Manager
PWR Project Directorate No. 2
Division of PWR Licensing-A

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart who is Vice President - Nuclear Operations, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 25 day of September, 19 86.

My Commission expires: February 10, 19 89.

Carolyn Moore
Notary Public

(SEAL)

S/001

ATTACHMENT 1
PROPOSED TECHNICAL SPECIFICATION CHANGES FOR
SURRY UNIT NOS 1 AND 2