

official file

MAY 15 1987

Virginia Electric and Power Company
ATTN: Mr. W. L. Stewart, Vice President,
Nuclear Operations
P. O. Box 26666
Richmond, VA 23261

Gentlemen:

SUBJECT: CONFIRMATION OF ENFORCEMENT CONFERENCE - SURRY - DOCKET NOS. 50-280
AND 50-281

This confirms the conversation between N. E. Clark of your staff, and F. S. Cantrell of my staff, on May 14, 1987, concerning an enforcement conference to be conducted at the NRC Region II Office on May 19, 1987, at 1:00 p.m. We requested this meeting to discuss the improper routing of 10 CFR 50 Appendix R related cables reported in Special Report 87-010-00. Enclosed is a proposed meeting agenda identifying specific issues of concern.

Should you have any questions regarding these arrangements, we will be pleased to discuss them.

Sincerely,

*Original Signed by
M. L. Ernst / for*

J. Nelson Grace
Regional Administrator

Enclosure:
Proposed Meeting Agenda

cc w/encl:
✓ R. F. Saunders, Station Manager
✓ N. E. Clark, Manager - Nuclear
Programs and Licensing

bcc w/encl:
✓ NRC Resident Inspector
Document Control Desk
Commonwealth of Virginia

RII *m*
RCroteau:jw
5/15/87

RII *ph*
FCantrell
5/15/87

RII *780*
TPeebles
5/15/87

RII *GRJ*
GJenkins
5/15/87

RII *BA*
WBrownlee
5/15/87

RII *ME*
MErnst
5/15/87

8705280476 870515
PDR ADOCK 05000280
F PDR

IE45

ENCLOSURE

PROPOSED MEETING AGENDA

Virginia Electric and Power Company Meeting with NRC
May 19, 1987

I. Opening Remarks

NRC

II. Issues of Concern

The improper routing of 10 CFR 50 Appendix R related cables as reported in Special Report 87-010-00 on April 10, 1987, specifically:

VEPCO

- A. How VEPCOs design control process will ensure 10 CFR 50 Appendix R requirements are met when performing design changes.
- B. Would a loss of offsite power have occurred with the loss of the Emergency Diesel Generators had a fire occurred in the Unit 2 Cable Vault and Tunnel.
- C. What specifically would be lost in the event of a fire in the Unit 2 Cable Vault and Tunnel.

III. Closing Remarks

NRC