

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

May 29, 1987

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Serial No. 87-263
NOD/JDH:vlh
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37

Gentlemen:


VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION UNITS 1 AND 2
PROPOSED TECHNICAL SPECIFICATIONS CHANGE
ADDITIONAL SMOKE DETECTORS IN AUXILIARY BUILDING

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests amendments, in the form of changes to the Technical Specifications, to Operating License Nos. DPR-32 and DPR-37 for Surry Power Station Units 1 and 2, respectively. The change (Attachment 1) revises Table 3.21-1 to increase from 12 to 14 the number of general area smoke detectors in the auxiliary building.

This request has been reviewed by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff to determine whether an unreviewed safety question (10 CFR 50.59) or a significant hazards consideration (10 CFR 50.92) exists. Our basis for determining that no significant hazards consideration exists is contained in Attachment 2.

We have evaluated this request in accordance with the criteria in 10 CFR 170. A voucher check in the amount of \$150.00 is enclosed as an application fee.

Very truly yours,



W. L. Stewart

Attachments:

1. Proposed Technical Specification Change
2. Discussion of Proposed Change
3. Application Fee

8706050183 870529
PDR ADOCK 05000280
P PDR

Acc'd
1/10

Rec'd w/ check \$150.00

cc: U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Suite 2900
Atlanta, Georgia 30323

Mr. Chandu P. Patel
NRC Surry Project Manager
PWR Project Directorate No. 2
Division of PWR Licensing-A

Mr. W. E. Holland
NRC Senior Resident Inspector
Surry Power Station

Mr. Charles Price
Department of Health
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart who is Vice President - Nuclear Operations, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 29 day of May, 19 87.

My Commission expires: February 25, 19 90.

Vicki L. Hull
Notary Public

(SEAL)

S/001