

NUREG/CR-4550
SAND86-2084
Vol. 3, Rev. 1, Part 2

Analysis of Core Damage Frequency: Surry, Unit 1 Internal Events Appendices

Prepared by R. C. Bertucio, J. A. Julius

Sandia National Laboratories

Prepared for
U.S. Nuclear Regulatory Commission

9006080169 900430
PDR ADOCK 05000280
P PDR

AVAILABILITY NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 2120 L Street, NW, Lower Level, Washington, DC 20555
2. The Superintendent of Documents, U.S. Government Printing Office, P.O. Box 37082, Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC Office of Inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Office of Information Resources Management, Distribution Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

DISCLAIMER NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Analysis of Core Damage Frequency: Surry, Unit 1 Internal Events Appendices

Manuscript Completed: February 1990
Date Published: April 1990

Prepared by
R. C. Bertucio,* J. A. Julius*

Program Manager: A. L. Camp
Principal Investigator: W. R. Cramond
Team Leader: R. C. Bertucio*

Sandia National Laboratories
Albuquerque, NM 87185

*E. I. Services
Kent, WA 98031

Prepared for
Division of Systems Research
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555
NRC FIN A1228

ABSTRACT

This document contains the appendices for the accident sequence analyses of internally initiated events for the Surry Nuclear Station, Unit 1. This is one of the five plant analyses conducted as part of the NUREG-1150 effort by the Nuclear Regulatory Commission. NUREG-1150 documents the risk of a selected group of nuclear power plants. The work performed and described here is an extensive reanalysis of that published in November 1986 as NUREG/CR-4550, Volume 3. It addresses comments from numerous reviewers and significant changes to the plant systems and procedures made since the first report. The uncertainty analysis and presentation of results are also much improved. The context and detail of this report are directed toward PRA practitioners who need to know how the work was performed and the details for use in further studies.

The mean core damage frequency at Surry was calculated to be $4.0E-5$ per year, with a 95% upper bound of $1.3E-4$ and 5% lower bound of $6.8E-6$ per year. Station blackout type accidents (loss of all AC power) were the largest contributors to the core damage frequency, accounting for approximately 68% of the total. The next type of dominant contributors were Loss of Coolant Accidents (LOCAs). These sequences account for 15% of core damage frequency. No other type of sequence accounts for more than 10% of core damage frequency.

The numerical results are dominated by the frequency of loss of offsite power, probabilities for non-recovery of offsite power, and diesel generator failure probabilities. Considerable effort was expended on the modeling of station blackout sequences, including the development of a reactor coolant pump seal LOCA model through elicitation of expert judgment. The study results can also be used to show the benefit of cross ties of important systems, between the two units at the Surry Station.

This report evaluates core damage frequency from internally initiated events. The consequences of these accidents are evaluated and reported under separate cover. Core damage sequences from externally initiated events are reported in Part 3 of this volume.

CONTENTS

- A. PLANT SPECIFIC THERMAL-HYDRAULIC CALCULATIONS
- B. SURRY BOOLEAN EQUATIONS AND FAULT TREES
- C. HUMAN RELIABILITY ANALYSIS - DETAILED RESULTS
- D. PLANT SPECIFIC ANALYSES
- E. IMPORTANCE VALUES AND CUT SETS FOR THE DOMINANT ACCIDENT SEQUENCES AND PLANT DAMAGE STATE GROUPS

FOREWORD

This is one of numerous documents that support the preparation of the NUREG-1150 document by the NRC Office of Nuclear Regulatory Research. Figure 1 illustrates the front-end documentation. There are three interfacing programs at Sandia National Laboratories performing this work: the Accident Sequence Evaluation Program (ASEP), the Severe Accident Risk Reduction Program (SARRP), and the Phenomenology and Risk Uncertainty Evaluation Program (PRUEP). The Zion PRA was performed at Idaho National Engineering Laboratory and Brookhaven National Laboratory.

Table 1 is a list of the original primary documentation and the corresponding revised documentation. There are several items that should be noted. First, in the original NUREG/CR-4550 report, Volume 2 was to be a summary of the internal analyses. This report was deleted. In Revision 1, Volume 2 now is the expert judgment elicitation covering all plants. Volumes 3 and 4 include external events analyses for Surry and Peach Bottom, respectively.

The revised NUREG/CR-4551 covers the analysis included in the original NUREG/CR-4551 and NUREG/CR-4700. However, it is different from NUREG/CR-4550 in that the results from the expert judgment elicitation are given in four parts to Volume 2 with each part covering one category of issues. The accident progression event trees are given in the appendices for each of the plant analyses.

Originally, NUREG/CR-4550 was published without the designation "Draft for Comment." Thus, this revision of NUREG/CR-4550 is designated Revision 1. The label Revision 1 is used consistently on all volumes except Volume 2, which was not part of the original documentation. NUREG/CR-4551 was originally published as a "Draft for Comment" so, in its final form, no Revision 1 designator is required to distinguish it from the previous documentatation.

There are several other reports published in association with NUREG-1150. These are:

NUREG/CR-5032, SAND87-2428, Modeling Time to Recovery and Initiating Event Frequency for Loss of Off-site Power Incidents at Nuclear Power Plants, R. L. Iman and S. C. Hora, Sandia National Laboratories, Albuquerque, NM, January 1988.

NUREG/CR-4840, SAND88-3102, Recommended Procedures for External Event Risk Analyses for NUREG-1150, M. P. Bohn and J. A. Lambright, Sandia National Laboratories, Albuquerque, NM, November 1989.

SUPPORT DOCUMENTS TO NUREG - 1150




FIGURE 1. DOCUMENTATION FOR NUREG-1150.

Table 1.
NUREG-1150 Analysis Documentation

Original Documentation

NUREG/CR-4550 Analysis of Core Damage Frequency From Internal Events	NUREG/CR-4551 Evaluation of Severe Accident Risks and the Potential for Risk Reduction	NUREG/CR-4700 Containment Event Analysis for Potential Severe Accidents
Volume 1 Methodology	Volume 1 Surry Unit 1	Volume 1 Surry Unit 1
2 Summary (Not Published)	2 Sequoyah Unit 1	2 Sequoyah Unit 1
3 Surry Unit 1	3 Peach Bottom Unit 2	3 Peach Bottom Unit 2
4 Peach Bottom Unit 2	4 Grand Gulf Unit 1	4 Grand Gulf Unit 1
5 Sequoyah Unit 1	5 Zion Unit 1	
6 Grand Gulf Unit 1		
7 Zion Unit 1		

Revised Documentation

NUREG/CR-4550, Revision 1 Analysis of Core Damage Frequency	NUREG/CR-4551, Evaluation of Severe Accident Risks
Volume 1 Methodology	Volume 1 Methodology
2 Part 1 Expert Judgment Elicit. Expert Panel	2 Part 1 Expert Judgment Elicit.--In-vessel
Part 2 Expert Judgment Elicit.--Project Staff	Part 2 Expert Judgment Elicit.--Containment
3 Part 1 Surry Unit 1 Internal Events	Part 3 Expert Judgment Elicit.--Structural
Part 2 Surry Unit 1 Internal Events App.	Part 4 Expert Judgment Elicit.--Source-Term
Part 3 Surry Unit 1 External Events	Part 5 Expert Judgment Elicit.--Supp. Calc.
4 Part 1 Peach Bottom Unit 2 Internal Events	Part 6 Expert Judgment Elicit.--Proj. Staff
Part 2 Peach Bottom Unit 2 Internal Events App.	Part 7 Expert Judgment Elicit.--Supp. Calc.
Part 3 Peach Bottom Unit 2 External Events	Part 8 Expert Judgment Elicit.--MACCS Input
5 Part 1 Sequoyah Unit 1 Internal Events	3 Part 1 Surry Unit 1 Anal. and Results
Part 2 Sequoyah Unit 1 Internal Events App.	Part 2 Surry Unit 1 Appendices
6 Part 1 Grand Gulf Unit 1 Internal Events	4 Part 1 Peach Bottom Unit 2 Anal. and Results
Part 2 Grand Gulf Unit 1 Internal Events App.	Part 2 Peach Bottom Unit 2 Appendices
7 Zion Unit 1 Internal Events	5 Part 1 Sequoyah Unit 2 Anal. and Results
	Part 2 Sequoyah Unit 2 Appendices
	6 Part 1 Grand Gulf Unit 1 Anal. and Results
	Part 2 Grand Gulf Unit 1 Appendices
	7 Part 1 Zion Unit 1 Anal. and Results
	Part 2 Zion Unit 1 Appendices

NUREG/CR-4772, SAND86-1996, Accident Sequence Evaluation Program Human Reliability Analysis Procedure, A. D. Swain III, Sandia National Laboratories, Albuquerque, NM, February 1987.

NUREG/CR-5263, SAND88-3100, The Risk Management Implications of NUREG-1150 Methods and Results, A. C. Camp et al., Sandia National Laboratories, Albuquerque, NM, December 1988.

A Human Reliability Analysis for the ATWS Accident Sequence with MSIV Closure at the Peach Bottom Atomic Power Station, A-3272, W. J. Luckas, Jr. et al., Brookhaven National Laboratory, Upton, NY, 1986.

A brief flow chart for the documentation is given in Figure 2. Any related supporting documents to the back-end NUREG/CR-4551 analyses are delineated in NUREG/CR-4551. A complete list of the revised NUREG/CR-4550, volumes and parts is given below.

General

NUREG/CR-4550, Volume 1, Revision 1, SAND86-2084, Analysis of Core Damage Frequency: Methodology Guidelines for Internal Events.

NUREG/CR-4550, Volume 2, SAND86-2084, Analysis of Core Damage Frequency from Internal Events: Expert Judgment Elicitation on Internal Events Issues - Part 1: Expert Panel Results, Part 2: Project Staff Results.

Parts 1 and 2 of Volume 2, NUREG/CR-4550 are bound together. This volume was not part of the original documentation and was first published in April 1989 and distributed in May 1989 with the title: Analysis of Core Damage Frequency from Internal Events: Expert Judgment Elicitation. In retrospect, a more descriptive title would be: Analysis of Core Damage Frequency: Expert Judgment Elicitation on Internal Events Issues.

Surry

NUREG/CR-4550, Volume 3, Revision 1, Part 1, SAND86-2084, Analysis of Core Damage Frequency: Surry Unit 1 Internal Events.

NUREG/CR-4550, Volume 3, Revision 1, Part 2, SAND86-2084, Analysis of Core Damage Frequency: Surry Unit 1 Internal Events Appendices.

NUREG/CR-4550, Volume 3, Revision 1, Part 3, SAND86-2084, Analysis of Core Damage Frequency: Surry Unit 1 External Events.

FRONT-END ANALYSIS

BACK-END ANALYSIS




Figure 2. Surry Related Documentation.

Peach Bottom

NUREG/CR-4697, EGG-2464, Containment Venting Analysis for the Peach Bottom Atomic Power Station, D. J. Hansen et al., Idaho National Engineering Laboratory (EG&G Idaho, Inc.) February 1987.

NUREG/CR-4550, Volume 4, Revision 1, Part 1, SAND86-2084, Analysis of Core Damage Frequency: Peach Bottom Unit 2 Internal Events.

- NUREG/CR-4550, Volume 4, Revision 1, Part 2, SAND86-2084, Analysis of Core Damage Frequency: Peach Bottom Unit 2 Internal Events Appendices.

NUREG/CR-4550, Volume 4, Revision 1, Part 3, SAND86-2084, Analysis of Core Damage Frequency: Peach Bottom Unit 2 External Events.

Sequoyah

NUREG/CR-4550, Volume 5, Revision 1, Part 1, SAND86-2084, Analysis of Core Damage Frequency: Sequoyah Unit 1 Internal Events.

NUREG/CR-4550, Volume 5, Revision 1, Part 2, SAND86-2084, Analysis of Core Damage Frequency: Sequoyah Unit 1 Internal Events Appendices.

Grand Gulf

NUREG/CR-4550, Volume 6, Revision 1, Part 1, SAND86-2084, Analysis of Core Damage Frequency: Grand Gulf Unit 1 Internal Events.

NUREG/CR-4550, Volume 6, Revision 1, Part 2, SAND86-2084, Analysis of Core Damage Frequency: Grand Gulf Unit 1 Internal Events Appendices.

Zion

NUREG/CR-4550, Volume 7, Revision 1, EGG-2554, Analysis of Core Damage Frequency: Zion Unit 1 Internal Events.

Table of Contents

<u>Section</u>	<u>Page</u>
A.1 Containment Pressure Rise After Loss of Containment Heat Removal	A-3
A.1.1 Excerpt from NUREG/CR-4551, Vol 1	A-4
A.1.2 Evaluation of Loss of Containment Heat Sink Scenarios for Surry	A-11
A.2 Buildup of Sump Inventory After Containment Spray Failure	A-21
A.2.2 Thermal Hydraulic Analyses of Sump Inventory after Containment Spray Failure	A-21
A.3 Success Criteria for Containment Heat Removal	A-23
A.4 References	A-23

APPENDIX A

A. Plant Specific Thermal Hydraulic Calculations

This appendix describes the plant specific thermal hydraulic calculations performed in the revised Surry probabilistic risk assessment. There were three important thermal hydraulic analyses performed for this study. A description and summary of these calculations was not available for this draft publication. They will be included in the final report. The three analyses are briefly described below.

A.1 Containment Pressure Rise After Loss of Containment Heat Removal

Several sequences in the Surry study involve loss of containment heat removal, with success of core make-up. These conditions were called core vulnerable conditions. Part of the resolution of core vulnerable conditions involved prediction of containment pressure rise versus time. Sandia performed a series of calculations in the Evaluation of Severe Accident Risks and the Potential for Risk Reduction: Surry Power Station, Unit 1, NUREG-4551 Volume 1, Draft for Comment, February 1987, A.S. Benjamin, et al. The portion of this report⁽¹⁾ describing the calculations is shown in an excerpt which follows. The results of the analysis calculated the best estimate probability of core vulnerable sequences resulting in core damage as 0.02. This probability was used for event tree heading CV and basic event CON-VFC-RP-COREM.

An additional analysis was conducted by Battelle⁽³⁾ to determine whether containment failure could be predicted and the timing of such failure. This analysis was evaluated for various size LOCAs followed by failure of containment heat removal scenarios. It has been reprinted in Section A.1.2.

A.2.2 Core-Vulnerable Sequences

One type of sequence is not addressed specifically by this set of plant-damage states. This type of sequence involves conditions in which the core is being cooled by high- or low-pressure recirculation, with decay heat rejected to the containment through a break or through the pressurizer relief valves. Under these circumstances, heat removal must be provided by the containment spray recirculation systems and their heat exchangers. Because of the mass and energy discharged to containment, failure of the containment heat removal system is likely to

lead eventually to overpressurization of the containment. These sequences may or may not result in core melt, and were therefore designated by ASEP as "core-vulnerable" sequences.

Several of these scenarios were examined by Battelle to ascertain whether or not containment failure would occur, and if so, when the failure would be expected. In consultation with the ASEP analysts, the SARRP team constructed a bridge event tree which identifies phenomenological events, system failures, and operator actions that might determine whether a core-vulnerable sequence proceeds to a core-damage sequence. Assessing the probabilities of the individual pathways resulted in a fraction that determines the percent of core-vulnerable sequences expected to result in core melt as a result of the initial containment failure.

Affected Sequences

For small LOCAs and transients, it was determined that the removal of decay heat via the steam generators would prevent overpressurization of containment, provided feedwater were available [2]. Even if feedwater were unavailable, the time it would take for containment to be overpressurized would be very long, although this case was retained for further analysis using the bridge event tree. The thermal hydraulic analysis of containment cooling modeled the specific Surry conditions and procedures as closely as possible.

For large and intermediate LOCAs however, the Battelle analysis showed that containment would be likely to fail at 51 hours. This result may well be conservative for two reasons. First, the Source Term Code Package does not adequately model containment heat sinks and the loss of heat to the environment is probably greater than the value calculated. Second, although the non-emergency fan coolers at Surry are at least partially submerged when

the RWST is injected, and are therefore unavailable during these accidents, the operations staff could continue to supply cooling water to the fans cooling units, achieving some degree of heat removal.

Bridge Event Tree

It is recognized that the containment failure does not automatically lead to core damage. First of all, the core cooling systems could continue to operate after the containment failure. Second, if the systems did fail, other systems could potentially be used to perform the cooling function. Third, because of the duration of the accident, the operators possibly could act to prevent overpressurization altogether, by a controlled depressurization. The ASEP sequence frequency already accounted for recovery of the heat removal systems in the time frames presented by these accidents.

In consultation with ASEP analysts, the bridge event tree illustrated in Figure A-1 was constructed to determine the probability of core-vulnerable sequences resulting in core damage. The events and phenomena that could lead to a consequential failure of emergency core systems are described below:

- Containment pressure relief. Pressure could be maintained within the containment capacity if operator action were taken to accomplish venting. The operations staff, and support personnel would have two days to take this type of corrective action.
- Injection piping not damaged. If the containment were to fail structurally, there is a potential that the injection piping itself could be damaged by the failure.
- Net-positive suction head (NPSH) for the low-pressure injection pumps maintained. As the containment depressurizes after failure, some of the water in the containment sump will flash to steam; sump water will also continue to evaporate in the ensuing period. If sufficient subcooling of the sump water is lost, the low-pressure injection pumps may fail due to a lack of adequate NPSH.
- Low-pressure injection pump in standby. In the long period following the early phases of the accident, it is very possible that the operators will secure equipment that is not needed for the immediate preservation of core cooling. If a low-pressure injection pump has been returned to a standby condition, it may be possible to maintain core cooling even if the operating pump fails due to loss of NPSH. It was judged to be likely that, in this situation, the operators would start the standby pump and take measures to protect it from failure. For example, because this situation would only arise many hours into the accident, it would be possible to stop the pump periodically if it were to begin to overheat due to NPSH problems.




Figure A-1. Bridge Event Tree for Evaluation of Core-Vulnerable Sequences

- Use High Pressure Pump from Other Unit or Refill RWST and Use High-Pressure Injection. The high pressure systems at Surry are cross-connected between units, and the RWST inventory of Unit 2 is part of the technical specification of Unit 1. The high pressure pumps can be used to inject into the hot legs to avoid any problems with the buildup of boron. A final possibility considered in the event tree was the restoration of a level in the RWST adequate to provide suction to the high-pressure injection pumps. Again, it was judged to be likely that the operators could establish such a pathway for core cooling. Because of the reduced requirements for decay-heat removal at this point, the flow could be throttled back to prevent runout of the high-pressure injection pumps, while still providing adequate core cooling.

Of the five events, the second and third were referred to the containment review experts for consideration. The other three and the actual tree constructions were examined jointly by SARRP and ASEP.

Expert Review Input

Tables A-3 and A-4 illustrate the inputs of the reviewers for the probability of ECCS pump and piping failure as a function of containment failure size. Table A-5 shows the

probability estimates of these same reviewers for containment failure pressure and Table A-6 illustrates their estimates of containment hole size as a function of containment failure pressure. Only three of the reviewers responded to all four questions as indicated. The inputs for containment failure pressures of 67 and 180 psig were added to those of 85 and 143 psig, respectively, for the purposes of this analysis.

These inputs were combined into composites as illustrated in Table A-7. The composite results of each reviewer were used for three distinct walkthroughs of the bridge tree.

TABLE A-3
EFFECT OF CONTAINMENT FAILURE ON ECCS PUMP OPERABILITY

OUTCOME CORRELATED TO FAILURE SIZE	WEIGHTING FACTORS		
	<u>Reviewer</u>		
	1	2	3
1. 4 sq. in.	0.0	0.0	0.0
2. .1 sq. ft.	0.0	0.0	0.0
3. .7 sq.ft.	.2	.2	.1
4. 7 sq. ft.	.3	.4	.3

TABLE A-4
EFFECT OF CONTAINMENT FAILURE ON INJECTION AND SUCTION PIPING

OUTCOME CORRELATED TO FAILURE SIZE	WEIGHTING FACTORS		
	<u>Reviewer</u>		
	1	2	3
1. 4 sq. in.	0.0	0.0	0.0
2. .1 sq. ft.	0.0	0.0	0.0
3. .7 sq.ft.	0.0	0.0	0.0
4. 7 sq. ft.	.1	.01	.1

TABLE A-5
REVIEWER INPUT FOR MEAN CONTAINMENT FAILURE PRESSURE

MEAN FAILURE PRESSURE	WEIGHTING FACTORS		
	<u>Reviewer</u>		
	1	2	3
1. 67 psi	0.0	0.0	0.0
2. 85 psi	.25	.2	.1
3. 119 psi	.5	.5	.3
4. 143 psi	.2	.2	.5
5. 180 psi	.05	.1	.05

TABLE A-6
CONTAINMENT FAILURE SIZE GIVEN SLOW PRESSURIZATION

OUTCOME Size of Opening	WEIGHTING FACTORS Reviewer		
	1	2	3
<u>For Containment Failure Pressure 119 psig</u>			
1. 4 sq. in.	.15	.35	.2
2. .1 sq. ft.	.2	.35	.2
3. .7 sq.ft.	.2	.2	.3
4. 7 sq. ft.	.45	.1	.3
<u>For Containment Failure Pressure 85 psig</u>			
1. 4 sq. in.	.15	.5	.4
2. .1 sq. ft.	.2	.4	.5
3. .7 sq.ft.	.2	.1	.1
4. 7 sq. ft.	.45	0.0	0.0
<u>For Containment Failure Pressure 143 or 180 psig</u>			
1. 4 sq. in.	.15	.3	0.0
2. .1 sq. ft.	.2	.3	0.0
3. .7 sq.ft.	.2	.2	.4
4. 7 sq. ft.	.45	.2	.6

TABLE A-7
OVERALL PROBABILITIES OF ECCS FAILURE

OUTCOME CORRELATED TO FAILURE SIZE	WEIGHTING FACTORS Reviewer		
	1	2	3
PUMP FAILURE PROBABILITY	.08	.17	.1
PIPING FAILURE PROBABILITY	.0014	.03	.019

Event Tree Sequence Description

The sequences of the bridge event tree are described briefly below. The quantification of the other events is also discussed.

Sequence 1. No core or containment damage results from this sequence. The containment pressure has been relieved and the operating pumps have not failed. The pressure relief is assumed to be controlled such that cavitation is not a problem with the operating pumps.

Sequence 2. Once again there is no core damage. The operating pump does fail, but the operator then uses the pump he previously placed in standby.

Sequence 3. This is similar to sequence 2, but the operator uses the high pressure injection pumps from Unit 2.

Sequence 4. Core damage results if the depressurization is large enough to cavitate the pumps and the operations staff does not perform any recovery action.

Sequence 5. The containment fails, but the core is maintained by the operating pumps which are not damaged by the depressurization.

Sequence 6. This is analagous to sequence 2, except that the containment does fail. The core is in a stable, cooled state.

Sequence 7. This is analagous to sequence 3, except that the containment does fail. The core is in a stable, cooled state.

Sequence 8. Core damage results because depressurization is large enough to cavitate the pumps and the operations staff does not perform any recovery action.

Sequence 9. Core damage results because the containment failure causes the injection piping to fail directly.

For the first event in the tree, containment pressure relief, a probability of 0.5 was assigned. This value was chosen because the analysts are nearly completely uncertain considering the likelihood of this event. There is certainly the time and means to affect containment venting, but to our knowledge, there are no procedures to do so. Also, both the ASEP and SARRP analyses have assumed that the instrumentation will continue to operate. If it does not, the operations staff may be very reluctant to create a containment opening without good knowledge of core and containment conditions. In addition, state and federal authorities could intervene, how, we cannot speculate.

For the fourth and fifth events, it was assessed "likely" that the staff will succeed if the operator has successfully recognized the situation and vented the containment. In keeping with

the philosophy of verbal descriptor probabilities used in the containment analysis, a value of 0.9 for success of each of these events was assigned

If venting did not occur, the fourth and fifth events are believed to be "uncertain", and a probability of 0.5 was assigned. At this point in time it is outside the scope to assess all of the reasons for failure to vent, but it is this event which is closely coupled with the other operator recoveries.

Results of the Bridge Tree Assessment

Three separate walkthroughs of the tree were quantified. All three used the split fractions of the first, fourth and fifth events discussed above. Each walkthrough differed in the second and third events by using the separate estimates of the three individual reviewers.

The probabilities of core vulnerable sequences resulting in core damage were calculated as 0.01, 0.02, and 0.04. These were used as the optimistic, central and pessimistic in the OCP analysis, respectively. In the limited Latin hypercube analysis, each result was weighted equally.*

*The resulting spread in the results is limited, perhaps more than if the uncertainty in this issue had been addressed by a larger group, or if their input had been manipulated differently.

A.1.2 EVALUATION OF LOSS OF CONTAINMENT HEAT SINK SCENARIOS FOR SURRY

Introduction

This note summarizes the results of the MARCH 3 calculations performed for the Surry S3G, S2G, S1G, and AG sequences. In these sequences a break in the primary system is accompanied by failure of the containment heat removal system; the emergency core cooling and containment spray systems are available. At the start of the incident the normal containment cooling system as well as the primary coolant pumps would be operating. Both of these would be turned off upon reaching the 25 psia containment spray initiation and containment isolation level. The operator would be expected to manually depressurize the secondary side of the steam generators over a period of four hours. For purposes of these analyses the water available to the auxiliary feedwater system was assumed to be unlimited. (The value of 100 psia for the steam generator secondary depressurization level used in the present analyses is hard-wired into MARCH; the more representative level may be 150 psia.)

The principal question to be answered by these analyses is whether containment failure would be predicted, and what would be the timing of such failure. In the event that containment failure did take place, it could be followed by failure of the emergency core cooling systems and eventual core melting.

S3G Sequence

The most probable initiating event for the S3G sequence has been indicated to be pump seal failure. ASEP analysed had previously indicated that pump seal failures would be characterized by primary system water leakages of 50 to 500 gallons per minute. In the present analysis a break area of 0.0044 sq ft, corresponding to a 0.9 inch diameter opening was used. With this break area and the predicted conditions of temperature and pressure, primary leakages of about 400 gallons per minute were observed. The emergency core cooling systems supplying makeup to the primary system were assumed to be available at their full capacities, with the pump performance curves being modeled in the analysis. With the limited break area associated with pump seal failure and the operability of the emergency core cooling systems, the primary system pressure was predicted to be maintained at about 770 psia. The balance between the leakage from the primary system and the coolant makeup rate was such that all the decay heat as well as that input by the primary pumps could be removed with no net steam generation in the primary system. With the combination of steam generator heat removal, containment cooler heat removal, and heat loss to structures, only a relatively small fraction of the total available energy was predicted to go into heating and pressurizing the containment atmosphere. The containment isolation and spray initiation setpoint of 25 psia was predicted to be reached at 3793 minutes after the start of the accident. Just prior to spray initiation about 60 percent of the decay and primary pump energy was being removed by the steam generators,

about 20 percent by the building coolers, and approximately 10 percent was being absorbed by containment structures.

The primary pumps as well as the building coolers were tripped off at spray initiation. The containment continued to pressurize slowly, with the sprays keeping the containment sump and atmosphere in equilibrium. The calculation was carried out for 12,000 minutes of accident time. At the end of the calculation the containment pressure was predicted to be 64 psia, with both the atmosphere and sump temperatures at 282 F. At this time approximately 60 percent of the decay heat was being removed by the steam generators, about 34 percent was going to structures, and the balance went to heating of the containment water inventory. At the end of the calculation the inside surface of the containment dome was predicted to be at 282 F, with the outside at 149 F. With the outside surface being predicted to have risen by 49 F, considerable heat loss to the environment would be possible. The latter is not included in the analysis.

S2G Sequence

The S2G sequence was assumed to be initiated by a primary system pipe rupture equivalent to two inches in diameter. As in the preceding S3G scenario, the auxiliary feedwater system as well as the full complement of emergency core cooling systems were assumed to be available.

For the 2 inch break the containment spray setpoint pressure was predicted to be reached in about 33 minutes after the start of the accident. The primary system pumps were initially on but were assumed to trip upon reaching the containment spray initia-

tion pressure, as in the preceding case.

With the larger break size the primary system pressure decreased fairly rapidly; this combined with the cold water injection by the emergency core cooling system resulted in primary system temperature dropping to the point where the steam generators were ineffective for heat removal. As the water supply to the primary system heated up with time, however, the steam generators were predicted to come back into play. The primary system pressure was predicted to be maintained between about 570 and 600 psia during the course of this transient. The leakage from the primary system was balanced by makeup by the emergency core cooling systems. As in the preceding case, it was predicted that all the decay heat could be removed with no net steam generation. Thus, again, the scenario was characterized by slow heatup of the containment water inventory, with significant heat removal by the steam generators. At the end of the calculation, at 11,880 minutes into the accident, the containment pressure was predicted to be 108 psia. The atmosphere and sump water temperatures at that time were 323 and 325 F, respectively. With the sump water being supplied to the primary system at an elevated temperature, about 72 percent of the decay heat was predicted to be removed by the steam generators, with about 26 percent of the decay heat being absorbed by containment structures. Thus only a small fraction of the decay heat was going into the heatup and pressurization of the containment atmosphere. At the end of the calculation the inside surface of the containment dome was predicted to be at 323 F, with the outside at 177 F. At the latter

outside temperature considerable heat loss to the environment would be possible; the latter is not included in the analysis.

S1G Sequence

Two examples of the intermediate (S1) size break were considered for this study, one with a break diameter of four inches, and the other with a six inch diameter break.

For the four inch diameter break the primary system depressurized rapidly and the containment spray initiation pressure was reached at about 5 minutes into the accident. Thus neither the containment coolers nor the primary system pumps had a significant impact on this scenario. The emergency core cooling systems switched to the recirculation mode at about 65 minutes.

Since the primary system was predicted to depressurize rapidly, the steam generators lost their effectiveness as heat sinks early in the sequence. Due to the continuing operation of the emergency core cooling systems, however, the primary system never completely depressurized. Late in time, as the sump water being pumped to the primary system heated up, the primary system pressure was predicted to increase. With increasing primary system pressure and temperature the steam generators were predicted to be able to remove a significant fraction of the decay heat. The latter is predicated on depressurization of the steam generator secondary side to 100 psia. At the end of the calculation at 12,000 minutes, for the four inch break case the containment pressure was predicted to be 116 psia, with the atmosphere and sump temperatures at 329 and 330 F, respectively. At that time approximately 75 percent of the decay heat was going to the steam

generators and about 23 percent to the containment structures. Thus only a very small fraction of the decay heat was going into the heating of the containment sump and atmosphere. Under these conditions substantial additional time would be required to reach the failure pressure of 135 psia.

The results for the 6 inch break are very similar to the preceding case. With the larger break area the containment spray initiation setpoint was reached in about 2 minutes. Thus, again, the containment coolers and the primary system pumps were turned off very early in the sequence. The primary system pressure was predicted to drop rapidly to about 140 psia, with the emergency core cooling sytem injection precluding complete depressurization. The switch to emergency core cooling recirculation was predicted at about 45 minutes. The steam generators were ineffective for heat removal during the initial part of the accident sequence. As the containment sump water heated up, the primary system pressure and temperature increased, and heat removal from the now depressurized steam generators became possible. At 12,000 minutes into the accident the containment pressure appeared to have leveled off at 118 psia, with the atmosphere and sump temperatures at 330 and 332 F, respectively. At this time the heat removal by the steam generators and the heat losses to structures were equal to the decay heat. At the end of the calculation the inside surface of the dome was predicted to be at 330 F, with the outside at 183 F; at the latter temperature considerable heat loss to the environment would be possible, but is not considered in the analysis.

AG Sequence

In a large break loss-of-coolant-accident the MARCH code precludes heat removal by the steam generators. This is an assumption built into the code which may not be applicable under all circumstances. For the accident scenario in question, i.e., a large pipe break with loss of containment heat removal, but with all the other safety systems operational, if the break is in the cold leg the effluent from the core would have to pass through the steam generators to get to the break in the system. If the temperature of the coolant leaving the core were higher than the secondary side of the steam generators, heat removal by the steam generators would be possible. Thus the assumption of no steam generator heat removal is strictly applicable only to large hot leg break cases; the latter would be the limiting cases from the point of view of containment pressurization.

The sequence of events predicted for the AG sequence is given in Table I. At the predicted time of containment failure at 3054 minutes the containment atmosphere and sump are at 340 F. The average water temperature in the primary system is about 350 F; at this level steam generator heat removal may be possible if the flow were through the steam generators. At the time of predicted containment failure the inside surface of the containment dome is predicted to be at 340 F, with the exterior surface at 104 F. Since the latter has only increased four degrees above the assumed initial temperature, little heat loss to the environment would be indicated. The latter is not included in these analyses.

Discussion

For the small and intermediate break cases accompanied by loss of containment heat removal the present analyses indicate the steam generators to be very effective in removing decay heat and thus limiting containment pressurization. With the low containment pressurization rates indicated, it would appear highly likely that time would be available for recovery actions and containment failure could be precluded in most of the scenarios considered. This conclusion is subject to effective depressurization of the steam generator secondary, continued availability of auxiliary feedwater, and of course, the approximations inherent in the MARCH modeling of the systems and their performance.

For all the small and intermediate break cases considered here the MARCH analyses predicted that the primary system would not completely depressurize. This aspect of the analysis may be somewhat questionable due to the quite simplified modeling of the primary system by MARCH. The essential indication that the steam generators can be quite effective in these scenarios appears to be valid, however. As the sump water temperature being supplied to the primary system approaches that of the steam generator secondary, and is further elevated by core decay heat, heat transfer from the primary to the secondary will take place. The efficiency of the steam generators under the conditions in question is quite uncertain. The present analyses indicate that a substantial fraction of the decay heat can be removed even at very small temperature differences between the primary and secondary sides of the steam generators. In this regard, MARCH has hard-wired into it a secondary depressurization pressure of 100

psia, with a corresponding saturation temperature of 327.8 F. If the actual secondary side pressure is higher, the effectiveness of the steam generators would be lower than indicated in the present analyses.

In the analyses considered here no consideration was given to heat losses from the containment to the environment. For the extended scenarios associated with the small and intermediate break cases it was observed that the outside surface of the containment would experience considerable temperature increases. With such temperature rises considerable heat losses to the environment would be possible. The latter would further limit containment pressurization during the already extended scenarios. Possible heat losses to the environment would not significantly influence the containment pressurization history for the limiting case of a large hot leg pipe break.

TABLE I. ACCIDENT EVENT TIMES FOR SURRY AG SEQUENCE

<u>EVENT</u>	<u>TIME.MIN</u>
Spray On	1
ECCS Recirculation	29
Containment Fails	3054
Core Uncovers	3081
Start Melt	3156
Core Slump	3207
Core Collapse	3210
Head Fails	3371
Concrete Attack	3372

A.2 Buildup of Sump Inventory After Containment Spray Failure

An important sequence in WASH-1400 was S₂C. This represents a small LOCA followed by failure of the containment spray system. Failure of the containment spray system prevented injection of the RWST directly into containment. Because the initiator is a small, only limited break flow is discharged into containment. The result is that insufficient water is in the containment sump to support inside and outside spray recirculation systems (ISR and OSR) operation. Automatic activation of these systems without sufficient water in the sump led to pump failure.

Battelle performed a thermal hydraulic analysis⁽²⁾ on these sequences to find accurate condensation rates and sump inventory levels versus time. This analysis is included in section A.2.2.

A.2.2 Thermal Hydraulic Analyses of Sump Inventory after Containment Spray Failure

SARRP SOURCE TERM ANALYSES FOR SURRY DESIGN

Introduction

The S₂C sequence was found to be one of the risk dominant sequences for the Surry design in the WASH-1400 analyses. In this sequence the initiating event is a small break in the primary coolant system and it is accompanied by failure of the containment spray injection system. In the Surry design the containment spray injection and spray recirculation systems utilize separate pumps and headers. The recirculation sprays are started automatically after a preset delay after the receipt of the spray actuation signal. For a small pipe break coupled with failure of spray injection, the automatic actuation of the recirculation sprays has been postulated to lead to the operation of the spray recirculation pumps while the sump is still dry; the latter could lead to the burnout of the pumps. Since containment heat removal is associated with the spray recirculation system, loss of the latter would imply loss of the former as well. In the absence of containment heat removal the containment pressure would increase to the failure level; the latter would be followed by the failure of the emergency core cooling system due to pump cavitation and eventual core melting. In the WASH-1400 analyses for Surry, it was postulated that the initiating event was a break in one of the in-core instrument penetrations in the reactor vessel, leading to the discharge of the primary coolant into the reactor cavity rather than the containment sump; in these analyses it was also assumed that the spray actuation signal would be received at the start of the accident. The latter would be true for a large break loss-of-coolant-accident but not necessarily applicable to other initiating events.

The likelihood that the S₂C sequence would lead to core melting is expected to be substantially lower in the current view than it was at the time of WASH-1400; however, since this sequence could still be risk significant, the availability of up to date results on the possible course of such an event would be useful in the development of an updated risk perspective for the Surry design. It will be recalled that the WASH-1400 analyses were limited in scope, focusing largely on large break initiated events, and are generally considered to be conservative in light of today's knowledge. Several MARCH 2 calculations were performed to model the S₂C sequence, considering the specific scenario postulated in WASH-1400 as well as some alternate assumptions. The key results from these analyses were the time of the receipt of the spray actuation signal and the quantity of water in the containment sump at that time. The basis for and the details of these analyses are discussed below.

Assumptions

The detailed description of the Surry plant design for the present analyses was identical to that used for the BMI-2104 source term calculations. The containment ventilation heat removal system was considered operable. The latter would be isolated at a containment pressure of 25 psia (10 psig), the containment spray actuation level. The emergency core cooling as well as the auxiliary feedwater systems were assumed to be available at their full capacities; the latter is in contrast to the WASH-1400 assumption of only minimal safety system operation. In the modeling of the emergency core cooling system the pump curve option was utilized, making pump capacity dependent on the primary system pressure. While heat removal by the steam generators was considered, depressurization of the steam generator secondary side was not included in the present analysis.

Results

The results of the WASH-1400 S₂C scenario, i.e., a break in an in-core instrument penetration in the bottom head of the reactor vessel, are discussed below. The break area for this analysis was taken to be 0.0205 sq. ft., corresponding to a 2 inch instrument line with a 0.5 inch instrument lead inside. The break was assumed to be in the vessel bottom head and discharged into the reactor cavity; when the latter as well as the in-core instrument tunnel were filled, at a total volume of 11,680 cu. ft., water was allowed to overflow into the containment sump. The MARCH 2 results for the above case indicate that the earliest time at which the containment pressure would approach the spray initiation setpoint of 25 psia is about 50 minutes from the start of the accident; though it is not clear if the sprays would be actuated at this time. At 50 minutes into the accident the reactor cavity would not have been completely filled, but there would be an excess of 130,000 lb of water on the containment floor due to steam condensation on structures. If the spray pumps were actuated at this time there would be sufficient water in the containment sump for their operation. Overflow of water from the reactor cavity into the containment sump is predicted to start at about 60 minutes.

At the time that the containment pressure first approaches the spray initiation setpoint the pressure rise is not monotonic, and is actually predicted to decrease somewhat after that due to the fact that the emergency core cooling system is able to cool off the primary system. Eventually, however, the containment pressure will start to increase again if heat removal is not restored. The containment pressure is predicted to exceed 25 psia at about 430 minutes from the start of the accident. If the sprays have not been started until this time, there is little question of their ability to operate since the inventory of the refueling water storage tank has been exhausted by this time and the containment sump is predicted to have about 2.3E+6 lb of water at a temperature of 197 F.

In addition to the above sequence of events, an alternate scenario was considered in which the pipe break was assumed to be at a high elevation in the primary system so that it would discharge steam instead of water to the containment. For this situation the containment spray actuation pressure would be reached in about 60 minutes, with about 100,000 lb of water in the containment sump at that time. Thus operability of the recirculation sprays would seem likely under these assumptions.

Conclusions

Based on the present analyses it appears that given the initiating events associated with the S₂C sequence, there would be more than adequate water in the containment sump at the time of recirculation spray actuation. Thus this combination of initiating events would not be expected to lead to containment failure or core melting.

A.3 Success Criteria for Containment Heat Removal

Surry design provides two systems for containment heat removal; the outside spray recirculation system and the inside spray recirculation system. Each of these systems is a two train system. The design basis for containment heat removal is that one heat exchanger in each train is sufficient. The utility performed an analysis to show that one heat exchanger was sufficient to provide containment heat removal. One heat exchanger will not provide sufficient containment pressure reduction to satisfy 10 CFR 100 site dosage limitations, but will keep the containment significantly below design pressure at all times. The single heat exchanger success criteria was used in this study.

A.4 References

- A-1. A.S. Benjamin, et al., Evaluation of Severe Accident Risks and the Potential for Risk Reductions: Surry Power Station, Unit 1, NUREG/CR-4551 Vol 1, Draft for Comment, February 1987.
- A-2. Peter Cybulskis, SAARP Source Term Analyses for Surry Design, Battelle Columbus Laboratories.
- A-3. Peter Cybulskis, Evaluation of Loss of Containment Heat Sink Scenarios for Surry, Draft, Battelle Columbus Laboratories, November 1985.

APPENDIX B

**Surry Boolean Equations
and
Fault Trees**

Table of Contents

Section	Page
B.1. BOOLEAN EQUATIONS	
B.1.1 Consequence Limiting Control System	B-4
B.1.2 Auxiliary Feedwater System during Station Blackout	B-5
B.1.3 Primary Pressure Relief System	B-6
B.1.4 Power Conversion System: Steam Generator Integrity	B-7
B.1.5 Recirculation Mode Transfer System	B-8
B.1.6 Safety Injection Actuation System	B-8
B.1.7 Reactor Coolant Pump Seal Cooling from Unit 2	B-9
B.1.8 Station Blackout	B-10
B.2. FAULT TREES	B-12
Surry Fault Tree Summary	B-13
Auxiliary Feedwater System	(AFW-L) B-16
Auxiliary Feedwater System - ATWS	(AFW-L2) B-25
Auxiliary Feedwater System - SGTR	(AFW-L3) B-35
Containment Spray System	(CSS) B-43
Charging Pump Cooling System	(CPCA) B-45
Charging Pump Cooling System	CPCB) B-48
Charging Pump Cooling System	(CPCC) B-50
High Pressure Injection - Automatic	(D ₁) B-51
High Pressure Injection - Manual	(D ₂) B-58
High Pressure Injection - RCP Seals	(D ₃) B-65
High Pressure Injection - Emergency Boration	(D ₄) B-67
Accumulators	(D ₅) B-69
Low Pressure Injection	(D ₆) B-72
Electrical Power - Stub Bus 1H	(ESTB1H) B-74
Electrical Power - Stub Bus 1J	(ESTB1J) B-75
Electrical Power - MCC 1H1-1	(EH1) B-76
Electrical Power - MCC 1H1-2	(EH2) B-77
Electrical Power - MCC 1J1-1	(EJ1) B-78
Electrical Power - MCC 1J1-2	(EJ2) B-79
Electrical Power - 480V 1H Bus	(E4801H) B-80
Electrical Power - 480V 1J Bus	(E4801J) B-81
Electrical Power - Vital Bus 1I	E1I B-82
Electrical Power - Vital Bus 1II	E1II B-83
Electrical Power - Vital Bus 1III	E1III B-84
Electrical Power - Vital Bus 1IV	E1IV B-85
Electrical Power - DC Bus 1A	E1A B-86
Electrical Power - DC Bus 1B	E1B B-87
High Pressure Recirculation System	HPR B-88
Low Pressure Recirculation System - to HPR	LPR-HH B-94
Low Pressure Recirculation System - to RCS	LPR-LH B-100
Inside Spray Recirculation System	ISR B-105
Outside Spray Recirculation System	OSR B-111
Operator Depressurization - LOCA	OD B-119
Operator Depressurization - SGTR	OD-SG B-126
Primary Pressure Relief System	P B-132
Primary Pressure Relief System - S ₂	P1 B-133

Table of Contents (Continued)

B.2 FAULT TREES (Cont'd)

Primary Pressure Relief System - ATWS	P2	B-135
Residual Heat Removal	W3	B-137
Component Cooling Water	W	B-142

APPENDIX B

B. Appendix B contains the Boolean equations and fault trees of the systems modeled for the Surry probabilistic risk assessment. The Boolean equations modeling for station blackout are also included. The appendix is organized into two subappendices as follows:

- B.1 Boolean Equations
 - System Event Equations
 - Station Blackout Equations
- B.2 Fault Trees

B.1 Boolean Equations

Boolean equations were used to model actuation systems, relief valves failing to reclose, steam generator integrity, station blackout (SBO) events, and several Unit 2 systems used in the SBO analysis. The system descriptions, nomenclature and identifiers used, assumptions made, and success criteria are contained in Section 4.6, System Analysis.

The following systems, or portions of systems, were modeled by Boolean equations shown and described in this appendix.

- Consequence Limiting Control System
- Auxiliary Feedwater System during Station Blackout
- Primary Pressure Relief System failing to reclose following a Transient
- Power Conversion System: SG Integrity
- Recirculation Mode Transfer System
- Safety Injection Actuation System
- Reactor Coolant Pump Seal Cooling from Unit 2
 - HPI seal cooling from Unit 2
 - CCW thermal barrier cooling from Unit 2

In addition to the systems modeled, two Boolean equations were developed to model the SBO at Unit 1 and SBO at Units 1 and 2. These equations are also included.

B.1.1 Consequence Limiting Control System

As shown in Section 4.6.6, the consequence limiting control system is modeled as two events. The Boolean equations for these two events are as follows:

$$\text{CLS-ACT-FA-2A} = \text{CLS-ACT-FA-CLS2A} + \text{DCP-TDC-LP-BUS1A.}$$

$$\text{CLS-ACT-FA-2B} = \text{CLS-ACT-FA-CLS2B} + \text{DCP-TDC-LP-BUS1B.}$$

The CLS-ACT-FA-CLS2A and CLS-ACT-FA-CLS2B terms represent the CLCS actuation train A and B unavailabilities. The DCP-TDC-LP-BUS1A and DCP-TDC-LP-BUS1B terms represent developed events, providing power to the actuation trains. The power events are developed as fault trees in the Emergency Power System, Section 4.6.8.

B.1.2 Auxiliary Feedwater System during Station Blackout

As shown in Section 4.6.3, the success criteria for the auxiliary feedwater (AFW) system during a transient is that flow from at least one of three AFW pumps supply one of three steam generators (SG). During SBO, the motor driven pumps are unavailable, so that the AFW-L fault tree reduces to the following equations representing failure of the turbine driven AFW pump at Unit 1.

$$\begin{aligned} \text{AFW-TDP-U1} = & \text{AFW-TDP-FR-2P6HR} + \\ & \text{AFW-TDP-FS-FW2} + \\ & \text{AFW-TDP-MA-FW2} + \\ & \text{AFW-CKV-OO-CV172} + \\ & \text{AFW-PSF-FC-XCONN} + \\ & \text{AFW-CCF-FT-102AB} + \\ & \text{AFW-CKV-FT-CV142} + \\ & \text{AFW-CCF-LK-STMBD} + \\ & \text{AFW-XVM-PG-XV153} + \\ & \text{AFW-AOV-FT-102A} * \text{AFW-AOV-FT-102B} + \\ & \text{AFW-TNK-VF-CST} + \\ & \text{AFW-CKV-FT-CV138} * \text{AFW-CKV-FT-CV131} + \\ & \text{AFW-CKV-FT-CV131} * \text{AFW-CKV-FT-CV136} + \\ & \text{AFW-CKV-FT-CV133} * \text{AFW-CKV-FT-CV136} + \\ & \text{AFW-CKV-FT-CV138} * \text{AFW-CKV-FT-CV133} + \\ & \text{AFW-AOV-PG-102A} * \text{AFW-AOV-PG-102B}. \end{aligned}$$

From the equation for failure of the turbine driven AFW pump at Unit 1, a similar equation was developed to model the turbine driven AFW pump at Unit 2. The motor driven pumps were not modeled at Unit 2. For the SBO at Unit 1 only, the loss of one bus (due to the loss of offsite power and failure of diesel 2 or 3) leaves only one motor driven pump which was assumed to have insufficient capacity to supply two units. For SBO at both units, there is no power to supply a motor driven pump at Unit 2.

$$\begin{aligned} \text{AFW-TDP-U2} = & \text{AFW-TDP-FR-6HRU2} + \\ & \text{AFW-TDP-FS-U2FW2} + \\ & \text{AFW-TDP-MA-U2FW2} + \\ & \text{AFW-CKV-OO-CV272} + \\ & \text{AFW-CCF-LK-2STMB} + \\ & \text{AFW-CCF-FT-202AB} + \\ & \text{AFW-CKV-FT-CV242} + \\ & \text{AFW-XVM-PG-XV253} + \\ & \text{AFW-MOV-FT-260A} * \text{AFW-MOV-FT-260B} + \\ & \text{AFW-AOV-FT-202A} * \text{AFW-AOV-FT-202B} + \\ & \text{AFW-TNK-VF-V2CST} + \\ & \text{AFW-CKV-FT-CV238} * \text{AFW-CKV-FT-CV232} + \\ & \text{AFW-CKV-FT-CV232} * \text{AFW-CKV-FT-CV236} + \\ & \text{AFW-CKV-FT-CV233} * \text{AFW-CKV-FT-CV236} + \\ & \text{AFW-CKV-FT-CV238} * \text{AFW-CKV-FT-CV233} + \\ & \text{AFW-AOV-PG-202A} * \text{AFW-AOV-PG-202B}. \end{aligned}$$

The top event heading L in the SBO event tree combines failures of the Unit 1 and 2 turbine driven pumps with an operator error. The top events for SBO at Unit 1 only and SBO at Units 1 and 2, are an expansion of the equations shown below.

$$L-SBOU1 = AFW-TDP-U1 * (AFW-XHE-FO-U1SBO + AFW-TDP-U2).$$

$$L-SBOU1U2 = AFW-TDP-U1 * (AFW-XHE-FO-U2SBO + AFW-TDP-U2 + UNIT2-LOW-POWER + QS-UNIT2).$$

The equation for SBO at Unit 1 and 2 also includes terms for failure of AFW from Unit 2 due to low initial power (no steam for the pump turbine) and a stuck open SG power operated relief valve at Unit 2 due to the SBO transient. Additionally, for SBO sequences with a stuck open SG relief valve, a cross connect to the Unit 2 condensate storage tank was required. These "extra" failures occur because if only Unit 1 has an SBO, the Unit 2 AFW motor driven pumps are still available.

B.1.3 Primary Pressure Relief System

The portion of the Primary Pressure Relief System (PPRS) modeled by Boolean equations is the failure of the reactor coolant system (RCS) power operated relief valves (PORV) to reclose following a transient demanding PORV opening. Section 4.6.14 describes the success criteria for event Q as one or more PORVs failing to reclose following a transient other than S₃. Event Q during an S₃ loss of coolant accident is modeled as a "black box" event in Appendix D.1. Event Q was modeled slightly differently for SBO (Q-SBO), steam generator tube rupture (Q-SGTR), and all other transients (Q). The expression for the failure of the RCS PORVs to reclose for generic transients, other than SBO or SGTR follows.

$$Q = PORV-DEMAND * PPS-SOV-OO-1455 * (ACP-TAC-LP-1J1-2 + PPS-MOV-OO-1536 + PPS-MOV-FC-OPER) +$$

$$PORV-DEMAND * PPS-SOV-OO-1456 * (ACP-TAC-LP-1H1-2 + PPS-MOV-OO-1535 + PPS-MOV-FC-OPER).$$

Each of the cut sets represent the PORV being demanded, PORV failing to reclose, and failure to shut the PORV block valve. Failure to shut the PORV block valve is due to loss of electrical power, failure of the motor operated block valve to shut, or failure of the operator to shut the block valve. The electrical power events (ACP-TAC-LP-1H1-2 and ACP-TAC-LP-1J1-2) are top events of fault trees developed in the Emergency Power System, Section 4.6.8. The PORV-DEMAND event consists of three terms multiplied together: the probability of initially being at high power (0.90), the probability that each relief is not blocked $\frac{1 - (.3)^2}{2}$, and the PORV demand probability. The PORV demand

probability is 0.1 for T₁ and 0.014 for all other sequences except SGTR and SBO. The PORV demand probability for SGTR and SBO are described below.

The expression for failure of the RCS PORVs to reclose during SBO is a reduction of the generic Q equation, with the loss of AC power failing the block valves, and the PORV demand rate equal to 1.0.

$$Q-SBO = SBO-PORV-DMD * PPS-SOV-OO-14556 + SBO-PORV-DMD * PPS-SOV-OO-1456.$$

For the steam generator tube rupture event tree, there are three different versions of the Q-SGTR. Each variation depends on the success or failure of the operator

depressurization and high pressure injection (HPI) events. Each version is identical to the generic Q expression, with a different identifier specifying the PORV demand rate. For successful operator depressurization and HPI, the PORV demand rate is 0.1 and the identifier is RCS-PORV-DMD. For successful operator depressurization and failure of HPI, the PORV demand rate is 0.25 and the identifier is RCS-PORV-ODMD. For failure to depressurize, the demand rate is 1.0 and the identifier is RCS-PORV-D1DMD. The resulting Boolean equations are shown below.

For success of operator depressurization and HPI:

$$\begin{aligned}
 \text{Q-SGTR} = & \\
 & \text{RCS-PORV-DMD} * \text{PPS-SOV-OO-1455C} * \\
 & \quad (\text{ACP-TAC-LP-1J1-2} + \text{PPS-MOV-OO-1536} + \text{PPS-} \\
 & \quad \text{MOV-FC-OPER}) + \\
 & \text{RCS-PORV-DMD} * \text{PPS-SOV-OO-1456} * \\
 & \quad (\text{ACP-TAC-LP-1H1-2} + \text{PPS-MOV-OO-1535} + \text{PPS-} \\
 & \quad \text{MOV-FC-OPER}).
 \end{aligned}$$

For successful depressurization, but HPI fails:

$$\begin{aligned}
 \text{Q-OD-SGTR} = & \\
 & \text{RCS-PORV-ODMD} * \text{PPS-SOV-OO-1455C} * \\
 & \quad (\text{ACP-TAC-LP-1J1-2} + \text{PPS-MOV-OO-1536} + \text{PPS-} \\
 & \quad \text{MOV-FC-OPER}) + \\
 & \text{RCS-PORV-ODMD} * \text{PPS-SOV-OO-1456} * \\
 & \quad (\text{ACP-TAC-LP-1H1-2} + \text{PPS-MOV-OO-1535} + \text{PPS-} \\
 & \quad \text{MOV-FC-OPER}).
 \end{aligned}$$

For failure to depressurize:

$$\begin{aligned}
 \text{Q-OD-D1-SGTR} = & \\
 & \text{RCS-PORV-D1DMD} * \text{PPS-SOV-OO-1455C} * \\
 & \quad (\text{ACP-TAC-LP-1J1-2} + \text{PPS-MOV-OO-1536} + \text{PPS-} \\
 & \quad \text{MOV-FC-OPER}) + \\
 & \text{RCS-PORV-D1DMD} * \text{PPS-SOV-OO-1456} * \\
 & \quad (\text{ACP-TAC-LP-1H1-2} + \text{PPS-MOV-OO-1535} + \text{PPS-} \\
 & \quad \text{MOV-FC-OPER}).
 \end{aligned}$$

B.1.4 Power Conversion System: Steam Generator Integrity

The success criterion for the SG portion of the power conversion system (PCS) was defined as closure of all SG penetrations following a transient. The PCS system assumptions and success criteria are further described in Section 4.6.13. This success criterion translates into three separate Boolean equations, one equation for SBO and two equations for SGTR. The Boolean equation derived for SBO follows:

$$\text{QS} - \text{SBO} = \text{SBO-SGSRV-DMD} * \text{MSS-SRV-OO-SGSRV}.$$

The probability for SBO-SGSRV-DMD is derived in Appendix D. For steam generator tube rupture, there are two equations, depending on the success of the operator depressurization event. If the operator succeeds in depressurization and cooldown, then the equation for Q_S is as follows:

$$\text{SIS-ACT-FA-B} = \text{SIS-ACT-FA-SISB} + \text{ACP-TAC-LP-BS1IV} + \text{DCP-TDC-LP-BUS1B}.$$

The SIS-ACT-FA-SISA and SIS-ACT-FA-SISB terms represent the SIS actuation train A or B unavailabilities. The other terms model electrical power dependencies. The electrical power events are described in Section 4.6.8 and are developed as top events in fault trees.

B.1.7 Reactor Coolant Pump Seal Cooling from Unit 2

Modeling of the reactor coolant pump (RCP) seal cooling supplied by Unit 2 (event W_2) involved modeling two Unit 2 systems, HPI and component cooling water (CCW). The Unit 2 HPI cools the RCP seals directly, whereas the CCW cools the RCP thermal barrier. The success criterion for top event W_2 was Unit 1 RCP seal cooling provided from Unit 2 HPI or CCW. This translated into the following top event and Boolean equation.

W_2 - Failure of the operator to provide seal cooling from Unit 2 or failure of Unit 2 HPI and Unit 2 CCW.

$$W_2 = \text{REC-XHE-FO-SCOOL} + (\text{D3U2} * \text{WU2}).$$

D3U2 represents failure of HPI from Unit 2 and is modeled by the following equation.

$$\begin{aligned} \text{D3U2} = & \text{MCW-CCF-VF-SBO} + \\ & \text{CPC-MDP-FS-SW20A} + \\ & \text{HPI-MDP-FS-CH2C} + \\ & \text{CPC-MDP-FS-2CC2A} + \\ & \text{HPI-CKV-OO-267U2} + \\ & \text{HPI-CKV-OO-276U2} + \\ & \text{CPC-MDP-FR-SW20A} + \\ & \text{HPI-MDP-FR-2C6HR} + \\ & \text{CPC-STR-PG-2AU26} + \\ & \text{CPC-STR-PG-1AU26} + \\ & \text{CPC-MDP-FR-2CC2A} + \\ & \text{ACP-BAC-ST-4KV2H} + \\ & \text{ACP-BAC-ST-2H1} + \\ & \text{ACP-BAC-ST-2H1-1} + \\ & \text{ACP-TFM-NO-2H1} + \\ & \text{ACP-CRB-CO-24H14} + \\ & \text{ACP-CRB-CO-25H7} + \\ & \text{ACP-CRB-CO-24H15}. \end{aligned}$$

The equation for D3U2 was derived from the solution of the Unit 1 D_3 fault tree. Similarly, the equation for CCW from Unit 2 (WU2) was based on the Unit 1 W fault tree. The equation for CCW from Unit 2 is shown below.

$$\begin{aligned} \text{WU2} = & \text{MCW-CCF-VF-SBO} + \\ & \text{ACP-XHE-FO-STBBS} + \\ & \text{CCW-MDP-FS-CCP2A} + \\ & \text{CCW-MDP-MA-CCP2A} + \\ & \text{CCW-CKV-OO-563U2} + \\ & \text{CCW-MDP-FR-CCP2A} + \end{aligned}$$

CCW-HTX-PG-U2E1A +
 ACP-BAC-ST-4KV2H +
 ACP-BAC-ST-STB2H +
 CCW-HTX-LK-U2E1A +
 SWS-XVM-PG-39U2 +
 CCW-XVM-PG-580U2
 IAS-AOV-PG-CC107 +
 CCW-XVM-PG-583U2 +
 SWS-XVM-PG-37U2 +
 ACP-CRB-CO-25H9 +
 IAS-AOV-LK-CC107 +
 IAS-AOV-OC-CC107.

B.1.8 Station Blackout

The methods used to develop the equations for SBO at Unit 1 and SBO at Units 1 and 2 are described in Section 4.6.8. The expanded version of the equation for SBO at Unit 1 only, with double maintenance terms which violate Technical Specifications deleted, is shown below. Note that a term NOTDG appears in each cut set for SBO-U1, accounting for the success of the third diesel generator.

SBO-U1 =

T1 * OEP-DGN-FS-DG02 * OEP-DGN-FS-DG01 * NOTDG +
 T1 * OEP-DGN-FS-DG03 * OEP-DGN-FS-DG01 * NOTDG +
 T1 * OEP-CCF-FS-DG13 * NOTDG-CCF +
 T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FS-DG01 * NOTDG +
 T1 * OEP-DGN-FR-6HDG3 * OEP-DGN-FS-DG01 * NOTDG +
 T1 * OEP-DGN-FS-DG02 * OEP-DGN-FR-6HDG1 * NOTDG +
 T1 * OEP-DGN-FS-DG03 * OEP-DGN-FR-6HDG1 * NOTDG +
 T1 * OEP-DGN-FR-6HDG3 * OEP-DGN-FR-6HDG1 * NOTDG +
 T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FR-6HDG1 * NOTDG +
 T1 * OEP-DGN-MA-DG03 * OEP-DGN-FS-DG01 * NOTDG +
 T1 * OEP-DGN-MA-DG01 * OEP-DGN-FS-DG03 * NOTDG +
 T1 * OEP-DGN-MA-DG02 * OEP-DGN-FS-DG01 * NOTDG +
 T1 * OEP-DGN-MA-DG01 * OEP-DGN-FS-DG02 * NOTDG +
 T1 * OEP-DGN-MA-DG02 * OEP-DGN-FR-6HDG1 * NOTDG +
 T1 * OEP-DGN-MA-DG01 * OEP-DGN-FR-6HDG2 * NOTDG +
 T1 * OEP-DGN-MA-DG03 * OEP-DGN-FR-6HDG1 * NOTDG +
 T1 * OEP-DGN-MA-DG01 * OEP-DGN-FR-6HDG3 * NOTDG +
 T1 * OEP-CRB-FT-15J3 * OEP-DGN-FS-DG01 * NOTDG +
 T1 * OEP-DGN-FS-DG02 * OEP-CRB-FT-15H3 * NOTDG +
 T1 * OEP-DGN-FS-DG03 * OEP-CRB-FT-15H3 * NOTDG +
 T1 * OEP-DGN-FR-6HDG2 * OEP-CRB-FT-15H3 * NOTDG +
 T1 * OEP-DGN-FR-6HDG3 * OEP-CRB-FT-15H3 * NOTDG +
 T1 * OEP-CRB-FT-15J3 * OEP-DGN-FR-6HDG1 * NOTDG +
 T1 * OEP-DGN-MA-DG01 * OEP-CRB-FT-15J3 * NOTDG +
 T1 * OEP-DGN-MA-DG03 * OEP-CRB-FT-15H3 * NOTDG +
 T1 * OEP-DGN-MA-DG02 * OEP-CRB-FT-15H3 * NOTDG +
 T1 * OEP-CRB-FT-15J3 * OEP-CRB-FT-15H3 * NOTDG.

The sum of the terms, or frequency of SBO-U1 is $2.9E-4$.

The expanded version of the equation for SBO at Units 1 and 2, with double maintenance terms which violate Technical Specifications deleted, is shown below. In the SBO-U1U2

equation, all three site diesel generators are explicitly modeled to fail. The sum of the terms, or frequency of SBO-U1U3 is $3.7E-5$.

SBO-U1U2 =

T1 * OEP-CCF-FS-DG123 +
T1 * OEP-DGN-FS-DG02 * OEP-DGN-FS-DG03 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FS-DG03 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-FS-DG02 * OEP-DGN-FS-DG03 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-FS-DG02 * OEP-DGN-FR-6HDG3 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FS-DG03 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-FS-DG02 * OEP-DGN-FR-6HDG3 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FR-6HDG3 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-MA-DG03 * OEP-DGN-FS-DG02 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-MA-DG02 * OEP-DGN-FS-DG03 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FS-DG02 * OEP-DGN-FS-DG03 +
T1 * OEP-DGN-MA-DG03 * NOTDG-CCF * OEP-CCF-FS-DG12 +
T1 * OEP-DGN-MA-DG01 * NOTDG-CCF * OEP-CCF-FS-DG23 +
T1 * OEP-DGN-MA-DG02 * OEP-CCF-FS-DG13 * NOTDG-CCF +
T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FR-6HDG3 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-MA-DG02 * OEP-DGN-FS-DG03 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-MA-DG03 * OEP-DGN-FR-6HDG2 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-MA-DG02 * OEP-DGN-FR-6HDG3 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FR-6HDG2 * OEP-DGN-FS-DG03 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FS-DG02 * OEP-DGN-FR-6HDG3 +
T1 * OEP-DGN-MA-DG03 * OEP-DGN-FS-DG02 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-FS-DG02 * OEP-CRB-FT-15J3 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-FS-DG02 * OEP-DGN-FS-DG03 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-FS-DG03 * OEP-DGN-FS-DG01 * OEP-CRB-FT-25H3 +
T1 * NOTDG-CCF * OEP-CCF-FS-DG12 * OEP-DGN-FR-DG03 +
T1 * OEP-CCF-FS-DG13 * NOTDG-CCF * OEP-DGN-FR-DG02 +
T1 * NOTDG-CCF * OEP-CCF-FS-DG23 * OEP-DGN-FR-DG01 +
T1 * OEP-DGN-MA-DG02 * OEP-DGN-FR-6HDG3 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FR-6HDG2 * OEP-DGN-FR-6HDG3 +
T1 * OEP-DGN-MA-DG03 * OEP-DGN-FR-6HDG2 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-FR-6HDG3 * OEP-DGN-FS-DG01 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-FS-DG02 * OEP-CRB-FT-15J3 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FS-DG03 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-FS-DG03 * OEP-DGN-FR-6HDG1 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-FR-6HDG2 * OEP-CRB-FT-15J3 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-FS-DG02 * OEP-DGN-FR-6HDG3 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-FR-6HDG3 * OEP-DGN-FR-6HDG1 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-FR-6HDG2 * OEP-CRB-FT-15J3 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-FR-6HDG2 * OEP-DGN-FR-6HDG3 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-MA-DG02 * OEP-CRB-FT-15J3 * OEP-DGN-FS-DG01 +
T1 * OEP-DGN-MA-DG03 * OEP-DGN-FS-DG02 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FS-DG02 * OEP-CRB-FT-15J3 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FS-DG03 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-MA-DG02 * OEP-DGN-FS-DG03 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-MA-DG03 * OEP-DGN-FS-DG01 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FR-6HDG2 * OEP-CRB-FT-15J3 +
T1 * OEP-DGN-MA-DG01 * OEP-DGN-FR-6HDG3 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-MA-DG02 * OEP-DGN-FR-6HDG3 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-MA-DG02 * OEP-CRB-FT-15J3 * OEP-DGN-FR-6HDG1 +
T1 * OEP-DGN-MA-DG03 * OEP-DGN-FR-6HDG2 * OEP-CRB-FT-15H3 +

T1 * OEP-DGN-MA-DG03 * OEP-DGN-FR-6HDG1 * OEP-CRB-FT-25H3 +
T1 * OEP-CRB-FT-15J3 * OEP-DGN-FS-DG01 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-FS-DG03 * OEP-CRB-FT-15H3 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-FS-DG02 * OEP-CRB-FT-15J3 * OEP-CRB-FT-15H3 +
T1 * OEP-CRB-FT-15J3 * OEP-DGN-FR-6HDG1 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-FR-6HDG2 * OEP-CRB-FT-15J3 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-FR-6HDG3 * OEP-CRB-FT-15H3 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-MA-DG03 * OEP-CRB-FT-15H3 * OEP-CRB-FT-25H3 +
T1 * OEP-DGN-MA-DG02 * OEP-CRB-FT-15J3 * OEP-CRB-FT-15H3 +
T1 * OEP-DGN-MA-DG01 * OEP-CRB-FT-15J3 * OEP-CRB-FT-25H3 +.

B.2 Fault Trees

This section contains the drawings of all of the fault trees used in the Surry probabilistic risk assessment. The fault tree name, system modeled, and top event heading are shown in Table B-1.

Table B-1
Surry Fault Tree Summary

<u>Fault Tree Name</u>	<u>System</u>	<u>Event Tree Heading</u>	<u>Top Gate Name</u>
AFW-L	Auxiliary Feedwater to 1 of 3 SG	L	AFW-1
AFW-L2	Auxiliary Feedwater to 2 of 3 SG	L ₂	AFW-2
AFW-L3	Auxiliary Feedwater to 1 of 2 SG	L ₃	AFW-3
CSS	Containment Spray System	C	CSS
CPCA	Charging Pump Cooling	None, support system to HPI pumps A,B, & C	CPCA
CPCB	Charging Pump Cooling		CPCB
CPCC	Charging Pump Cooling		CPCC
D ₁	High Pressure Injection - Automatic	D ₁	D ₁
D ₂	High Pressure Injection - Manual	D ₂	D ₂
D ₃	High Pressure Injection - RCP seals	D ₃	D ₃
D ₄	High Pressure Injection - Emergency Boration	D ₄	HPI-EB
D ₅	Accumulators	D ₅	ACC
D ₆	Low Pressure Injection	D ₆	LPI

B-13

Table B-1 (Continued)
Surry Fault Tree Summary

<u>Fault Tree Name</u>	<u>System</u>	<u>Event Tree Heading</u>	<u>Top Gate Name</u>
ESTB1H	Electrical Power - Stub Bus 1H	None, support systems to front line systems.	ACP-TAC-LP-STB1H
ESTB1J	Electrical Power - Stub Bus 1J		ACP-TAC-LP-STB1J
EH1*	Electrical Power - MCC 1H1-1		ACP-TAC-LP-1H1-1
EH2	Electrical Power - MCC 1H1-2		ACP-TAC-LP-1H1-2
EJ1*	Electrical Power - MCC 1J1-1		ACP-TAC-LP-1J1-1
EJ2	Electrical Power - MCC 1J1-2		ACP-TAC-LP-1J1-2
E4801H	Electrical Power - 4801H Bus		ACP-TAC-LP-4801H
E4801J	Electrical Power - 4801J Bus		ACP-TAC-LP-4801J
E1I	Electrical Power - Vital Bus 1I		ACP-TAC-LP-BUS1I
E21II	Electrical Power - Vital Bus 1II		ACP-TAC-LP-BS1II
E31III	Electrical Power - Vital Bus 1III		ACP-TAC-LP-BS1III
E41IV	Electrical Power - Vital Bus 1IV		ACP-TAC-LP-BS1IV
E1A	Electrical Power - DC Bus 1A		DCP-TDC-LP-BUS1A
E1B	Electrical Power - DC Bus 1B		DCP-TDC-LP-BUS1B
HPR-H2	High Pressure Recirculation	H ₂	HPR
LPR-HH	Low Pressure Recirculation - to HPR	H ₁ (S ₂ ,S ₃ ,T)	LPR-HH
LPR-LH	Low Pressure Recirculation - to RCS	H ₁ (A,S ₁)	LPR-LH


B-14

Table B-1 (Continued)
Surry Fault Tree Summary

<u>Fault Tree Name</u>	<u>System</u>	<u>Event Tree Heading</u>	<u>Top Gate Name</u>
ISR	Inside Spray Recirculation	F ₁	ISR-F1
OSR	Outside Spray Recirculation	F ₂	OSR
OD	Power Conversion System	O _D	OD
OD-SG	Power Conversion System	O _D (T ₇)	OD-SG
P	Primary Pressure Relief - 2 of 2	P	P
P ₁	Primary Pressure Relief - 1 of 2	P ₁	P1
P ₂	Primary Pressure Relief - ATWS	P ₂	P2
RHR	Residual Heat Removal	W ₃	W3
W	Component Cooling Water	W	CCW1

B-15

* The 4160 VAC 1H and 1J bus events (ACP-TAC-LP-4KV1H and ACP-TAC-LP-4KV1J) are contained in the EH1 and EJ1 fault trees, respectively.



B-16

INSUF FLOW
 THRU PIPE SEG
 PS80,PS81, & PS82
 AFW15

Transfers from Page(s) 1 7

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS82
 AFW16

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS80
 AFW18

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS81
 AFW17

Page 5

Page 4

FAULTS IN PIPE
 SEGMENT PS82 PTRN
 3B
 AFW23

FAILURE OF 4KV AC
 BUS 1J
 ACP-TAC-LP-4KV1J

FAILURE OF 120V
 DC BUS 1B
 DCP-TDC-LP-BUS1B

NO ACTUATION
 SIGNAL TO AFW
 PUMP 3B
 AFW-ACT-FA-PMP3B

INSUF WATER
 AVAILABLE FROM
 110,000 GALLON
 CST
 AFW-TNK-VF-CST

UNDETECT LKAGE
 THRU CHK VLV
 CV27,CV58,OR CV89
 AFW-CCF-LK-STMBD

6.0E-004

1.0E-006

1.0E-004

INSUFFICIENT
 FLOW THRU PUMP
 DUE TO BACKFLOW
 AFW27

CHECK VALVE CV172
 FAILS TO OPEN
 AFW-CKV-FT-CV172

MANUAL VALVE
 XV183 PLUGGED
 AFW-XVM-PG-XV183

MDP AFW 3B FAILS
 TO START
 AFW-MDP-FS-FW3B

COMMON CAUSE
 FAILURE OF AFW
 MOTOR DRIVEN PUMP
 AFW-CCF-FS-FW3AB

MDP AFW 3B FAILS
 TO RUN 6 HOURS
 AFW-MDP-FR-3B6HR

TEST AND
 MAINTENANCE ON
 AFW MDP 3B
 AFW-MDP-MA-FW3B

1.0E-004

4.0E-005

6.3E-003

3.5E-004

1.8E-004

2.0E-003

BACKFLOW
 THROUGH MDP FW3A
 AFW29

BACKFLOW
 THROUGH TDP FW2
 AFW31

Page 2

Page 3

BACKFLOW
 THROUGH MDP FW3A
 AFW29

Transfers from Page(s) 2 5


MDP AFW 3A FAILS
 TO START
 AFW-MDP-FS-FW3A

BACKFLOW THROUGH
 CV157
 AFW-CKV-00-CV157

6.3E-003

1.0E-003

B-17



INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PSB1
 AFW17

Transfer from Page 2

FAULTS IN PIPE
 SEGMENT PSB1 PTRN
 3A
 AFW24

FAILURE OF 4KV AC
 BUS 1H
 ACP-TAC-LP-4KV1H

FAILURE OF 120V
 DC BUS 1A
 DCP-TDC-LP-BUS1A

NO ACTUATION
 SIGNAL TO AFW
 PUMP 3A
 AFW-ACT-FA-PMP3A
 6.0E-004

INSUF WATER
 AVAILABLE FROM
 110,000 GALLON
 CST
 AFW-TNK-VF-CST
 1.0E-006

UNDETECT LKAGE
 THRU CHK VLV
 CV27, CV58, OR CV89
 AFW-CCF-LK-STMBD
 1.0E-004

INSUFFICIENT
 FLOW THRU PUMP
 DUE TO BACKFLOW
 AFW26

CHECK VALVE CV157
 FAILS TO OPEN
 AFW-CKV-FT-CV157
 1.0E-004

MANUAL VALVE
 XV168 PLUGGED
 AFW-XVM-PG-XV168
 4.0E-005

MDP AFW 3A FAILS
 TO START
 AFW-MDP-FS-FW3A
 6.3E-003

COMMON CAUSE
 FAILURE OF AFW
 MOTOR DRIVEN PUMP
 AFW-CCF-FS-FW3AB
 3.5E-004

MDP AFW 3A FAILS
 TO RUN 6 HOURS
 AFW-MDP-FR-3A6HR
 1.8E-004

TEST AND
 MAINTENANCE ON
 AFW MDP 3A
 AFW-MDP-MA-FW3A
 2.0E-003

BACKFLOW
 THROUGH MDP FW3B
 AFW30
 Page 4

BACKFLOW
 THROUGH TDP FW2
 AFW31
 Page 3


BACKFLOW
 THROUGH MDP FW3B
 AFW30

Transfers from Page(s) 4 5

MDP AFW 3B FAILS
 TO START
 AFW-MDP-FS-FW3B
 6.3E-003

BACKFLOW THROUGH
 CV172
 AFW-CKV-OO-CV172
 1.0E-003

B-19



B-20

INSUF STEAM
 FLOW TO TDPFW2
 THRU PIPE SEG
 PS99
 AFW21

Transfer from Page 5

INSUF STM FLOW
 THRU PIPE SEG
 PS95, PS96, PS97
 AFW22

△ Page 5

NO ACTUATION
 SIGNAL TO
 AOV-MS102B
 AFW-ACT-FA-VLVB

◇ 6.0E-004

AIR OPERATED
 VALVE MS102B
 FAILS TO OPEN
 AFW-AOV-FT-102B

○ 1.0E-003

AIR OPERATED
 VALVE MS102B
 PLUGGED
 AFW-AOV-PG-102B

○ 4.0E-005

COMMON CAUSE
 FAILURE OF MS102A
 AND B TO OPEN
 AFW-CCF-FT-102AB

○ 1.0E-004

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS84
AFW14

Transfers from Page(s) 1 8

CHECK VALVE CV133
FAILS TO OPEN

AFW-CKV-FT-CV133

○ 1.0E-004

FLOW DIVERSION TO
UNIT 2 THRU PIPE
SEG PS94

AFW-PSF-FC-XCONN

◇ 1.5E-004

CHECK VALVE CV131
FAILS TO OPEN

AFW-CKV-FT-CV131

○ 1.0E-004

INSUF FLOW
THRU PIPE SEG
PS80, PS81, & PS82

AFW15

△ Page 2

Tree: AFW-L
Project: SURRY
Page 7 of 9
Date Last Modified:
Wed Jul 06 13:11:54 1988

INSUF FLOW
THRU PIPE SEG
PS87 & PS88
AFW5

Transfer from Page 1

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS87
AFW9

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS88
AFW10

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS83
AFW13

MOTOR OPERATED
VALVE FW151C
PLUGGED
AFW-MOV-PG-151C

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS84
AFW14

MOTOR OPERATED
VALVE FW151D
PLUGGED
AFW-MOV-PG-151D

△ Page 1

○ 4.0E-005

△ Page 7

○ 4.0E-005

Tree: AFW-L
Project: SURRY
Page 8 of 9
Date Last Modified:
Wed Jul 06 13:11:54 1988

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS85

AFW11

Transfer from Page 1

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS83

AFW13


Page 1

MOTOR OPERATED
VALVE FW151A
PLUGGED


AFW-MOV-PG-151A

4.0E-005

Tree: AFW-L
Project: SURRY
Page 9 of 9
Date Last Modified:
Wed Jul 06 13:11:54 1988





B-25



Tree: AFW-L2
 Project: SURRY
 Page 2 of 10
 Date Last Modified:
 Wed Jul 06 13:11:56 1988


B-26





B-27

Tree: AFW-L2
 Project: SURRY
 Page 4 of 10
 Date Last Modified:
 Wed Jul 06 13:11:56 1988



B-28

BACKFLOW
THROUGH MDP FW3A

AFW31

Transfers from Page(s) 3 2

MDP AFW 3A FAILS
TO START

AFW-MDP-FS-FW3A

○ 6.3E-003

BACKFLOW THROUGH
CV157

AFW-CKV-OO-CV157

○ 1.0E-003

Tree: AFW-L2
Project: SURRY
Page 5 of 10
Date Last Modified:
Wed Jul 06 13:11:56 1988

INSUF STMFLOW
THRU PIPE SEG
PS95, PS96, &
PS97
AFW22

Transfers from Page(s) 2 7

INSUF STEAM
FLOW THRU PIPE
SEG PS95
AFW33

INSUF STEAM
FLOW THRU PIPE
SEG PS96
AFW34

INSUF S FLOW
THRU PIPE SEG
PS97
AFW35

CHECK VALVE CV182
FAILS TO OPEN
AFW-CKV-FT-CV182

MANUAL VALVE XV87
PLUGGED
AFW-XVM-PG-XV87

CHECK VALVE CV178
FAILS TO OPEN
AFW-CKV-FT-CV178

MANUAL VALVE
XV120 PLUGGED
AFW-XVM-PG-XV120

CHECK VALVE CV176
FAILS TO OPEN
AFW-CKV-FT-CV176

MANUAL VALVE
XV158 PLUGGED
AFW-XVM-PG-XV158

○ 1.0E-004

○ 4.0E-005

○ 1.0E-004

○ 4.0E-005

○ 1.0E-004

○ 4.0E-005

Tree: AFW-L2
Project: SURRY
Page 6 of 10
Date Last Modified:
Wed Jul 06 13:11:56 1988

INSUF STEAM
FLOW TO TDPFW2
THRU PIPE SEG
PS99

AFW21

Transfer from Page 2

INSUF STMFLOW
THRU PIPE SEG
PS95, PS96, &
PS97

AFW22

Page 6

NO ACTUATION
SIGNAL TO
AOV-MS102B

AFW-ACT-FA-VLVB

6.0E-004

AIR OPERATED
VALVE MS102B
FAILS TO OPEN

AFW-AOV-FT-102B

1.0E-003

AIR OPERATED
VALVE MS102B
PLUGGED

AFW-AOV-PG-102B

4.0E-005

COMMON CAUSE
FAILURE OF MS102A
AND B TO OPEN

AFW-CCF-FT-102AB

1.0E-004

Tree: AFW-L2
Project: SURRY
Page 7 of 10
Date Last Modified:
Wed Jul 06 13:11:56 1988

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS84

AFW14

Transfers from Page(s) 1 9 10

CHECK VALVE CV131
FAILS TO OPEN

AFW-CKV-FT-CV131

○ 1.0E-004

FLOW DIVERSION TO
UNIT 2 THRU PIPE
SEG PS94

AFW-PSF-FC-XCONN

◇ 1.5E-004

CHECK VALVE CV133
FAILS TO OPEN

AFW-CKV-FT-CV133


○ 1.0E-004

INSUF FLOW
THRU PIPE SEG
PS80 & PS81 OR
PS82

AFW15

△ Page 2

Tree: AFW-L2
Project: SURRY
Page 8 of 10
Date Last Modified:
Wed Jul 06 13:11:56 1988



B-33

INSUF FLOW
THRU PIPE SEGMENT
PS91 TO SG C
AFW3

Transfers from Page(s) 1

INSUF FLOW
THRU PIPE SEGMENT
PS85 AND PS86
AFW6

CHECK VALVE CV89
FAILS TO OPEN
AFW-CKV-FT-CV89
1.0E-004

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS85
AFW11

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS86
AFW12

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS83
AFW13

MOTOR OPERATED
VALVE FW151A
PLUGGED
AFW-MOV-PG-151A
4.0E-005

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS84
AFW14


MOTOR OPERATED
VALVE FW151B
PLUGGED
AFW-MOV-PG-151B
4.0E-005

Page 2


Page 8

Tree: AFW-L2
Project: SURRY
Page 10 of 10
Date Last Modified:
Wed Jul 06 13:11:56 1988

B-34



B-35



B-36

BACKFLOW
THROUGH TDP FW2
AFW31


Transfers from Page(s) 2 4

TURBINE DRIVEN
AFW PUMP FAILS TO
START
AFW-TDP-FS-FW2
1.1E-002

BACKFLOW THROUGH
CV142
AFW-CKV-OO-CV142
1.0E-003

Tree: AFW-L3
Project: SURRY
Page 3 of 8
Date Last Modified:
Wed Jul 06 13:11:56 1988

B-37



B-38

Transfer from Page 2

Page 4

Page 3

Transfers from Page(s) 4 5

INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS80

AFW18

Transfer from Page 2

FAULTS IN PIPE SEGMENT PS80 TDP TRAIN

AFW25

INSUF WATER AVAILABLE FROM 110,000 GALLON CST

AFW-TNK-VF-CST

1.0E-006

UNDETECT LKAGE THRU CHK VLV CV27, CV58, OR CV89

AFW-CCF-LK-STMBD

1.0E-004

INSUF STM FLOW TO TDPFW2 THRU P SEG PS98, PS99

AFW19

INSUFFICIENT FLOW THRU PUMP DUE TO BACKFLOW

AFW28

CHECK VALVE CV142 FAILS TO OPEN

AFW-CKV-FT-CV142

1.0E-004

MANUAL VALVE XV153 PLUGGED

AFW-XVM-PG-XV153

4.0E-005

TURBINE DRIVEN AFW PUMP FAILS TO START

AFW-TDP-FS-FW2

1.1E-002

TEST AND MAINTENANCE ON AFW TDP 2

AFW-TDP-MA-FW2

1.0E-002

TURBINE DRIVEN PUMP FAILS TO RUN FOR 6 HOURS

AFW-TDP-FR-2P6HR

3.0E-002

INSUF STEAM FLOW TO TDPFW2 THRU PIPE SEG PS98

AFW20

INSUF STEAM FLOW TO TDPFW2 THRU PIPE SEG PS99

AFW21

Page 6

BACKFLOW THROUGH MDP FW3A

AFW29

Page 2

BACKFLOW THROUGH MDP FW3B

AFW30

Page 4

AIR OPERATED VALVE MS102A FAILS TO OPEN

AFW-AOV-FT-102A

1.0E-003

NO ACTUATION SIGNAL TO AOV-MS102A

AFW-ACT-FA-VLVA

6.0E-004

AIR OPERATED VALVE MS102A PLUGGED

AFW-AOV-PG-102A

4.0E-005

COMMON CAUSE FAILURE OF MS102A AND B TO OPEN

AFW-CCF-FT-102AB

1.0E-004

INSUF STM FLOW THRU PIPE SEG PS95, PS96, PS97

AFW22

Page 5

INSUF STM FLOW THRU PIPE SEG PS95, PS96, PS97

AFW22

Transfers from Page(s) 5 6

INSUF STM FLOW THRU PIPE SEG PS95

AFW32

INSUF STM FLOW THRU PIPE SEG PS96

AFW33

INSUF STM FLOW THRU PIPE SEG PS97

AFW34

CHECK VALVE CV182 FAILS TO OPEN

AFW-CKV-FT-CV182

1.0E-004

MANUAL VALVE XV87 PLUGGED

AFW-XVM-PG-XV87

4.0E-005

CHECK VALVE CV178 FAILS TO OPEN

AFW-CKV-FT-CV178

1.0E-004

MANUAL VALVE XV120 PLUGGED

AFW-XVM-PG-XV120

4.0E-005

CHECK VALVE CV176 FAILS TO OPEN

AFW-CKV-FT-CV176

1.0E-004

MANUAL VALVE XV158 PLUGGED

AFW-XVM-PG-XV158

4.0E-005

Tree: AFW-L3
Project: SURREY
Page 5 of 8
Date Last Modified:
Wed Jul 06 13:11:56 1988

B-39

INSUF STEAM
FLOW TO TDPFW2
THRU PIPE SEG
PS99
AFW21

Transfer from Page 5

INSUF STM FLOW
THRU PIPE SEG
PS95, PS96, PS97
AFW22

△ Page 5

NO ACTUATION
SIGNAL TO
AOV-MS102B
AFW-ACT-FA-VLVB

◇ 6.0E-004

AIR OPERATED
VALVE MS102B
FAILS TO OPEN
AFW-AOV-FT-102B

○ 1.0E-003

AIR OPERATED
VALVE MS102B
PLUGGED
AFW-AOV-PG-102B

○ 4.0E-005

COMMON CAUSE
FAILURE OF MS102A
AND B TO OPEN
AFW-CCF-FT-102AB

○ 1.0E-004

Tree: AFW-L3
Project: SURRY
Page 6 of 8
Date Last Modified:
Wed Jul 06 13:11:56 1988

B-40

Tree: AFW-L3
 Project: SURRY
 Page 7 of 8
 Date Last Modified:
 Wed Jul 06 13:11:56 1988

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS84
 AFW14

Transfers from Page(s) 1 8

CHECK VALVE CV133
 FAILS TO OPEN
 AFW-CKV-FT-CV133

FLOW DIVERSION TO
 UNIT 2 THRU PIPE
 SEG PS94
 AFW-PSF-FC-XCONN

CHECK VALVE CV131
 FAILS TO OPEN
 AFW-CKV-FT-CV131

INSUF FLOW
 THRU PIPE SEG
 PS80, PS81, & PS82
 AFW15

○ 1.0E-004


◇ 1.5E-004


○ 1.0E-004

△ Page 2

B-41

Tree: AFW-L3
Project: SURRY
Page 8 of 8
Date Last Modified:
Wed Jul 06 13:11:56 1988








B-43

Page 2

Page 1


INSUFFICIENT FLOW FROM CSS TRAIN B
CSS2

Transfer from Page 1




INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS55
CSS8

Transfer from Page 2



Tree: CSS
Project: SURRY
Page 2 of 2
Date Last Modified:
Mon Aug 29 07:09:16 1988

B-44



B-45


Page 3

Page 2

Page 1

Transfer from Page 1

Tree: CPCA
Project: SURRY
Page 2 of 3
Date Last Modified:
Wed Jul 06 13:43:50 1988



INSUFFICIENT
FLOW THRU SEAL
COOLER OF MDPCH1A

CPCA2

Transfer from Page 1

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS111

CPC3

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS118

CPC4

FAULTS IN PIPE
SEGMENT PS111
CONTD

CPC6

FAILURE OF 480V
AC MCC 1J1-1

ACP-TAC-LP-1J1-1

NO ACTUATION
SIGNAL TO START
CPC PUMP 2B

CPC-ICC-FA-CCPBS

3.2E-004

MDP CC2A FAILS TO
RUN AS LONG AS
CHRGNG PUMPS

CPC-MDP-FR-CC2A

1.8E-004

FAILURE OF 480V
AC MCC 1H1-1

ACP-TAC-LP-1H1-1

BACKFLOW
THROUGH PS118

CPC11

MDP CC2B FAILS TO
START

CPC-MDP-FS-CC2B

8.0E-003

MDP CC2B FAILS TO
RUN AS LONG AS
CHRGNG PUMPS

CPC-MDP-FR-CC2B

3.0E-003

TEST AND
MAINTENANCE ON
MDP CC2B

CPC-MDP-MA-CC2B

2.0E-003

MANUAL VALVE
XV701 PLUGGED

CPC-XVM-PG-XV701

4.0E-005

MANUAL VALVE
XV781 PLUGGED

CPC-XVM-PG-XV781

4.0E-005

CHECK VALVE CV752
FAILS TO OPEN

CPC-CKV-FT-CV752

1.0E-004

CHECK VALVE CV764
FAILS TO
SHUT, CAUSE
BACKFLOW

CPC-CKV-OO-CV764

1.0E-003

MDP CC2A FAILS TO
RUN AS LONG AS
CHRGNG PUMPS


CPC-MDP-FR-CC2A

1.8E-004

Tree: CPCA
Project: SURRY
Page 3 of 3
Date Last Modified:
Wed Jul 06 13:43:50 1988

B-47

Tree: CPCB
 Project: SURRY
 Page 1 of 2
 Date Last Modified:
 Wed Jul 06 13:12:00 1988



B-48

INSUFFICIENT
FLOW THRU SEAL
COOLER OF
MDP-CH1B
CPCB2


Transfer from Page 1

INSUF FLOW THRU
CPC PIPE SEGMENT
PS111
CPC3

INSUF FLOW THRU
CPC PIPE SEGMENT
PS118
CPC4

Tree: CPCB
Project: SURRY
Page 2 of 2
Date Last Modified:
Wed Jul 06 13:12:00 1988

Tree: CPCC
 Project: SURRY
 Page 1 of 1
 Date Last Modified:
 Wed Jul 06 13:12:02 1988



B-50

FAIL HIGH PRES
FLOW-CLD LEGS FRM
3 CHRGM PMP AUTO

D1

Tree: D1
Project: SURRY
Page 1 of 7
Date Last Modified:
Fri Jul 08 09:17:54 1988

INSUF FLOW
FROM CHARGING
PUMP DISCHARGE
HEADER

HPI2

CHECK VALVE CV225
FAILS TO OPEN

HPI-CKV-FT-CV225

1.0E-004

INSUF FLOW
THRU PIPE
SEGMENTS PS21 AND
PS22

HPI3

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS12

HPI5

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS13

HPI6

Page 5

INSUF FLOW
THROUGH PIPE
SEGMENT PS11

HPI4

Page 1

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS22

HPI7

Page 6

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS21

HPI8

Page 7

INSUFFICIENT
FLOW THROUGH MDP
CH-1B IN PS12

HPI17

COMMON CAUSE
FAILURE TO START
MDPS CH1B,CH1C

HPI-CCF-FS-CH1BC

8.4E-004

NO SIGNAL FROM
SIS TRAIN B

SIS-ACT-FA-SISB

1.6E-003

MOTOR OPERATED
VALVE 1269A
PLUGGED

HPI-MOV-PG-1269A

4.0E-005

MOTOR OPERATED
VALVE 1286B
PLUGGED

HPI-MOV-PG-1286B

4.0E-005

CHECK VALVE CV267
FAILS TO OPEN

HPI-CKV-FT-CV267

1.0E-004

INSUF FLOW
FROM CHARGING
PUMP SUCTION
HEADER

HPI19

Page 2

FAILURE OF 4KV AC
BUS 1J

ACP-TAC-LP-4KV1J

FAILURE OF 120V
DC BUS 1B

DCP-TDC-LP-BUS1B

INSF CPC CH1B:SW
TO LUBE OIL,CC TO
SEAL COOLER

CPCB

HPI MDP CH1B
FAILS TO START ON
DEMAND

HPI-MDP-FS-CH1B

4.0E-003

MDPCH1B FAILS TO
RUN FOR 6 HOURS

HPI-MDP-FR-1B6HR

4.0E-004

TEST AND
MAINTENANCE ON
MDP CH1B

HPI-MDP-MA-CH1B

2.0E-003

INSUF FLOW FM
MDP CH-1B,1C DUE
TO BACKFLOW

HPI21

Page 4

INSUF FLOW
THROUGH PIPE
SEGMENT PS11

HPI4

Transfer from Page 1

CHARGING PUMP
CH1A FAILS TO RUN
FOR 6 HOURS

HPI-MDP-FR-1A6HR

4.0E-004

FAILURE OF 4KV AC
BUS 1H

ACP-TAC-LP-4KV1H

INSF CPC CH1A:SW
TO LUBE OIL,CC TO
SEAL COOLER

CPCA


INSUF FLOW
FROM CHARGING
PUMP SUCTION
HEADER

HPI9

Page 2

B-51

Tree: D1
 Project: SURRY
 Page 2 of 7
 Date Last Modified:
 Fri Jul 08 09:17:54 1988



B-52

FAILURE OF
MOV1115C TO CLOSE
HP115

Transfer from Page 2

NO SIGNAL FROM
SIS TRAIN A
SIS-ACT-FA-SISA

1.6E-003

FAILURE OF 480V
AC MCC 1H1-2
ACP-TAC-LP-1H1-2

ACP-TAC-LP-1H1-2

HPI MOV 1115C
FAILS TO CLOSE
HPI-MOV-FT-1115C

3.0E-003

Tree: D1
Project: SURRY
Page 3 of 7
Date Last Modified:
Fri Jul 08 09:17:54 1988

INSUF FLOW FM
MDP CH-1B, 1C DUE
TO BACKFLOW

HP121

Transfers from Page(s) 1 5

CHARGING PUMP
CH1A FAILS TO RUN
FOR 6 HOURS

HPI-MDP-FR-1A6HR

4.0E-004

CHECK VALVE CV258
FAILS TO
SHUT, CAUSE
BACKFLOW

HPI-CKV-00-CV258

1.0E-003

Tree: D1
Project: SURRY
Page 4 of 7
Date Last Modified:
Fri Jul 08 09:17:54 1988

INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS13
HP16

Transfer from Page 1

INSUFFICIENT FLOW THROUGH MDP CH-1C IN PS13
HP118

NO ACTUATION SIGNAL TO CHARGING PUMP MDP-CH1C
HP110
Page 5

INSUF FLOW FROM CHARGING PUMP SUCTION HEADER
HP19
Page 2

FAILURE OF 4KV AC BUS 1H
ACP-TAC-LP-4KV1H

FAILURE OF 120V DC BUS 1A
DCP-TDC-LP-BUS1A

INSF CPC CH1C:SW TO LUBE OIL,CC TO SEAL COOLER
CPCC

HPI MDP CH1C FAILS TO START ON DEMAND
HPI-MDP-FS-CH1C
4.0E-003

HPI MDP CH1C FAILS TO RUN FOR 12 HOURS
HPI-MDP-FR-1C12H
8.0E-004

TEST AND MAINTENANCE ON MDP CH1C
HPI-MDP-MA-CH1C
2.0E-003

COMMON CAUSE FAILURE TO START MDPS CH1B,CH1C
HPI-CCF-FS-CH1BC
8.4E-004

OPERATOR FAILS TO REMOVE PULL LOCK CONDITION
HPI-XHE-FO-PLLCK
2.7E-003

MOTOR OPERATED VALVE 1270A PLUGGED
HPI-MOV-PG-1270A
4.0E-005

MOTOR OPERATED VALVE 1286C PLUGGED
HPI-MOV-PG-1286C
4.0E-005

CHECK VALVE CV276 FAILS TO OPEN
HPI-CKV-FT-CV276
1.0E-004

INSUF FLOW FM MDP CH-1B,1C DUE TO BACKFLOW
HPI21
Page 4

NO ACTUATION SIGNAL TO CHARGING PUMP MDP-CH1C
HP110

Transfer from Page 5

NO SIGNAL FROM SIS TRAIN A
SIS-ACT-FA-SISA
1.6E-003

NO SIGNAL FROM SIS TRAIN B
SIS-ACT-FA-SISB
1.6E-003

Tree: D1
Project: SURRY
Page 5 of 7
Date Last Modified:
Fri Jul 08 09:17:54 1988

B-55

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS22
HP17

Transfer from Page 1

NO SIGNAL FROM
SIS TRAIN A

SIS-ACT-FA-SISA
◇ 1.6E-003

FAILURE OF 480V
AC MCC 1H1-1

ACP-TAC-LP-1H1-1
◇

MOTOR OPERATED
VALVE 1867C
PLUGGED

HPI-MOV-PG-1867C
○ 4.0E-005

HPI MOV 1867C
FAILS TO OPEN ON
DEMAND

HPI-MOV-FT-1867C
○ 3.0E-003

COMMON CAUSE
FAILURE OF HPI
MOVS 1867C, 1867D

HPI-CCF-FT-867CD
○ 2.6E-004

Tree: D1
Project: SURRY
Page 6 of 7
Date Last Modified:
Fri Jul 08 09:17:54 1988

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS21

HP18

Transfer from Page 1

NO SIGNAL FROM
SIS TRAIN B

SIS-ACT-FA-SISB

◇ 1.6E-003

FAILURE OF 480V
AC MCC 1J1-1

ACP-TAC-LP-1J1-1

◇

MOTOR OPERATED
VALVE 1867D
PLUGGED

HPI-MOV-PG-1867D

○ 4.0E-005

HPI MOV 1867D
FAILS TO OPEN ON
DEMAND

HPI-MOV-FT-1867D

○ 3.0E-003

COMMON CAUSE
FAILURE OF HPI
MOVS 1867C, 1867D

HPI-CCF-FT-867CD

○ 2.6E-004

Tree: D1
Project: SURRY
Page 7 of 7
Date Last Modified:
Fri Jul 08 09:17:54 1988

FAIL HIGH PRES
FLOW TO CLD
LEGS-3 CHRGR PMP
MANUAL
D2

Tree: D2
Project: SURRY
Page 1 of 7
Date Last Modified:
Fri Jul 08 09:19:40 1988

INSUF FLOW FROM CHARGING PUMP DISCHARGE HEADER HP12	CHECK VALVE CV225 FAILS TO OPEN HPI-CKV-FT-CV225 1.0E-004	OP FAILS TO ESTABLISH FEED AND BLEED OPERATIO HPI-XHE-FO-FDBLD 7.1E-002	INSUF FLOW THRU PIPE SEGMENTS PS21 AND PS22 HP13
--	---	---	---

INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS12 HP15	INSUF FLOW THROUGH PIPE SEGMENT PS11 HP14 Page 1	INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS13 HP16 Page 5	INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS22 HP17 Page 6	INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS21 HP18 Page 7
---	--	---	---	---

INSUFFICIENT FLOW THROUGH SEGMENT PS12 PTRN HP117	FAILURE OF 4KV AC BUS 1J ACP-TAC-LP-4KV1J	FAILURE OF 120V DC BUS 1B DCP-TDC-LP-BUS1B	INSF CPC CH1B:SW TO LUBE OIL,CC TO SEAL COOLER CPCB	MOTOR OPERATED VALVE 1286B PLUGGED HPI-MOV-PG-1286B 4.0E-005	MOTOR OPERATED VALVE 1269A PLUGGED HPI-MOV-PG-1269A 4.0E-005	CHECK VALVE CV267 FAILS TO OPEN HPI-CKV-FT-CV267 1.0E-004	INSUF FLOW FROM CHARGING PUMP SUCTION HEADER HP19 Page 3
--	--	---	--	--	--	---	--

INSUF FLOW FROM CHARGING PUMP DUE TO BACKFLOW HP121 Page 2	COMMON CAUSE FAILURE TO START MDPS CH1B,CH1C HPI-CCF-FS-CH1BC 8.4E-004	TEST AND MAINTENANCE ON MDP CH1B HPI-MDP-MA-CH1B 2.0E-003	HPI MDP CH1B FAILS TO START ON DEMAND HPI-MDP-FS-CH1B 4.0E-003	MDPCH1B FAILS TO RUN FOR 6 HOURS HPI-MDP-FR-1B6HR 4.0E-004
--	--	---	--	--

INSUF FLOW THROUGH PIPE SEGMENT PS11
HP14

Transfer from Page 1

CHARGING PUMP CH1A FAILS TO RUN FOR 6 HOURS HPI-MDP-FR-1A6HR 4.0E-004	FAILURE OF 4KV AC BUS 1H ACP-TAC-LP-4KV1H	INSF CPC CH1A:SW TO LUBE OIL,CC TO SEAL COOLER CPCA	INSUF FLOW FROM CHARGING PUMP SUCTION HEADER HP19 Page 3
---	--	--	--

B-58

INSUF FLOW
FROM CHARGING
PUMP DUE TO
BACKFLOW
HPI21

Transfers from Page(s) 1 5

CHARGING PUMP
CH1A FAILS TO RUN
FOR 6 HOURS
HPI-MDP-FR-1A6HR

4.0E-004

CHECK VALVE CV258
FAILS TO
SHUT, CAUSE
BACKFLOW
HPI-CKV-00-CV258

1.0E-003

Tree: D2
Project: SURRY
Page 2 of 7
Date Last Modified:
Fri Jul 08 09:19:40 1988

FAILURE OF
MOV1115E TO CLOSE
HP116

Transfer from Page 3

FAILURE OF 480V
AC MCC 1J1-2
ACP-TAC-LP-1J1-2

HPI MOV 1115E
FAILS TO CLOSE
HPI-MOV-FT-1115E

3.0E-003

Tree: D2
Project: SURRY
Page 4 of 7
Date Last Modified:
Fri Jul 08 09:19:40 1988

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS13
HPI16

Transfer from Page 1

Tree: D2
Project: SURRY
Page 5 of 7
Date Last Modified:
Fri Jul 08 09:19:40 1988

INSUFFICIENT
FLOW THROUGH
SEGMENT PS13 PTRN
HPI18

FAILURE OF 4KV AC
BUS 1H
ACP-TAC-LP-4KV1H

FAILURE OF 120V
DC BUS 1A
DCP-TDC-LP-BUS1A

OPERATOR FAILS TO
REMOVE PULL LOCK
CONDITION
HPI-XHE-FO-PLLCK

MOTOR OPERATED
VALVE 1270A
PLUGGED
HPI-MOV-PG-1270A

INSF CPC CH1C:SW
TO LUBE OIL,CC TO
SEAL COOLER
CPCC

COMMON CAUSE
FAILURE TO START
MDPS CH1B,CH1C
HPI-CCF-FS-CH1BC

INSUF FLOW
FROM CHARGING
PUMP SUCTION
HEADER
HPI19

○ 2.7E-003

○ 4.0E-005

○ 8.4E-004

△ Page 3

INSUF FLOW
FROM CHARGING
PUMP DUE TO
BACKFLOW
HPI21

CHECK VALVE CV276
FAILS TO OPEN
HPI-CKV-FT-CV276

MOTOR OPERATED
VALVE 1286C
PLUGGED
HPI-MOV-PG-1286C

HPI MDP CH1C
FAILS TO START ON
DEMAND
HPI-MDP-FS-CH1C

HPI MDP CH1C
FAILS TO RUN FOR
12 HOURS
HPI-MDP-FR-1C12H

TEST AND
MAINTENANCE ON
MDP CH1C
HPI-MDP-MA-CH1C

○ 1.0E-004

○ 4.0E-005

○ 4.0E-003

○ 8.0E-004

○ 2.0E-003

△ Page 2

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS22
HPI7

Transfer from Page 1

FAILURE OF 480V
AC MCC 1H1-1
ACP-TAC-LP-1H1-1

HPI MOV 1867C
FAILS TO OPEN ON
DEMAND
HPI-MOV-FT-1867C

MOTOR OPERATED
VALVE 1867C
PLUGGED
HPI-MOV-PG-1867C

COMMON CAUSE
FAILURE OF HPI
MOVS 1867C, 1867D
HPI-CCF-FT-867CD

3.0E-003

4.0E-005

2.6E-004

Tree: D2
Project: SURRY
Page 6 of 7
Date Last Modified:
Fri Jul 08 09:19:40 1988

B-63

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS21
HP18

Transfer from Page 1

FAILURE OF 480V
AC MCC 1J1-1
ACP-TAC-LP-1J1-1

HPI MOV 1867D
FAILS TO OPEN ON
DEMAND
HPI-MOV-FT-1867D

MOTOR OPERATED
VALVE 1867D
PLUGGED
HPI-MOV-PG-1867D

COMMON CAUSE
FAILURE OF HPI
MOVS 1867C, 1867D
HPI-CCF-FT-867CD

○ 3.0E-003

○ 4.0E-005

○ 2.6E-004

Tree: D2
Project: SURRY
Page 7 of 7
Date Last Modified:
Fri Jul 08 09:19:40 1988

INSUF FLOW
 FROM ALL CHR G PMP
 TO THE RCP SEALS
 D3

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS13
 HP16

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS11
 HP14

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS12
 HP15

Page 1

Page 2

INSUFFICIENT
 FLOW THROUGH
 SEGMENT PS13 PTRN
 HP18

FAILURE OF 4KV AC
 BUS 1H
 ACP-TAC-LP-4KV1H

INSF CPC CH1C:SW
 TO LUBE OIL,CC TO
 SEAL COOLER
 CPCC

FAILURE OF 120V
 DC BUS 1A
 DCP-TDC-LP-BUS1A

OPERATOR FAILS TO
 REMOVE PULL LOCK
 CONDITION
 HPI-XHE-FO-PLLCK

MOTOR OPERATED
 VALVE 1270A
 PLUGGED
 HPI-MOV-PG-1270A

MOTOR OPERATED
 VALVE 1286C
 PLUGGED
 HPI-MOV-PG-1286C

CHECK VALVE CV276
 FAILS TO OPEN
 HPI-CKV-FT-CV276

2.7E-003

4.0E-005

4.0E-005

1.0E-004

INSUFFICIENT
 FLOW FM CH MDP
 DUE TO BACKFLOW
 HP121

COMMON CAUSE
 FAILURE TO START
 MDPS CH1B,CH1C
 HPI-CCF-FS-CH1BC

TEST AND
 MAINTENANCE ON
 MDP CH1C
 HPI-MDP-MA-CH1C

HPI MDP CH1C
 FAILS TO START ON
 DEMAND
 HPI-MDP-FS-CH1C

HPI MDP CH1C
 FAILS TO RUN FOR
 12 HOURS
 HPI-MDP-FR-1C12H

Page 2

8.4E-004

2.0E-003

4.0E-003

8.0E-004

INSUFFICIENT
 FLOW THROUGH PIPE
 SEGMENT PS11
 HP14

Transfer from Page 1


CHARGING PUMP
 CH1A FAILS TO RUN
 FOR 6 HOURS
 HPI-MDP-FR-1A6HR

FAILURE OF 4KV AC
 BUS 1H
 ACP-TAC-LP-4KV1H


INSF CPC CH1A:SW
 TO LUBE OIL,CC TO
 SEAL COOLER
 CPCA

4.0E-004

B-65



B-66



B-67

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS131

PPS4

Transfer from Page 1

PORV BLOCK VLV
MOV1536 FAILS IN
THE CLOSED POS

PPS6

PORV PCV1455C
FAILS TO OPEN ON
DEMAND

PPS-SOV-FT-1455C

1.0E-003

FAILURE OF 120V
DC BUS 1A

DCP-TDC-LP-BUS1A

COMMON CAUSE
FAILURE OF THE
PORVS TO OPEN

PPS-CCF-FT-PORV

7.0E-005

PORV BLOCK VLV
MOV1536 FAILS TO
OPEN

PPS8

BLOCK VALVE MOV
1536 SHUT DUE TO
LEAKING PORV

PPS-MOV-FC-1536

3.0E-001

PORV BLOCK VALVE
1536 FAILS TO
OPEN

PPS-MOV-FT-1536

4.0E-002

FAILURE OF 480V
AC MCC 1J1-2

ACP-TAC-LP-1J1-2

3.5E-003

COMMON CAUSE
FAILURE OF PORV
BLOCKING VALVES

PPS-CCF-FT-15356

4.0E-005



PORV BLOCK VALVE
1536 PLUGGED

PPS-MOV-PG-1536

Tree: D4
Project: SURRY
Page 2 of 2
Date Last Modified:
Fri Jul 08 09:22:58 1988

B-68

Tree: D5
 Project: SURRY
 Page 1 of 3
 Date Last Modified:
 Wed Jul 06 13:12:08 1988



B-169

INSUF FLOW
THRU PIPE SEGMENT
PS121
ACC5

Transfers from Page(s) 1

CHECK VALVE CV130
FAILS TO OPEN
ACC-CKV-FT-CV130
○ 1.0E-004

ACC MOTOR
OPERATED VALVE
1865B PLUGGED
ACC-MOV-PG-1865B
○ 6.5E-004

CHECK VALVE CV128
FAILS TO OPEN
ACC-CKV-FT-CV128
○ 1.0E-004

Tree: D5
Project: SURRY
Page 2 of 3
Date Last Modified:
Wed Jul 06 13:12:08 1988

B-70

INSUF FLOW
THRU PIPE SEGMENT
PS122
ACC6

Transfers from Page(s) 1

CHECK VALVE CV147
FAILS TO OPEN

ACC MOTOR
OPERATED VALVE
1865C PLUGGED

CHECK VALVE CV145
FAILS TO OPEN

ACC-CKV-FT-CV147

ACC-MOV-PG-1865C


ACC-CKV-FT-CV145

○ 1.0E-004

○ 6.5E-004

○ 1.0E-004

Tree: D5
Project: SURRY
Page 3 of 3
Date Last Modified:
Wed Jul 06 13:12:08 1988



B-72

INSUF FLOW TO
MOV1890C FROM LOW
HEAD SI TRN B

LPI4

Transfer from Page 1

Tree: D6
Project: SURRY
Page 2 of 2
Date Last Modified:
Thu Jul 07 15:38:52 1988

INSUF FLOW TO
MOV1890C FROM LPI
PTRN B

LPI6

LPI MOTOR
OPERATED VALVE
1864B PLUGGED

LPI-MOV-PG-1864B

4.4E-004

FAILURE OF 480V
AC BUS 1J

ACP-TAC-LP-4801J

FAILURE OF 120V
DC BUS 1B

DCP-TDC-LP-BUS1B

NO SIGNAL FROM
SIS TRIN B

SIS-ACT-FA-SISB

1.6E-003

LPI MOTOR OPER
VALVE 1862B
PLUGGED

LPI-MOV-PG-1862B

4.0E-005

CHECK VALVE CV46B
FAILS TO OPEN

LPI-CKV-FT-CV46B

1.0E-004

INSUFFICIENT
FLOW FM LHSI 1B
DUE TO BACKFLOW

LPI9

MANUAL VALVE XV48
PLUGGED

LPI-XVM-PG-XV48

4.0E-005

CHECK VALVE CV50
FAILS TO OPEN

LPI-CKV-FT-CV50

1.0E-004

LPI MDP S11B
FAILS TO START ON
DEMAND

LPI-MDP-FS-S11B

3.0E-003

LPI MDP S11B
FAILS TO RUN 1
HOUR

LPI-MDP-FR-1B1HR

3.0E-005

TEST AND
MAINTENANCE ON
LPI MDPS11B

LPI-MDP-MA-S11B

2.0E-003

COMMON CAUSE
FAILURE OF MDPS
S11A AND S11B

LPI-CCF-FS-S11AB

4.5E-004

LPI MDP S11A
FAILS TO START ON
DEMAND

LPI-MDP-FS-S11A

3.0E-003


CHECK VALVE CV58
FAILS TO
SHUT, CAUSE
BACKFLOW

LPI-CKV-OO-CV58

1.0E-003


B-73

Tree: ESTB1H
 Project: SURRY
 Page 1 of 1
 Date Last Modified:
 Wed Jul 06 13:12:20 1988




B-74


Tree: ESTB1J
 Project: SURRY
 Page 1 of 1
 Date Last Modified:
 Wed Jul 06 13:12:22 1988



Tree: EH1
 Project: SURRY
 Page 1 of 1
 Date Last Modified:
 Wed Jul 06 13:12:16 1988




B-76




B-77

Tree: EJ1
 Project: SURRY
 Page 1 of 1
 Date Last Modified:
 Wed Jul 06 13:12:18 1988


B-78



B-79




Tree: E4801H
Project: SURRY
Page 1 of 1
Date Last Modified:
Wed Jul 06 13:12:14 1988



B-80


FAILURE OF
480V AC BUS 1J

ACP-TAC-LP-4801J





Tree: E4801J
Project: SURRY
Page 1 of 1
Date Last Modified:
Wed Jul 06 13:12:16 1988

B-82




B-83






B-84




B-85

Tree: E1A
 Project: SURRY
 Page 1 of 1
 Date Last Modified:
 Thu Jun 30 10:12:26 1988




B-86



B-87

Page 1

B-88



Tree: HPR-H2
Project: SURRY
Page 2 of 6
Date Last Modified:
Fri Jul 08 08:43:54 1988

INSUF FLOW DUE TO BACKLEAKAGE THRU MDP CH-1A 18 HR
HPR14

Transfers from Page(s) 1 5

CHARGING PMP MDP-CH1A FAILS TO RUN FOR 18 HRS
HPR-MDP-FR-A18HR

○ 1.2E-003

CHECK VALVE CV258 FAILS TO SHUT, CAUSE BACKFLOW
HPI-CKV-00-CV258

○ 1.0E-003

B-89

INSUF FLOW DUE
TO BACKLEAKAGE
THRU MDP CH-1A 6
HR
HPR15

Transfers from Page(s) 1 5


CHARGING PUMP
CH1A FAILS TO RUN
FOR 6 HOURS
HPI-MDP-FR-1A6HR
4.0E-004

CHECK VALVE CV258
FAILS TO
SHUT, CAUSE
BACKFLOW
HPI-CKV-00-CV258
1.0E-003

Tree: HPR-H2
Project: SURRY
Page 3 of 6
Date Last Modified:
Fri Jul 08 08:43:54 1988


INSUFFICIENT
FLOW FROM
CHARGING PUMP
MDP-CH1B
HPR13

Transfer from Page 1



Tree: HPR-H2
Project: SURRY
Page 4 of 6
Date Last Modified:
Fri Jul 08 08:43:54 1988

Tree: HPR-H2
 Project: SURRY
 Page 5 of 6
 Date Last Modified:
 Fri Jul 08 08:43:54 1988



B-92

INSUFFICIENT
FLOW FROM
CHARGING PUMP
MDP-CH1C
HPR12

Transfer from Page 5

INSF CPC CH1C:SW
TO LUBE OIL,CC TO
SEAL COOLER
CPCC

HPR MOTOR DRIVEN
PUMP FAILS TO
RUN 12 HRS
HPR-MDP-FR-1C12H
8.0E-004

OPERATOR FAILS TO
REMOVE PULL LOCK
CONDITION
HPI-XHE-FO-PLLCK
2.7E-003


FAILURE OF 4KV AC
BUS 1H
ACP-TAC-LP-4KV1H

FAILURE OF 120V
DC BUS 1A
DCP-TDC-LP-BUS1A

Tree: HPR-H2
Project: SURRY
Page 6 of 6
Date Last Modified:
Fri Jul 08 08:43:54 1988

Tree: LPR-HH
 Project: SURRY
 Page 1 of 6
 Date Last Modified:
 Wed Jul 06 13:12:24 1988

B-94



INSUF FLOW FROM LPSI PMP TRN A TO MOV 1863A
 LPR-HH1

Transfers from Page(s) 1 6

INSUFFICIENT FLOW THROUGH SEGMENT PS32 PTRN A
 LPR-HH4

INSUFFICIENT FLOW FROM LPSI PMP TRN A
 LPR-HH3

INSUF FLOW THRU PS37 OR FAILURE TO ISOL PS30
 LPR-HH5

Page 2

Page 3

INSUF FLOW DUE TO BACKFLOW THRU MDP S11B
 LPR-HH9

MANUAL VALVE XV57 PLUGGED
 LPI-XVM-PG-XV57
 4.0E-005

CHECK VALVE CV58 FAILS TO OPEN
 LPI-CKV-FT-CV58
 1.0E-004

LPI MDP S11A FAILS TO START ON DEMAND
 LPI-MDP-FS-S11A
 3.0E-003

LPI MDP FAILS TO RUN FOR 6 HOURS
 LPI-MDP-FR-1A6HR
 1.8E-004

COMMON CAUSE FAILURE OF MDPS S11A AND S11B
 LPI-CCF-FS-S11AB
 4.5E-004

TEST AND MAINTENANCE ON LPI MDPS11A
 LPI-MDP-MA-S11A
 2.0E-003

LPI MDP S118 FAILS TO START ON DEMAND
 LPI-MDP-FS-S118
 3.0E-003

CHECK VALVE CV50 FAILS TO SHUT, CAUSE BACKFLOW
 LPI-CKV-00-CV50
 1.0E-003

INSUFFICIENT FLOW FROM LPSI PMP TRN A
 LPR-HH3

Transfer from Page 2

PLUGGING OF THE CONTAINMENT SUMP
 LPR-CCF-PG-SUMP
 5.0E-005

MOTOR DRIVEN PUMP S11A FAILS TO RUN FOR 24 HR
 LPI-MDP-FR-A24HR
 7.2E-004

NO SIGNAL FROM RMTS TRAIN A
 RMT-ACT-FA-RMTSA
 1.6E-003

FAILURE OF 120V DC BUS 1A
 DCP-TDC-LP-BUS1A


COMMON CAUSE FAILURE RMT DUE TO MISCALIBRATION
 RMT-CCF-FA-MSCAL
 3.0E-004

FAILURE OF 480V AC BUS 1H
 ACP-TAC-LP-4801H

B-95

INSUF FLOW
THRU PS37 OR
FAILURE TO ISOL
PS30
LPR-HH5

Transfer from Page 2



Tree: LPR-HH
Project: SURRY
Page 3 of 6
Date Last Modified:
Wed Jul 06 13:12:24 1988

INSUF FLOW
 FROM LPSI PMP TRN
 B TO MOV 1863B
 LPR-HH2

Transfers from Page(s) 1 6

INSUFFICIENT FLOW THROUGH SEGMENT PS33 PTRN B LPR-HH7	INSUFFICIENT FLOW FROM LPSI PMP TRN B LPR-HH6	INSUF FLOW THRU PS38 OR FAILURE TO ISOL PS31 LPR-HH8
---	--	--

Page 4

Page 5

INSUF FLOW DUE
TO BACKFLOW
THROUGH MDP S11A
LPR-HH10

MANUAL VALVE XV48
PLUGGED
LPI-XVM-PG-XV48

CHECK VALVE CV50
FAILS TO OPEN
LPI-CKV-FT-CV50

LPI MDP S11B
FAILS TO START ON
DEMAND
LPI-MDP-FS-S11B

LPI MDP FAILS TO
RUN FOR 6 HOURS
LPI-MDP-FR-1B6HR

COMMON CAUSE
FAILURE OF MDPS
S11A AND S11B
LPI-CCF-FS-S11AB

TEST AND
MAINTENANCE ON
LPI MDPS11B
LPI-MDP-MA-S11B

4.0E-005

1.0E-004

3.0E-003

1.8E-004

4.5E-004

2.0E-003

LPI MDP S11A
FAILS TO START ON
DEMAND
LPI-MDP-FS-S11A

CHECK VALVE CV58
FAILS TO
SHUT, CAUSE
BACKFLOW
LPI-CKV-00-CV58

3.0E-003

1.0E-003

INSUFFICIENT
FLOW FROM LPSI
PMP TRN B
LPR-HH6

Transfer from Page 4

PLUGGING OF THE
CONTAINMENT SUMP
LPR-CCF-PG-SUMP

MOTOR DRIVEN PUMP
S11B FAILS TO RUN
FOR 24 HR
LPI-MDP-FR-B24HR

NO SIGNAL FROM
RMTS TRAIN B
RMT-ACT-FA-RMTSB

FAILURE OF 120V
DC BUS 1B
DCP-TDC-LP-BUS1B

COMMON CAUSE
FAILURE RMT DUE
TO MISCALIBRATION
RMT-CCF-FA-MSCAL

FAILURE OF 480V
AC BUS 1J
ACP-TAC-LP-4801J

5.0E-005

7.2E-004

1.6E-003

3.0E-004

B-97

INSUF FLOW
THRU PS38 OR
FAILURE TO ISOL
PS31
LPR-HHB

Transfer from Page 4

LPR MOTOR
OPERATED VALVE
1862B FAILS TO
CLOSE
LPR-MOV-FT-1862B
○ 5.2E-003

COMMON CAUSE
FAILURE OF MOV
1862A/B
LPR-CCF-FT-862AB
○ 2.6E-004


MOTOR OP VALVE
1860B FAILS TO
OPEN
LPR-MOV-FT-1860B
○ 3.0E-003

COMMON CAUSE
FAILURE OF MOV
1860A/B
LPR-CCF-FT-860AB
○ 2.6E-004

CHECK VALVE CV47
FAILS TO OPEN
LPR-CKV-FT-CV47
○ 1.0E-004


FAILURE OF 480V
AC MCC 1J1-2
ACP-TAC-LP-1J1-2
◇

Tree: LPR-HH
Project: SURRY
Page 5 of 6
Date Last Modified:
Wed Jul 06 13:12:24 1988



B-99

B-100



PIPE SEGMENT
PS30 OR PS37
FAULTS

LPR9

Transfer from Page 1

COMMON CAUSE
FAILURE OF MOV
1862A/B

LPR-CCF-FT-862AB

○ 2.6E-004

FAILURE OF 480V
AC MCC 1H1-2

ACP-TAC-LP-1H1-2

◇

LPR MOTOR
OPERATED VALVE
1862A FAILS TO
CLOSE

LPR-MOV-FT-1862A

○ 5.2E-003

LPR-MOV-1860A
FAILS TO OPEN

LPR-MOV-FT-1860A

○ 3.0E-003

COMMON CAUSE
FAILURE OF MOV
1860A/B

LPR-CCF-FT-860AB

○ 2.6E-004

CHECK VALVE CV56
FAILS TO OPEN

LPR-CKV-FT-CV56

○ 1.0E-004

Tree: LPR-LH
Project: SURRY
Page 2 of 5
Date Last Modified:
Fri Jul 08 09:15:40 1988


B-101

PIPE SEGMENT
PS33 FAULTS

LPR10

Transfer from Page 1

Tree: LPR-LH
Project: SURRY
Page 3 of 5
Date Last Modified:
Fri Jul 08 09:15:40 1988



B-102

PIPE SEGMENT
PS31 OR PS38
FAULTS
LPR11

Transfer from Page 1

COMMON CAUSE
FAILURE OF MOV
1862A/B

LPR-CCF-FT-862AB

2.6E-004

FAILURE OF 480V
AC MCC 1J1-2

ACP-TAC-LP-1J1-2

◇

LPR MOTOR
OPERATED VALVE
1862B FAILS TO
CLOSE

LPR-MOV-FT-1862B

5.2E-003

MOTOR OP VALVE
1860B FAILS TO
OPEN

LPR-MOV-FT-1860B

3.0E-003

COMMON CAUSE
FAILURE OF MOV
1860A/B

LPR-CCF-FT-860AB


2.6E-004

CHECK VALVE CV47
FAILS TO OPEN

LPR-CKV-FT-CV47

1.0E-004

Tree: LPR-LH
Project: SURRY
Page 4 of 5
Date Last Modified:
Fri Jul 08 09:15:40 1988



B-104

INSUF FLOW/COOLING FROM BOTH ISR SYSTEM TRAINS
ISR-F1

Tree: ISR
Project: SURRY
Page 1 of 6
Date Last Modified:
Thu Aug 11 00:18:40 1988

INSUF FLOW/COOLING FROM PIPE SEGMENT PS60
ISR1

INSUF FLOW/COOLING FROM PIPE SEGMENT PS61
ISR2

Page 6

INSUF FLOW/COOLING FROM PS60 PTRN A
ISR3

FAILURE OF 120V DC BUS 1A
DCP-TDC-LP-BUS1A

FAILURE OF 480V AC BUS 1H
ACP-TAC-LP-4801H

NO SIGNAL FROM CLCS TRAIN A
CLS-ACT-FA-CLS2A
1.6E-003

PLUGGING OF THE CONTAINMENT SUMP
LPR-CCF-PG-SUMP
5.0E-005

INSUF COOLING OF PIPE SEGMENT PS60 FLOW
SWS1

ISR MDP RS1A FAILS TO START ON DEMAND
ISR-MDP-FS-RS1A
3.8E-002

ISR MOTOR DR PUMP RS1A FAILS TO RUN
ISR-MDP-FR-RS1A
7.2E-004

TEST AND MAINTENANCE ON MDP RS1A
ISR-MDP-MA-RS1A
2.0E-003

COMMON CAUSE FAIL TO START ISR PMPS
ISR-CCF-FS-RS1AB
4.2E-003

ISR STRAINER RS1AS PLUGGED
ISR-STR-PG-RS1AS
7.2E-004

INSUF FLOW THRU PIPE SEG PS67, PS68, PS66 - HD A
SWS3

INSUFFICIENT INTAKE CANAL LEVEL
MCW-CCF-VF-INLVL
1.0E-009

INSUF FLOW THROUGH PIPE SEG PS62
SWS5

INSUF FLOW THROUGH PIPE SEG PS66 TO HEADER A
SWS11

INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS67
SWS9
Page 2

INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS68
SWS10
Page 3

SWS MOTOR OPER VALVE 104A PLUGGED
SWS-MOV-PG-104A
6.5E-004

SWS MOTOR OPER VALVE 105A PLUGGED
SWS-MOV-PG-105A
6.5E-004

INSUF FLOW THROUGH PIPE SEG PS69 AND PS70
SWS15

SWS MOTOR OPER VALVE 106A PLUGGED
SWS-MOV-PG-106A
6.5E-004

SWS MOTOR OPER VALVE 106B PLUGGED
SWS-MOV-PG-106B
6.5E-004

INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS69
SWS12
Page 4

INSUFFICIENT FLOW THROUGH PIPE SEGMENT PS70
SWS13
Page 5

B-105

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS67

SWS9

Transfers from Page(s) 1 6

FAILURE OF 480V
AC MCC 1H1-1

NO SIGNAL FROM
CLCS TRAIN A

SWS MOTOR OP VLV
103A FAILS TO
OPEN

TEST AND
MAINTENANCE SWS
MOV 103A

COMMON CAUSE
FAILURE OF SWS
ISOL MOV 103ABCD

ACP-TAC-LP-1H1-1

CLS-ACT-FA-CLS2A

SWS-MOV-FT-103A

SWS-MOV-MA-103A

SWS-CCF-FT-3ABCD

◇ 1.6E-003

○ 3.0E-003

○ 2.0E-004

○ 6.3E-004


Tree: ISR
Project: SURRY
Page 2 of 6
Date Last Modified:
Thu Aug 11 00:18:40 1988

B-106

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS68

SWS10

Transfers from Page(s) 1 6



Tree: ISR
Project: SURRY
Page 3 of 6
Date Last Modified:
Thu Aug 11 00:18:40 1988

B-107

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS69
SWS12

Transfers from Page(s) 1 6

FAILURE OF 480V
AC MCC 1J1-1
ACP-TAC-LP-1J1-1

NO SIGNAL FROM
CLCS TRAIN B
CLS-ACT-FA-CLS2B
1.6E-003

SWS MOTOR OP VLV
103C FAILS TO
OPEN
SWS-MOV-FT-103C
3.0E-003

TEST AND
MAINTENANCE SWS
MOV 103C
SWS-MOV-MA-103C
2.0E-004

COMMON CAUSE
FAILURE OF SWS
ISOL MOVS 103ABCD
SWS-CCF-FT-3ABCD
6.3E-004


Tree: ISR
Project: SURRY
Page 4 of 6
Date Last Modified:
Thu Aug 11 00:18:40 1988

B-108

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS70

SWS13

Transfers from Page(s) 1 6



Tree: ISR
Project: SURRY
Page 5 of 6
Date Last Modified:
Thu Aug 11 00:18:40 1988

B-109

INSUF
FLOW/COOLING FROM
PIPE SEGMENT PS61

ISR2

Transfer from Page 1

INSUF
FLOW/COOLING FROM
PS61 PTRN B

ISR4

NO SIGNAL FROM
CLS TRAIN B

CLS-ACT-FA-CLS2B

◇ 1.6E-003

PLUGGING OF THE
CONTAINMENT SUMP

LPR-CCF-PG-SUMP

○ 5.0E-005

FAILURE OF 480V
AC BUS 1J

ACP-TAC-LP-4801J

◇

FAILURE OF 120V
DC BUS 1B

DCP-TDC-LP-BUS1B

◇

INSUFFICIENT
COOLING OF PIPE
SEGMENT PS61 FLOW

SWS2

ISR MDP RS1B
FAILS TO START ON
DEMAND

ISR-MDP-FS-RS1B

○ 3.8E-002

ISR MOTOR DR PUMP
RS1B FAILS TO RUN

ISR-MDP-FR-RS1B

○ 7.2E-004

TEST AND
MAINTENANCE ON
MDP RS1B

ISR-MDP-MA-RS1B

○ 2.0E-003

COMMON CAUSE FAIL
TO START ISR PMPS

ISR-CCF-FS-RS1AB

○ 4.2E-003

ISR STRAINER
RS1BS PLUGGED

ISR-STR-PG-RS1BS

○ 7.2E-004

INSUF FLOW
THRU PIPE SEG
PS69, PS70, PS66 -
HD B

SWS4

INSUFFICIENT
INTAKE CANAL
LEVEL

MCW-CCF-VF-INLVL

○ 1.0E-009

INSUF FLOW
THROUGH PIPE SEG
PS63

SWS6

INSUF FLOW
THROUGH PIPE SEG
PS66 TO HEADER B

SWS14

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS69

SWS12

△ Page 4

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS70

SWS13

△ Page 5

SWS MOTOR OPER
VALVE 104B
PLUGGED

SWS-MOV-PG-104B

○ 6.5E-004

SWS MOTOR OPER
VALVE 105B
PLUGGED

SWS-MOV-PG-105B

○ 6.5E-004

INSUF FLOW
THROUGH PIPE SEG
PS67 AND PS68

SWS16

SWS MOTOR OPER
VALVE 106A
PLUGGED

SWS-MOV-PG-106A

○ 6.5E-004

SWS MOTOR OPER
VALVE 106B
PLUGGED

SWS-MOV-PG-106B

○ 6.5E-004

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS67

SWS9

△ Page 2


INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS68

SWS10


△ Page 3

Tree: ISR
Project: SURRY
Page 6 of 6
Date Last Modified:
Thu Aug 11 00:18:40 1988

B-110



B-111



B-112

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS70

SWS13

Transfers from Page(s) 2 6

FAILURE OF 480V
AC MCC 1H1-1

NO SIGNAL FROM
CLCS TRAIN A

SWS MOTOR OP VLV
103D FAILS TO
OPEN

TEST AND
MAINTENANCE ON
SWS MOV103D

COMMON CAUSE
FAILURE OF SWS
ISOL MOV5 103ABCD

ACP-TAC-LP-1H1-1

CLS-ACT-FA-CLS2A

SWS-MOV-FT-103D

SWS-MOV-MA-103D

SWS-CCF-FT-3ABCD



1.6E-003

3.3E-003


2.0E-004

6.3E-004

Tree: OSR
Project: SURRY
Page 3 of 8
Date Last Modified:
Wed Jul 06 13:12:32 1988

B-113

Tree: OSR
 Project: SURRY
 Page 4 of 8
 Date Last Modified:
 Wed Jul 06 13:12:32 1988




B-114

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS68


SWS10

Transfers from Page(s) 2 6



Tree: OSR
Project: SURRY
Page 5 of 8
Date Last Modified:
Wed Jul 06 13:12:32 1988

B-115



B-116

INSUFFICIENT
FLOW IN PMP TRAIN
B OF PS72
OSR4

Transfer from Page 1

OSR MOTOR OPER
VALVE 155B
PLUGGED
OSR-MOV-PG-155B
4.0E-005

OSR MDP RS2B
FAILS TO START ON
DEMAND
OSR-MDP-FS-RS2B
3.0E-003

COMMON CAUSE FAIL
TO START OSR MDPS
OSR-CCF-FS-RS2AB
3.3E-004

OSR MDP RS2B
FAILS TO RUN 24
HOURS
OSR-MDP-FR-B24HR
7.2E-004

OSR MOTOR OPER
VALVE 156B
PLUGGED
OSR-MOV-PG-156B
4.0E-005

TEST AND
MAINTENANCE ON
OSR MDPRS2B
OSR-MDP-MA-RS2B
2.0E-003

Tree: OSR
Project: SURRY
Page 7 of 8
Date Last Modified:
Wed Jul 06 13:12:32 1988

B-117

INSUFFICIENT
FLOW/COOLING FROM
PIPE SEG PS72

OSR6

Transfer from Page 1

NO SIGNAL FROM
CLCS TRAIN B

FAILURE OF 120V
DC BUS 1B

PLUGGING OF THE
CONTAINMENT SUMP

FAILURE OF 480V
AC BUS 1J

CHECK VALVE CV11
FAILS TO OPEN

OSR MDP RS2B SUMP
STRAINER PLUGGED

CLS-ACT-FA-CLS2B

DCP-TDC-LP-BUS1B

LPR-CCF-PG-SUMP

ACP-TAC-LP-4801J

OSR-CKV-FT-CV11

OSR-STR-PG-RS2B

◇ 1.6E-003

◇

○ 5.0E-005


◇



○ 1.0E-004

○ 7.2E-004

Tree: OSR
Project: SURRY
Page 8 of 8
Date Last Modified:
Wed Jul 06 13:12:32 1988

B-119





B-120

FAILURE TO
COOLDOWN VIA A
TURB BYP VLV BYP

OD15

Transfers from Page(s) 2 6 7

A BYP TO TURB
BYPASS FAILS TO
OPEN

PCS-AOV-FT-BYP-A

1.0E-003

A BYP TO TURB
BYPASS PLUGGED

PCS-AOV-PG-BYP-A

4.0E-005

COMMON CAUSE
FAILURE OF
TURBINE BYPASS
VALVES

PCS-CCF-FT-TRBYP

4.3E-005

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR

IAS-CCF-LF-INAIR

2.7E-005

Tree: OD
Project: SURRY
Page 3 of 7
Date Last Modified:
Mon Aug 29 13:43:44 1988

FAILURE TO
COOLDOWN VIA B
TURB BYPASS

OD16

Transfers from Page(s) 2 6 7

B TURB BYPASS
FAILS TO OPEN

PCS-AOV-FT-MSTVB

1.0E-003

B TURBINE BYPASS
PLUGGED

PCS-AOV-PG-MSTVB

4.0E-005

COMMON CAUSE
FAILURE OF
TURBINE BYPASS
VALVES

PCS-CCF-FT-TRBYP

4.3E-005

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR

IAS-CCF-LF-INAIR

2.7E-005

Tree: 00
Project: SURRY
Page 4 of 7
Date Last Modified:
Mon Aug 29 13:43:44 1988

B-122

FAILURE TO
COOLDOWN VIA B
TURB BYP VLV BYP
OD17

Transfers from Page(s) 2 6 7

B BYP TO TURB
BYPASS FAILS TO
OPEN
PCS-AOV-FT-BYP-B

1.0E-003

B BYP TO TURB
BYPASS PLUGGED
PCS-AOV-PG-BYP-B

4.0E-005

COMMON CAUSE
FAILURE OF
TURBINE BYPASS
VALVES
PCS-CCF-FT-TRBYP

4.3E-005

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR
IAS-CCF-LF-INAIR

2.7E-005

Tree: OD
Project: SURRY
Page 5 of 7
Date Last Modified:
Mon Aug 29 13:43:44 1988

B-123

FAILURE TO
COOLDOWN VIA SG B

OD7

Transfer from Page 1

FAILURE TO
COOLDWN VIA SG B
PORV

OD12

FAILURE TO
COOLDOWN VIA B
TURB BYPASS

OD16

FAILURE TO
COOLDOWN VIA B
TURB BYP VLV BYP

OD17

FAILURE TO
COOLDOWN VIA A
TURB BYPASS

OD14

FAILURE TO
COOLDOWN VIA A
TURB BYP VLV BYP

OD15

Page 4

Page 5

Page 2

Page 3

SG B PORV FAILS
TO OPEN

MSS-AOV-FT-101B

SG E PORV PLUGGED

MSS-AOV-PG-101B

SG B PORV
BLOCKED

MSS-AOV-FC-101B

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR

IAS-CCF-LF-INAIR

COMMON CAUSE
FAILURE OF SG
PORVS

MSS-CCF-FT-01ABC

1.0E-003

4.0E-005

1.5E-001

2.7E-005

1.0E-004

Tree: OD
Project: SURRY
Page 6 of 7
Date Last Modified:
Mon Aug 29 13:43:44 1988

B-124

FAILURE TO
COOLDOWN VIA SG C

OD8

Transfer from Page 1

FAILURE TO
COOLDWN VIA SG C
PORV

OD13

FAILURE TO
COOLDOWN VIA A
TURB BYPASS

OD14

FAILURE TO
COOLDOWN VIA A
TURB BYP VLV BYP

OD15

FAILURE TO
COOLDOWN VIA B
TURB BYPASS

OD16

FAILURE TO
COOLDOWN VIA B
TURB BYP VLV BYP

OD17

Page 2

Page 3

Page 4

Page 5

SG C PORV FAILS
TO OPEN

MSS-AOV-FT-101C

1.0E-003

SG C PORV PLUGGED

MSS-AOV-PG-101C

4.0E-005

SG C PORV BLOCKED

MSS-AOV-FC-101C

1.5E-001

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR

IAS-CCF-LF-INAIR

2.7E-005


COMMON CAUSE
FAILURE OF SG
PORVS

MSS-CCF-FT-01ABC

1.0E-004



Tree: OD
Project: SURRY
Page 7 of 7
Date Last Modified:
Mon Aug 29 13:43:44 1988

Tree: OD-SG
 Project: SURRY
 Page 1 of 6
 Date Last Modified:
 Mon Aug 29 13:07:16 1988



B-126

Tree: OD-SG
 Project: SURRY
 Page 2 of 6
 Date Last Modified:
 Mon Aug 29 13:07:16 1988



B-127

FAILURE TO
COOLDOWN VIA B
TURB BYP VLV BYP

OD17

Transfers from Page(s) 2 6

B BYP TO TURB
BYPASS FAILS TO
OPEN

PCS-AOV-FT-BYP-B

1.0E-003

B BYP TO TURB
BYPASS PLUGGED

PCS-AOV-PG-BYP-B

4.0E-005

COMMON CAUSE
FAILURE OF
TURBINE BYPASS
VALVES

PCS-CCF-FT-TRBYP

4.3E-005

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR

IAS-CCF-LF-INAIR

2.7E-005

Tree: OD-SG
Project: SURRY
Page 3 of 6
Date Last Modified:
Mon Aug 29 13:07:16 1988

B-128

FAILURE TO
COOLDOWN VIA A
TURB BYPASS

OD14

Transfers from Page(s) 2 6

A TURB BYPASS
FAILS TO OPEN

PCS-AOV-FT-MSTVA

○ 1.0E-003

A TURB BYPASS
PLUGGED

PCS-AOV-PG-MSTVA

○ 4.0E-005

COMMON CAUSE
FAILURE OF
TURBINE BYPASS
VALVES

PCS-CCF-FT-TRBYP

○ 4.3E-005

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR

IAS-CCF-LF-INAIR

○ 2.7E-005

Tree: OD-SG
Project: SURRY
Page 4 of 6
Date Last Modified:
Mon Aug 29 13:07:16 1988

B-129

FAILURE TO
COOLDOWN VIA A
TURB BYP VLV BYP
OD15

Transfers from Page(s) 2 6

A BYP TO TURB
BYPASS FAILS TO
OPEN
PCS-AOV-FT-BYP-A
○ 1.0E-003

A BYP TO TURB
BYPASS PLUGGED
PCS-AOV-PG-BYP-A
○ 4.0E-005


COMMON CAUSE
FAILURE OF
TURBINE BYPASS
VALVES
PCS-CCF-FT-TRBYP
○ 4.3E-005

COMMON CAUSE FAIL
AOVS DUE TO LOSS
OF AIR
IAS-CCF-LF-INAIR
○ 2.7E-005

Tree: OD-SG
Project: SURRY
Page 5 of 6
Date Last Modified:
Mon Aug 29 13:07:16 1988


B-130

Tree: OD-SG
 Project: SURRY
 Page 6 of 6
 Date Last Modified:
 Mon Aug 29 13:07:16 1988




B-131

Tree: P
 Project: SURRY
 Page 1 of 1
 Date Last Modified:
 Thu Aug 18 13:34:28 1988



B-132



B-133

Page 2

INSUFFICIENT
FLOW THROUGH PIPE
SEGMENT PS131

PPS4

Transfer from Page 1

PORV BLOCK VLV
MOV1536 FAILS IN
THE CLOSED POS

PPS6

PORV PCV1455C
FAILS TO OPEN ON
DEMAND

PPS-SOV-FT-1455C

1.0E-003

FAILURE OF 120V
DC BUS 1A

DCP-TDC-LP-BUS1A

COMMON CAUSE
FAILURE OF THE
PORVS TO OPEN

PPS-CCF-FT-PORV

7.0E-005

FAILURE OF THE
OPERATOR TO OPEN
ONE PORV

PPS-XHE-FO-1PORV

7.1E-002

PORV BLOCK VLV
MOV1536 FAILS TO
OPEN

PPS8

BLOCK VALVE MOV
1536 SHUT DUE TO
LEAKING PORV

PPS-MOV-FC-1536

3.0E-001

PORV BLOCK VALVE
1536 FAILS TO
OPEN

PPS-MOV-FT-1536

4.0E-002

FAILURE OF 480V
AC MCC 1J1-2

ACP-TAC-LP-1J1-2

COMMON CAUSE
FAILURE OF PORV
BLOCKING VALVES

PPS-CCF-FT-15356

3.5E-003

PORV BLOCK VALVE
1536 PLUGGED

PPS-MOV-PG-1536

4.0E-005

B-134

Tree: P1
Project: SURRY
Page 2 of 2
Date Last Modified:
Thu Aug 18 13:35:26 1988

FAILURE TO OPEN 3
OF 3 SRVS, OR 2
OF 3 SRVS AND 2
OF 2 PORVS, ATWS
P2

FAILURE OF 3 OF 3
SRVS TO OPEN
P23

FAILURE TO OPEN 2
OF 3 SRVS AND 2
OF 2 PORVS
P22
△ Page 2

FAILURE OF 2 SRVS
TO OPEN DURING
ATWS
P25

COMMON CAUSE
FAILURE OF RCS
SRVS TO OPEN
PPS-CCF-FT-SRVS
○ 7.0E-005

FAILURE OF 2 SRVS
TO OPEN DURING
ATWS
P26

FAILURE OF 2 SRVS
TO OPEN DURING
ATWS
P27

SAFETY RELIEF
VALVE 1551A FAILS
TO OPEN
PPS-SRV-FT-1551A
○ 1.0E-003

SAFETY RELIEF
VALVE 1551B FAILS
TO OPEN
PPS-SRV-FT-1551B
○ 1.0E-003

SAFETY RELIEF
VALVE 1551A FAILS
TO OPEN
PPS-SRV-FT-1551A
○ 1.0E-003


SAFETY RELIEF
VALVE 1551C FAILS
TO OPEN
PPS-SRV-FT-1551C
○ 1.0E-003

SAFETY RELIEF
VALVE 1551C FAILS
TO OPEN
PPS-SRV-FT-1551C
○ 1.0E-003


SAFETY RELIEF
VALVE 1551B FAILS
TO OPEN
PPS-SRV-FT-1551B
○ 1.0E-003

Tree: P2
Project: SURRY
Page 1 of 2
Date Last Modified:
Mon Aug 29 13:59:32 1988

B-135



B-136



B-137

SEGMENTS PS4
 AND 5 COMMON
 FAULTS
 RHRB

Transfers from Page(s) 1 4

INSUF FLOW TO SEGMENT PS4 AND 5, FM RHR PUMPS RHR9	INSUFFICIENT COMPONENT COOLING FROM CCW CCW1	FCV-1605 TRANSFERS FULLY OPEN AND REMAINS OPEN RHR-AOV-00-1605 2.4E-006
---	---	--

INSUFFICIENT FLOW THROUGH SEGMENT PS3 PTRN B RHR10	INSUFFICIENT FLOW THROUGH SEGMENT PS2 PTRNA RHR11
--	--

Page 3

INSUF FLOW THROUGH SEGMENT PS3 PTRN B CONTD RHR13	MANUAL VALVE XV2 PLUGGED RHR-XVM-PG-XV2 4.4E-004	CHECK VALVE CV5 FAILS TO OPEN RHR-CKV-FT-CV5 1.0E-004	RHR MDP 1B FAILS TO START ON DEMAND RHR-MDP-FS-RHR1B 3.0E-003	RHR MDP 1B FAILS TO RUN FOR 24 HOURS RHR-MDP-FR-B24HR 7.2E-004	COMMON CAUSE FAILURE OF MDP 1A AND 1B TO START RHR-CCF-FS-MDPAB 4.5E-004	INSUF FLOW DUE TO BACKLEAKAGE THRU MDP RHR1A RHR16
--	---	--	---	--	--	---

INSUF FLOW THRU SEGMENT PS1, PMP SUCTION EM LP1 RHR14	MANUAL VALVE XV6 PLUGGED RHR-XVM-PG-XV6 4.4E-004	FAILURE OF 4 KV AC STUB BUS 1J ACP-TAC-LP-STB1J	FAILURE OF 120V DC BUS 1B DCP-TDC-LP-BUS1B	INSUFFICIENT COMPONENT COOLING FROM CCW CCW1	RHR MDP 1A FAILS TO START ON DEMAND RHR-MDP-FS-RHR1A 3.0E-003	BACKFLOW THROUGH CV11 RHR-CKV-00-CV11 1.0E-003
---	---	---	--	---	---	---

Page 2

INSUF FLOW
THRU SEGMENT
PS1, PMP SUCTION
EM LP1
RHR14

Transfers from Page(s) 2 3

INSUF FLOW THRU SEGMENT PS1, PMP SUCTION CONTD RHR15	FAILURE OF 480V AC MCC 1J1-2 ACP-TAC-LP-1J1-2	FAILURE OF 480V AC MCC 1H1-2 ACP-TAC-LP-1H1-2
--	---	---

RHR MOTOR OPERATED VALVE 1700 RHR-MOV-PG-1700 4.0E-005	RHR MOV 1700 FAILS TO OPERATE ON DEMAND RHR-MOV-FT-1700 3.0E-003	RHR MOTOR OPER VALVE 1701 PLUGGED RHR-MOV-PG-1701 4.0E-005	RHR MOV 1701 FAILS TO OPEN ON DEMAND RHR-MOV-FT-1701 3.0E-003
--	--	--	---

B-138

INSUFFICIENT
FLOW THROUGH
SEGMENT PS2 PTRNA
RHR11

Tree: RHR
Project: SURRY
Page 3 of 5
Date Last Modified:
Thu Aug 18 13:33:18 1988

Transfer from Page 2

INSUF FLOW
THROUGH SEGMENT
PS2 PTRN A CONTD
RHR12

MANUAL VALVE XV8
PLUGGED
RHR-XVM-PG-XV8
○ 4.4E-004

CHECK VALVE CV11
FAILS TO OPEN
RHR-CKV-FT-CV11
○ 1.0E-004

RHR MDP 1A FAILS
TO START ON
DEMAND
RHR-MDP-FS-RHR1A
○ 3.0E-003

RHR MDP 1A FAILS
TO RUN 24 HOURS
RHR-MDP-FR-A24HR
○ 7.2E-004

COMMON CAUSE
FAILURE OF MDP 1A
AND 1B TO START
RHR-CCF-FS-MDPAB
○ 4.5E-004

INSUF FLOW DUE
TO BACKLEAKAGE
THRU MDP RHR1B
RHR17

INSUF FLOW
THRU SEGMENT
PS1,PMP SUCTION
EM LP1
RHR14

MANUAL VALVE XV12
PLUGGED
RHR-XVM-PG-XV12
○ 4.4E-004

FAILURE OF 4 KV
AC STUB BUS 1H
ACP-TAC-LP-STB1H
◇

FAILURE OF 120V
DC BUS 1A
DCP-TDC-LP-BUS1A
◇

INSUFFICIENT
COMPONENT COOLING
FROM CCW
CCW1
◇

RHR MDP 1B FAILS
TO START ON
DEMAND
RHR-MDP-FS-RHR1B
○ 3.0E-003

BACKFLOW THROUGH
CV5
RHR-CKV-OO-CV5
○ 1.0E-003

△ Page 2

B-139

INSUFFICIENT
FLOW THROUGH
SEGMENT PS5, HX
E1B
RHR7

Transfer from Page 1

SEGMENTS PS4
AND 5 COMMON
FAULTS
RHR8

MANUAL VALVE XV20
PLUGGED
RHR-XVM-PG-XV20

MANUAL VALVE XV24
PLUGGED
RHR-XVM-PG-XV24

RHR HEAT
EXCHANGER E1B
PLUGGED.
RHR-HTX-PG-E1B

RHR HEAT
EXCHANGER E1B
TUBE LEAKS
RHR-HTX-LK-E1B

△ Page 2

○ 4.4E-004

○ 4.4E-004

○ 1.4E-004

○ 7.2E-005

Tree: RHR
Project: SURRY
Page 4 of 5
Date Last Modified:
Thu Aug 18 13:33:18 1988

B-140

INSUF FLOW
FROM SEGMENT PS9,
DISCH TO LOOP 3

RHR3

Transfer from Page 1

INSUF FLOW
THROUGH SEGMENT
PS 7, HX DISCH HDR

RHR4

△ Page 1

CHECK VALVE
CVRC24 FAILS TO
OPEN.

RHR-CKV-FT-RC24

○ 1.0E-004

FAILURE OF 480V
AC MCC 1J1-2

ACP-TAC-LP-1J1-2

◇

RHR MOV 1720B
FAILS TO OPERATE
ON DEMAND.

RHR-MOV-FT-1720B

○ 3.0E-003

RHR MOTOR
OPERATED VALVE
1720B PLUGGED.

RHR-MOV-PG-1720B

○ 4.0E-005


COMMON CAUSE
FAILURE OF RHR
MOVS 1720A, 1720B

RHR-CCF-FT-720AB


○ 2.6E-004

Tree: RHR
Project: SURRY
Page 5 of 5
Date Last Modified:
Thu Aug 18 13:33:18 1988



Tree: W
 Project: SURRY
 Page 1 of 2
 Date Last Modified:
 Wed Jul 06 13:12:36 1988










B-142









Transfer from Page 1



Page 2



Transfer from Page 2



B-143

APPENDIX C

Human Reliability Analysis - Detailed Results

Table of Contents

<u>Section</u>	<u>Page</u>
C. Human Reliability Analysis - Detailed Results	C-3
C.1 Pre-Initiator Error Analysis	C-3
C.2 Post-Initiator Error Analysis	C-3

List of Tables

C-1 Feed and Bleed Cooling Sequences	C-10
C-2 Station Blackout Sequences	C-22
C-3 SGTR with a Faulted SG Sequence	C-34
C-4 SGTR with HPI Failure Sequence	C-46
C-5 Large and Intermediate LOCA Recirculation Sequences	C-58
C-6 Small and Very Small LOCA ECCS Sequences	C-70
C-7 CPC Service Water Failure During LOCA Sequences	C-82
C-8 ATWS Sequences	C-94

C. Human Reliability Analysis - Detailed Results

This appendix contains the analysis performed to calculate the probabilities for human actions used in the revised Surry probabilistic risk assessment (PRA). This section presents the detailed results of the Human Reliability Analysis (HRA) described in Section 4.8 of the main report. Two types of human errors, pre-initiator and post initiator, were studied for the PRA.

Pre-initiator error analysis was entirely concerned with miscalibration errors and equipment restoration errors. Human actions which lead to these errors were done under normal plant operating conditions with stress levels appropriate for everyday work environments. The calculation of error probabilities for these actions was concerned with the adequacy of the maintenance and inspection procedures, the dependence of related tasks, and the administrative redundancy of restoration procedures. The pre-initiator analysis is detailed in Section C.1.

The other category of human errors was post-initiator errors. Post-initiator error analysis was concerned with human errors made in response to the mitigation of an initiating event. The human actions from which these errors derive were procedure directed. Calculation of error probabilities for these actions was primarily concerned with the amount of time available to complete the task, the stress level under which the task was performed, and the amount of redundant verification that was possible within the allowable time period. The post-initiator error analysis is detailed in Section C.2.

C.1 Pre-Initiator Error Analysis

The pre-initiator error analysis started with the establishment of a set of screening criteria. The screening criteria determined which systems were susceptible to pre-initiator errors. Only two pre-initiator errors survived the screening process. These were restoration of the containment spray pump test lines and miscalibration of the RWST level sensors. A more detailed discussion of the screening process and the two pre-initiator errors is contained in Section 4.8 of the main report.

C.2 Post-Initiator Error Analysis

Post-initiator human actions are those operator actions performed after the accident has started. The methodology used to evaluate post-accident human actions is described in detail in reference C-1. In summary, the evaluation was performed in eight major steps:

- (1) Identification of the sequence and subsequent accident conditions.
- (2) Based on the cut set (and sequence), the timing of the events (i.e., occurrences, failures, alarms, indications, etc.) was established.
- (3) Based on the cut set (and sequence), the symptoms and therefore the possible recovery actions (and required activities) were identified.
- (4) The time available to the operator to diagnose and perform the action (and activities) was established.
- (5) The probability of the operator failing to properly diagnose the accident was determined. This considered operator training, simulator exercises, and other factors.

- (6) The type of recovery action (whether 'dynamic' or 'step-by-step') was determined by the plant using symptom-oriented procedures or not, and operator training, etc.
- (7) The stress level of the operator was determined, considering the time available, difficulty of the action, and training.
- (8) The probability of the operator failing to perform the recovery action was evaluated.

In evaluating the accident sequences for potential recovery credit, the HRA process was documented in a series of eleven tables, as follows:

- (1) The first table identifies the accident sequence with a detailed description of the accident scenario.
- (2) The second table establishes the timing of the accident: timing of the events, annunciators, and alarms.
- (3) Based on Table 1, this third table identifies the symptoms, potential recovery actions, and those activities associated with them.
- (4) The time available for the operator to perform the recovery action is determined and shown in Table 4.
- (5) The time it takes the operator to perform the action is calculated in Table 5.
- (6) The amount of time the operator has to diagnose problems is displayed in Table 6.
- (7) Diagnosis error probabilities are evaluated and documented in two tables (Table 7, more than one abnormal event, and Table 8, one abnormal event).
- (8) Table 9 identifies the 'type' of action the operator performed.
- (9) The 'stress' level of operators, considering the accident sequence, is documented in Table 10.
- (10) Using the information from the previous tables, the probability of the operator failing to recover from the faults of the accident sequence is evaluated in Table 11.

The event identifiers with an HRA subscript represent the HRA portion of a recovery action. See Section 4.9 for the hardware contribution and the total unavailability. The event identifiers without subscripts represent basic events whose sole contributor is an HRA unavailability. The notes that describe each column in the tables are presented below.

Table 1 Notes:

- (1) This should include a detailed description of the accident sequence under consideration -- what functions and systems are failing and succeeding, what phenomena are occurring because of the failures and successes and their resulting effects, what is the final outcome of the sequence, etc.
- (2) The basic accident type is described here.
- (3) Because of the accident type and the "symptoms" of the accident, certain immediate conditions, (i.e., entry conditions) are generated (e.g., reactor trip, low reactor water level, high drywell pressure, etc.). These immediate conditions are listed here.
- (4) From the accident conditions or symptoms, the operator is immediately directed into certain EOPs. These are listed here. Additionally, other relevant procedures are also listed here.

Table 2 Notes:

- * See Step #1, page 6-9 and Step #3, page 8-3 of ASEP HRA procedures.
- (1) Identify the major events which are expected to comprise the accident sequence.
 - (2) Identify the time at which each event is expected to occur, beginning with the initiating event at T=0. Subsequent events are expressed in minutes following the initiating event.
 - (3) Identify any annunciators or other indicators notifying the operators that each event has occurred.
 - (4) Provide any additional comments which serve to clarify information on this table, as required.

Table 3 Notes:

- * See Step #2, page 6-10 and Step #4, page 8-3 of ASEP HRA procedures.
- (1) Identify the principal component functional failures which comprise the cut sets for the accident sequence.
 - (2) Identify the specific symptoms which will indicate to the operators that the component functional failure has occurred.
 - (3) Identify all actions which may be taken by the operator in response to each component functional failure.
 - (4) Identify the individual activities (tasks) which comprise each potential operator action. List only significant operator actions as opposed to decisions, diagnoses, etc.
 - (5) Any additional comments required to clarify the information on this table.

Table 4 Notes:

- (1) The actions listed in Column 3, Table 3, are listed here.
- (2) The last possible time at which, if the operator establishes the required function, subsequent core damage is prevented.
- (3) In many cases, the operator is not alerted to the failure at the time of the initiator. List the time at which the operator recognizes that the failure has occurred.
- (4) The difference between the time in which the operator must successfully perform the action following the initiating event and the time at which the operator recognizes that the action must be taken. $T_{cd} - T_o = T_m$

Table 5 Notes:

- * See Step #3, page 6-10 and Steps #5, 6, and 7, pages 8-3 and 8-4 of ASEP HRA procedures.
- (1) The major activities (tasks) which comprise the operator actions are listed.
 - (2) Identify the location in which each activity must be performed.
 - (3) Identify the travel time required for an operator to transit from his likely location at the time the requirement for the action is recognized to the location at which the activity must be performed. Assume that the operator knows the proper location.
 - (4) Identify the time which is required to perform the activity, given that the operator has reached the location at which the activity must be performed. Assume that the operator knows how to perform the required activity. Any anticipated difficulties or complexities should be reflected in this estimate.

Table 6 Notes:

- * See Step #4, page 6-10 and Step #7, page 8-4 of the ASEP HRA procedures.
- (1) T_m is determined in Table 4.
 - (2) T_a is determined in Table 5
 - (3) Time available to diagnoses is equal to T_m less T_a .
 - (4) Any additional comments required to clarify the information in this table.

Table 7 Notes:

- * See Step 9, pages 8-4 to 8-7 of the ASEP HRA procedures.
- (1) In order to accomplish the action, if the operator must diagnose for each activity, the probability of mis-diagnosis for each activity needs to be determined.
- (2) If the analyst can determine that the probability of the operator failing to diagnose the event is negligible, then remainder table is not applicable. Reasons for determining that the diagnosis error is negligible should be discussed in the comment column.
- (3) See Table 3 for definition of abnormal event.
- (4) If there is more than one abnormal event, there is the probability that the operator will fail to recognize an additional occurrence of another event. Therefore, the probability that the signal of subsequent abnormal events are not noticed needs to be estimated. These HEPs are added to the final HEP. At the time of the second, third, etc. abnormal event, you need to determine the total number of annunciators being alarmed. Read down the column marked "Number of ANNs" to the total number of annunciators you have determined, then read straight across to the column marked $Pr(F_1)$, this is the HEP that the operator will fail to respond to the signal of the second, etc. abnormal event in the midst of the other annunciators.
- (5) Based on Td (from Table 6) an initial HEP for failure to diagnose is selected from Table 8-2. Use mean value.
- (6) Indicate whether or not the action is "skill-based" as defined in Table 2-1, Page 2-6 of the ASEP HRA procedures.
- (7) It is assumed that mis-diagnosis of scram is "epsilon" ($1E-4$). The HEP for each action (or activity) should be adjusted accordingly (up or down) depending on whether the event is covered in training, the event is practiced by the operators, the event is well recognized and interviews indicate that all operators are familiar with the accident, the event is practiced by the operators in simulator requalification exercises and the complexity of sequence (e.g., conflicting readings). To adjust the HEP upward and downward, use the associated error factor to adjust.
- (8) Any additional comments required to clarify the information in this table.

Table 8 Notes:

- * See Step 9, pages 8-4 to 8-7 of the ASEP HRA procedures.
- (1) List the actions identified in Table 3, Column 3 which are part of one abnormal event.
- (2) If the analyst determines that the probability of the operator failing to diagnose the event is negligible, then the remainder of the table is not applicable. Reasons for determining that the diagnosis error is negligible should be discussed in comment column.

- (3) Based on Td (from Table 6), an initial HEP for failure to diagnoses is selected from Figure 8-1. Use mean value.
- (4) Indicate whether or not the action is "skill-based" as defined in Table 2-1, page 2-6 of the ASEP HRA procedures.
- (5) It is assumed that mis-diagnosis of scram is "epsilon" ($\leq 1E-4$). The initial HEP is adjusted downward (use lower bound) or upward (use upper bound) depending on whether the plant uses symptom-oriented EOPs, event is covered in the EOPs, operators are trained on the EOPs and the EOPs are well designed. Additionally, the HEP for each action (or activity) should be adjusted to reflect any special complexity of the sequence (e.g., conflicting readings).
- (6) Any additional comments required to clarify the information in this table.

Table 9 Notes:

- * See Step #10, pages 8-7 and 8-8 in the ASEP HRA procedures.
- (1) List the actions identified in Table 3, Column 3.
 - (2) List any safety systems that were functioning and then failed.
 - (3) Indicate whether or not EOPs are well designed, operators use EOPs, and operators are well trained on procedures.
 - (4) Indicate whether or not an individual operator performs more than one safety function using a system without good indication (cues) that he must shift from one activity to another.
 - (5) If any safety systems fail after initially operating (#2), EOP design or training is not adequate (#3), or if operator performs more than one function (#4) without adequate indication, then the action (or activity) should be classified as "dynamic" and not "step-by-step". Generally, step-by-step is defined as a routine, procedurally-guided set of steps when performed one-at-a-time.
 - (6) Any additional comments required to clarify the information in this table.

Table 10 Notes:

- * See Step #10, pages 8-7 and 8-8 in the ASEP HRA procedures.
- (1) List the actions identified in Table 3, Column 3.
 - (2) Indicate whether or not the time available to diagnose and perform the action (activities) is less than two hours.
 - (3) Indicate whether or not more than two safety systems fail in the course of the sequence.

- (4) Indicate whether or not operator is very experienced in the sequence, regardless of items 2 and 3 above.
- (5) Extremely high stress is assessed if the response to Items #2 or #2 is yes and the response to item #3 is no. However, if Item #4 is yes, moderately high stress can be assessed. Additionally, the stress should be adjusted accordingly, taking into account such things as "degree of burden", complexity of action (activity), action (activity) needs to be performed "quickly", action location not easily accessible, etc. Any PWR large LOCA is presumed to involve extremely high stress until recirculation is established.
- (6) Any additional comments required to clarify the information in this table.

Table 11 Notes:

* See Table 8-5, pages 8-13 and 8-14 in the ASEP HRA procedures.

- (1) List the actions identified in Table 3, Column 3
- (2) List the activities (tasks) which comprise each action as identified in Table 3, Column 4.
- (3) The failure probability of the original operator performing the activity. The HEP is based on whether the activity is step-by-step, dynamic, moderately high stress, extremely high stress (refer to Tables 9 and 10). The HEP is taken from either Item #3, #4, or #5 of Table 8-5 of the ASEP HRA procedures.
- (4) If recovery of the activity (action) made by the original operator is possible, identify the probability that a second person (generally the shift supervisor) fails to correct the original operator. This HEP is based on whether the activity is step-by-step, dynamic, moderately high stress, extremely high stress (refer to Tables 9 and 10). The HEP is taken from either Item #6, #7, or #8 of Table 8-5 of the ASEP HRA procedures.
- (5) If the accident sequence is such that a third independent check (e.g., accident management team, second shift, etc.) is performed, the probability for failing to do so is assessed. This HEP is based on whether the activity is step-by-step, dynamic, moderately high stress, extremely high stress (refer to Tables 9 and 10). The HEP is taken from Item #6, #7 or #8 of Table 8-5 of the ASEP HRA procedures.
- (6) The probability of failing to perform an action is the multiplication of the HEPs of Items #3, #4, and #5.
- (7) Any comments required to clarify the information in this table.

C. Reference

- C-1 A.D. Swain, Accident Sequence Evaluation Program Human Reliability Analysis Procedure, NUREG/CR-4772, February 1987.

Table C-1
Feed and Bleed Cooling Sequences

The following sheets calculate human error probabilities for:

AFW-XHE-F0-UNIT2_{HRA} - Failure to cross connect AFW from Unit 2

HPI-XHE-F0-FDBLD - Failure to initiate HPI for feed and bleed

PPS-XHE-F0-PORVS - Failure to open PORVs for feed and bleed

for S₃, T₂, T₃, and T₁ sequences with two DGs operable.

TABLE 1

ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: T₁, T₂, T₃

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: T₁LD₂ / T₁LP / T₂LD₂ / T₂LP / T₃LMD₂ / T₃LMP / S₃LMP

SEQUENCE DESCRIPTION:

(1)

Turbine trip with or without main feedwater is the initiating event. Main feedwater will be isolated when T_{AVE} reaches 543°F - which is shortly after turbine trip. After immediate post trip recovery, operator will attempt to restore MFW via opening of the main feed regulating bypass valves, or will go to AFW. If this is unavailable, he will go to AFW at Unit 2. [AFW from Unit 1 will start automatically on low steam generator water level]. If AFW from Unit 2 is unavailable, he will go to feed and bleed, using at least one charging pump and 2 PORVs.

APPLICABLE PROCEDURES:

(4)

- EP 1.0 - Reactor Trip or SI
- EP1.01 - Reactor Trip Recovery
- FRP H.1 - Loss of Secondary Heat Sink

TABLE 2
SEQUENCE AND CUT SET TIMING*

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. Reactor trip/turbine trip	t = 0	Yes	
2. Main feedwater isolate	t = 3m		
3. Operator attempts to restore MFW thru bypass valve	t = 5m		
4. Lo level in SG	t = 10m	Yes	
5. AFW - Unit 1 fails to start	t = 10m	Yes	
6. Operator attempts AFW from Unit 2	t = 15m		
7. Operator fails to initiate feed and bleed	t = 35m		

C-12

TABLE 3

CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	POTENTIAL OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Loss of MFW		AFW from Unit 1	1) start pumps	
2. Loss of AFW-U1	a) no flow b) lo SG level	AFW from Unit 2	1) close 251 valves at Unit 2 2) open 160 A/B MOV 3) start AFWP at Unit 2	
3. Loss of AFW-U2	a) no flow b) lo SG level	Feed and bleed	1) start charging pump 2) open both PORVs and block valves if necess.	

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

CUT SETS:

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT TO PREVENT SUBSEQUENT CORE DAMAGE (T _{cd}) (2)	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (T _o) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (T _m) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
AFW-XHE-FO-UNIT2 HRA	35m	10m	25m	
HPI-XHE-FO-FDBLD	35m	15m	20m	
PPS-XHE-FO-PORVS	35m	15m	20m	

C-14

TABLE 5

OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (Ta) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
AFW-XHE-FO-UNIT2 _{HRA}						
	a) close 251 valves	CR	1m	1m	2m	
	b) open 160 A/B vlv	CR	--	1m	2m	
	c) start AFW P	CR	--	1m	<u>1m</u> 4m	- It actually can all be done in 2 minutes or less.
PPS-XHE-FO-PORVS						
	open PORVs	CR	1m	1m	2m	
HPI-XHE-FO-FDBLD						
	start charging pumps	CR	1m	1m	2m	

C-15

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

SEQUENCE/CUT SET	MAXIMUM TIME AVAILABLE (T _m) (1)	TOTAL ACTION TIME (T _a) (2)	TIME AVAILABLE TO DIAGNOSIS (T _d) (3)	COMMENTS/ SOURCE OF INFORMATION (4)
AFW-XHE-FO-UNIT ₂ HRA	25m	2m	23m	
HP1-XHE-FO-FDBLD	20m	2m	18m	
PPS-XHE-FO-PORVS	20m	2m	18m	

TABLE 7

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
----------------------------	--------------------------------	----------------------------------	--	--	------------------------	-----------------------------------	--

NOT APPLICABLE

TABLE 8
DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLECTIBLE (2)	FAILURE TO DIAGNOSE (Figure 8-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
AFW-XHE-FO-UNIT2 _{HRA}	Yes				This is procedure directed by FRP H,1; which will be entered directly on low feed flow.
Feed and bleed	Applicable to sequences where F&B is required because of operator errors involving AFW.	2.66E-2			If AFW at Unit 2 is unavailable because of mechanical failures, the operator would recognize this and go to the next steps in the procedure which tell him to feed and bleed. If the operator makes an error in alignment of AFW from U2, then he must diagnose that an error has been made. The STA will be monitoring the core status trees and will have the opportunity to recognize that there is no AFW.

C-18

POST-DIAGNOSIS ACTION-TYPE IDENTIFICATION*

CUT SETS:

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
AFW - U2	1	Yes	Yes	Step by Step	
Feed and bleed	1	Yes	Yes	Step by Step	If AFW has previously failed due to operator error, the time to do feed and bleed is shortened and time stress is present.

C-19

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

CUT SETS:

ACTION (Activities) (1)	Tm 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
AFW - Unit 2	NA	No	Yes	Moderate	
Feed and bleed	NA	No	Yes	Moderate	

C-20

TABLE 11
POST-DIAGNOSIS ANALYSIS*

CUT SETS:

ACTION (1)	ACTIVITIES (2)	ORIGINAL OPERATOR HEP (3)	SUPERVISOR FAILS TO CORRECT OPERATOR HEP (4)	THIRD INDEPENDENT CHECK/CORRECTION HEP (5)	TOTAL HEP (6)	COMMENTS/ SOURCE OF INFORMATION (7)
AFW - U2	a) close 251 valves	3.2E-2	3.2E-1		1.04E-2	
	b) open 160 valves	3.2E-2	3.2E-1		1.04E-2	
	c) start pumps	3.2E-2	3.2E-1		<u>1.04E-2</u> 3.1E-2	
C-21 HPI-XHE-FO-FDBLD	start HPI pump	6.4E-2	6.4E-1		4.1E-2	
PPS-XHE-FO-PORVS (after previous oper. error)	open PORV	6.4E-2	6.4E-1		4.1E-2	
HPI-XHE-FO-FDBLD	start HPI pump	3.2E-2	3.2E-1		1.04E-2	
PPS-XHE-FO-PORVS (no previous oper. error)	open PORV	3.2E-2	3.2E-1		1.04E-2	

Table C-2
Station Blackout Sequences

The following sheets calculate human error probabilities for events during a station blackout. These are:

- 0 - Operator fails to depressurize and cooldown the RCS
- AFW-CST-F0-CST2_{HRA} - Operator fails to connect CST #2 to the emergency CST - in the event of a stuck open SG safety valve.
- AFW-XHE-F0-U2SBO - Operator fails to feed both units with one turbine driven AFW pump.
- AFW-XHE-F0-U1SBO_{HRA} - Operator fails to cross connect AFW from Unit 2, when U-2 has the TDP and a MDP operable,
- REC-XHE-F0-SCOOL - Operator fails to cross connect seal cooling from Unit 2.
- MCW-CCF-VF-SBO_{HRA} - Failure to isolate condenser water box to supply service water to CPC suction.

ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: T_{1S} - Station Blackout

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: T_{1S}-L / T_{1S}-Q_S / T_{1S}-O / T_{1S}-W₂

SEQUENCE DESCRIPTION:

(1)

Loss of offsite power is the initiating event. Both diesels are unavailable to Unit 1. For some sequences, Unit 2 may have power. The four sequences listed above involve different failures. In T_{1S}-L, the turbine driven AFW pump from Unit 1 is unavailable. In sequence T_{1S}-Q_S, a SG-SV fails to reclose, leading to uncontrolled blowdown in one SG. This leads to a greater AFW demand. The operator must manually align the normal CST to the emergency CST in order to assure long term feedwater supply. The third sequence (T_{1S}-O) is an extended SBO where the operators fail to cooldown and depressurize the RCS. This is not a critical failure in itself, but does affect the timing of other sequences. The fourth sequence represents failure to provide seal cooling from Unit 2.

APPLICABLE PROCEDURES:

(4)

ECA - 1.0 Loss of all AC power
AP - 11 Station Blackout

TABLE 2
SEQUENCE AND CUT SET TIMING*

CUT SETS:

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. Loss offsite power	t = 0	Yes, Many	
2. All DG unavailable	t = 1m	Yes	
3. AFW-TDP - Unit 1 unavailable	t = 1m	Yes	
4. Stuck open SG-SV	t = 5m, 25m, 45m	Yes	
5. Operator fail to depressurize	t = >1 hr	No	
6. SW Intake canal fail to isolate	t = 1m	Yes	

C-24

CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	POTENTIAL OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Loss AFW-U1	a) TDP not operable b) no AFW flow	cross connect from Unit 2	a) start TDP b) open cross connect valves c) balance flow by manually throttle valves	
2. Stuck open SG-SV	a) continued loud noise in yard b) uncontrolled decrease in SG pressure	cross connect CST to ensure AFW feed supply	a) isolate CST from hotwell b) open CST transfer valves to emergency CST	
3. Station Blackout	No AC power	Operator directed to cooldown RCS	a) manual line up of valves- bypass MSTV, dump to condenser - vent condenser	
	Cross connect RCP seal cooling from Unit 2	a) open valves in cross tie header b) throttle valves on Unit 2 to balance flows between headers. c) isolate condenser water boxes to provide suction source for CPC pumps	a) assumes only one pump is operable at Unit 2.	

C-25

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

CUT SETS:

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT TO PREVENT SUBSEQUENT CORE DAMAGE (T _{cd}) (2)	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (T _o) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (T _m) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
0	NA	NA	NA	
AFW-CST-FO-CST	100m	5m	95m	
AFW-XHE-FO-U1SBO AFW-XHE-FO-U2SBO	35m	5m	30m	
REC-XHE-FO-SCOO	90m	5m	35m	
MCW-CCF-VF-SBO	90m	5m	85m	

C-26

OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (Ta) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
0	a) Bypass MSTV b) Close x-tie c) Open bypass d) Open hoppers	Local Local Local Local	10 10 10 10	10 10 10 10	20 20 20 20 <u>30m</u>	Multiple people perform these tasks. Travel time additive.
AFW-CST-FO-CST2 HRA	a) Isolate CST2 from hotwell b) X-tie CST2 to CST1A	Local Local	10 10	10 10	20 <u>20</u> 30	Travel time is not additive.
C-27 AFW-XHE-FO-U1SBO HRA	a) Isolate headers at Unit 2 b) Open X-tie valves	CR CR	1m 1m	5m 2m	6 3	
AFW-XHE-FO-U2SBO	a) throttle dis- charge valves to balance flows	Local	10m	continual	NA	
REC-XHE-FO-SCOOOL	a) open x-tie valves b) throttle valves at U-2 to balance flow	Local CR	10m 1m	10m continual	20m NA	
MCW-CCF-VF-SBO HRA	a) manually close condenser isol. valve	Local	10m	45m	55m	

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

SEQUENCE/CUT SET	MAXIMUM TIME AVAILABLE (T _m) (1)	TOTAL ACTION TIME (T _a) (2)	TIME AVAILABLE TO DIAGNOSIS (T _d) (3)	COMMENTS/ SOURCE OF INFORMATION (4)
0	NA	30m	NA	
AFW-CST-FO-CST2 _{HRA}	95m	30m	65m	
AFW-XHE-FO-U1SBO _{HRA}	30m	10m	20m	
AFW-XHE-FO-U2SBO	30m	NA	20m	
REC-XHE-FO-SCOOOL	85m	20m	65m	
MCW-CCF-VF-SBO _{HRA}	85m	55m	30m	

TABLE 7

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
----------------------------	--------------------------------	----------------------------------	--	--	------------------------	-----------------------------------	--

NOT APPLICABLE

TABLE 8
DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	FAILURE TO DIAGNOSE (Figure 8-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
0	Yes				
AFW-XHE-FO-CST _{HRA}	Yes				
AFW-XHE-FO-U1SBO _{HRA}	No	2.66E-2	No		Diagnosis error Included because operator must realize the normal cross connect alignment is not possible. Must figure a way to cross connect with Inoperable motor operated valves.
AFW-XHE-FO-U2SBO	Yes				In these events, flow balancing is a continual action. It is considered dynamic due to the circumstances, and thus assigned a higher failure rate. The confusion error is therefore included in the dynamic action error.
REC-XHE-FO-SCOOL	Yes				
MCW-CCF-VF-SBO _{HRA}	No	2.66E-2	No		Diagnosis error assigned to account for operator failure to correctly diagnose which condenser should be isolated.

C-30

TABLE 9
POST-DIAGNOSIS ACTIVITY TYPE IDENTIFICATION*

CUT SETS:

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
0		Yes	No	Step by Step	
AFW-XHE-FO-CST2 _{HRA}		Yes	No	Step by Step	
AFW-XHE-FO-U1SBO _{HRA}		Yes	No	Step by Step	
AFW-XHE-FO-U2SBO			Yes	Dynamic	
REC-XHE-FO-SCOOL			Yes	Dynamic	
MCW-CCF-VF-SBO _{HRA}			No	Step by Step	

C-31

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

CUT SETS:

ACTION (Activities) (1)	T _m 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
0	No	--	--	Moderate	
AFW-XHE-FO-CST2 _{HRA}	No	--	--	Moderate	
AFW-XHE-FO-U1SBO _{HRA}	No	--	--	Moderate	
AFW-XHE-FO-U2SBO	No	--	--	Moderate	
REC-XHE-FO-SCOOL	No	--	--	Moderate	
MCW-CCF-VF-SBO _{HRA}	No	--	--	Moderate	

C-32

LE 11
POST-DIAGNOSIS ANALYSIS*

CUT SETS:

ACTION (1)	ACTIVITIES (2)	ORIGINAL OPERATOR HEP (3)	SUPERVISOR FAILS TO CORRECT OPERATOR HEP (4)	THIRD INDEPENDENT CHECK/CORRECTION HEP (5)	TOTAL HEP (6)	COMMENTS/ SOURCE OF INFORMATION (7)
0	a) Bypass MSTV	.032	.32	--	.011	
	b) Close x-tie	.032	.32	--	.011	
	c) Open bypass	.032	.32	--	.011	
	d) Open Hoggers	.032	.32	--	.011	
					<u>.044</u>	
AFW-XHE-FO-CST2 _{HRA}	a) Isolate CST2 from hotwell	.032	--	--	.032	
	b) X-tie CST2 to CST1A	.032	--	--	.032	
					<u>.064</u>	
AFW-XHE-FO-U1SBO _{HRA}	a) Isolate headers at U-2	.032	.32	--	.011	
	b) open X-tie valves	.032	.32	--	.011	
					<u>.022</u>	
AFW-XHE-FO-U2SBO	a) open X-tie	.032	.32	--	.011	
	b) throttle dis- charge vlvs	.08	.8	--	.064	
					<u>.075</u>	
REC-XHE-FO-SC00L	a) open X-tie	.032	--	--	.032	
	b) close MOV 1287C	.032	.32	--	.0104	
	c) throttle vlvs at U-2 to balance flow	.08	.8	--	.064	
	d) start HPI pp	.032	.32	--	.0104	
	e) start CPC pp	.032	.32	--	.0104	
					<u>.127</u>	
MCW-CCF-VF-SBO _{HRA}	a) close condenser Isol valves	.032	--	--	.032	

C-33

Table C-3
SGTR with a Faulted SG Sequence

These tables explain the derivation of human error probabilities for the following events:

- | | |
|---------------------------------|--|
| MSS-XHE-FO-BLOCK | - Manually isolate block valve on SG ADV |
| MSS-XHE-FO-ISAFW _{HRA} | - Manually close AFW TDP steam supply valve |
| MSS-XHE-FO-ISBLDN | - Manually close isolation valve on SG blowdown line |
| RCS-XHE-FO-DPRT7 | - Depressurize RCS in time to prevent pressure relief demand in SG |
| REC-XHE-FO-DPRES | - Cooldown and depressurize the RCS in time to prevent break flow. |

They all appear at various times in T_{70DQS} and T_{70DQQS}

ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: T₇ - Steam Generator Tube Rupture

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: T₇O_DQ_S, T₇O_DQQ_S

SEQUENCE DESCRIPTION:

(1)

Steam generator tube rupture of 600 gpm. Safety Injection comes on due to low pressurizer pressure. Ruptured steam generator (SG) starts to be pressurized due to break flow. Operator is expected to close MSIV on high radiation indication. In order to mitigate the accident, the operator must depressurize the reactor to a pressure less than the SG-SV and ADV set point; and isolate all other lines which represent blowdown paths from the SG. In this sequence the operator fails to depressurize the RCS and the ruptured SG loses its integrity (becomes faulted) thus leading to uncontrolled blowdown from the RCS. The operator error in this case represents the failure to depressurize before a SG-RV (SV or ADV) demand. Should this event occur and should there be an uncontrolled blowdown, there is still an additional 8-10 hours to recover. Recovery can be accomplished by isolation of the faulted SG (if possible) or RCS depressurization to a point where the break flow is of little consequence. Additionally, in T₇O_DQQ_S an RCS PORV sticks open.

C-35

APPLICABLE PROCEDURES:

(4)

- EP 1.0 - Reactor Trip
- EP 4.0 - Steam Generator Tube Rupture
- EP 3.0 - Faulted Steam Generator Isolation
- ECA 4.01 - SGTR with Loss of Reactor Coolant, Subcooled Recovery

TABLE 2
SEQUENCE AND CUT SET TIMING*

T_{7D00}S, T_{7D00}S

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. Steam generator tube rupture	t = 0	high condenser radiation low pressurizer pressure	
2. Safety Injection	t = 0 +	many	
3. SG blowdown line fail to close	on SI	indicated in CR	
4. AFW TDP - steam valve fail to close	< 10m	none	
5. SG pressure relief demand	45m after oper closes MSIV	noise opening indicated in CR	Operator assumed to close MSIV soon
6. SG ADV opens and sticks	45m	position indicated in CR	
7. SG SV opens and sticks	45m		

C-36

CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	REQUIRED OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. SGTR	See Table 2 - #1	Must depressurize RCS to terminate break flow and isolate SG	<ol style="list-style-type: none"> 1. Oper. must cooldown by dumping steam 2. Enhanced AFW is desired, but not necessary 3. After he cooldown 50°F or more, can begin depressurization 4. Must depressurize using pwr. spray, PORV, or aux spray 	
2. Stuck open ADV	<ol style="list-style-type: none"> a) uncontrolled SG pressure drop b) position indicated in CR c) loud noises in yard 	<ol style="list-style-type: none"> Close block valve or depressurize RCS to terminate inventory loss 	<ol style="list-style-type: none"> 1. Locally close valve 2. Cooldown and depressurize within 8 hours 	
3. Stuck open SV	<ol style="list-style-type: none"> a) uncontrolled SG pressure drop b) loud noises in yard 	<ol style="list-style-type: none"> Depressurize RCS to terminate inventory loss 	<ol style="list-style-type: none"> 1. Cooldown and depressurize within 8 hours 	
4. Stuck open SG blowdown line	<ol style="list-style-type: none"> a) indicated in CR 	<ol style="list-style-type: none"> a) Manual close valve b) Close block valve c) depressurize 	same as column 3	
5. Fail to close AFW-TDP steam supply valve	<ol style="list-style-type: none"> a) none 	<ol style="list-style-type: none"> a) stop TD pump b) close supply valve c) depressurize 	same as column 3	

C-37

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (T _o) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (T _m) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Depressurize to prevent SG pressure relief demand	45m	5m	40m	
2. Close SG ADV block	10hr	50m	9h 10m	
3. Close AFW TDP supply	10hr	15m	9h 45m	
4. Close SG blowdown	10hr	10m	9h 50m	
5. Depressurize to conserve RCS/RWST Inventory	10hr	50m	9h 10m	

C-38

TABLE 5
OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (Ta) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Depressurize to prevent SG SV/RV demand	a) Open stm dump or SG-PORV	CR	--	1m	25m	Although the actions are very quick and simple, the reactor takes time to depressurize and cooldown. It is estimated that cooldown and depressurization will take 25m. At North Anna it was accomplished in 12m, at Ginna it wasn't done by 27m.
	b) Depressurize RCS via spray or PORV	CR	--	1m	25m	
2. Close SG ADV block	a) manually close valve	local	10m	10m	20m	
3. Close AFW TDP supply	a) close valve	local	10m	10m	20m	
4. Close SG blowdown	a) close valve	local	10m	10m	20m	
5. Depressurize to conserve RCS/RWST Inventory	a) open steam dumps	CR	1m	--	5hr	To depressurize enough to terminate RCS leakage, if there is a faulted SG, requires that oper. cooldown to 300°F or so. At 50°/hr, this will take approx. 5hr.
	b) depressurize RCS	CR	1m	--	5hr	

C-39

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

ACTION	MAXIMUM TIME AVAILABLE (T _m) (1)	TOTAL ACTION TIME (T _a) (2)	TIME AVAILABLE TO DIAGNOSIS (T _d) (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. Depressurize RCS to prevent SG SV/RV demand	40m	25m	15m	
2. Close SG ADV block	9h - 10m	20m	8hr - 50m	
3. Close AFW TDP supply	9h - 45m	20m	9h 25m	
4. Close SG blowdown line	9h - 50m	20m	9h - 30m	
5. Depressurize to conserve inventory	9h - 10m	5hr	4h - 10m	

C-40

TABLE 7

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
----------------------------	--------------------------------	----------------------------------	--	--	------------------------	-----------------------------------	--

NOT APPLICABLE

C-41

TABLE 8
DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

ACTION (1)	DIAGNOSIS NEGLECTIBLE (2)	FAILURE TO DIAGNOSE (Figure 7-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Depressurize to prevent SG SV/RV demand	No	6.8E-3		Lower Bound	A diagnosis error is assigned here, even though action is procedure directed because operator must diagnose SGTR and jump into EP 4.0 in order to start depress. in time. Lower bound used because recent North Anna SGTR considered to make operators highly aware of SGTR at VEPCO.
2. Close SG ADV block	Yes				Procedure directed. Time available to work through procedures.
3. Close AFW TDP supply	Yes				See above
4. Close SG blowdown	Yes				See above
5. Depressurize to conserve inventory	Yes				Operator has 2 hours to initiate cooldown. It is procedure directed. Time available to work through procedures.

C-42

POST-DIAGNOSIS ACTION-TYPE IDENTIFICATION*

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Depress. RCS	No	Yes	Yes	Step by Step	
2. Close SG ADV block	No	Yes	Yes	Step by Step	
3. Close AFW TDP supply	No	Yes	Yes	Step by Step	
4. Close SG blowdown line	No	Yes	Yes	Step by Step	
5. Depress. In long term	No	Yes	Yes	Step by Step	

C-43

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

ACTION (Activities) (1)	Tm 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Depressurize RCS to prevent SG SV-RV demand	NA	No	Yes	Moderate h1	
2. Close SG ADV block	--	No	Yes	Moderate h1	
3. Close AFW TDP	--	No	Yes	Moderate h1	
4. Close SG blowdown line	--	No	Yes	Moderate h1	
5. Depressurize RCS to conserve inventory	--	No	Yes	Moderate h1	

C-44

Table 11

Post-Diagnosis Analysis*

Action (1)	Activities (2)	Original Operator HEP (3)	Supervisor Fails to correct operator HEP (4)	Third Independent check/correction HEP (5)	Total HEP (6)	Comments/ Source of Information (7)
1. Depressurize RCS to prevent SG SV/RV demand	a) Dump steam	3.2E-2	3.2E-1	--	1.04E-2	
	b) Spray pzz or open PORV	3.2E-2	3.2E-1	--	<u>1.04E-2</u> 2.08E-2	
2. Close SG ADV block valve	--	6.4E-2	--	--	6.4E-2	BHEP of .032 was doubled for this event to account for potentially harsh or stressful environmental conditions for this action.
3. Close AFW TDP supply	--	3.2E-2	3.2E-1	3.2E-1	3.3E-3	
4. Close SG blowdown	--	3.2E-2	3.2E-1	3.2E-1	3.3E-3	
5. Depressurize to conserve RCS inventory	--					The value of 2.1E-4 was not used in the quantification. This action is found in cut sets along with action number 1. The compound human error probability would then be 4E-6. The HRA guidelines for minimum human error probabilities and the guidelines for maximum attempts at one action were consulted to modify the probability of action #5, in order that the overall cut set HEP met these guidelines. The resulting HEP for action #5 was calculated to be 1.4E-2.
	a) Dump stream	3.2E-2	3.2E-1	* 3.2E-2 x 3.2E-1 = 2.16E-04		
	b) Spray pzz or open PORV	3.2E-2	3.2E-1			

Table C-4
SGTR with HPI Failure Sequence

C-46

ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: T₇ - Steam Generator Tube Rupture

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: T₇D₁O_D

SEQUENCE DESCRIPTION:

(1)

Steam generator tube rupture with subsequent failure of HPI. Operator must cope with the tube rupture and the HPI failure. The tube rupture requires cooldown and depressurization of the primary, while the HPI failure requires opening alternate injection paths, or cross-connect of HPI from Unit 2. The beginning of the sequence is previously described in the Tables for T₇O_DQ_S. However, HPI fails when responding to low pressurizer pressure. At this point, the operator must diagnose two events, and respond to each one. For the purposes of this HRA, the HPI failure was considered to be the first event to be observed and thus the focus of his attention. The tube rupture was the second event.

APPLICABLE PROCEDURES:

(4)

EP 4.0 Steam Generator Tube Rupture
EP 1.0 Reactor Trip, Safety Injection
FRP C.2 Inadequate Core Cooling

TABLE 2
SEQUENCE AND CUT SET TIMING*

CUT SETS:

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3) SOURCE OF INFORMATION (4)	COMMENTS/
1. Steam Generator Tube Rupture	t = 0		
2. SI signal on low pressurizer	t = 0+	yes	
3. Failure to initiate SI flow	t = 0+		1. SI flow indicates zero 2. Possible indication of mispositioned valves 3. Possible indication of pump failure

TABLE 3

CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	POTENTIAL OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/SOURCE OF INFORMATION (5)
1. SGTR (T ₇)	1. H ₁ condenser radiation ind. 2. Low pressurizer pressure	1. Operator must cool-down and depressurize RCS to terminate flow 2. Must also isolate SG	1. Open steam dump valves 2. Enhance feed flow 3. Depressurize RCS through pressurizer spray or PORV opening 4. Isolate SG effluent lines.	
2. Failure of HPI (D ₁)	1. No indication of SI flow 2. Possible valve misposition 3. Possible pump malfunction	1. Open alternate injection paths 2. Cross connect from Unit 2	1. Open alternate paths as necessary 2. Isolate pump at Unit 2 3. Open cross-connect valve locally 4. Start pump Unit 2	

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

CUT SETS:

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT TO PREVENT SUBSEQUENT CORE DAMAGE (T _{cd}) (2)	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (T _o) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (T _m) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. RCS-XHE-FO-DPT7D	60m	5m	55m	Time in column 2 is longer than for T ₇ with HPI.
2. HPI-XHE-FO-ALTS3 _{HRA}	150m	5m	145m	
3. HPI-XHE-FO-UN2S3 _{HRA}	150m	5m	145m	

C-50

OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (Ta) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. RCS-XHE-FO-DPT7D		CR	--	35m	35m	
2. HPI-XHE-FO-ALTS3	HRA	CR	--	--	--	
		Local	10m	10m	20m	
3. HPI-XHE-FO-UN2S3	HRA	CR	--	--	--	
		Local	10m	10m	20m	

C-51

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

SEQUENCE/CUT SET	MAXIMUM TIME AVAILABLE (T _m) (1)	TOTAL ACTION TIME (T _a) (2)	TIME AVAILABLE TO DIAGNOSIS (T _d) (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. RCS-XHE-FO-DPT7D	55m	35m	20m	
2. HPI-XHE-FO-ALTS3 HRA	145m	20m	125m	
3. HPI-XHE-FO-UN2S3 HRA	145m	20m	125m	

C-52

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
1. RCS-XHE-FO-DPT7D		2	--	2.66E-1	--	--	

TABLE 8
 DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLECTIBLE (2)	FAILURE TO DIAGNOSE (Figure 8-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. HPI-XHE-F0-ALTS3 HRA	Yes	--	Yes		
2. RCS-XHE-F0-DPT7D	No	5.2E-4	--		

C-54

POST-DIAGNOSIS ACTION-TYPE IDENTIFICATION*

CUT SETS:

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. RCS-XHE-FO-DPT7D	HPI	--	Yes	Dynamic	
2. HPI-XHE-FO-ALTS3 _{HRA}	HPI	--	Yes	Step by Step	
3. HPI-XHE-FO-UN2S3 _{HRA}	HPI	--	Yes	Step by Step	

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

CUT SETS:

ACTION (Activities) (1)	T _m 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. RCS-XHE-FO-DPT7D	No	No	No	Moderate	
2. HPI-XHE-FO-ALTS3 _{HRA}	No	No	No	Moderate	
3. HPI-XHE-FO-UN2S3 _{HRA}	No	No	No	Moderate	

C-56

POST-DIAGNOSIS ANALYSIS*

CUT SETS:

ACTION (1)	ACTIVITIES (2)	ORIGINAL OPERATOR HEP (3)	SUPERVISOR FAILS TO CORRECT OPERATOR HEP (4)	THIRD INDEPENDENT CHECK/CORRECTION HEP (5)	TOTAL HEP (6)	COMMENTS/ SOURCE OF INFORMATION (7)
1. RCS-XHE-FO-DPT7D	A. Cooldown	.08	.8	--	.064	
	B. Depressurize	.08	.8	--	.064	
					<u>.128</u>	
2. HPI-XHE-FO-ALTS3	HRA					
	A. Open local valve	.064	--	--	.064	No independent verification due to local nature of task. BHEP of .032 doubled to account for possible harsh environments
3. HPI-XHE-FO-UN2S3	HRA					
	A. Isolate charging pump Unit 2	.032	.32	--	.011	
	B. Open cross-connect	.032	.32	--	.011	
	C. Start pump	.032	.32	--	.011	
					<u>.033</u>	

C-57

Table C-5
Large and Intermediate LOCA Recirculation Sequences

TABLE 1

ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: Large and Intermediate LOCA (A and S₁)

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: AH₁, S₁H₁

SEQUENCE DESCRIPTION:

(1)

Large or Intermediate LOCA, which has successfully gone through the ECCS injection phase. RWST is down to 28% and it is time to go to recirculation. The Recirculation Transfer system fails to actuate and the operator must manually activate systems. In the large LOCA scenario, the operator must also switch to hot leg recirculation at 16 hours after the initiator.

APPLICABLE PROCEDURES:

(4)

- EP 2.03 - Transfer to cold leg recirc
 - EP 2.04 - Transfer to hot leg recirc
 - ECA 2.01 - Loss of emergency coolant recirc
-

TABLE 2
SEQUENCE AND CUT SET TIMING*

CUT SETS:

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3)	COMMENTS/ SOURCE OF INFORMATION (4)
Failure of RMT Actuation System	30m	Yes	

C-60

TABLE 3
CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	POTENTIAL OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Failure of RMT actuation systems		1. Manual actuation of valves		
2. 16 hours after LOCA		1. Switch to hot leg recirc		

C-61

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

CUT SETS:

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT TO PREVENT SUBSEQUENT CORE DAMAGE (T _{cd}) (2)	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (T _o) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (T _m) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Manual RMT	45m	30m	15m	
2. Hot leg recirc	32hr	16hr	16hr	

C-62

TABLE 5
 OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (T _a) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual RMT		CR	--	5m	5m	
2. Hot leg recirc		CR	--	20m	20m	

C-63

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

SEQUENCE	AVAILABLE (T_m) (1)	TIME (T_a) (2)	TO DIAGNOSIS (T_d) (3)	SOURCE OF INFORMATION (4)
----------	----------------------------	-----------------------	-------------------------------	------------------------------

NOT APPLICABLE

C-64



TABLE 7

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
----------------------------	--------------------------------	----------------------------------	--	--	------------------------	-----------------------------------	--

NOT APPLICABLE

TABLE 8
DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	FAILURE TO DIAGNOSE (Figure 8-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual RMT	Yes				Procedure directed ECA 2.01
2. Hot leg rectrc	Yes				Procedure directed In EP 2.04

C-66

TABLE 9

POST-DIAGNOSIS ACTION-TYPE IDENTIFICATION*

CUT SETS:

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual RMT	--	Yes	--	Step by Step	
2. Hot leg recirc	--	Yes	--	Step by Step	

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

CUT SETS:

ACTION (Activities) (1)	Tm 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual RMT	No	--	--	Extreme	Per guidelines in NUREG/CR-4772, extreme stress present in a large LOCA until recirculation complete.
2. Hot leg recirc	Yes	--	--	Low	

C-68

POST-DIAGNOSIS ANALYSIS*

CUT SETS:

ACTION (1)	ACTIVITIES (2)	ORIGINAL OPERATOR HEP (3)	SUPERVISOR FAILS TO CORRECT OPERATOR HEP (4)	THIRD INDEPENDENT CHECK/CORRECTION HEP (5)	TOTAL HEP (6)	COMMENTS/ SOURCE OF INFORMATION (7)
1. Manual RMT		.08	.8	--	.064	
2. Switch to hot leg recirc		.02	.02	.1	4E-5	Due to low stress for this event, median value of operator error used. Due to extended timing, three independent checks were postulated.

Table C-6
Small and Very Small LOCA ECCS Sequences

The following sheets present HRA for the following events:

- HPI-XHE-FO-UN2S2_{HRA} - Failure to cross connect SI flow from Unit 2 in the event of HPI failure at Unit 1, after an S₂ break
- HPI-XHE-FO-UN2S3_{HRA} - Failure to cross connect SI flow from Unit 2 in the event of HPI failure at Unit 1, after an S₃ break
- HPI-XHE-FO-ALTS3_{HRA} - Failure to open alternate injection paths for SI flow
- HPI-XHE-FO-UN2H1_{HRA} - Failure to recovery emergency coolant recirculation during S₂ events
- RCS-XHE-FO-DPRES - Failure to cooldown and depressurize the RCS during S₂ and S₃ events
- HPI-XHE-FO-20DH2_{HRA} - Failure to recover emergency coolant recirculation during S₂ events, after previous failure to depressurize
- HPI-XHE-FO-30DH2_{HRA} - Failure to recover emergency coolant recirculation during S₃ events, after previous failure to depressurize

1
ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: Small and Very Small LOCA (S_2 , and S_3)

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: S_{2D1} , S_{2H1} , $S_{2O}H_2$, S_{3D1} , S_{3H1} , $S_{3O}H_2$

SEQUENCE DESCRIPTION:

(1)

These sequences involve small and very small LOCAs with failure of emergency coolant injection or emergency coolant recirculation. The failures involve mechanical failures of equipment. Operator depressurization of the RCS is an expected occurrence during small break scenarios. Failure to do this does not lead to core damage, but does affect sequence timing, and impacts other failures.

APPLICABLE PROCEDURES:

(4)

- EP 2.0 Loss of Primary or Secondary Coolant
- EP 2.02 Post LOCA Cooldown and Depressurization
- EP 2.03 Transfer to Cold Leg Recirculation
- ECA 2.01 Loss of Emergency Coolant Recirculation

TABLE 2
SEQUENCE AND CUT SET TIMING*

CUT SETS:

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. Break	t = 0	Yes	
2. Failure of HPI	t = 1m	Yes	
3. Operator Depressurize	t = 60m		
4. Failure of Recirculation	t = 4 hours to 12 hours, depending on sequence		

C-72

CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	POTENTIAL OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Failure of HPI	a) no SI flow b) possible valve mispositions c) possible pump malfunctions		i) open alternate injection paths if applicable ii) cross connect from U-2 if applicable	
2. Loss of sump recirculation	same as above		i) cross connect HPI from Unit 2 ii) cross connect RWST from Unit 2	

C-73

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

CUT SETS:

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT TO PREVENT SUBSEQUENT CORE DAMAGE (T _{cd}) (2)	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (T _o) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (T _m) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. HPI-XHE-FO-ALTS3 HRA	150m	5m	145m	
2. HPI-XHE-FO-UN2S2 HRA	45m	5m	40m	
3. HPI-XHE-FO-UN2S3 HRA	150m	5m	145m	
4. HPI-XHE-FO-UN2H1 HRA	t _f + 60m	t _f + 5	55m	
5. HPI-XHE-FO-20DH2 HRA	t _f + 60m	t _f + 5	55m	
6. HPI-XHE-FO-30DH2 HRA	t _f + 150	t _f + 5	145m	

C-74

TABLE 5

OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (Ta) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1.	HPI-XHE-FO-ALTS3 _{HRA} a) local valve operation	local	10m	10m	20m	
2.	HPI-XHE-FO-UN2S2 _{HRA} a) open X-tie b) isol chp U2 c) start chp U2	local CR CR	10m 1m 1m	10m 2m 2m	20m 3m 3m <u>20m</u>	Time is not additive
3.	HPI-XHE-FO-UN2S3 _{HRA}					Same as HPI-XHE-FO-UN2S2 _{HRA}
4.	HPI-XHE-FO-UN2H1 _{HRA} for cross connect RWST: a) open 1 of 2	CR CR	1m	4m	5m	Same as HPI-XHE-FO-UN2S2 _{HRA} for for cross connect of HPI
5.	HPI-XHE-FO-20DH2 _{HRA} HPI-XHE-FO-30DH2 _{HRA}					Same as HPI-XHE-FO-UN2H1 _{HRA} Same as HPI-XHE-FO-UN2H1 _{HRA}

C-75

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

SEQUENCE/CUT SET	MAXIMUM TIME AVAILABLE (T _m) (1)	TOTAL ACTION TIME (T _a) (2)	TIME AVAILABLE TO DIAGNOSIS (T _d) (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. HPI-XHE-FO-ALTS3 _{HRA}	145m	20m	125m	
2. HPI-XHE-FO-UN2S2 _{HRA}	40m	20m	20m	
3. HPI-XHE-FO-UN2S3 _{HRA}	145m	20m	125m	
4. HPI-XHE-FO-UN2H1 _{HRA}	55m	25m	30m	
5. HPI-XHE-FO-20DH2 _{HRA}	55m	25m	30m	
6. HPI-XHE-FO-30DH2 _{HRA}	145m	25m	120m	

C-76

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
----------------------------	--------------------------------	----------------------------------	--	--	------------------------	-----------------------------------	--

NOT APPLICABLE

TABLE 8
DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLECTIBLE (2)	FAILURE TO DIAGNOSE (Figure 8-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. HPI-XHE-FO-ALTS3 _{HRA}	Yes				
2. HPI-XHE-FO-UN2S2 _{HRA}	No	.266			Diagnosis error included because x-connect of HPI is not directly referenced from the EPs. X-connect from U2 is directed in FRP C.1 and FRP C.2, which are entered on conditions of inadequate core cooling. There is insufficient time to hook up x-connect after indications of inadequate core cooling occur. Therefore, need for x-connect must be diagnosed.
3. HPI-XHE-FO-UN2S3 _{HRA}	No	5.2E-4			See comment above
4. HPI-XHE-FO-UN2H1 _{HRA}	Yes				Procedure directed in ECA 2.01
5. HPI-XHE-FO-20DH2 _{HRA}	No	2.66E-3	No		Diagnosis error was included here, because of previous failure to depressurize
6. HPI-XHE-FO-30DH2 _{HRA}	No	5.2E-4	No		See above comment

C-78

TABLE 9

POST-DIAGNOSIS ACTION-TYPE IDENTIFICATION*

CUT SETS:

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. HPI-XHE-FO-ALTS3 HRA	--	Yes	One	Step by Step	
2. HPI-XHE-FO-UN2S2 HRA	--	Yes	One	Step by Step	
3. HPI-XHE-FO-UN2S3 HRA	--	Yes	One	Step by Step	
4. HPI-XHE-FO-UN2H1 HRA	--	Yes	One	Step by Step	
5. HPI-XHE-FO-20DH2 HRA	--	Yes	One	Step by Step	
6. HPI-XHE-FO-30DH2 HRA	--	Yes	One	Step by Step	
7. RCS-XHE-FO-DPRES	--	Yes	One	Step by Step	

C
T
9

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

CUT SETS:

ACTION (Activities) (1)	Tm 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. HPI-XHE-FO-ALTS3 _{HRA}	No	No	--	Moderate	
2. HPI-XHE-FO-UN2S2 _{HRA}	No	No	--	Moderate	
3. HPI-XHE-FO-UN2S3 _{HRA}	No	No	--	Moderate	
4. HPI-XHE-FO-UN2H1 _{HRA}	Yes	No	--	Moderate	For RWST x-connect: time stress is present for second operation. This was assumed to be HPI x-connect
5. HPI-XHE-FO-20DH2 _{HRA}	Yes	No	--	see above	
6. HPI-XHE-FO-30DH2 _{HRA}	Yes	No	--	see above	
7. RCS-XHE-FO-DPRES	Yes	No	--	Moderate	

08-80

TABLE 11

POST-DIAGNOSIS ANALYSIS*

CUT SETS:

ACTION (1)	ACTIVITIES (2)	ORIGINAL OPERATOR HEP (3)	SUPERVISOR FAILS TO CORRECT OPERATOR HEP (4)	THIRD INDEPENDENT CHECK/CORRECTION HEP (5)	TOTAL HEP (6)	COMMENTS/ SOURCE OF INFORMATION (7)
1. HPI-XHE-FO-ALTS3 _{HRA}	a) open valve locally	.064	--	--	.064	BHEP doubled to account for potential harsh environments.
2. HPI-XHE-FO-UN2S2 _{HRA}	a) isolate chp	.032	.32	--	.011	
	b) open x-tie	.032	.32	--	.011	
	c) start pump	.032	.32	--	.011	
					<u>.033</u>	
3. HPI-XHE-FO-UN2S3 _{HRA}	same as #2 above					
4. HPI-XHE-FO-UN2H1 _{HRA}	a) x-tie RWST	.032	.32	--	.011	
	b) x-connect					
	i) isolate chp	.064	.64	--	.041	time stress present
	ii) open x-tie	.064	.64	--	.041	
	iii) start pp	.064	.64	--	.041	
					<u>.132</u>	
5. HPI-XHE-FO-20DH2 _{HRA}	- same as #4					
6. HPI-XHE-FO-30DH2 _{HRA}	- same as #4					
7. RCS-XHE-FO-DPRES	a) dump steam	.032	.32	--	.011	
	b) depress.	.032	.32	--	.011	
					<u>.022</u>	

C-81

Table C-7
CPC Service Water Failure during LOCA Sequences

C-82

PAGE 1
ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: Intermediate, Small, and Very Small LOCA (S₁, S₂, and S₃)

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: S₁D₁, S₂D₁, S₃D₁

SEQUENCE DESCRIPTION:

(1)

Any size LOCA followed by failure of the high pressure injection system due to failure of component cooling to the HPI pumps.

APPLICABLE PROCEDURES:

(4)

- EP 2.0 Loss of Primary or Secondary Coolant
 - EP 2.02 Post LOCA Cooldown and Depressurization
 - EP 2.03 Transfer to Cold Leg Recirculation
 - ECA 2.01 Loss of Emergency Coolant Recirculation
-

TABLE 2
SEQUENCE AND CUT SET TIMING*

CUT SETS:

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3)	COMMENTS/ SOURCE OF INFORMATION (4)
----------------------	----------	----------------------------	--

NOT APPLICABLE

C-84



CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	POTENTIAL OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Failure of CPC actuation	1. Misposition valves 2. Inoperable pumps 3. High Bearing temperatures	Manual activation		
2. Service water strainer plugging	1. low flow to CPC-SW pumps	Re-align suction of service system		

C-85

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

CUT SETS:

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT TO PREVENT SUBSEQUENT CORE DAMAGE (T _{cd}) (2)	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (T _o) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (T _m) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Manual activation	--	--	30m	
2. Re-align of SW suction	--	--	30m	

C-86

OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (T _a) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual activation CPC	CR	--	--	1m		
2. Re-align SW suction	CR	--	--	1m		

C-87

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

SEQUENCE/CUT SET	MAXIMUM TIME AVAILABLE (T _m) (1)	TOTAL ACTION TIME (T _a) (2)	TIME AVAILABLE TO DIAGNOSIS (T _d) (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. Manual CPC actuation	30m	1m	30m	
2. Re-align SW suction	30m	1m	30m	

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLECTIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
----------------------------	---------------------------------	----------------------------------	--	--	------------------------	-----------------------------------	--

NOT APPLICABLE

TABLE 8
DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	FAILURE TO DIAGNOSE (Figure 8-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual CPC Actuation	No	2.6E-2	No		Used upper bound for diagnosis. This failure may not be visible during a LOCA.
2. Re-align SW Suction	No	2.6E-2	No		Used upper bound for diagnosis. This failure may not be visible during a LOCA.

C-90

POST-DIAGNOSIS ACTION-TYPE IDENTIFICATION*

CUT SETS:

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual CPC Actuation	--	--	one	Step by Step	
2. Re-align Sw Suction	--	--	one	Step by Step	

C-91

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

CUT SETS:

ACTION (Activities) (1)	Tm 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual CPC Actuation	--	--	--	Moderate	
2. Re-align SW Suction	--	--	--	Moderate	

C-92

POST-DIAGNOSIS ANALYSIS*

CUT SETS:

ACTION (1)	ACTIVITIES (2)	ORIGINAL OPERATOR HEP (3)	SUPERVISOR FAILS TO CORRECT OPERATOR HEP (4)	THIRD INDEPENDENT CHECK/CORRECTION HEP (5)	TOTAL HEP (6)	COMMENTS/ SOURCE OF INFORMATION (7)
1. Manual CPC Actuation	a) start pump	.032	.32	--	.011	
2. Re-align SW Suction	a) open cross- tie valves	.032	--	--	.032	

Table C-8
ATWS Sequences

ACCIDENT SEQUENCE DESCRIPTION

EVENT TREE: ATWS

SEQUENCE NUMBER:

SEQUENCE DESIGNATOR: TKRD₄, TKRT, TKRL₂

SEQUENCE DESCRIPTION:

(1)

ATWS event for which manual scram has failed. Manual scram has been ineffective either due to operator error (2.7E-3) or failures which are not recoverable by manual scram (.167). The event has progressed for 2 to 5 minutes. Primary pressure has risen to the point that the pressurizer safety valves are open. The operator must initiate emergency boration in order to reduce the primary pressure, thus closing the relief valves and conserving coolant inventory. During some ATWS events, the operator may need to trip the turbine and start AFW, if these actions do not occur automatically.

APPLICABLE PROCEDURES:

(4)

EP 1.0 - Reactor Trip
FRP S.1 - Response to Nuclear Power Generation/ATWS

TABLE 2
SEQUENCE AND CUT SET TIMING*

CUT SETS:

EVENT/OCCURRENCE (1)	TIME (2)	ANNUNCIATOR/INDICATION (3)	COMMENTS/ SOURCE OF INFORMATION (4)
1. Initiator	t = 0		
2. Failure of RPS	t = 0+	Yes	
3. Failure of Manual Scram	t = 1m		
4. Failure of Turbine Trip	t = 1m		
5. Failure of AFW Actuation	t = 1m		

C-96

TABLE 3
CUT SET FAILURE AND POTENTIAL OPERATOR ACTIONS*

CUT SETS:

DESCRIPTION OF EVENT (1)	SYMPTOMS (2)	POTENTIAL OPERATOR ACTIONS (3)	ACTIVITIES (TASKS) REQUIRED TO PERFORM ACTION AND PROCEDURALIZED (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Failure of RPS		1. Manual scram 2. Emergency boration 3. Trip turbine if necessary 4. Start AFW if necessary	1. Push manual scram 1. Open valve from BAT pumps to charging pump suction 2. Turn BAT pump to fast speed 3. Open PORV	

C-97

TABLE 4
SEQUENCE AND CUT SET AVAILABLE TIME

CUT SETS:

ACTION (1)	TIME BY WHICH OPERATOR MUST ACT TO PREVENT SUBSEQUENT CORE DAMAGE (Tcd) (2)	TIME AT WHICH OPERATOR IS ALERTED THAT SYMPTOM HAS OCCURRED (To) (3)	MAXIMUM TIME AVAILABLE TO PERFORM THE IDENTIFIED OPERATOR ACTIVITIES (Tm) (4)	COMMENTS/ SOURCE OF INFORMATION (5)
1. Manual scram	NA			
2. Emergency boration	10m	2m	8m	
3. Trip turbine	2m	1m	1m	
4. Start AFW	2m	1m	1m	

C-98

TABLE 5
OPERATOR ACTION PERFORMANCE TIME*

CUT SETS:

ACTION	ACTIVITIES (1)	LOCATION (2)	TRAVEL TIME (3)	PERFORMANCE TIME (4)	TOTAL TIME (Ta) (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1.	Manual scram	CR	--	10 sec	10 sec	
2.	Turbine trip	CR	--	10 sec	10 sec	
3.	Start AFW	CR	--	10 sec	10 sec	
4.	Emergency boration	a) open MOV 1350 CR b) switch BAT CR pump to fast c) open PORV CR	-- -- --	<u>1m</u>	<u>1m</u>	

C-99

TABLE 6
DIAGNOSIS TIME OF SEQUENCE CUT SET*

SEQUENCE/CUT SET	MAXIMUM TIME AVAILABLE (T _m) (1)	TOTAL ACTION TIME (T _a) (2)	TIME AVAILABLE TO DIAGNOSIS (T _d) (3)	COMMENTS/ SOURCE OF INFORMATION (4)
------------------	--	---	---	---

NOT APPLICABLE

C-100

TABLE 7

DIAGNOSIS ANALYSIS -- MORE THAN ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	NUMBER OF ABN EVENT (3)	ANNUNCIATOR HEP (Table 8-4) (4)	FAILURE TO DIAGNOSE (Table 8-2) (5)	SKILL-BASED (6)	ADJUSTMENT IN FINAL HEP (7)	COMMENTS/ SOURCE OF INFORMATION (8)
----------------------------	--------------------------------	----------------------------------	--	--	------------------------	-----------------------------------	--

NOT APPLICABLE

C-101

TABLE 8
DIAGNOSIS ANALYSIS - ONE ABNORMAL EVENT*

CUT SETS:

ACTION (Symptom) (1)	DIAGNOSIS NEGLIGIBLE (2)	FAILURE TO DIAGNOSE (Figure 8-1) (3)	SKILL-BASED (4)	ADJUSTMENT IN FINAL HEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Manual scram	Yes		Yes		
2. Turbine trip	Yes		Yes		
3. Start AFW	Yes		Yes		
4. Emergency boration	Yes		No		

C-102

TABLE 9

POST-DIAGNOSIS ACTION-TYPE IDENTIFICATION*

CUT SETS:

ACTION (Activities) (1)	SAFETY SYSTEMS FAILED (2)	EOPs, TRAINING, USE EOPs, WELL-DESIGNED EOPs (3)	OPERATOR PERFORMS ONE ACTIVITY (4)	DYNAMIC OR STEP-BY-STEP (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Emergency Boration	--	Yes	one	Step by Step	

C-103

TABLE 10
POST-DIAGNOSIS STRESS-LEVEL INDICATION*

CUT SETS:

ACTION (Activities) (1)	Time 2 h AFTER IE (2)	MORE THEN TWO SAFETY SYSTEMS FAIL (3)	OPERATOR FAMILIAR W/SEQUENCE (4)	STRESS LEVEL (5)	COMMENTS/ SOURCE OF INFORMATION (6)
1. Emergency Boration	No	No	Yes	Moderate	

C-104

PAGE 11
POST-DIAGNOSIS ANALYSIS*

CUT SETS:

ACTION (1)	ACTIVITIES (2)	ORIGINAL OPERATOR HEP (3)	SUPERVISOR FAILS TO CORRECT OPERATOR HEP (4)	THIRD INDEPENDENT CHECK/CORRECTION HEP (5)	TOTAL HEP (6)	COMMENTS/ SOURCE OF INFORMATION (7)
1.	Manual scram	2.7E-3	--	--	2.7E-3	
2.	Trip turbine	2.7E-3	--	--	2.7E-3	
3.	Start AFW	2.7E-3	--	--	2.7E-3	
4.	Emergency borate					
	a) open 1350	.032	.032	.32	3.3E-4	
	b) switch BAT pump to fast	.032	.032	.32	3.3E-4	
	c) open PORV	.032	.032	.32	<u>3.3E-4</u>	
					1.0E-3	

C-105

Table of Contents

<u>Section</u>	<u>Page</u>
D.1 Failure Mode and Effect Analysis on Support Systems	D-3
D.2 Small Break Initiating Event Frequency Assessment	D-54
D.3 Development of the T ₁ Initiating Event Frequency and Non-Recovery Probabilities for AC Power	D-58
D.4 Estimation of Core Uncovery Time Versus Break Size	D-62
D.5 Development of Plant Specific Reactor Coolant Pump Seal LOCA Model	D-66
D.6 Failure Data Development	D-73
D.7 Discussion of Mission Time for Diesel Generators for LOSP Initiators	D-86

List of Figures

D.3-1 Distribution of Initiating Frequency for Surry	D-59
D.3-2 Recovery Curve for Surry	D-61
D.4-1 Time to Core Uncovery and Core Melt Variation with LOCA Break Size	D-64
D.4-2 Time to Core Uncovery Variation with LOCA Break Size and Secondary Depressurization	D-65

List of Tables

D.1 Surry Failure Modes and Effects Analyses	
Containment Instrument Air FMEA	D-4
Component Cooling Water FMEA	D-7
Instrument Air FMEA	D-18
120 VAC Power FMEA	D-30
480 VAC Power FMEA	D-41
4160 VAC Power FMEA	D-43
Service Water FMEA	D-45
Auxiliary Ventilation FMEA	D-49
D.2-1 Summary of Small Break Experience	D-55
D.3-1 Distribution of Initiating Event Frequency for Surry	D-60
D.4-1 Times from Start of Accident to Uncovery of the Core	D-63
D.5-1 Aggregated RCP Seal LOCA Probabilities - Three Pumps	D-67
D.5-2 Surry RCP Seal LOCA Model Paths	D-68
D.5-3 Surry RCP Seal LOCA Model	D-71
D.6-1 Mission Times	D-74
D.6-2 Plant Specific Failure Data	D-76
D.7-1 Typical Core Uncovery Frequency Due to Battery Depletion During Station Blackout and the Effect of Modeling Considerations	D-90

APPENDIX D

D. Plant Specific Analyses

Appendix D contains the details of several plant specific analyses performed in support of the revised Surry probabilistic risk assessment for NUREG-1150. The analyses cover a wide range of areas: from initiating events to the reactor coolant pump (RCP) seal LOCA model to failure data and mission times. This appendix is organized into subappendices as follows:

- D.1 Failure Mode and Effect Analysis on Support Systems
- D.2 Small Break Initiating Event Frequency Assessment
- D.3 T₁ Initiating Event Frequency and Non-Recovery of AC Power Probabilities
- D.4 Core Uncovery Time Versus Break Size
- D.5 RCP Seal LOCA Model
- D.6 Failure Data Development
- D.7 Discussion of Mission Time for Diesel Generators for LOSP Initiators

D.1 Failure Mode and Effect Analysis on Support Systems

The effects of the loss of support systems were examined on an individual basis to determine if they should be included as initiating events. This section describes the analysis performed on the support systems as part of the initiating event identification and grouping task, described in Section 4.3 of the main report.

A list of systems at Surry which provide supporting services to components in front line safety systems and normally operating systems was developed. Each of these systems was viewed as a potential initiator. A Failure Mode and Effect Analysis (FMEA) was done on the support systems in order to support this investigation.

The FMEA identifies the failure causes for the support systems. Then, the FMEA qualitatively assesses the impact of each of these failure causes on the unit's front line systems. FMEA's were performed on the following systems:

- Containment Instrument Air
- Component Cooling Water
- Instrument Air
- 120 VAC Power
- 480 VAC Power
- 4160 VAC Power
- Service Water
- Auxiliary Ventilation

The FMEAS follow.

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CIA (Inside Contmt)
 DRAWING NO. 11448-FM-25E, J

UNIT Surry-1
 SHEET 1 of 3

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Entire Inside Containment IA System (All Loads)	CIA compressors fail (1 FTR and 1 FTS)	CIA pressure ind. (PI-IA-101) < 85 psi	If CIA not restored in a reasonable period of time, begin a normal reactor shutdown to a cold shutdown condition (Tech. Spec. 3.8)	Cross-connect valves (1-IA-1003, 446, and 447) can be opened for IA backup to CIA if air header pressure decreases below 85 psi
	- or -	Cont instr air compr 4A or 4B alarm		
	CIA separator or compressor HX rupture and failure to isolate train and start other compressor	Cont instr air hdr lo-press alarm	Prolonged operation with outside air being sup- plied to containment will increase containment partial pressure	If IA system is cross- connected to supply CIA, the containment partial air pressure must be monitored
	- or -			
	CIA air dryer rupture and failure to isolate and open cross-connect to other dryer	Charging pump regen HX hi-lo flow alarm		Air leaks must be stopped to prevent overheating and tripping of air compressors
	- or -			
	CIA receiver (2A or 2B) ruptures and failure to isolate (or both rupture)			
	- or -			
	CIA supply isolation valve (TV-IA-100) transfers closed			
	- or -			
CIA suction isolation valve (TV-IA-101A or B) transfers closed and alternate suction (TV-IA-103) fails to open				
- or -				
CIA header rupture				

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CIA (Inside Contmt)

UNIT Surry-1

DRAWING NO. 11448-FM-25E

SHEET 2 of 3

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
PORVs (PCV-1455C, 1456)	Local air line rupture - or - Manual valve plug - or - Check valve transfer shut	Local air leakage	No effect	Alternate supply from high- pressure nitrogen bottles Isolate lines affected by air leak - Check valve to prevent loss from high pressure air
Normal (RCP) Pressurizer Spray Valves (PCV-1455A,B)	Local air line rupture - or - Manual valve plug (2 must plug for each PCV to lose air supply)	Loss of normal pressurizer spray capability Local air leakage	On pressure surge, PORVs may open and possible reactor trip on high pres- surizer P, unless one normal spray or aux. spray is available May be able to control pressurizer pressure during hot standby justing SG level	Spray valves fail closed on loss of CIA Isolate lines affected by air leaks. The normal spray valve air supply is isolated separately from aux spray valves supply
Aux (Chg PP) Pressurizer Spray Valve (HCV-1311)	Local air line rupture - or - Manual valve plug	Loss of auxiliary pressurizer spray capability Local air leakage	On pressure surge, PORVs may open and possible reactor trip on high pres- surizer P, unless normal sprays available May be able to control pressurizer pressure during hot standby by adjusting SG level	Spray valve fails closed on loss of CIA Isolate lines affected by air leaks - aux spray valve air supply is isolated separately from normal spray valves air supply

D-5

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CIA (Inside Contmt)
DRAWING NO. 11448-FM-25E

UNIT Surry-1
SHEET 3 of 3

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Letdown Flow To Regen HX (LCV-1460A,B)	Local air line rupture - or - Manual valve plug	Loss of letdown flow	No effect (comply with requirements for restoring letdown flow)	Valves fail closed on loss of IA (valves are in series) Close air line valves or crimp line to isolate leaks
Letdown Orifice Valves (HCV-1200A,B,C)	Local air line rupture - or - Manual valve plug	Charging pump to regen HX low flow alarm	Seal water return is only letdown available, may cause pressurizer level to increase	Valves fail closed on loss of IA (valves are in parallel, A and C normally closed) Close air line valves or crimp line to isolate leaks
Seal Leak Off Lines No. 1 & 2 (HCV-1303A,B,C; HCV-1307)	Local air line rupture - or - Manual valve plug	Local air leakage Reduced seal flow (HCV-1307)	No effect RCP seal flow is functional, but reduced due to full charging flow if FCV-1122 fails open	Valves HCV-1303A,B,C fail open on loss of IA and HCV-1307 fails closed Close air line valves or crimp line to isolate leaks
CCW Load Isolation Valves (Neutron Shield Tank Coolers: FCV-CC-112A,B; 113A,B; Excess LD HX: HCV-CC-108; Prim Drain Clr: HCV-CC-114)	Local air line rupture - or - Manual valve plug	Neutron shield tank cooler flow high temperature Excess letdown flow high temp	No effect Comply with requirements for operation without NST or primary drain cooling Comply with requirements for operation without letdown flow	Valves fail closed on loss of IA Stop letdown flow (close HCV-1200A,B,C) on loss of cooling Close air line valves or crimp line to isolate leaks

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
 DRAWING NO. 11448-FM-22A-D

UNIT Surry - 1
 SHEET 1 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Entire CCW System at Unit 1 (All Loads)	Surge Tank (1-CC-TK-1) rupture	Surge tank low level	If CCW flow not re-established immediately: - Stop affected RCP - Trip the reactor - Initiate "Reactor Trip/EP Safety Injection" - Request initiation of "Station Emergency Manager Controlling Procedure" - Prepare to backup containment IA with Turb. Bldg. IA - Cooldown plant using natural circulation and steam dumps	Addressed as event W on T2 event tree CCW pumps trip on low NPSH - caused by low surge tank level RCP must be stopped within 2 minutes or before either upper or lower bearing temps reach 200°F Following loss of offsite power the operator must re-connect the stub bus for CCW pumps If standby CCW pump doesn't start, pumps 1C and 1D which normally supply Unit 2 can supply Unit 1 Surge tank make-up LCV can be hand-operated on loss of IA
	-or-			
	Surge tank makeup failure, valve LCV-CC-100 closed	Pump motor protection alarm		
	-or-			
	Surge tank vent (HCV-CC-100) closed	Disch. header low flow		
	-or-			
	Surge tank level transmitter fail low (LT-CC-100)	Disch. header low pressure		
	-or-			
	Surge tank drain opened	RCP flow high temp.		
	-or-			
Operating pump fails and standby pump fails to start (1-CC-P-1A,1B)	Excess letdown flow high temp.			
and	Primary shield pen. cooling coils low pressure			
Failure to align Pumps 1C or 1D	Primary shield water wall coolers low pressure			
	Neutron shield tank coolers flow high temp.			

D-7

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
 DRAWING NO. 11448-FM-22A-D

UNIT Surry - 1
 SHEET 2 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Entire CCW System at Unit 1 (All Loads) (cont'd)	-or- CCW heat exchanger tube rupture or plug and Failure to align standby HX -or- Loss of SW to CCW HXs (refer to SW FMEA) -or- Return/discharge header rupture	Reactor con- tainment air coolers high temp. Non-regen. HX (main coolant) high temp.	(see previous page)	CCW standby heat exchanger must be aligned manually

D-8

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
 DRAWING NO. 11448-FM-22A

UNIT Surry - 1
 SHEET 3 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Reactor coolant pumps (RCP) 1-RC-P-1A,1B,1C upper bearing lube oil coolers	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut -or- Containment isol. valve closure (TV-CC-105A,B,C) -or- Loss of IA	RCP motor bearings high temp	If CCW flow to RCPs not re-established immediately: - Stop affected RCPs - Trip Reactor - Initiate "Reactor Trip/EP Safety Injection"	RCP must be stopped within 2 minutes or before either upper or lower bearing temps reach 200°F Containment valve closure will cause loss of all CCW loads inside containment.
RCP lower bearing lube oil coolers	see above	see above	see above	see above
RCP stator coolers	see above	see above	see above	see above
RCP thermal barriers	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut	see above	see above	see above

D-9

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
DRAWING NO. 11448-FM-22A

UNIT Surry - 1
SHEET 4 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
RCP thermal barriers (cont'd)	-or- Containment valve closure (TV-CC-107) -or- Loss of IA	-----refer to previous page-----		
Reactor shroud cooling coils (1-VS-E-6A,6B,6C)	Pipe rupture		No effect unless amount of time required to restore exceeds time allowed for operation with shroud coils isolated (Tech. Specs.).	For pipe rupture, isolate affected coils and return unaffected coils to operation
	-or- Manual valve plug			
	-or- Check valve transfer shut			
	-or- Containment valve closure (TV-CC-105A,B,C)			
	-or- Loss of IA			Containment valve closure will cause loss of all CCW inside containment.
Residual heat removal pumps (1-RH-P-1A,1B)	Loss of all CCW		No effect if RHR not required. Otherwise RNR not available for unit cooldown.	Used for unit cooldown. Isolated during normal operations
	-or- Failure to align CCW to pumps			
	-or- Pipe rupture			

D-10

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW

UNIT Surry - 1

DRAWING NO. 11448-FM-22A

SHEET 5 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Residual heat removal exchangers (1-RH-E-1A, 1B)	Loss of all CCW -or- Pipe rupture -or- Failure to align CCW to RHR HXs		No effect if RHR not required. Otherwise RHR unavailable for unit cooldown.	Used for unit cooldown. Isolated during normal operations
Primary drain cooler (1-DC-E-1)	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut -or- Valve closure (HCV-CC-114; TV-CC-109B) -or- Loss of IA		No effect unless amount of time required to restore exceeds time allowed for operation with cooler isolated (Tech. Specs.).	For pipe rupture, isolate cooler and return unaffected CCW loads to operation
Excess letdown heat exchanger (1-CH-E-4)	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut -or- Valve closure (HCV-CC-108; TV-CC-109B) -or- Loss of IA	Excess letdown flow high temp	No effect if amount of time required to restore exceeds time allowed for operation without letdown flow, comply with Tech. Specs.	Stop letdown flow by closing valves HCV-1200A, B, C Insure flow is maintained to RCP seals For pipe rupture, isolate HX

D-11

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW

UNIT Surry - 1

DRAWING NO. 11448-FM-22A,B

SHEET 6 of 11

D-12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Inner pipe penetration cooling coils	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut -or- Valve closure (TV-CC-109B) -or- Loss of IA		No effect unless amount of time required to restore exceeds time allowed for operation with coils isolated (Tech. Specs.).	For pipe rupture, isolate affected coils and return unaffected coils to operation
Outer pipe penetration cooling coils	Pipe rupture -or- Manual valve plug	see above	see above	see above
Reactor containment air recirc coolers (1-VS-E-2A,2B,2C)	Pipe rupture -or- Manual valve plug -or- Check valve(s) transfer shut -or- Valve closure (HCV-CC-101A,B; TV-CC-110A,B,C) -or- Loss of IA	Reactor containment air recirc coolers high temp	No effect unless amount of time required to restore exceeds time allowed for operation with air coolers isolated (Tech. Specs.).	For pipe rupture, isolate affected coolers and return unaffected coolers to operation For loss of all CCW or closure of HCV-101A or B, shift to chilled component cooling, start chiller and place on chilled component cooling HX

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
DRAWING NO. 11448-FM-22B

UNIT Surry - 1
SHEET 7 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Primary shield penetration cooling coils (1-CC-E-3A,...,3F)	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut -or- Valve closure (TV-CC-109B) -or- Loss of IA	Primary shield penetration cooling coils low pressure	No effect unless amount of time required to restore exceeds time allowed for operation with shield coils isolated (Tech. Specs.).	For pipe rupture, isolate affected coils and return unaffected coils to operation
Primary shield water wall cooler panel sections (1-NS-E-2A,...,2L)	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut -or- Valve closure (TV-CC-109B) -or- Loss of IA	Primary shield water wall coolers low pressure	see above	see above
Neutron shield tank coolers (1-NS-E-1A, 1B)	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut	Neutron shield tank coolers flow high temp	No effect unless amount of time required to restore exceeds time allowed for operation with NST cooler isolated (Tech. Specs.).	For loss of all CCW or closure of HCV-101A or B, shift to chilled component cooling, start chiller and place on CD HX

D-13

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
 DRAWING NO. 11448-FM-22B,C,D

UNIT Surry - 1
 SHEET 8 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Neutron shield tank coolers (cont'd)	Valve closure (FCV-CC-112A,B; HCV-CC-101A,B; TV-CC-110A,C) -or- Loss of IA	-----refer to previous page-----		For pipe rupture, isolate affected cooler and align unaffected cooler for operation
Liquid waste disposal system Evap (1-SS-E-7) Cooler (1-LW-E-3) Cond (1-LW-E-2) Dist PP(1-LW-P-4) Circ PP(1-LW-P-8) HLWDT PP(1-LW-P-2A,B)	Pipe rupture -or- Manual valve plug -or- Valve closure (PCV-LW-111; FICV-CC-108A,B FICV-109,110) -or- Loss of IA		No effect unless amount of time required to restore exceeds time allowed for operation without liquid waste disposal, (Tech. Specs.)	For lost LW CCW, shutdown LW disposal by placing pump 1-LW-P-8 to "off" For loss of IA, bypass TCV-CC-105 For pipe rupture, isolate affected sections and return unaffected sections to operation
Boron recovery system Cooler(1-BR-E-2A,B) Cond(1-BR-E-7A,B) Dist PP(1-BR-P-3A,B) Circ PP(1-BR-P-6A,B) Str Circ PP(1-BR-P-7A,B) PDT PP(1-BR-P-4A,B) Ovhd Cond(1-BR-E-8) Chlr Cond(1-BR-E-9) Str Trim Clr(1-BR-E-12)	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut -or- Valve closure (PCV-BR-109A,B; TCV-BR-111A,B; HCV-BR-101D,G; TCV-BR-128,129; FICV-CC-104-107A,B		No effect unless amount of time required to restore exceeds time allowed for operation without boron recovery, (Tech. Specs.)	For lost BR CCW, shutdown boron recovery by placing pumps 1-BR-P-4A,B; and 6A,B to "off" For pipe rupture, isolate affected sections and return unaffected sections to operation

D-14

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
DRAWING NO. 11448-FM-22C

UNIT Surry - 1
SHEET 9 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Boron recovery system (cont'd)	Loss of IA	-----refer to previous page-----		For loss of IA, throttle HCV-BR-101D & G and bypass TCV-BR-129
Sample Coolers RHR(1-SS-E-9) PZR(1-SS-E-10) Gas Str(1-SS-E-5) Cold Leg(1-SS-E-12) Hot Leg(1-SS-E-4) SG BD(1-SS-E-3A,B,C)	Pipe rupture -or- Manual valve plug		No effect unless amount of time required to restore exceeds time allowed for operation with sample coolers isolated (Tech. Specs.).	For pipe rupture, isolate affected coolers and restore unaffected coolers to operation
Recombiner aftercooler (1-GW-HC-1)	Pipe rupture -or- Manual valve plug		No effect unless amount of time required to restore exceeds time allowed for operation without GW disposal, (Tech. Specs.).	Shutdown gaseous waste disposal by placing compressors 1GW-C-2A or B to "stop" For pipe rupture, isolate aftercooler
Fuel pit coolers (1-FC-E-1A-1B)	Pipe Rupture -or- Manual valve plug	Fuel pool water high temp.	No effect unless amount of time required to restore exceeds time allowed for operation with fuel pit cooler isolated, (Tech. Specs.)	For pipe rupture, isolate affected cooler and align unaffected cooler for operation

D-15

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
DRAWING NO. 11448-FM-22C,D

UNIT Surry - 1
SHEET 10 of 11

D-16

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Non-regenerative heat exchanger (1-CH-E-2)	Pipe rupture -or- Manual valve plug -or- Valve closure (TCV-CC-103)	Non-regen HX (main coolant) high temp	No effect unless amount of time required to restore exceeds time allowed for operation without charging flow, (Tech. Specs.)	Stop charging flow by closing FCV-1122 Insure flow is maintained to RCP seals C or pipe rupture, isolate HX For Loss of IA, throttle TV-CC-103
Seal water heat exchanger (1-CH-E-1)	Pipe rupture -or- Manual valve plug	Seal water high temp.	No effect, unless amount of time required to restore exceeds time allowed for operation without charging flow, (Tech. Specs.)	Stop charging flow by closing FCV-1122 Insure flow is maintained to RCP seals (HCV-1303A,B,C)
Fuel Casks (Decontamination Building)	Loss of all CCW -or- Pipe rupture -or- Failure to align	(refer to loss of all CCW)	None	Isolated during normal operation
Waste gas diaphragm compressors (1-GW-C-1A,1B)	Pipe rupture -or- Manual valve plug	Waste gas flow high temp.	No effect, unless amount of time required to restore exceeds time allowed for operation without GW disposal (Tech. Specs.)	Shutdown GW disposal by placing compressors 1-GW-C-2A or B to "stop" For pipe rupture, isolate affected compressor

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM CCW
DRAWING NO. 11448-FM-22,C,D

UNIT Surry -1
SHEET 11 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Refueling water storage tank coolers (1-CD-E-2A,B)	Loss of all CCW -or- Pipe rupture -or- Failure to align	(refer to loss of all CCW)	No effect, possible delay when refueling RWST use by injection systems not affected	Used during refueling - isolated during normal operations
Chilled water system Pumps(1-CD-P-1A,B,C) Cooler(1-CD-E-1A,B,C) Condensate Air EJ(1-CD-EJ-1,2A,B) Circ PPs(1-CD-P-2A,B)	Pipe rupture -or- Manual valve plug -or- Check valve transfer shut	Chilled component cooling water flow high temp.	No effect, unless amount of time to restore exceeds time allowed for operation with components isolated, (Tech. Specs.),	For pipe rupture, isolate affected sections and return unaffected sections to operation

D-17

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Contmt)
 DRAWING NO. 11448-FM-25A-D,L

UNIT Surry-1
 SHEET 1 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Entire IA System Outside Containment (All Loads)	IA compressor failure and loss of service air (SA) to IA rcvr	IA press ind (PI-IA-100 < 85 psi	RCPs tripped manually due (to loss of CCW to containment)	CCW from containment isolated
	- or -			
	IA aftercooler rupture and loss of SA to IA rcvr	Unit 1 IA compr alarm	Reactor trip (due to MSIV closure or SG low level)	MSIVs fail closed, main main feed reg valve fails closed & lo-lo SG level signal given
	- or -			
	IA receiver rupture, or relief valve sticks open, and failure to align SA to IA header	Local air leaks/decr pressure	Loss of MFW (due to reg. valves closure)	MFW reg valves fail closed
	- or -			
	IA dehydrator rupture and failure to use bypass	MSIVs closed alarm	TDAFW pumps start (due to open steam admission valves)	TDAFW pump steam admission valves fail open
- or -				
IA header rupture	SG lo-lo level alarm	(also refer to entries for these individual loads)	Loss of IA also causes a false lo-lo canal level signal - a signal < 18 FT will cause turbine trip	
	Charging pump to regen HX			
	Hi-Lo flow alarm			Air leaks must be stopped to prevent overheating & tripping of air compressors
				SA receiver acts as backup to IA system. SA use can be limited or SA loads isolated to ensure sufficient IA pressure
				IA from condensate polishing building can be valved in

D-18

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Cntmt)
 DRAWING NO. 11448-FM-25A-D,L

UNIT Surry-1
 SHEET 2 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
MFW Regulator Valves (FCV-1478, 1488, 1498)	Local air line rupture - or - Manual Valve Plug	Reg valves(s) fail closed Local leakage	Loss of MFW	MFW loss addressed as initiating event T ₂ Feed pumps shift to recirc, operator should secure For air leaks, can isolate air to one or all valves with air line valves, or crimp air line
MFW Minimum Flow Valves (FCV-FW-150A,B)	Local air line rupture - or - Manual valve plug	Min flow valve(s) fail closed Local leakage	No effect - when not in startup or low FW flow (comply with any re- quirements for min flow valve operability)	Min flow valve(s) used at low FW flow For air leaks, can isolate air to one or all valves with air line valves, or crimp air line
Feedwater Bypass Valves (HCV-FW-155A,B,C)	Local air line rupture - or - Manual valve plug	Unable to open FW by- pass valve(s) Local leakage	No effect (comply with any re- quirements for FW bypass operability)	FW bypass valves normally closed and fail closed on loss of IA For air leaks, can isolate air to one or all valves with air line valves, or crimp air line

D-19

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Cntmt)
 DRAWING NO. 11448-FM-25B

UNIT Surry-1
 SHEET 3 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Condensate Flow Control Valve To Extrac. Steam (LCV-CN-101)	Local air line rupture	Valve fails closed	No effect	Upstream valve (MOV-CP-100) normally closed
	- or - Manual valve plug	Local leakage		Flow to extrac. steam available from CST Decreased condenser level control capability Can isolate air leak upstream of LCV or crimp air line
Condenser Level Control Makeup Valves from CST (LCV-CN-102A,B)	Local air line rupture	Valve(s) fail rupture	No effect closed	Can isolate air leak(s) upstream of either LCV or crimp air line
	- or - Manual valve plug	Local leakage		
Condensate Recirc To Condenser Flow Control Valve (FCV-CN-107)	Local air line rupture	Valves fail closed	No effect	Condensate pumps functional through air ejector and gland steam condenser to main condenser via FCV-CN-107 Close upstream air valves or crimp line to isolate air leak
	- or - Manual valve plug	Local leakage		

D-20

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Cntmt)
 DRAWING NO. 11448-FM-25B, L

UNIT Surry-1
 SHEET 4 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
MSIVs (TV-MS-101A, B,C)	Local air line rupture - or - Manual valve plug - or - Check valve transfer shut	MSIV(s) F.C. High dP between steam line(s) and steam line header	Reactor trip	MSIV closure included as T ₂ initiator Operator can bypass around trip valves (1-MS-84, 116, 155) to supply steam to header
SG ADVs (RV-MS-101A,B,C)	Local air line rupture - or - Manual valve plug (2 must plug at ADV) - or - Check valve transfer shut	ADV(s) fail to open if needed Local leakage	None	Two air isol valves for each ADV - Both must be closed to isolate air to ADV, or a single upstream valve closed, or air line crimped
Decay Heat Release Valve (HCV-MS-104)	see above	Unable to open decay ht rel vlv Local leakage	None	Two air line valves, or a single valve upstream must be closed, or air line crimped to isolate air to decay heat release valve.
Turbine Control Valves (PCV-MS-111,...., 114)	Local air line rupture - or - Manual valve plug	Turbine control valve(s) fail closed	Loss of H.P. turbine control Turbine trip on loss of air to turbine	

D-21

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Cntmt)
 DRAWING NO. 11448-FM-25B, L

UNIT Surry-1
 SHEET 5 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>	
Turbine Bypass Valves (TCV-MS-105A,B; 106A,B,107A,B; 108A,B)	Local air line rupture	Unable to open turbine bypass valve(s)	No effect (comply with any re- quirements for minimum number of operable bypass valves)	Bypass valves normally closed Steam dumps (TCV-MS-105B, 106B) can be hand-operated for temperature control	
	- or - Manual valve plug	Local leakage			Can isolate air leaks for individual bypass valves and continue to operate with air available to unaffected bypass valves or crimp line
TDAFW Pump Steam Admission Valves (PCV-MS-102A,B)	Local air line rupture	Steam admission valves fail open	TDAFW pump starts	Can isolate air leaks with a single valve (air to both PCVs isolated)	
	- or - Manual valve plug	TDAFW pump starts			Nitrogen bottle backup to operate PCVs on loss of air
	- or - Check valve transfer shut				IA not needed for AFW operation
				Maintain SG levels by throttling AFW MOVs and/or securing AFW pumps	

D-22

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Contmt)

UNIT Surry-1

DRAWING NO. 11448-FM-25C

SHEET 6 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Makeup Line (HPI/HPR) (FCV-1122)	Local air line rptr - or - Manual valve plug (2 must plug at FCV) - or - Check valve	Unable to close FCV to stop makeup flow	No effect Full charging flow, charging pump recirc is functional but re- duced due to full charging flow	Makeup line FCV fails open on loss of IA Can isolate air leaks by closing one or both valves immediately upstream or single valve farther upstream
Fill Line (FCV-1160)	Local air line rupture -or- Manual valve plug	Unable to open FCV for fill	No effect (comply with any re- quirements for restoring fill capability)	Fill line FCV normally closed and fails closed on loss of IA
Seal Injection Flow Valve (HCV-1186)	Local air line rupture - or - Manual valve plug (2 must plug at HCV) - or - Check valve transfer shut	Unable to close HCV to stop seal injection	No effect. Throttle seal water injection to 6 gpm per pump	Seal Injection HCV fails open on loss of IA Can isolate air leaks by closing one or both valves immediately upstream or single valve farther upstream

D-23

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Contmt)
 DRAWING NO. 11448-FM-25A-D,L

UNIT Surry-1
 SHEET 7 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Letdown Line (TV-1204)	Local air line rupture - or - Manual valve plug - or - Check valve transfer shut	Loss of letdown flow	Close letdown flow orifice valves (HCV- 1200A,B,C, see CIA) Seal water return is only letdown available, may cause pressurizer level to increase	Letdown flow TV fails closed on loss of IA Can isolate air leaks at TV-1204 only, or isolate with other valve(s) air supply at a point farther upstream, or crimp air line
VCT Level Control Valve (LCV-1115A)	Local air line rupture - or - Manual valve plug	Loss of VCT automatic level control VCT hi/low level	No effect	Cycle LCV-1115B&D to maintain VCT level between 14 and 34% Manually vent VCT to primary drain tank

D-24

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Contmt)

UNIT Surry-1

DRAWING NO. 11448-FM-25C, D

SHEET 8 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
CCW Containment Isolation Valves (TV-CC-105A,B,C; and TV-CC-107)	Local air line rupture	Valves fail closed	Trip RCP(s) manually, and trip reactor.	Loss of CCW to RCP bearing & stator coolers and thermal barrier
	- or - Manual valve plug	RCP increasing bearing temp		
CCW Surge Tank Vent and Makeup (HCV-CC-100; LCV-CC-100)	Local air line rupture	Surge tank low	No effect (refer to CCW FMEA)	Vent and makeup fail closed on loss of IA
	- or - Manual valve plug			
Reactor CNTMT Air Recirc Coolers CCW/ Chilled Water Supply Valves (HCV-CC-101A,B; HCV-CC-102A,B)	Local air line rupture	Air recirc coolers high temperature indication	No effect (refer to CCW FMEA)	Valves fail closed on loss of IA
	- or - Manual valve plug			
	- or - Check valve transfer shut			If only CCW valve(s) close, align chilled water for air recirc cooling, if only chilled water valves lose air - No effect - these are normally closed
				Can isolate local air leaks upstream of individual valves

D-25

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Cntmt)
 DRAWING NO. 11448-FM-25A-D,L

UNIT Surry-1
 SHEET 9 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
CCW Load Isolation Valves (TCV-CC-103; TV-CC-109A,B; TV-CC-110A,B)	Local air line rupture	Non-regen HX (main coolant) decr temp	No effect	TCV-CC-103 fails open, TV-CC-109A,B; 110A,B,C fail closed on loss of IA
	- or - Manual valve plug (2 must plug for TCV-CC-103)	Excess letdown flow high temp	If CCW unavailable to RHR, cooldown to cold shutdown not possible	
	- or - Check valve transfer shut	Air recirc coolers high temp	Comply with requirements for operation without air recirc cooling	Can isolate local air leaks up- stream of individual TV/TCVs with one or more valves

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Contmt)

UNIT Surry-1

DRAWING NO. 11448-FM-25A-D

SHEET 10 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Intake Canal Level Transmitter (LT-CW-101)	Local air line rupture - or - Manual valve plug	False lo-lo canal level signal	Turbine trip and reactor trip on lo-lo canal level signal Condenser inlet and outlet MOVs, BC HX MOVs, and CC HX MOVs close on 18ft signal	Check confirming indications Can isolate air leak upstream of transmitter
Charging Pump Lube Oil Cooler Temp Control Valves (TCV-SW-108A,B,C)	Local air line rupture - or - Manual valve plug - or - Check valve transfer shut	Charging pump bearing decreasing temp	No effect	TCVs fail open on loss of IA Air leaks can be isolated up- stream of individual TCVs
Chiller Cond Temp Control Valves (TCV-SW-108A,B,C)	Local air line rupture - or - Manual valve plug	Chilled water unit decreasing temperature	No effect (comply with any re- quirements for chilled water unit TCVs oper- ability)	Chilled water unit TCVs fail open on loss of IA Isolate air leaks for affected individual valves
Control & Relay Room AC Chillers Temp Control Valves (TCV-SW-100A,B,C)		Room temperature indications	No effect (refer to Auxiliary ventilation FMEA)	Ventilation system is sized to limit temperatures to 100°F in occupied spaces and 120°F in machinery spaces

D-27

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Contmt)
 DRAWING NO. 11448-FM-25A-D

UNIT Surry-1
 SHEET 11 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Liquid Waste (miscellaneous AOVs)	Local air line rupture -or- Manual valve plug -or- Check valve transfer shut	Discharges to circ. water cease LW evap inoperable	No effect (comply with any requirements for liquid waste operability)	Secure liquid waste evap. bottoms pump and evaporator Line up drain header to low- level LW tanks All discharges to circ water secured on loss of IA
Boron Recovery (miscellaneous AOVs)	Local air line rupture -or- Manual valve plug -or- Check valve transfer shut	Primary drain tank pumps trip due to level transmitter failure Gas stripper pumps trip OVHD Gas com- pressor inoperable	No effect, (comply with any requirements for boron recovery opera- bility)	Evaporator feed pumps shift to recirc, bottoms draining and circulating is secured, bottoms tank is secured and BRTT discharge is secured on loss of IA Operator should secure boron recovery evap. bottoms pumps & evaporators

D-58
88

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM IA (Outside Cntmt)
 DRAWING NO. 11448-FM-25A-D

UNIT Surry - 1
 SHEET 12 of 12

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Gaseous Waste (miscellaneous AOVs)	Local air line rupture -or- Manual valve plug -or- Check valve transfer shut		No effect, (comply with any requirements for gaseous waste operability)	Process vent discharge FCV fails open Feed and bleed to and from AT secured, and WG diaphragm compressors inoperable on loss of IA
Bearing cooling (miscellaneous AOVs)	Local air line rupture -or- Manual valve plug -or- Check valve transfer shut	High BC temp	No effect	BC-2 makeup is secured on loss of IA, BC is supplied to all equipment Makeup available via fire main

D-29

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER

UNIT Surry - 1

DRAWING NO. _____

SHEET 1 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Loss of Vital Bus I (Red)	Bus short	Loss of corresponding VB voltage indication	Turbine auto runback	Loss of air ejectors vent to atmosphere causing low condensor vacuum High RCP bearing temperatures; may necessitate reactor trip
	-or- Load short		Low condenser vacuum	
	-or- UPS failure	Loss of corresponding instrument channel	One SI train lost (not energized) - manual activation available on both trains.	
		NIS rod drop, turbine run-back without IPRI rod drop indication	One CLS-Hi sensor input activated. One CLS-Hi-Hi sensor input lost.	
			CC to RCP Thermal Barrier isolated.	
		NIS rod drop, rod stop and turbine run-back annunciators	Containment Air isolated.	

D-30

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
DRAWING NO. _____

UNIT Surry - 1
SHEET 2 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Loss of Vital Bus II (White)	Bus short	Loss of corresponding VB voltage indication	Reactor trip required	Cooling to RCP-B radial bearings lost (TV-CC-105B fails closed) PORVs will not operate in auto Normal letdown flow lost (TV-1204 fails closed) Charging and letdown flow indications inoperable
	-or- Load short		RCP-B trip required	
	-or- UPS failure	Loss of corresponding nuclear instrument channel	Manual primary system pressure control required	
	-or- Loss of Inverter 1-II		One SI train lost (not energized) - manual acti- vation available on both trains One CLS-Hi sensor input activated, One CLS-Hi-Hi sensor input lost	

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
DRAWING NO. _____

UNIT Surry - 1
SHEET 3 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>	
Loss of Vital Bus III (Blue)	Bus short	Loss of cor- responding VB voltage	Reactor trip required	Cooling to RCP-A radial bearings lost (TV-CC-105A fails closed)	
	-or- Load short		RCP-A trip required		
	-or- Failure of UPS	Loss of cor- responding nuclear in- strument	One SI train lost (not energized) manual acti- vation available on both trains		FW bypass valves, AFW flow to SG-C indication, and SG-C WR level indication inoperable
	-or-		One CLS-Hi sensor input activated. One CLS-Hi- Hi sensor input lost		Pressurizer level is maintained with letdown orifice bypass valves
			FW bypass valves fail shut		

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
DRAWING NO. _____

UNIT Surry - 1
SHEET 4 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Loss of Vital Bus IV (Yellow)	Bus short	Loss of cor- responding VB voltage indication	Reactor trip required	Cooling to RCP-C radial bearings lost (TV-CC-105C fails closed) PC-444J input fails low Control charging with FCV-1122; LCV-1460 fails open
	-or- Load short		RCP-C trip required	
	-or UPS failure	Loss of cor- responding nuclear in- strument channel	Manual pressurizer pres- sure control required	
			MSW bypass valves fail closed	
			Manual control of charg- ing flow required	
			One SI train lost (not energized) manual acti- vation available on both trains	
	One CLS-Hi sensor input activated. One CLS-Hi-Hi sensor input lost			
		RMT control power lost		

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
DRAWING NO. 11448-ESK-6CD2,3

UNIT Surry - 1
SHEET 5 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
RHR CCW Discharge Valves (TV-CC-109A, B)	109A: VB-I, ckt 16 trip 109B: VB-II, ckt 21 trip	Excess letdown flow high temperature Primary shield coolers low pressure	RHR-CCW unavailable for unit cooldown.	SOVs energized to open valves CLS signal de-energizes SOV on Hi-Hi containment pressure
RCP CCW Discharge Valves (TV-CC-105A, B, C)	105A: VB-III, ckt 18 trip 105B: VB-II, ckt 20 trip 105C: VB-IV, ckt 18 trip	Increasing RCP bearing temperature	RCP must be tripped within 2 minutes of CCW loss or before bearing temperatures reach 200 ^o F Reactor must be tripped	SOVs energized to open valves CLS signal de-energizes SOV on Hi-Hi containment pressure
RCP CCW Thermal Barrier Discharge Valve (TV-CC-107)	VB-I, ckt 13 trip	RCP flow increasing temperature	No effect	SOV from VB-I energized to open valve CLS signal de-energizes SOV on Hi-Hi containment pressure.
Cont. Air Recirc. Coolers CCW Discharge Valves (TV-CC-110A, B, C)	110A: VB-III, ckt 18 trip 110B: VB-II, ckt 20 trip 110C: VB-IV, ckt 16 trip	Reactor containment air recirculation coolers high temperature	None unless amount of time required to restore CCW flow exceeds time allowed for operation without cont. air recirc. cooling, (Tech. Specs.)	SOVs energized to open valves CLS signal de-energizes SOV on Hi-Hi containment pressure

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
 DRAWING NO. 11448-ESK-6EJ,6CD6

UNIT Surry - 1
 SHEET 6 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
FW Recirc. Valves (FCV-FW-150A,B)	VB-I, ckt 16 trip	Decrease in FW flow to reactor	No effect. AFW required to feed SGs	SOVs energized to close valves
FW Bypass Valves (HCV-FW-155A,B,C) (2 SOVs per valve)	VB-III, ckt 23 trip and VB-IV, ckt 26 trip	Bypass flow indication	No effect. Feed SGs via bypass valves	Either SOV energized to close associated valve
Containment In- strument Air Suction Valves (TV-IA-101A,B)	101A: VB-I, ckt 27 trip 1-1B: VB-IV, ckt 21 trip	CIA low pressure indication	No effect. Open alternate suction valve (SOV-IA- 103) or cross-connect with IA system	SOVs energized to open valves
Containment In- strument Air Alt. Suction Valve (SOV-IA-103)	1-DP-IAC, ckt 1 trip		No effect. Alternate suction valve normally closed	SOV energized to open valve
Containment In- strument Air Discharge Valve (TV-IA-100)	VB-I, ckt 17 trip	CIA header low pressure alarm	No effect. Cross-connect with IA system	SOV energized to open valve

D-35

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
 DRAWING NO. 11448-ESK-6CD3,9;6EJ

UNIT Surry - 1
 SHEET 7 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
MS Condenser Drain Valve (TV-MS-109)	VB-I, ckt 13 trip	Valve closure	No effect. Loss of main stream line drain flow	SOV energized to open valve
SG Blowoff Tank Drain Valve (TV-MS-110)	VB-I, ckt 13 trip	Valve closure	No effect. Blowdown line manual valves nor- mally closed	SOV energized to open valve
Cond. Air Eject Vent Valve (TV-SV-102A)	VB-IV, ckt 13 trip		No effect. Vent valve normally closed	SOV energized to open valve
Condensate Recirc. Valve (FCV-CN-107)	VB-I, ckt 16 trip		No effect. Valve normally open, unable to regulate recirc. flow to condenser	SOV energized to close valve
Steam Generator Blowdown Valves (SOV-BD-100A,B,C; SOV-BD-102A,B,C; TV-BD-100A,C,E; TV-BD-100B,D,F)	100A,B,C: unident vital bus 102A,B,C: VB-I unident. ckt 100A,C,E: VB-I, ckt 15 trip 100B,D,F: VB-II, ckt 21 trip	Blowdown valve closure	Loss of SG blowdown	100A,B,C: SOVs energized to open valves 102A,B,C: SOVs energized to close valves Trip valves energized to open

D-36

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
 DRAWING NO. 11448-ESK-6CD1,5;6FF

UNIT Surry - 1
 SHEET 8 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Letdown Line Trip Valve (TV-1204)	VB-II, ckt 21 trip	Loss of normal letdown flow	No effect	SOV energized to open valve
RWST Cross- tie Valves (SOV-SI-102A1,A2; SOV-SI-102B1,B2)	102A1:VB-I, ckt 29 trip 102B1: VB-II, ckt 30 trip 102A2,B2:U-2 VB	None	No effect Cross-tie valves normally closed.	Cross-tie valves fail open on loss of IA or loss of associated VB
N2 Supply Valve (TV-SI-100)	VB-IV, ckt 17 trip			SOV energized to open valve
N2 Relief Trip Valves (TV-SI-101A,B)	101A: VB-I, ckt 15 trip 101B: VB-II, ckt 21 trip	Valve closure	No effect. Control/relief valves HCV-1898 and HCV-1936 normally closed.	SOVs energized to open valves.

D-37

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEZ 120 VAC POWER
DRAWING NO. 11448-ESK-6FB,6KD,J

UNIT Surry - 1
SHEET 9 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Control & Relay Room AC Chillers (VS-E-4A,B,C)	4A,C: VB-II, ckt 25 trip 4B: VB-IV, ckt 29 trip	Increased control room temperature Aux. Ventil. Control Panel	No effect Ventilation system is sized to limit tempera- tures to 120°F in machinery spaces	One chiller can provide sufficient cooling
Cable Vault & MCC Room Ventilation Supply Damper (VS-HV-2)		Aux. Ventil. Control Panel	No effect	Damper energized to close
Aux. Building Chg. PP Cubicle Exhaust Dampers (SOV-VS-107A,B; 116A, 108)	107A,B: VB-I, ckt 19 and VB-II, ckt 33 trip 108: VB-II, ckt 33 trip 116: VB-I, ckt 19 trip	Aux. Ventil. Control Panel	No effect Loss of one circuit, dampers on other circuit remain open to provide sufficient ventilation	107A,B: SOVs energize to to open dampers 108, 116 SOVs energize to close dampers
Charging Pump Cubicle Exhaust Dampers (MOD-VS-101A,B,C)	101A,C: VB-I, ckt 19 trip 101B: VB-II, ckt 33 trip	Aux. Ventil. Control Panel	No effect	Dampers energized to close

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
 DRAWING NO. 11448-ESK-6KH,L,S

UNIT Surry - 1
 SHEET 10 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(s)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Safeguards Area Exhaust Dampers (MOD-VS-100A,B; SOV-VS-110A,B)	100A,110A: VB-I, ckt 19 trip 100B,110B: VB-II, ckt 33 trip	Aux. Ventil. Control Panel	No effect. Loss of one circuit, AOD fails open and MOD on other circuit remains open to provide sufficient ventilation.	M.O. Dampers energized to open, SOVs energized to close A.O. dampers
Aux. Building Supply Fans (VS-HV-1A,B)	VB-III, ckt 21 trip and VB-IV, ckt 21 trip	Aux. Ventil. Control Panel	No effect. Loss of one circuit, alternate fan still operable	One fan provides sufficient ventilation
Ventilation Vent Stack Isolation Dampers (AOD-VS-112A,B)	112A: VB-I, ckt 19 trip 112B: VB-II, ckt 33 trip	Aux. Ventil. Control Panel	No effect. Utilize bypass flow path(s), as when ventilation vent high radiation detected	SOVs energize to open dampers
Miscellaneous Ventilation System Dampers, Fans & Bypasses	Misc. circuit(s) trip	Aux. Ventil. Control Panel	No effect. Loss of decon or fuel building ventilation - possible contamination	Redundancy for fans, dampers, and bypasses

D-39

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 120 VAC POWER
 DRAWING NO. 11448-ESK-6EF,G,H

UNIT Surry - 1
 SHEET 11 of 11

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Miscellaneous Boron Recovery System Valves	unidentified VB circuit(s) trip	Valve closure	No effect. Comply with requirements for operation with por- tions of boron recovery inoperable	Operator should secure pumps and tank discharges. Redun- dancy of some valves
Miscellaneous Gaseous Waste System Valves	VB-II, ckt 29 trip or VB-III, ckt 30 trip	Valve closure	No effect. Comply with requirements for operation without or with reduced capacity of gaseous waste system	SOVs energize valves to open
Miscellaneous Sample System Trip Valves	VB-I, ckt 15 or trip or VB-IV, ckt 17 or 18 trip	Valve closure	No effect. Comply with requirements for operation without sample systems	Valves energized to open

D-40

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 480 VAC POWER (1H1-1)
 DRAWING NO. 11448-FE-IL

UNIT Surry-1
 SHEET 1 of 1

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
All MOVs			No immediate effect	MOVs fail as is
Service Water Pump 10A (1-SW-P-10A) (1-SW-P-10A)			Loss of A train charging pump cooling	B train is normally available, or can cross- connect charging pump from Unit 2.
Component Cooling Pump 2A (1-CC-P-2A)			Loss of A train component cooling to to charging pump	B train is normally available
Containment Vacuum Pump (1-CV-P-1A)			No immediate effect Gradual containment pressure increase may lead to Tech Spec violation	
AC Chiller Pump 2A (1-VS-P-2A)			See Aux. Vent. FMEA	
Emergency Makeup Feedwater Pump (1-FW-P-1A)			None	

D-41

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 480 VAC POWER (1H)
DRAWING NO. 11448-FE-IF

UNIT Surry-1
SHEET 1 of 1

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Pressurizer Heater Bank (Backup Group)			Reduced pressure heater capacity	B train of heaters is is normally available
Low Head Safety Injection Pump 1A (1-SI-P-1A)			None	LPI pumps in standby during normal operation
Inside Spray Recirc Pump 1A (1-RS-P-1A)			None	ISR pumps in standby during normal operation
Outside Spray Recirc Pump 1A (1-RS-P-2A)			None	OSR pumps in standby during normal operation
Containment Recirc Fan 1A (1-VS-F-1A)			None	
Containment Spray Pump (1-CS-P-1A)			None	CS pumps in standby during normal operation

D-42

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 4160 VAC POWER (H Bus)
 DRAWING NO. 1148-FE-1D

UNIT Surry-1
 SHEET 1 of 1

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Auxiliary Feedwater Pump (1-FW-P-3A)			None, if unit at power	AFW pump in standby during manual operation
Charging Pump (1-CH-P-1A)			Loss of normal charging and seal injection flow	B pump is normally available and will provide charging flow. If B pump inoperable, C pump required to be operable.
480V Bus Feeders			Loss 480V buses	See 480V Bus FMEA
Component Cooling Pump 1A (1-CC-P-1A)			Loss of one CCW pump	B pump is normally available and will provide CCW flow.
RHR Pump 1A (1-RH-P-1A)			None, if unit at power	RHR pump in standby during normal operation

D-43

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM 4160 VAC POWER (H Bus)
 DRAWING NO. 1148-FE-1D

UNIT Surry-1
 SHEET 1 of 1

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Auxiliary Feedwater Pump (1-FW-P-3A)			None, if unit at power	AFW pump in standby during manual operation
Charging Pump (1-CH-P-1A)			Loss of normal charging and seal injection flow	B pump is normally available and will provide charging flow. If B pump inoperable, C pump required to be operable.
480V Bus Feeders			Loss 480V buses	See 480V Bus FMEA
Component Cooling Pump 1A (1-CC-P-1A)			Loss of one CCW pump	B pump is normally available and will provide CCW flow.
RHR Pump 1A (1-RH-P-1A)			None, if unit at power	RHR pump in standby during normal operation

D-44

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM SW
 DRAWING NO. 11448-FM-21A-D

UNIT Surry-1
 SHEET 1 of 4

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Entire SW System (All Loads)	Monumental biofouling	Chilled water unit high temp	Low canal level causes: - turbine trip - reactor trip - condenser isol (Trips related to loss of circ water not loss of SW)	Traveling screens must block 80% to fail SW
	- or -			
	Dam Failure	Condenser vacuum priming		
	- or -	seal recirc		
	LOSP and failure to isolate multiple condensers	pump low flow		
		Lo canal level		
		SW pump discharge low pressure		
		Component cooling pumps suction high temperature		Rupture of 42" SW line - low probability
		Bearing cooling water HXs outlet high temperature		Dam failure not included in internal events analysis

D-45

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM SW
DRAWING NO. 11448-FM-21A

UNIT Surry-1
SHEET 2 of 4

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Component Cooling Water Heat Exchangers (1-CC-E-1A,1C) (Standby:1B,1D)	Pipe rupture - or - Manual valve plug - or - MOVs SW-102A&B transfer shut	Component cooling pumps suction high temperature	If RCP motor bearings (CCW load) reach 200 ⁰ F, stop RCP and trip reactor	Valve plug addressed in event W fault tree Local pipe rupture or valve plug - align standby CCW HX and isol affected HX Both MOVs must close (or CCF) to fail load
Unit 1 Bearing Cooling Water Heat Exchangers (1-BC-E-1A,1C) (Standby:1B)	Pipe rupture - or - Manual valve plug - or - MOVs SW-101A&B transfer shut	Bearing cooling water HX outlet high temperature		Turbine plant equipment designed for max CW temp of 105 ⁰ F IA compressor jacket may be cooled by fire protection well water Rupture or plug: isol affected HX - align standby HX Both MOVs must close (or CCF) to fail load
Unit 1 Recirc Spray Heat Exchangers (1-RS-E-1A,1B, 1C,1D)	Pipe rupture - or - Check valve(s) fail to transfer - or - MOVs SW-103A,B,C,D all fail to open	(refer to loss of all SW)	Loss of recirc spray cooling	Addressed in ISR and OSR fault trees - events F1 and F2 Recirc spray HXs normally isolated

D-46

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM SW
DRAWING NO. 11448-FM-21B

UNIT Surry-1
SHEET 3 of 4

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Charging Pump Intermediate Seal Cooler (1-SW-E-1B) (Standby:1A)	Pipe rupture - or - Manual valve/ strainer plug (1-DS-S-2B, 1-VS-S-1A) - or - Check valve transfer shut - or - Charging pump SW pumps fail (1-SW-P-10A, B)	Charging pump bearing increasing temperature	Loss of charging pump seal cooling, impacts pump operation for seal injection flow and SI flow	Addressed in CPC fault tree Rupture - isol affected cooler and align standby Plugged valve/strainer - align standby loop or X connect from Unit 2 Pump fails/check valve closed - start standby pump
Charging Pump Lube Oil Coolers (1-CH-E-5A,5B, 5C)	(refer to above) - or - Coolers plugged (1-CH-E-5A,5B,5C) - or - TCVs SW-108A,B,C transfer shut	see above	see above	see above Plugged cooler - isolate affected cooler and stop affected pump

D-47

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM SW
DRAWING NO. 11448-FM-21C

UNIT Surry-1
SHEET 4 of 4

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Unit 1 Chiller Condenser (1-CD-REF-1A)	Pipe rupture - or - Check valve transfer shut - or - Manual Valve/ Strainer plug (1-CW-S-4) - or - SW pumps fail (1-SW-P-4A, 4B) - or - TCV-SW-107A Transfers shut	Chilled water unit high temperature SW pumps discharge low pressure	No effect unless amount of time required to restore exceeds the allowed for operation without chilled water unit, (Tech Specs)	Strainer plug - blowdown or rotate Pump fails - start standby Loss of SW - shutdown chilled water unit
Control & Relay Room AC Chiller Condensers (1-VS-E-4A, 4B, 4C)	Pipe rupture - or - Manual valve/ strainer plug (1-VS-S-1A,1B) - or - Pumps fail (1-VS-P-1A,1B,1C) - or - PCVs SW-100A,B,C Transfer shut	High room temperatures		

D-48

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM Auxiliary Ventilation
 DRAWING NO. _____

UNIT Surry-1
 SHEET 1 of 5

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Entire System (all ventilation loads)	Loss of all AC	Auxiliary ventila- tion control panel (VNTX) & annuncia- tor	Possible contamination. No effect on unit opera- tion	One fan can provide 70% capacity exhaust and a step flow reduction capability Parallel arrangement of safety- related filter system provides an effective standby filter Safety-related fans draw air through ECCS equipment areas to safety-related filters
	Loss of SW		No effect. Degraded fil- ter performance and reduced exhaust flow rate	Fan inlet dampers fail open on loss of compressed air Exhaust bypasses allow for selective filtration of any exhaust system. Other exhaust systems have dampers in series to provide redundant closure after a LOCA

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM Auxiliary Ventilation
DRAWING NO. _____

UNIT Surry-1
SHEET 2 of 5

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Control & Relay Room Area	Failure of both air conditioning systems (1 FTR and 1 FTS) -or- Failure of all 3 refrigeration chillers (or CCF) -or- Loss of SW flow to all 3 chiller condensers (1-VS-E-4A,4B,4C) -or- Failure of all 3 condenser SW pumps (1-VS-P-1A,1B,1C) -or- Failure of normal exhaust & makeup and Failure of bottled air supply and Failure of emergency ventilators	Increased control room temperature Auxiliary Ventilation Control Panel (VNTX) & Annunciator	No effect. Ventilation systems sized to limit temperatures to 100°F in occupied spaces and 120°F in normally unoccupied machinery spaces, assuming heat-producing equipment is operating	Each AC system consists of 1 air handling unit for each space (2 for control room & 1 for relay room) One refrigeration chiller can support both AC systems - providing redundant chilled water supplies SW flow provided by 2 independent sources (see SW FMEA) Normally, exhaust & makeup air is provided by other service building ventilation systems During emergency conditions, the control and relay room area is sealed. A 1-hour supply of bottled air provides breathing air and pressurization; upon depletion of bottled air, emergency ventilators supply breathing air and pressurization indefinitely. AC systems continue to operate normally (powered from emergency buses)

D-50

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM DRAWING NO. Auxiliary Ventilation

UNIT Surry-1
SHEET 3 of 5

<u>LOAD/COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Auxiliary Building	Both air handling units fail -or- Central area and potentially contaminated general area exhaust fans fail -or- Both exhaust fans to ventilation vent fail -or- Charging pump cubicle(s) exhaust damper(s) fail to open when pump(s) operating -or- Non-safety-related high-head fans fail and General area exhaust stream contaminated -or- Heating steam system failure	Auxiliary Ventilation Control Panel (VNTX) &	Possible contamination. No effect on unit operation	The supply fans and one exhaust fan for the central area and general area are tripped on ventilation vent hi-radiation from unidentified source If general area exhaust stream is contaminated, it is manually diverted through the non-safety-related filter subsystem by stopping the ventilation vent exhaust fans, realigning dampers, and starting high-head NSR fan
	Auxiliary Building decreasing temperatures		Low Auxiliary Building temperatures	

D-51

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM
DRAWING NO.

Auxiliary Ventilation

UNIT Surry-1
SHEET 4 of 5

LOAD/
COMPONENT

FAILURE/LOSS OF
LOAD CAUSES

DETECTION
METHOD(S)

FAILURE EFFECT ON UNIT

REMARKS

Safeguards
Area

Both exhaust fans
for potentially
contaminated areas
fail

-or-

Intake supply sys-
tems fail

-or-

Both exhaust stream
dampers fail closed

-or-

Heating steam sys-
tem fails

Auxiliary Ventila-
tion Control Panel
(VNTX) & Annuncia-
tor

Safeguards areas
increasing tempera-
tures

Safeguards areas
decreasing
temperatures

Possible contamination
or area high tempera-
tures (may exceed 120⁰F
in pump cubicles)

Exhaust systems automatically
bypassed on CLCS signal to
ensure any radioactive leakage
is removed

Redundant intake systems, ex-
haust fans and exhaust stream
dampers provide flow paths to
filters following a LOCA

Service
Building

All exhaust fans
for potentially
contaminated areas
fail

Auxiliary Ventila-
tion Control Panel
(VNTX) & Annuncia-
tor

Possible contamination
No effect on unit
operation

Ventilation provided for
radioactive contamination
removal

D-52

SYSTEM LEVEL FAILURE MODES AND EFFECTS ANALYSIS

SYSTEM Auxiliary Ventilation
DRAWING NO. _____

UNIT Surry-1
SHEET 5 of 5

<u>LOAD/ COMPONENT</u>	<u>FAILURE/LOSS OF LOAD CAUSES</u>	<u>DETECTION METHOD(S)</u>	<u>FAILURE EFFECT ON UNIT</u>	<u>REMARKS</u>
Decontamination Building	Supply fan fails -or- Both exhaust fans fail -or- An exhaust duct damper fails closed -or- Heating steam system failure	Auxiliary Ventilation Control Panel (VNTX) & Annunciator Decon building decreasing temperatures	Possible contamination No effect on unit operations	Normally ventilated at 15 air changes per hour Dampers designed to provide redundant closure following a LOCA
Fuel Building	Spent fuel pit supply fan fails -or- Both exhaust fans fail -or- An exhaust duct damper fails closed -or- Heating steam system failure	Auxiliary Ventilation Control Panel (VNTX) & Annunciator Fuel building decreasing temperatures	Possible contamination, buildup of condensation, or spent-fuel pool clouding	During refuel, exhaust is continuously bypassed through filters to ensure radioactivity removal Dampers designed to provide redundant closure following a LOCA

D-53

D.2 Assessment of Frequency of Small Breaks, Based on Historical Experience

The original NUREG/CR-4550 analysis used a frequency of $2E-2$ for very small breaks. One of the industry comments received during the review cycle indicated that if the value of $2E-2$ was accurate, there should have been approximately 20 small breaks in the history of nuclear power. This is based on an accumulated U.S. LWR experience of approximately 350 reactor years for BWRs and 600 reactor years for PWRs. This number of failures would be visible and thus provide an accurate historical basis for calculation of small break frequency. As a result of these comments, a survey of historical experience was done to assess the frequency of small breaks. This survey resulted in the assessment of a frequency of $1.3E-2$ per year for this event.

D.2.1 Scope of Search

Very small LOCA is defined as a loss of coolant inventory which is large enough to cause a safety injection signal but not large enough to be put in the S_2 event category. Very small LOCAs could result from the following:

- Reactor Coolant Pump Seal Failures
- Pipe Breaks
- Component Failures

A search of operating experience was made for each of these type of events. The results are summarized in Table D.2-1 and discussed individually in the following sections.

D.2.2 Reactor Coolant Pump Seal Failures

This event category involves LOCAs due to random internal failures of the seal. Seal failures due to loss of cooling are not included in this category. NUREG/CR-4400 (Reference D.2-1) provides a survey of seal failure events from 1974 to January 1984. Five of these events were considered applicable to this effort.

<u>Plant</u>	<u>Date</u>	<u>Leakrate</u>	<u>Total Leakage</u>
Oconee 2	1/74	90 gpm	50,000 gallons
H.B. Robinson	5/75	500 gpm	200,000 gallons
Indian Point 2	7/77	75 gpm	90,000 gallons
Salem 1	10/78	--	15,000 gallons
ANO 1	5/80	400 gpm	60,000 gallons

These five events were applicable due to leak size and total leakage as compared with the other events. A sixth event, at Connecticut Yankee in August 1977, resulted in total leakage of 4020 gallons at an unspecified leak rate. This event was not included as an applicable seal failure because of the limited total leakage, compared with the other events.

The survey in NUREG/CR-4400 covers operational experience up to January 1984. An LER search was performed for all PWR seal LOCA events from January 1984 to January 1988. No events were found. PWR operating experience through January 1984 was calculated to be 418 reactor years. Total PWR experience through January 1988 was calculated to be 610 reactor years.

At first it would seem appropriate to divide 5 failures by 610 years, for a point estimate of $8.2E-3$ per year. However, comparison of the dates when the five large seal failures occurred with the dates of all the non-serious seal failures listed in NUREG/CR-4400, it

SUMMARY OF SMALL BREAK EXPERIENCE

<u>Break Type</u>	<u>LER Survey or Reference</u>	<u>Number of Occurrences</u>	<u>Number of Applicable Occurrences</u>	<u>Number of Reactor Years</u>	<u>Point Estimate Frequency</u>	<u>Comments</u>
RCP Seal LOCA	Ref. D.2-1	Many	5	418		Frequency represents the mean of a Bayesian update of pre '81 data with post '81 data
	LER Survey 1/84 - 1/88	0	0	192	.0039	
Pipe Break	Ref. D.2-2	19	8	741		Combined PWR and BWR experience. Assumed 20% of PWR piping was LOCA sensitive.
	LER Survey 1/85 - 1/88	2	0	216	.0017	
Component Leakage	Ref. D.2-3 (PWR Cat. 5)	20	14	370	.0076	PWR experience only. Assumed 20% LOCA sensitive piping
					.0132	

D-55

is clear that seal problems have significantly decreased over the years. The experience was therefore correlated, based on the hypothesis that seal quality has improved over the years, and that seal failures were predominately an early-industry problem. The data was split into two time periods, and the performance of the first time period was combined with the performance of the second time period through Bayesian update, as summarized below:

<u>Time Period</u>	<u>Seal Failures</u>	<u>Reactor Years</u>
1/74 - 1/81	5	281
1/81 - 1/88	0	329

The prior used 5 failures in 281 years with a range factor of 5. The resultant mean frequency, after updating the data was $3.9E-3$, error factor 2.7.

D.2.3 Pipe Breaks

NUREG/CR-4407 was reviewed for occurrences of pipe break events. Pipe breaks are different from component failures as described in the next section. This category represents failures in pipes themselves rather than pumps, heat exchangers, valves or thermocouples. NUREG/CR-4407 reports on pipe failures in nuclear grade systems, including steam generator systems, steam, and feedwater systems. The survey shows that through 1985, 19 pipe failures had occurred. An LER search was done to survey experience through 1988. This yielded two additional failures; a Surry MFW pipe failure and a Farley charging system pipe crack. Of these 21 failures, none have occurred in LOCA sensitive piping connected to the reactor coolant system. The failures have occurred in steam generator, feedwater, steam systems, and non-LOCA sensitive portions of the primary systems. It was therefore necessary to correlate the total number of failures and apportion the frequency to LOCA sensitive piping.

This apportioning was based on the following estimates of pipe lengths in a typical Westinghouse PWR. The values below are based on Table 6 in NUREG/CR-4407.

	<u>Pipe Length (ft)</u>
A. Reactor Coolant System	960
B. High Pressure Injection System	2280
C. Residual Heat Removal System	2380
D. Chemical Volume and Control System	6110
E. Main Steam System	4300
F. Main Feedwater System	1000

For purposes of determining the percentage of LOCA sensitive piping, it was considered that 100% of A, 33% of B and C, and 10% of D were LOCA sensitive. This yields an overall ratio of 18% (or approximately 20%) for LOCA sensitive piping.

Of the 19 pipe failures in Reference D.2-2, eight were classified as large (greater than 15 gpm), and occurring during startup or power operation. None were assumed to be large enough to be a larger size LOCA. Of the two additional failures uncovered by the LER search, only the Surry MFW break was categorized as large. However, it is clearly too large to be counted as a very small break. Therefore, there were eight applicable failures in 957 reactor years. Multiplying by the 20% LOCA sensitive ratio results in an estimate of $1.7E-3$ for pipe break frequency in LOCA sensitive piping.

D.2.4 Component Boundary Failures

NUREG/CR-3862 was surveyed for component boundary failures. The referenced document lists 41 categories for PWR transient initiators. PWR category 5 was considered applicable to this evaluation. Category 5 is "leakage in primary system." Category 4, "leakage from control rods" was initially examined, but it was concluded that it was not physically possible to get control rod leakage of sufficient magnitude to require safety injection flow (i.e., definition of a LOCA). NUREG/CR-3862 surveys experience through January 1984, accounting for 418 PWR years. Twenty events are reported in category 5. Of these, 6 were eliminated. Two events were seal LOCAs at ANO-1 and Salem, which have been previously counted in Section D.2.2. Four other events occurred in the first year of reactor operation and were eliminated on that basis. Fourteen events in 370 reactor years (i.e., eliminate first year), times 20% LOCA sensitive piping = $7.6E-3$ per year.

D.2.5 References

- D.2-1 Azarm, M.A., Boccio, J.L., Mitra, S., The Impact of Mechanical and Maintenance Induced Failures of Main Reactor Coolant Pump Seals on Plant Safety, NUREG/CR-4400, Brookhaven National Laboratory, Upton, New York, December 1985.
- D.2-2 Wright, R.E., Steverson, J.A., Suroff, W.F., Pipe Break Frequency Estimation for Nuclear Power Plants, NUREG/CR-4407, EG&G Idaho, Inc., May 1987.
- D.2-3 Mackowiak, D.P., et al, Development of Initiating Event Frequencies for Use in Probabilistic Risk Assessments, NUREG/CR-3862, EG&G Idaho Inc., May 1985.

D.3 Development of the T_1 Initiating Event Frequency and Non-Recovery Probabilities for Offsite AC Power

A Bayesian statistical analysis was performed in support of NUREG-1150, in order to derive a plant specific frequency for loss of offsite AC power and the probabilities for non-recovery of offsite power by various times. The methodology and supporting data for this analysis is described in detail in Reference D.3-1. This section provides a summary of the methodology, the plant specific data used in the calculation, and the results.

Reference D.3-1 provides a statistical analysis of 63 loss of offsite power events at nuclear plants in 721 calendar years. The 721 calendar years represent 503 operating years of experience. For each of the 63 events, the actual time for recovery of offsite power is known. The 63 events are divided into three categories, based on the cause of power loss. The categories and events are

- 43 plant centered events: caused by faults in the switchyard
- 7 weather related events: grid failure due to severe weather
- 13 grid related events: grid failures or instabilities.

The plant centered events were further divided into three categories, based on switchyard configuration. These groups are I1, I2 and I3 as described in NUREG-1032. The number of events in each category are:

- 14 events for group I1
- 13 events for group I2
- 16 events for group I3

A generic distribution for frequency of loss of offsite power was generated, based on a two component model. The plant centered component included 43 events in 503 operating years. The grid/weather component included 20 events in 721 calendar years. Each part of the two component model was analyzed using Bayesian methods to generate a plant specific distribution. The two components were combined to form the cumulative distribution for frequency of loss of offsite power at Surry. The Surry specific experience is zero plant centered failures in 12.3 operating years and zero grid/weather failures in 15.1 calendar years. The resultant distribution for loss of offsite power frequency is shown in Figure D.3-1. The statistical characteristics are shown in Table D.3-1.

A three component model for probability of non-recovery of AC power was similarly developed. However, it was not possible to include plant specific experience in this model. Rather, a model was developed for each switchyard type. All plants with a particular switchyard type can be represented by the same non-recovery curve. The non-recovery model included grid and weather components applicable to all plants, and a plant centered component representative of the switchyard. Surry has an I3 switchyard configuration. The resultant recovery curve is shown in Figure D.3-2.

D.3.1 Reference

Iman, R.L., Hora, S.D., Modeling Time to Recovery and Initiating Event Frequency for Loss of Off-Site Power Incidents at Nuclear Power Plants, NUREG/CR-5032, January 1988.

DISTRIBUTION OF INITIATING FREQUENCY FOR SURRY




Figure D.3-1

Table D.3-1

DISTRIBUTION OF INITIATING EVENT FREQUENCY FOR SURRY 1
 9:56 TUESDAY, JANUARY 12, 1988

UNIVARIATE

VARIABLE=FREQ

MOMENTS

N	1000	SUM WGTS	1000
MEAN	0.0768503	SUM	76.8503
STD DEV	0.0389527	VARIANCE	0.00151732
SKEWNESS	0.728448	KURTOSIS	1.87615
USS	7.42177	CSS	1.5158
CV	50.6865	STD MEAN	0.00123179
T:MEAN=0	62.3889	PROB> T	0.0001
SGN RANK	250250	PROB> S	0.0001
NUM 0	1000		

QUANTILES(DEF=4)

EXTREMES

100% MAX	0.284425	99%	0.198115	LOWEST	HIGHEST
75% Q3	0.0983122	95%	0.140835	.000026496	0.226843
50% MED	0.0766992	90%	0.120537	.000229286	0.236011
25% Q1	0.0514392	10%	0.0270755	.000459511	0.236011
0% MIN	0.00026496	5%	0.0156033	.000101039	0.24271
		1%	0.00202154	.000811486	0.284425
RANGE	0.284399				
Q3-Q1	0.046873				
MODE	0.236011				

RECOVERY CURVE FOR SURRY




Figure D.3-2

D.4 Core Uncovery Time Versus Break Size

Core uncovery times versus break size for sequences with no high pressure makeup were developed based on a survey of existing analyses on Surry, Sequoyah and generic Westinghouse plants. Based on the results of the survey, it was decided that modeling assumptions and computer code differences produced greater variations in results than plant-to-plant variability could produce. All analysis on Westinghouse plants was therefore considered applicable to this generic evaluation. The applicable data (i.e., small break sequences) listed in Table D.4-1 plus results from in NUREG-1032, WCAP 9763, and Westinghouse seal LOCA analysis have formed the basis for the development of the core uncovery curve.

The times to core uncovery and core damage of the individual analyses were plotted versus break size. The distinction between core uncovery and core damage was retained in the correlation of data. In addition, some analyses report break size and some report flow rate. A mass flux constant of $11,000 \text{ lb/s-ft}^2$ was used to put the data on a consistent basis. This value is taken from the Moody critical flow chart, saturated water at 2200 psi. The plot of core uncovery time versus break size is shown in Figure D.4-1.

A curve was constructed for core uncovery, and another curve was constructed for core melt. The uncovery curve, not the core melt curve, became the basis for determining recovery times in the recovery analysis. The next step was to develop a curve which included the effect of operator induced depressurization of the primary system. The data points in Figure D.4-1 represent analysis with no operator depressurization.

The effect of operator induced depressurization on the extension of core uncovery times depends upon when depressurization begins, how fast it occurs, and how low the RCS pressure is reduced. These parameters are sequence and reactor specific. In order to provide a generic estimate, the depressurization curve was based on results from a Westinghouse seal LOCA analysis (Ref. D.4-3), which developed uncovery times with and without depressurization. The percent increase in uncovery time for specific break size from the Westinghouse analysis was used to develop the uncovery curve shown in Figure D.4-2.

D.4.1 References

- D.4-1 WCAP-9763 - Inadequate Core Cooling Studies of Scenarios with Feedwater Available, Using the NOTRUMP Computer Code, Westinghouse Electric Corp., Pittsburgh, Pennsylvania, November 1980.
- D.4-2 Baranowsky, P., Evaluation of Station Blackout Accidents at Nuclear Power Plants, NUREG-1032, U.S. Nuclear Regulatory Commission, May 1985.
- D.4-3 Presentation to NUREG-1150 Expert Elicitation Meeting by M. Hitchler, Westinghouse Electric Corporation, November 1987.

Table D.4-1
Times from Start of Accident to Core Uncovery

<u>Plant</u>	<u>Sequence</u>	<u>Time to Uncovery (Min)</u>	<u>Source</u>
Surry	TMLB'	95.5	BMI-2104
Surry	S2D	27.8	BMI-2104
Surry	V	20.6	BMI-2104
Surry	AB (2 Vol.)	9.4	BMI-2104
Surry	AB (4 Vol.)	7.1	BMI-2104
Surry	AG	3081.	BMI-2139
Surry	TMLB'	97.2	BMI-2139
Surry	S2D	28.5	BMI-2139
Surry	S3B	87.6	BMI-2160
Sequoyah	S3HF	272.4	BMI-2139
Sequoyah	S3HF	273.7	BMI-2160
Sequoyah	S3B	236.6	BMI-2139
Sequoyah	S3B (delayed)	362.	BMI-2160
Sequoyah	TMLU-SGTR	104.0	BMI-2139
Sequoyah	TBA	517.8	BMI-2139
Seabrook	TMLB' (fast)	120.	W MAAP
Seabrook	TMLB' (slow)	420. after FW loss	W MAAP
Sequoyah	S2D	48.	Idcor MAAP
Sequoyah	S2H	78.	Idcor MAAP
Sequoyah	S2HF	72.	Idcor MAAP
Sequoyah	TMLB'	105.	Idcor MAAP
Sequoyah	T23ML	90.	Idcor MAAP
Sequoyah	TMLB'	97.8	BMI-2104
Sequoyah	S ₂ HF	163.	BMI-2104
Sequoyah	TML	97.2	BMI-2104




Figure D.4-1. Time to Core Uncovery and Core Melt Variation With LOCA Break Size




Figure D.4-2. Time to Core Uncovery Variation With LOCA Break Size and Secondary Depressurization

D.5 Integration of Reactor Coolant Pump Seal LOCA Model into Station Blackout Sequences

Prediction of reactor coolant pump seal behavior under loss of all seal cooling conditions is an integral part of station blackout model development. Due to the unavailability of seal performance data to this project, the issue of seal performance was resolved through expert elicitation. The process of this elicitation and the results are presented in NUREG/CR-4550, Volume 2, Revision 1. This section provides a discussion of how the elicitation results were used to develop a plant specific model and how this model was integrated into the event tree analysis and quantification process.

The expert elicitation process resulted in a series of leak rates, probabilities, and times for seal failure. This information became the starting point for seal LOCA model development. Table C.4-9. from Volume 2, Rev. 1 presents these results. This table is included here as Table D.5-1. It shows probabilities of RCS leak rates for various times after loss of seal cooling. The leak rates represent total leakage from all three pumps. The three pumps were not necessarily postulated to fail in the same manner, thus they may have different leak rates. The probabilities for a given leak rate changed with time in a manner that indicates that the leak rates increase with time. The experts generally considered seal behavior to be dynamic with loss of seal integrity increasing with time. Each seal stage was modeled individually, and each seal stage was allowed to fail in different modes, thus resulting in different leak rates through that stage. Overall leak rate was dependent on the combination of each stage failure. A series of individual seal LOCA scenarios was therefore possible, each scenario being a distinct combination and progression of seal stage failures.

In order to incorporate this information into the sequence models, it is necessary to calculate a time of initial seal failure and a core uncover time for each possible failure scenario. Therefore, it is necessary to define a series of individual scenarios which identify the time of seal failure, the initial leak rate, the progression of the leak rate, and the probability of the scenario. The data in Table D.5-1 were used to develop these scenarios.

A total of 20 scenarios were identified and are shown in Table D.5-2. They include the initial leak rate, the time of initial seal failure, any increases in leak rate, the time at which the leak rate increases, and the probability. These 20 scenarios were used to develop point estimate probabilities (i.e., no uncertainty stated) for seal failure and core uncover. These values were not used in the uncertainty analysis. In order to calculate the probability distributions for seal LOCA sequences, the 20 scenarios were consolidated into eight states. There are seven failure states and one success state (the 63 gpm state is a success state). The eight seal states are summarized below:

<u>Leak Path (gpm)</u>	<u>Time to Transfer</u>	<u>Probability</u>
750*	1 1/2	.5302
183 - 750	2 1/2	.1270
183*	2 1/2	.0161
183*	3 1/2	.0161
1440*	1 1/2	.0043
183*	1 1/2	.0140
372 - 750	2 1/2	.0062
63* (success)		.274

* Constant leak rate

Table D.5-1 Aggregated RCP Seal LOCA Probabilities - Three Pumps

Leak Rate (gpm)	Old O-Rings Time (Hrs.)					New O-Rings Time (Hrs.)				
	1.5	2.5	3.5	4.5	5.5	1.5	2.5	3.5	4.5	5.5
83	.308	.280	.274	.274(.258)*	.274(.241)	.817	.818	.814	.812	.811
103	-	-	-	-	-	7.7E-3	7.7E-3	7.7E-3	7.7E-3	7.7E-3
183/224	.148	.0370	.0502	.0478(.0840)	.0466(.0790)	.0136	.0142	.0157	.0173	.019
284	-	-	-	-	-	1.9E-3	1.9E-3	1.9E-3	1.9E-3	1.9E-3
372	8.5E-3	5.0E-3	4.5E-3	3.7E-3	3.3E-3	4.5E-4	5.0E-3	5.3E-3	5.7E-3	6.0E-3
425	-	-	-	-	-	1.9E-3	1.9E-3	1.9E-3	1.9E-3	1.9E-3
518/526/546	3.5E-4	3.4E-4	3.2E-4	3.2E-4	3.2E-4	.145	.145	.145	.145	.145
602/614	.001	0	0	0	0	4.7E-4	4.7E-4	4.7E-4	4.7E-4	4.7E-4
750	.530	.660	.660	.660	.660	7.7E-3	7.7E-3	7.7E-3	7.7E-3	7.7E-3
1440	4.3E-3	4.3E-3	4.3E-3	4.3E-3	4.3E-3	5.0E-3	5.0E-3	5.0E-3	5.0E-3	5.0E-3

*Parentheses denote calculations which change if no depressurization is assumed.

These values are the probabilities of being at a particular leak rate at a particular time.

Table D.5-2
Surry RCP Seal LOCA Model Paths

<u>Leak Path (Gpm)</u>	<u>Time to Transfer (Hours)</u>	<u>Probability</u>
63*	-	.274
63 - 183	2 1/2	.0161
63 - 183	3 1/2	.0161
183*	-	.0140
183 - 372	2 1/2	.0005
183 - 372	3 1/2	.0005
183 - 750	2 1/2	.1270
183 - 750	3 1/2	.0024
183 - 750	4 1/2	.0024
183-750	5 1/2	.0012
372*	-	.0022
372 - 750	2 1/2	.0040
372 - 750	3 1/2	.0009
372 - 750	4 1/2	.0009
372 - 750	5 1/2	.0005
530*	-	.0003
602 - 980	2 1/2	.0010
750*	-	.5302
980*	-	.0013
1440*	-	<u>.0043</u>
Total		1.006

* Constant Leak Rate

This probability distribution is interpreted as a representation of the experts collective degrees of belief in the eight states that represent possible outcomes for seal LOCA. The occurrence of a seal LOCA is therefore treated as a modeling uncertainty with respect to time and size. These states were sampled as either a zero or unity probability in the TEMAC uncertainty analysis. The following discussion illustrates how the seal LOCA model was integrated into the station blackout event trees. Two constraining criteria were applied to this task: 1) the event heading for non-recovery of AC power would be separate from the event heading for seal LOCA, and 2) a minimum number of headings for seal failure and non recovery would be used.

The conclusion of the expert panel was that at 90 minutes after loss of all seal cooling, the seal temperatures have increased enough to be at risk of failure. Prior to 90 minutes, there is no risk of seal failure. If AC power is restored before 90 minutes, seal failure is averted. After 90 minutes, with no cooling, the seal may fail or may remain intact. It may develop a small leak which increases with time, or may have a constant leak rate. If a seal failure occurs, core uncovering can be averted if AC power is restored in sufficient time, thus enabling restoration of safety injection flow.

The mathematical development of the core damage probability due to seal LOCA is given as a weighted average of the 20 seal states as follows:

Prob. Core =	Prob. at	Prob.	Prob. no
Damage	risk for *	SLOCA *	recovery AC
	SLOCA	occurs	prior to core
			uncovery

The probability of being at risk for a seal LOCA is the probability that AC power has not been restored (within 90 minutes after loss of seal cooling). The probability of a seal LOCA is given by the results of the expert elicitation. There are 20 seal LOCA scenarios, each with a characteristic uncovering time and a specific probability. All seal scenarios start at 90 minutes from loss of cooling. Finally, the probability of not recovering is just the probability of non-recovery of AC power prior to the characteristic core uncovering time associated with each seal scenario. Note that in developing the probabilities for this equation, the non-recovery term must be conditional on non-recovery of AC power in the first 90 minutes. The core damage (CD) equation can be written as:

$$\text{Prob. CD} = \sum_{i=1}^{20} P_{\text{NRAC}}(t) * f_{\text{sl}_i}(t) * C_{\text{NRAC}}(t + \lambda_i)$$

where i = seal LOCA scenario index, and t , in this case, equals 90 minutes.

λ_i = core uncovering time associated with the i^{th} scenario.

$f_{\text{sl}_i}(t)$ = probability of i^{th} seal LOCA scenario.

$P_{\text{NRAC}}(t)$ = probability of non-recovery of AC power by time t , given loss of power at $t = 0$ (shown in Figure D.3-2). $P_{\text{NRAC}}(t) = 1 - F_{\text{NRAC}}(t)$, where F is the cumulative probability of recovery of AC power.

$C_{NRAC}(t + \lambda)$ = conditional probability of non-recovery of AC power by time $t + \lambda$, given no recovery at time t .

$$C_{NRAC}(t + \lambda) = \frac{P_{NRAC}(t + \lambda)}{P_{NRAC}(t)} = \frac{1 - F_{NRAC}(t + \lambda)}{1 - F_{NRAC}(t)}$$

recognizing the form for C_{NRAC} , the equation reduces to:

$$\sum_{i=1}^{20} f_{sl_i}(t) * P_{NRAC}(t + \lambda_i)$$

The values for f_{sl_i} , λ_i , and $P_{NRAC}(t + \lambda_i)$ are shown in Table D.5-3. Core uncover times were calculated for the case with and without secondary depressurization. The core uncover times were calculated from the data in Appendix D.4.

Table D.5-3
 Surry RCP Seal LOCA Model¹

Leak Path (Gpm)	Time to Transfer (Hours)	Prob.	Time to CU (Hrs) (with secondary depressurization)	Time to RAC (Hrs)	Prob. NRAC	Prob. CD	Time to CU (Hrs) (without secondary depressurization)	Time to RAC (Hrs)	Prob NRAC	Prob CD
63 C	-	.274	24	24	.05	-	10.6	10.6	.05	-
63 - 183	2 1/2	.0161	12.0	13.5	.05	.00081	6.3	7.8	.05	.00081
63 - 183	3 1/2	.0161	12.2	13.7	.05	.00081	6.9	8.4	.05	.00081
183 C	-	.0140	10.9	12.4	.05	.00070	5.6	7.1	.05	.00070
183 - 372	2 1/2	.0005	5.81	7.3	.05	.00003	3.87	5.4	.077	.00004
183 - 372	3 1/2	.0005	6.32	7.8	.05	.00003	4.38	5.9	.067	.00003
183 - 750	2 1/2	.1270	2.75	4.3	.108	.01372	2.61	4.1	.115	.01461
183 - 750	3 1/2	.0024	3.51	5.0	.086	.00021	3.36	4.9	.088	.00021
183 - 750	4 1/2	.0024	4.34	5.8	.070	.00017	4.12	5.6	0.72	.00017
183 - 750	5 1/2	.0012	5.17	6.7	.054	.00006	4.88	6.4	.058	.00007
372 C	-	.0022	5.23	6.7	.054	.00012	3.73	5.2	.082	.00018
372 - 750	2 1/2	.0040	2.6	4.1	.115	.00047	2.36	3.9	.123	.00049
372 - 750	3 1/2	.0009	3.14	4.6	.096	.00008	2.86	4.4	.104	.00009
372 - 750	4 1/2	.0009	3.79	5.3	.08	.00007	3.36	4.9	.008	.00008
372 - 750	5 1/2	.0005	4.44	5.9	.067	.00003	3.73	5.2	.082	.00004
530 C	-	.0003	3.15	4.7	.093	.00003	2.62	4.1	.115	.00004
602 - 980	2 1/2	.0010	1.88	3.4	.147	.00015	1.80	3.3	.15	.00015
750 C	-	.5302	2.07	3.6	.138	.07317	1.85	3.35	.15	.07953
980 C	-	.0013	1.4	2.9	.18	.00024	1.4	2.9	.18	.00024
1440 C	-	.0043	.97	2.5	.21	.00091	.97	2.5	.21	.00091
Total		1.006				.09181				.09920

D-71

Table D.5-3 (Cont'd)
Surry RCP Seal LOCA Model

Notes to Table D.5-3

(1) Abbreviations used:

C	Constant Leak Rate
CD	Core Damage
CU	Core Uncovery
GPM	Gallon Per Minute
Hrs	Hours
NRAC	Non-Recovery of AC Power
Prob.	Probability
RAC	Recover AC Power

D.6 Failure Data Development

The derivation of selected event failure probabilities is detailed in the following sections. In addition, failure rates calculated from plant specific data are discussed. Undeveloped events from the fault trees and "black box" events from the event trees are also detailed.

D.6.1 Mission Times

An event in a fault tree may have several different unavailability values, depending on the accident scenario in which the fault tree is involved. The length of time that a system is required to run for the different accident initiators is defined as the mission time. The mission times used in the Surry analysis are shown in Table D.6-1. The electrical power system components (except diesel generators) were required to remain operating for 24 hours, regardless of the accident sequence they were involved in. Selection of the mission time for Diesel Generators for Loss of Offsite Power Initiators is discussed in Appendix D.7.

D.6.2 Failure Rates from Plant Specific Data

Surry maintenance records for the five years preceeding this study were searched in order to get plant specific failure history on selected components at both Units 1 and 2. The number of demands and hours of use for these components was estimated. Failure probability distributions for the plant specific data were developed as follows. First, it was assumed that all components could be represented by log normal failure distributions.

The 95% upper bound of the log normal distribution was determined by the 95% Chi-square value associated with the component data. The number of degrees of freedom used was $2n+2$, where n is the number of failures. For example, the AFW motor driven pumps experienced six failures in 960 demands. The 95% Chi-square value for 14 degrees of freedom is 23.68. The 95% upper bound is then $\frac{23.68}{2 \times 40 \times 24}$ or $1.2E-2/D$.

The mean of the log normal distribution was determined to be the point estimate, or the number of failures divided by the number of demands (or hours). In the AFW motor driven pump example, this is 6 failures divided by 960 demands ($40D/c-y \times 24c-y/AFW$ pump) or $6.3E-3/D$.

Finally, the median and error factor of the log normal distribution was calculated from the known mean and 95% upper bound. For the AFW motor driven pump example, the 95% upper bound is $1.2E-2D$ and the mean is $6.3E-3/D$. The error factor comes out to be 2.2 and the median $5.6E-3/D$.

The results of the quantification of the plant specific data are displayed in Table D.6-2.

D.6.3 AFW Actuation

AFW-ACT-FA-PMP3A AFW-ACT-FA-PMP3B
AFW-ACT-FA-VLVA AFW-ACT-FA-VLVB

The AFW actuation circuitry is much simpler than the RMT/CLS/SIS actuation circuitry. Therefore, it was not considered appropriate to use the generic failure probability of $1.6E-3$. A value of $6.0E-4$ was estimated for AFW pump and valve actuation

Table D.6-1

Mission Times
(Hours)

Event Tree Heading	<u>T₁</u>	<u>SBO</u>	<u>T₂</u>	<u>T₃</u>	<u>T₅</u>	<u>T₇</u>	<u>A</u>	<u>S₁</u>	<u>S₂</u>	<u>S₃</u>	<u>ATWS</u>
C	1	-	1	1	1	-	1/2	1	1	1	1
D1	-	-	-	-	-	24	-	3	6	24	-
D2	6	-	6	6	6	-	-	-	-	-	-
D3	6	-	6	6	6	-	-	-	-	-	-
D4	-	-	-	-	-	-	-	-	-	-	1
D5	-	-	-	-	-	-	DMD	DMD	-	-	-
D6	-	-	-	-	-	-	1/2	3	-	-	-
F1	24	-	24	24	24	-	24	24	24	24	24
F2	24	-	24	24	24	-	24	24	24	24	24
H1	18	-	18	18	18	-	24	21	24	24	-
H2	18	-	18	18	18	-	-	-	18	18	-
L	24	6	24	24	6	-	-	-	6	24	-
L2	-	-	-	-	-	-	-	-	-	-	1
L3	-	-	-	-	-	24	-	-	-	-	-
K	DMD	-	DMD	DMD	DMD	DMD	-	DMD	DMD	DMD	-
M	-	-	-	6	-	-	-	-	-	24	1

D-74

Event Tree
Heading

	<u>T₁</u>	<u>SBO</u>	<u>T₂</u>	<u>T₃</u>	<u>T₅</u>	<u>T₇</u>	<u>A</u>	<u>S₁</u>	<u>S₂</u>	<u>S₃</u>	<u>ATWS</u>
P	24	-	24	24	24	-	-	-	-	24	-
P1	-	-	-	-	-	-	-	-	6	-	-
P2	-	-	-	-	-	-	-	-	-	-	1
Q	DMD	DMD	DMD	DMD	DMD	-	-	-	-	DMD	-
R	-	-	-	-	-	DMD	-	-	-	-	DMD
T	-	-	-	-	-	-	-	-	-	-	DMD
W	24	-	24	24	24	-	-	-	-	-	-
W2	-	6	-	-	-	-	-	-	-	-	-
W3	-	-	-	-	-	-	-	-	-	24	-
Z	-	-	-	-	-	-	-	-	-	-	DMD

Table D.6-2

Plant Specific Failure Data¹

Component	Failure Mode	Number of Failures	Components in Population	Component Cal. Yrs. (C-Y)	Demands or Hours Per C-Y	95% χ^2	Mean	Median	EF
AFW Motor Driven Pump	FS	6	4	24	40D	1.2E-2/D	6.3E-3/D	5.6E-3/D	2.2
AFW Turbine Driven Pump	FS/FR	2	2	6	30.2D	3.5E-2/D	1.1E-2/D	7.5E-3/D	4.6
CPC Service Water Pump	FS	3	4	20	19.1D	2.0E-2/D	7.9E-3/D	5.9E-3/D	3.5
	FR	15	4	20	4380H	2.6E-4/H	1.7E-4/H	1.6E-4/H	1.6
Charging Pump	FS	3	6	30	23.8D	1.1E-2/D	4.2E-3/D	3.1E-3/D	3.5
	FR	4	6	30	1920H	1.6E-4/H	6.9E-5/H	5.6E-5/H	2.9
Diesel Generator	FS	11	3	-	484D	-	2.2E-3	-	1.7
Inside Spray Recirc. Pump	FS	10	4	20	13D	6.5E-2/D	3.8E-2/D	3.6E-2	1.8
PORV Block Valve	FT	5	4	20	6.1D	8.6E-2	4.1E-2	3.6E-2	2.4

Note 1

C-Y - Calendar Year
 EF - Error Factor
 FR - Fail to Run
 H - Hours

D - Demand
 FS - Fail to Start
 FT - Failure to Transfer Open
 χ^2 - Chi-Square

unavailability, based on the number of relays and switches which must operate. An error factor of five was assigned, to be consistent with SIS actuation.

D.6.4 AFW Condensate Storage Tank

AFW-TNK-VF-CST AFW-TNK-VF-U2CST

An unavailability of $1.0E-6$ was selected based on engineering judgment. The Condensate Storage Tank can be filled from multiple water sources. An error factor of three was assigned.

D.6.5 AFW Diversion Flow

AFW-PSF-FC-XCONN

Diversion of the AFW flow from of Unit 1 to Unit 2 via the cross connect header was calculated to have an unavailability of $1.5E-4$ /demand. This was based on spurious transfer of one of two motor operated valves at a failure rate of $3E-6$ per hour per valve over 24 hours. The failure rate of $3E-6$ was selected based on a survey of other PRA (references D.6-1 through D.6-6) values for the probability of spurious transfer of a MOV. The probabilities ranged from $9.7E-8$ at Indian Point to $4.6E-6$ for Millstone.

D.6.6 AFW Pumps

AFW-MDP-FS-FW3A AFW-MDP-FS-FW3B
AFW-TDP-FS-FW2 AFW-TDP-FS-U2FW2

AFW Motor Driven Pump Fail to Start.

Sufficient plant specific data was gathered to determine a plant specific failure rate for the AFW pump failure to start on demand. A mean value of $6.3E-3/D$ was derived based on plant specific data of six failures in 960 demands to start. A 95% upper bound of $1.2E-2$ and an error factor of 2.2 were calculated. An error factor of 3 was assigned.

AFW Turbine Driven Pump Fail to Start.

Sufficient plant specific data also existed to calculate the unavailability of the AFW turbine driven pump to start on demand. A mean unavailability of $1.1E-2$ was derived for failure of the AFW turbine driven pump to start on demand. This was based on two failures in 181 demands. The 95% upper bound was calculated to be $3.5E-2$.

An error factor of ten was assigned, consistent with ASEP generic turbine driven pump error factors.

D.6.7 AFW Steambinding

AFW-CCF-LK-STMBD AFW-CCF-LK-2STMB

Reference D.6-4 indicates steambinding of AFW pumps may be a generic problem at PWRs. The report was reviewed for its applicability to Surry. Three instances of steambinding in the AFW system occurred at Surry during the years of the survey, 1981 through 1983, inclusive. One occurrence failed two pumps and the other two occurrences failed one pump. The three events occurred very close in time and all occurred at Surry Unit 2. This indicates that it was a plant specific problem, which is consistent with the

Surry troubleshooting that found steam cuts on the valve seats of the AFW check valves. The valves were rebuilt, and other remedial measures were taken, such as shiftily checking of the AFW discharge piping temperature, and removal of piping insulation to aid in condensation of any steam which did appear in the system. No subsequent steambinding has occurred.

Although the reported occurrences of steambinding at Surry appear to be specifically caused by leaking check valves, and the problem appears to have been corrected, AFW failure due to steambinding was included in the AFW system model. The problem appears to be widespread, based on the referenced report and the causes of steambinding at other plants may appear at Surry. In addition, steambinding can potentially be a common cause failure of all AFW pumps and therefore may be dominant even though it has a low probability. For these reasons, it was desired to include steambinding in the AFW model. Steambinding was conservatively assumed to be a common cause failure of all three AFW pumps in the AFW model.

The probability of steambinding was calculated based on generic data in NRC report AEOD/C404.

The data is as follows:

- 22 occurrences of steambinding of an AFW pump,
- 3 years of operating experience -- 1981 - 1983,
- 47 operating units in this 3-year period,
- 38 estimated AFW demands per unit per year. This includes 8 per year for reactor trip, 30 per year for monthly pump testing. All testing is staggered.

This data results in a point estimate for steambinding of:

$$\frac{22 \text{ events}}{47 \times 3 \times 38} = 4.1\text{E-}3/\text{demand}$$

The root cause of steambinding is considered to be check valve leakage, which is properly modeled with an hourly failure rate. The value of .0041 demand shows the probability that check valve leakage occurred between pump demands. In order to find an hourly failure rate, it was necessary to calculate a demand period.

Each reactor had averaged 38 AFW demands per year. This is an average demand period of 9.6 days. The hourly check valve failure rate is therefore:

$$\frac{.0041/\text{demand}}{231 \text{ hours/demand}} = 1.8\text{E-}5/\text{hr}$$

Accounting for the shiftily (eight hours) check, the probability of steambinding being undetected during a random AFW demand is:

$$1.8\text{E-}5/\text{hr} \times 8 \text{ hr} = 1.4\text{E-}4/\text{demand}$$

This was rounded to 1E-4 for use in the fault tree quantification. An error factor of 30 was subjectively chosen. The large error factor reflects the estimation in this calculational process.

D.6.8 Beta for Common Cause Failure of CPC Service Water Strainers

BETA - STR
CPC-CCF-LF-STR1H CPC-CCF-LF-STRAB
CPC-CCF-LF-STR6H CPC-CCF-LF-STR3H
CPC-CCF-LF-STR24 CPC-CCF-LF-STR18

The components of interest here are the passive strainers in the suction of the dedicated HPI service water system. An LER review of Surry 1 and Surry 2 indicated several instances of degraded flow through the CPC service water strainers 2A and 2B (2A is in the A train and 2B is in the B train). Degraded flow was considered to be insufficient flow through the strainers, or strainer failure. Note that it is conservative to assume that the strainer has failed when flow is only degraded. Between 1980 and 1984, there were nine instances of single strainer failure and three instances of both strainers (common cause) failing. Each of these failures was due to plugging. In 1984, the strainers were replaced with duplex strainers. Between 1984 and 1987 there were no instances of single train strainer failure, but two instances involving dual train strainer failure (common cause). These two instances were due to air binding of the CPC Service Water pump due to improper venting of the duplex strainer. Because there have been no single train strainer failures while using the duplex strainers, generic data (3E-5hr) was used for the single strainer failure rate.

However, since there have been five instances of common cause failure out of 19 total individual strainer (common cause and random independent) failures, a plant specific Beta factor of 0.263 (5/19) was calculated. A maximum entropy distribution was assigned to the Beta with a lower bound of 2.6E-2 and an upper bound at 1.0. This Beta only applies to CPC Service Water (duplex) Strainers 2A and 2B. The 1A and 1B CPC service water strainers and rotating basket type strainers with no history of degraded flow.

D.6.9 Service Water Isolation Valve Common Cause Failure

BETA-SW SWS-CCF-FT-3ABCD

An LER review of Surry 1 and 2 identified one occurrence of common cause failure of the four containment spray heat exchanger service water valves to open when activated from the control room. This occurrence formed the basis for inclusion of common cause failure of these valves in the ISR and OSR fault trees.

The one failure incident occurred in 1983. Since that time, the test interval on the valve has been reduced from yearly to quarterly. Also, the valves have been replaced with an improved design and new material. Although the valves have been replaced, they still operate in the same brackish water environment, which is thought to be the root cause of the 1983 failure. As such, they are considered to be more susceptible to failure than the generic motor operated valve that works in a fresh water environment. Therefore, the Beta factor for common cause failure of these valves was set equal to the 95% upper bound of the generic beta (or .21).

D.6.10 Charging/HPI/HPR Pumps

HPI-MDP-FS-CH1B	HPI-MDP-FS-CH1C
HPI-MDP-FS-CH2A	HPI-MDP-FS-CH2C
HPI-MDP-FR-1A3HR	HPI-MDP-FR-1B3HR
HPI-MDP-FR-1C3HR	HPI-MDP-FR-1A6HR
HPI-MDP-FR-1B6HR	HPI-MDP-FR-1C6HR
HPI-MDP-FR-2A6HR	HPI-MDP-FR-2C6HR
HPI-MDP-FR-1C12H	HPI-MDP-FR-C12HR
HPR-MDP-FR-A18HR	HPR-MDP-FR-B18HR
HPR-MDP-FR-C18HR	HPI-MDP-FR-1A24H
HPI-MDP-FR-1B24H	HPI-MDP-FR-1C24H

Plant specific data was also available for the charging pumps (the HPI/HPR pumps) failure to start and failure to run. A failure to start on demand mean probability of $4E-3$ was calculated based on three failures in 714 demands.

The 95% upper bound was found to be $1.1E-2$ and the error factor 3.5, using the method described in section D.6.3.

A mean failure rate of $6.9E-5$ /hr for failure to run was calculated based on four failures in 57,400 hours. The 95% upper bound was determined to be $1.6E-4$ /hr, and the error factor 2.9. The error factor was rounded off to 3.0.

D.6.11 CPC Actuation

CPC-ICC-FA-CCPBS	CPC-ICC-FA-SWPBS
CPC-ICC-FA-TCV8B	CPC-ICC-FA-TCV8C

CPC Pump Actuation (CPC-ICC-FA-CCPBS, CPC-ICC-FA-SWPBS)

The CPC actuation was approximated as a simple circuit with a single switch and a single relay. Both the switch and the relay were assumed to have a median failure probability of $1E-4$ with an error factor of 5. Thus, the total unavailability was $3.2E-4$.

CPC Containment Isolation Valve Actuation (CPC-ICC-FA-TCV8B, CPC-ICC-FA-TCV8C).

Assumed to be the same as CLS actuation, which is a containment isolation actuation system. An unavailability of $1.6E-3$ with an error factor of 5 was assigned using the ASEP generic data.

D.6.12 CPC Service Water Pump

CPC-MDP-FS-SW10A	CPC-MDP-FS-SW10B
CPC-MDP-FS-SW20A	CPC-MDP-FR-SW10A
CPC-MDP-FR-SW10B	CPC-MDP-FR-SWA3H
CPC-MDP-FR-SWB3H	CPC-MDP-FR-SWA6H
CPC-MDP-FR-SWB6H	CPC-MDP-FR-SWA18
CPC-MDP-FR-SWB18	CPC-MDP-FR-SWA24
CPC-MDP-FR-SWB24	

Plant specific data was available for the CPC service water pump failure to start and failure to run. A mean failure to start on demand probability of $7.9E-3$ was calculated based on three failures in 382 demands. The 95% upper bound was calculated to be $2.0E-$

2/D, and the error factor 3.5. The procedure for calculating these values is described in Section D.6.3.

A probability of $1.7E-4$ /hr for failure to run was calculated based on 15 failures in 87,600 hours. The 95% upper bound was determined to be $2.64E-4$ /hr, and the error factor 1.6. An error factor of 3 was assigned to failure to run, to be consistent with the generic error factor for motor driven pump fail to run.

D.6.13 Diesel Generator

OEP-DGN-FS-DG01 OEP-DGN-FS-DG02
OEP-DGN-FS-DG03 OEP-DGN-FC-DGU3
DGN-FTO

Plant specific data was available to calculate the emergency diesel generator failure to start probability. Between 1980 and 1988, there were a total of 19 diesel generator failures to start. Seven of the eleven failures occurred when the plant was in cold shutdown, with the diesel generator not required by Technical Specification. These failures were included even though the diesels were not required administratively because 1) they were honest failures and 2) it was not possible to partition the number of demands into corresponding categories. Post-maintenance testing failures were excluded. This left eleven failures to start in 484 start demands. From this a failure to start probability of $2.2E-2$ was derived. The ratio of the 95% Chi square and the 50% Chi square (mean) of eleven failures in 484 demands yields an error approximation of 1.56. The error factor was then conservatively assigned to be 3.

Events DGN-FTO and OEP-DGN-FC-DG3U2 are failures of diesel generator #3 to supply Unit 1, due to being aligned to Unit 2. The probability of these events was calculated based on faults (failure to start and failure to run) with Unit 2's diesel generator #2. The sum of the unavailabilities for diesel generator #2 failure to start and failure to run equals $3.4E-2$. An error factor of 3 was assigned based on the failure to start.

D.6.14 ISR Pump

ISR-MDP-FS-RS1A ISR-MDP-FS-RS1B

The ISR motor driven pumps had plant specific data from which a failure to start on demand probability was calculated. The ten failures in 260 start demands yielded a mean unavailability of $3.8E-2$. An error factor of 1.8 was calculated, as described in Section D.6.3. An error factor of 3 was assigned. The 95% upper bound was determined to be $6.5E-2$.

D.6.15 Instrument Air

IAS-CCF-LF-INAIR IAS-AOV-LK-CC107 IAS-AOV-OC-CC107

Event IAS-CCF-LF-INAIR, common cause loss of instrument air to air operated valves, was assumed to be caused by total loss of instrument air. Probability was calculated as follows:

$$\frac{(0.01 \text{ incidents/yr})}{(8760 \text{ hr/yr})} \frac{(24 \text{ hr})}{(24 \text{ hr})} = 2.7E-5$$

Event IAS-AOV-LK-CC107, leak in the air supply to containment isolation valve TVCC-107, was calculated by assuming a 1E-6/hr leak rate and applying a 24-hour mission time.

The probability of spurious transfer for TVCC-107 (IAS-AOV-OV-CC107) was determined by surveying several other PRAs for the probability of an air operated valve to transfer closed. Values ranged from 1.7E-7 in the Indian Point PRA to 8.0E-7 for the Oconee PRA. The other sources surveyed were Zion, Seabrook, Millstone 3, and IREP (references D.6-1 through D.6.6). A median value of 6E-7 with an error factor of 3 was chosen, resulting in a mean value of 7.5E-7.

D.6.16 Insufficient Canal Level

MCW-CCF-VF-INLVL MCW-CCF-VF-SBO

An unavailability of 1E-9 was assumed for insufficient canal level from non external event sources to supply service water during normal plant operations (MCW-CCF-VF-INLVL). During station blackout the unavailability of for insufficient canal level is made up of two parts, 5.86E-2 is the HRA contribution and 9E-4 is for failure of one diesel driven pump to start. The 1E-3 failure probability is from the ASEP generic data base.

D.6.17 LPR Motor Operated Valve

LPR-MOV-FT-1862A LPR-MOV-FT-1862B

LPR motor operated valves 1862A and 1862B event probabilities include failure to transfer and plugging. The flow test interval for these valves is once every five years. Thus 3E-3/D for failure to transfer plus 1/2 (1E-7/hr) (5 yr) (8760 hr/yr) equals 5.2E-3/D. An error factor of 10 was assigned to be consistent with the failure to transfer error factor.

D.6.18 Main Feedwater Event

M

The event tree heading representing failure of Main Feedwater was modeled by failure of two motor driven pumps to run, failure of the feed regulating valves and their bypasses, and operator failure to feed the steam generators with Main Feedwater. A total unavailability of 2.9E-3 was derived as follows:

$$M = \text{MFW-MDP-FR-PMP1} * \text{MFW-MDP-FR-PMP2} + \\ \text{MFW-AOV-FT-FR VBYP1} * \text{MFW-AOV-FT-FR VBYP2} + \\ \text{MFW-CCF-FT-FR VBYP} + \\ \text{Loss of Instrument Air} + \\ \text{MFW-XHE-FO-FLOW.}$$

$$(3E-5/HR)24HR * (3E-5/HR)24Hr + \\ (1E-3) * (1E-3) + \\ (1E-3) 0.1 + \\ \frac{(0.01/YR)(24HR)}{8760 HR/YR} + \\ 2.7E-3$$

$$M = 2.9E-3$$

D.6.19 Time Averaged Non-Recovery of AC Power

NRAC-6HR-AVG NRAC-24HR-AVG

Time averaged non-recovery of AC power was calculated for use in the station blackout cut sets where the AFW turbine driven pump failed to run. This was done to estimate more accurately the average unavailability of the AFW turbine driven pump and AC power. Using a half hour after loss of feed flow for steam generator dryout, the time averaged non-recovery value was derived as follows:

$$\begin{aligned} \text{Let } 6\text{HR-SUM-TOTAL} &= (\text{AFW-TDP-FR})_{1\text{st HR}} * (\text{NRAC } 1 \text{ HR}) + \\ &(\text{AFW-TDP-FR})_{2\text{nd HR}} * (\text{NRAC } 2 \text{ HR}) + \\ &(\text{AFW-TDP-FR})_{3\text{rd HR}} * (\text{NRAC } 3 \text{ HR}) + \\ &(\text{AFW-TDP-FR})_{4\text{th HR}} * (\text{NRAC } 4 \text{ HR}) + \\ &(\text{AFW-TDP-FR})_{5\text{th HR}} * (\text{NRAC } 5 \text{ HR}) + \\ &(\text{AFW-TDP-FR})_{6\text{th HR}} * (\text{NRAC } 6 \text{ HR}) \\ &= 5.82\text{E-}3 \end{aligned}$$

Where AFW-TDP-FR = Hourly Failure Rate for the AFW-TDP(5E-3/hr)

NRAC 1 HR = The probability of non-recovery of AC power by 1 hour after the LOSP. Taken from Appendix D-3. The other NRAC factors are determined in a similar manner.

The 6HR-SUM-TOTAL = the probability of: AFW-TDP-FR-2P6HR * NRAC-6HR-AVG

and since AFW-TDP-FR-2P6HR is 3.00E-2,

$$\text{NRAC-6HR-AVG} = \frac{5.82\text{E-}3}{3.00\text{E-}2} = 1.94\text{E-}1$$

Similarly, the 24-hour time averaged non-recovery factor can be calculated:

$$\begin{aligned} \text{Let } 24\text{HR-SUM-TOTAL} &= (\text{AFW-TDP-FR})_{1\text{HR}} * (\text{NRAC } 1 \text{ HR}) + \\ &(\text{AFW-TDP-FR})_{2\text{HR}} * (\text{NRAC } 2 \text{ HR}) + \\ &\quad \vdots \quad \quad \quad \vdots \quad \quad \quad \vdots \quad \quad \quad \vdots \quad \quad \quad \vdots \\ &(\text{AFW-TDP-FR})_{24\text{HR}} * (\text{NRAC } 24 \text{ HR}) \end{aligned}$$

$$\text{Then, NRAC-24-AVG} = \frac{7.32\text{E-}2}{1.2\text{E-}1} = 6.1\text{E-}2$$

D.6.20 PPRS Block Valves

- PPS-MOV-FC-1535 PPS-MOV-FC-1536
- PPS-MOV-FT-1535 PPS-MOV-FT-1536
- PPS-MOV-OO-1535 PPS-MOV-OO-1536

The RCS power operated relief valves have historically had occasional leakage requiring the associated block valve to be shut. Based on plant experience from 1982-1987, the probability of an RCS PORV being blocked is estimated at 0.3, and was assigned to events PPS-MOV-FC-1535 and PPS-MOV-FC-1536.

Plant specific data was available for failure of the block valve to transfer. A mean unavailability of 4E-2/demand was derived from five failures in 122 demands. The 95% upper bound was determined to be 8.6E-2. An error factor of 2.4 was calculated, but an error factor of 3 was conservatively assigned. The identifiers PPS-MOV-OO-1535 and PPS-MOV-OO-1536 for these events mean failure to shut the valves. The PPS-MOV-FT-1535 and PPS-MOV-FT-1536 identifiers mean failure to open the valves.

D.6.21 RCS PORV Failure to Reclose Event

Qc

Event Qc is failure of the RCS PORV to reshut during an S₃ LOCA. During the very small LOCA, the HPI capacity exceeds the LOCA leak rate and demands the PORV if the operator fails to control injection flow. Therefore,

$$\begin{aligned} Qc &= (\text{PROB OPER FAIL TO CONTROL SI}) * (\text{PROB PORV NOT BLOCKED}) * \\ &\quad .1 \qquad \qquad \qquad 0.9 \\ &\quad (\text{PROB PORV FAILS TO RECLOSE}) * (\text{PROB OPERATOR SHUTS BLOCK VALVE} \\ &\quad \quad 3E-2 \qquad \qquad \qquad 2.7E-3 \\ &\quad \qquad \qquad \qquad \qquad \qquad + \text{PROB BLOCK VALVE FAILS TO CLOSE}). \\ &\quad \qquad \qquad \qquad \qquad \qquad .04 \\ &= 1.2E-4 \end{aligned}$$

The action of the operator to shut the block valve was considered to be a skill-based action, and thus accorded a probability of 2.7E-3, independent of the previous operator error.

D.6.22 Station Blackout Relief Demand Rate

SBO-PORV-DMD SBO-SGSRV-DMD QS-SBO

The probability for pressurizer PORV demand during station blackout was assessed to be 1.0, due to the unavailability of the SG ADV. It was necessary to calculate a per valve demand basis. The probability of having at least one PORV unblocked is 1-(0.3) * (0.3) or 0.91. The probability for each PORV opening then is $\frac{0.91}{2}$ = SBO-PORV-DMD.

A maximum entropy distribution was assigned with an upper bound of 1.0 and a lower bound of 4.5E-2.

The probability for a SG PORV to be demanded during station blackout was estimated to be one SG PORV demanded every 20 minutes on each steam generator for one hour. Thus, there are 9 demands on a SG PORV.

The probability of a SG PORV being demanded and failing to reclose (QS-SBO) is the number of demands times the probability for failure to reclose.

QS-SBO = (9 Demands) (3E-2) = 2.7E-1. A maximum entropy distribution was assigned with an upper bound of 1.0 and a lower bound of 2.7E-2.

D.6.23 SG Tube Rupture Relief Valve Demand Rate

SGTR-SGSRV-DMD SGTR-SGADV-DMD
SGTR-SGSRV-ODMD1 SGTR-SGADV-ODMD
SGTR-SGSRV-ODMD2

The probability of a SG PORV (ADV) being demanded during a SG tube rupture (SGTR) transient was estimated to be 0.3 if the operator depressurized the RCS and controlled safety injection flow (SGTR-SGADV-DMD). If the operator failed to depressurize the RCS, the demand probability was assumed to be 1.0 (SGTR-SGADV-ODMD).

The probability of a SG safety relief valve (SRV) being demanded during SGTR with operator depressurization was also estimated to be 0.3 (SGTR-SGSRV-DMD) if the ADV is blocked. If the operator failed to depressurize the RCS and the PORV is not blocked, the demand probability was assumed to be 0.15 (SGTR-SGSRV-ODMD2). If the operator failed to depressurize the RCS and if the PORV is blocked, then it was estimated (conservatively) that the demand probability for the SG SRV is 1.00 (SGTR-SGSRV-ODMD1). Each was assigned a maximum entropy distribution with an upper bound of 1.0 and a lower bound of one-tenth the failure rate.

D.6.24 SG Relief Block Valves

MSS-AOV-FC-101A MSS-AOV-FC-101B MS-AOV-FC-101C

The steam generator power operated relief valves (MSS-101A, MSS-101B, MSS-101C) have historically had occasional leakage requiring the associated block valve to be shut. Based on plant data from 1984-1987, the probability of a SG PORV being blocked is 0.15. This number is a point estimate only, and an error factor was not assigned.

D.6.25 SWS Cross Connect Plugging

SWS-PSF-LF-XCONN

The probability of Service Water flow being lost through the cross connect is equal to plugging of either one of two motor operated valves, or $2E-4$. An error factor of 3 was assigned, to be consistent with generic MOV plugging.

D.6.26 References

- D.6-1 Oconee PRA, A Probabilistic Risk Assessment of Oconee Unit 3, NSAC-60, Electric Power Research Institute, June 1984.
- D.6-2 Zion Probabilistic Safety Study, Commonwealth Edison Company, 1981.
- D.6-3 Seabrook Station Probabilistic Safety Assessment, PLG-0300; Pickard, Lowe and Garrick, Inc., Irvine, CA. December 1983.
- D.6-4 Millstone Unit 3 Probabilistic Safety Study, Northeast Utilities Company, August 1983.
- D.6-5 Indian Point Probabilistic Safety Study, Power Authority of the State of New York and Consolidated Edison Co., 1982.

D.7 Discussion of Mission Time for Diesel Generators for Loss of Offsite Power Initiators

D.7.1 Introduction

Modeling for loss of offsite power (LOSP) initiators involves two important parts. One is the AC power status model and the other is the plant response model. The two parts must be integrated to calculate accident sequence frequencies. The nature of LOSP is such that the characteristics of the plant response model determine features of the power status model and vice versa.

D.7.2 Power Status Model

The power status model has three states: a) offsite power restored, b) onsite emergency power available, c) and station blackout. In general, if offsite power is restored, the initiator is considered to be successfully terminated and no further analysis is done. The second state, availability of onsite emergency power, is an interim state which can flip to the first state if offsite power is restored, or can lead to station blackout if the diesel generators fail to provide emergency power. Plant response for this state is similar to loss of main feedwater with offsite power available. Station blackout is an undesirable state in that the plant response model has constraining characteristics such that AC power must be restored in a given time or else core damage occurs. The maximum allowable duration of station blackout is determined by the plant response model.

Development of the power status model involves modeling of the diesel generators (DG) fail to start, fail to run, and maintenance outage, as well as recovery of offsite power, onsite non-diesel generator sources of AC power, and recovery of diesel generator failures.

D.7.3 Plant Response Model

The plant response model characterizes the response of the plant to reduced power availability. The plant response to the onsite-AC-available state is quite similar to other transients. The plant response to station blackout is very different from any other transient. For typical PWRs, there are four major station blackout types of scenarios with potential for core damage. These are a) stuck open PORVs, b) unavailability of auxiliary feedwater, c) RCP seal LOCA, and d) battery depletion. Each scenario has two important timing considerations; the time at which the critical failure occurs, and the duration for which the failure can continue unmitigated without resulting in core uncover. Typical times for PWRs, for station blackouts occurring at the time of LOSP, are shown below:

	<u>Time Critical Failure Incurred</u>	<u>Time to Core Uncovery from Failure Occurrence</u>
PORV Open	5m	1 1/2 hr
AFW Fail	5m	1 hr
RCP Seal LOCA	1 1/2 hr	2 hr (approx)
Battery Depletion	4 hr	3 hr

These response times are only applicable for station blackouts occurring at the time of the LOSP ($t = 0$). If a LOSP originally went into the DG available state, and then slipped into the blackout state at 6 hours, the plant response model would be quite different. After six hours on diesel generators, the plant may be cooled down, depressurized, or

possibly in shutdown cooling. If so, the PORV scenario would not apply and the seal LOCA scenario would not apply. If the plant was in shutdown cooling, the AFW scenarios would not apply, but other scenarios involving failure of shutdown cooling systems may be appropriate. A rigorous plant response model could include plant response at several time phases throughout the event.

D.7.4 Discussion of Six Hour Mission Time

The previous discussion has been provided as background information. The following discusses the power state modeling for the Surry study, and shows that a six-hour mission time for diesel generators is acceptable for station blackout.

The power status model for this study calculates the total probability of both diesel generators failing at any time in the first six hours after LOSP. The probabilities for all failure combinations are lumped together and modeled as if all DG failures occurred at time zero (hereafter referred to as the lumping method). All station blackout occurrences are thus integrated with the time zero plant response model. Some refinements were made to the cut sets, such as removing the long term failures (fail to run) from the blackout frequency associated with the PORV scenarios. The PORV scenario only occurs during the initial scram. Recovery of offsite AC power and recovery of diesel generator failures were applied to the lumped SBO frequency, as a function from time zero. Since recovery of offsite power is more probable as time goes on, this technique underestimates recovery for the long term diesel failures.

The adequacy of the six-hour mission time for diesel generators has been questioned. It is possible that a significant portion of diesel generator failures which could occur after six hours are being omitted from the calculation. Previous attempts to justify mission time have been directed only at the power status model. That is, the justification is only in terms of the DG failure probabilities and the AC power non-recovery probabilities. Addressing this issue is better done on the basis of the overall core damage frequencies, thus including the impact of the plant response model. This discussion will show that extension of mission time beyond six hours is not necessary, even though a substantial portion of diesel generator failures are omitted. The reason for this is that a significant portion of the SBO frequency is incurred at time zero. That is, the fail-to-start and maintenance terms are very large compared to the hourly fail-to-run terms. At time periods when the fail-to-run terms approach the magnitude of the initial unavailability, the recovery of AC power becomes so probable that these failure combinations present an ever decreasing contribution to SBO. In addition, it will be shown that the method chosen for this study underestimates recovery of AC power and thus tends to compensate for any core damage frequency omitted by selection a six-hour mission time.

The following calculations are based on a two train DG model. The Surry plant has a 3 DG-4 train power system, and thus the numbers quoted below may not be the same as found in the PRA study. The simpler model is used here for purposes of illustration.

Using Surry specific failure probabilities for diesel generators, the probability of both diesel generators being unavailable at time zero is $1.6E-3$. After six hours, the probability of both DGs being failed is $2.2E-3$, and after 24 hours it is $6.5E-3$. Including the probability of non-recovery of offsite power, the conditional probability (given LOSP) of being in station blackout at one hour is $7.6E-4$. At six hours after the event, the (cumulative) probability of having been in a station blackout at any time is $2.2E-3$; and the (cumulative) probability of having been in an SBO at 24 hours is $3.25E-3$ (note, the probability of being in SBO at six hours is $1.6E-4$ and the probability at 24 hours is $2.7E-5$). It is clear that a significant portion of diesel generator failures are neglected. However, the following discussion will show that

when the plant response model is combined with the power status model, core damage frequency is not underestimated.

D.7.5 Comparison of Modeling Methods and Mission Times

In order to provide a comparison of results it is necessary to choose a specific core damage scenario. Of the four scenarios discussed in the plant response model, the battery depletion scenario is used here for demonstration.

The "lumping" method used in this study generates cut sets, representing core damage due to battery depletion, which combine diesel failures at six hours with non-recovery of offsite AC at seven hours. Obviously, if SBO is entered six hours after LOSP, offsite AC power does not need to be recovered until 13 hours to prevent core uncover. An accurate recovery for this cut set would be non-recovery of AC by 13 hours. In the lumped model, it is recovered with a probability of $5E-2$, (NRAC-7hr) when accurate recovery would be $1.7E-2$ (NRAC-13hr). This cut set accounts for 7% of the total SBO frequency. A similar situation exists for the 5-hour cut set which accounts for 6.7% of the total frequency and is under recovered by $.05/.02$. Sample calculations were made to determine the extent of underestimation of recovery and the impact of DG mission time.

The results are shown in Table D.7-1. Calculations of core uncover probability were made using one-hour, six-hour, and 24-hour diesel generator mission times combined with the lumped and actual recovery methods. Method A represents what was done in this study. Method A underestimates the total probability of DG failure, but also underestimates the probability of recovery of offsite AC power (i.e., one counters the other). Method B provides accurate estimation of recovery probabilities, but underestimates the total diesel failure probability. Method C is obviously the most conservative. Method C includes the total diesel generator failure probability in the first 24 hours, but provides recovery on the lumped frequency, thus underestimating the true probability of recovery of offsite AC power. As expected, the representative core uncover frequency for Method C is the highest. Method D can be considered the most accurate method. It includes all of the diesel failure probability in 24 hours, and provides actual non-recovery probabilities. Method E was used to provide a lower bound core uncover frequency. Method E only counts the initial diesel generator failures, so obviously it underestimates the true station blackout frequency. Because only initial DG failures are included, lumped recovery and actual recovery are the same. Therefore, recovery is actual in Method E.

D.7.5 Summary

Method E represents the lower bound and Method C represents the upper bound. Method C is obviously conservative, because it provides unrealistic recovery, and Method E is obviously non conservative because it only accounts for initial DG failures. Method D is the most accurate and will be considered as a baseline for comparison. Although Method D is the most accurate, it was not used in the PRA because it is the most time consuming, significantly increasing the number of cut sets in the SBO sequences.

Method A was used for this study because it offers a convenient technique advantage. It typically underestimates core uncover frequency, but not significantly, as can be seen by comparison with the results of Method D.

It should be noted that the numbers in Table D.7-1 were calculated using Surry specific event probabilities, and that use of different event probabilities would result in different numbers and possibly different conclusions.

However, the conclusions for Surry are that, for long term scenarios, selection of six-hour mission time in combination with the lumped recovery method leads to acceptable results for SBO modeling. This is because 1) for reasonably short mission times, diesel generator failure probability is determined by initial unavailability and 2) in the long term, recovery of offsite power is so probable that the impact of later diesel failures on core damage is minimal.

Table D.7-1
**Typical Core Uncovery Frequency Due to Battery Depletion
 During Station Blackout and the Effect of Modeling Considerations**

<u>Method</u>	<u>Conditional Prob. of SBO</u>	<u>Average Prob. for Non- Recovery of AC Power in 7 hrs from SBO</u>	<u>Prob. Core Uncovery</u>
A. Six hour mission time, lumped at t=0. Recovery on lumped frequency.	2.2E-3	.05	1.11E-4
B. Six hour mission time. Failures recovered at actual time.	2.2E-3	.046	1.00E-4
C. 24 hour mission time, lumped at t=0. Recovery on lumped frequency.	6.5E-3	.050	3.25E-4
D. 24 hour mission time. Failures recovered at actual time.	6.5E-3	.018	1.20E-4
E. 1 hour mission time.	1.7E-3	.050	8.50E-5

APPENDIX E

**Importance Values and Cut Sets
for the
Dominant Accident Sequences
and
Plant Damage State Groups**

Table of Contents

<u>Section</u>	<u>Page</u>
Surry Accident Sequence Core Damage Frequencies	E-5
Surry Plant Damage State Group Frequencies	E-6
Importance Values and Top Cut Sets for the Total Surry Core Damage Frequency	E-7
Importance Values and Top Cut Sets for the Surry Dominant Accident Sequences	
1. SBO-BATT	E-75
2. SBO-SLOCA	E-82
3. SBO-L	E-94
4. SBO-SLOCA2	E-103
5. V	E-110
6. SBO-Q	E-114
7. S ₁ H ₁	E-121
8. T ₇ O _D Q _S	E-126
9. T ₂ LD ₂	E-131
10. S ₁ D ₁	E-136
11. TKRZ	E-141
12. AH ₁	E-146
13. T ₂ LP	E-151
14. S ₁ D ₆	E-157
15. SBO-L2	E-162
16. AD ₅	E-170
17. TKRD ₄	E-175
18. S ₃ D ₁	E-180
19. S ₂ D ₁	E-185
20. SBO-BATT2	E-190
21. SBO-Q2	E-197
22. AD ₆	E-203
23. T ₇ D ₁ O _D	E-208
24. T _{5A} LP	E-213
25. T _{5B} LP	E-218
26. T ₇ L ₃	E-223
27. T ₇ O _D QQ _S	E-228
28. T ₇ KR	E-233

Table of Contents (Cont'd)

<u>Section</u>	<u>Page</u>
Importance Values and Top Cut Sets for Each Plant Damage State Group	
PDS-1	E-238
PDS-2	E-257
PDS-3	E-267
PDS-4	E-279
PDS-5	E-283
PDS-5	E-295
PDS-6	E-295
PDS-7	E-300

APPENDIX E

E. Importance Values and Cut Sets for the Dominant Accident Sequences and Plant Damage State Groups.

This appendix presents the results of the TEMAC importance measures and uncertainty analysis. There are three levels of detail used in documenting the TEMAC results. First, the top twenty events (in terms of importance) and the top page of cut sets for the total core damage frequency (CDF) model are shown and discussed in Section 5 of the main report. Second, an intermediate level is presented in this appendix, which gives all events for each importance measure and nearly all of the cut sets contributing to the core damage frequency; at least those cut sets contributing 90% or more of the frequency. Last, the complete listing of events and cut sets for the total core damage frequency, each accident sequence, and each plant damage state is available on diskettes from the the NRC upon request. This complete listing also includes other lists with the results sorted differently.

The purpose for not providing all the TEMAC output is to reduce the size of the document, especially since only a very limited number of readers will want the additional detail contained on the diskettes.

There are five lists given in this appendix. The following table shows the extent of each list provided in this appendix.

	<u>Total CDF</u>	<u>Each Accident Sequence</u>	<u>Each Plant Damage State Group</u>
1. Descriptive Statistics	All (1 Page)	All (1 Page)	All (1 Page)
2. Risk Reduction	All (5 Pages)	All (1 Page)	All (1 Page)
3. Risk Increase	All (4 Pages)	All (1 Page)	All (1 Page)
4. Uncertainty Importance	All (5 Pages)	All (1 Page)	All (1 Page)
5. Ranked Cut Sets	All Cut Sets Above 9.2E-10 (52 Pages)	8 Pages Max.	12 Pages Max.

All of the importance measure results are included for the total Surry core damage frequency, each accident sequences, and each plant damage state group. However, the number of cut sets presented was limited in a few instances as shown above. Detailed explanations of the risk measures are given in Section 4.12.

Tables E-1 and E-2 show a summary of the accident sequence and plant damage state group frequencies. The accident sequence results are arranged in order of descending frequency, as shown in Table E-1. Plant damage state results are for all plant damage state groups and are arranged numerically.

Table E-1

SURRY ACCIDENT SEQUENCE CORE DAMAGE FREQUENCIES

Accident Sequence	Description	5%	Median	Mean	95%	% of Total
SBO-BATT	STATION BLACKOUT (U1) - BATTERY DEPLETION	2.4E-7	3.3E-6	1.1E-5	4.1E-5	26.0
SBO-SLOCA	STATION BLACKOUT (SBO) (U1)-RCP SEAL LOCA	0	1.0E-6	5.3E-6	2.0E-5	13.1
SBO-L	STATION BLACKOUT (U1) - AFW FAILURE	7.9E-8	1.3E-6	4.7E-6	2.1E-5	11.6
SBO-SLOCA2	STATION BLACKOUT (U1, U2) - RCP SEAL LOCA	0	1.1E-6	3.3E-6	1.4E-5	8.2
SBO-Q	STATION BLACKOUT (U1) - STUCK OPEN PORV	9.1E-9	3.4E-7	2.2E-6	8.7E-6	5.4
S ₁ H ₁	MEDIUM LOCA - RECIRCULATION FAILURE	1.1E-7	7.7E-7	1.7E-6	5.6E-6	4.2
V	INTERFACING LOCA	3.8E-11	4.9E-8	1.6E-6	5.3E-6	4.0
T ₇ O _D Q _S	SGTR - NO DEPRESS. - SG INTEGRITY FAILS	3.4E-8	3.7E-7	1.4E-6	5.1E-6	3.5
T ₂ LD ₂	LOSS OF MFW/AFW - FEED AND BLEED FAILS	1.4E-8	2.0E-7	9.8E-7	2.5E-6	2.4
S ₁ D ₁	MEDIUM LOCA - INJECTION FAILURE	1.1E-7	4.6E-7	8.6E-7	2.4E-6	2.1
TKRZ	ATWS - UNFAVORABLE MOD. TEMP. COEFF.	6.3E-9	1.5E-7	8.2E-7	3.2E-6	2.0
AH ₁	LARGE LOCA - RECIRCULATION FAILURE	6.3E-8	3.8E-7	8.2E-7	3.0E-6	2.0
T ₂ LP	LOSS OF MFW/AFW - FLEED AND BLEED FAILS	2.3E-8	2.6E-7	7.4E-7	2.6E-6	1.8
S ₁ D ₆	MEDIUM LOCA - INJECTION FAILURE	4.2E-8	2.3E-7	6.7E-7	2.2E-6	1.7
SBO-L ₂	SBO (U1, U2) - AFW FAILURE	1.7E-8	2.3E-7	6.5E-7	2.6E-6	1.6
AD ₅	LARGE LOCA - ACCUMULATOR FAILURE	1.1E-7	4.6E-7	6.4E-7	1.8E-6	1.6
TKRD ₄	ATWS - EMERGENCY BORATION FAILURE	9.5E-9	1.5E-7	6.4E-7	2.8E-6	1.6
S ₃ D ₁	VERY SMALL LOCA - INJECTION FAILURE	4.2E-8	2.7E-7	6.3E-7	2.4E-6	1.5
S ₂ D ₁	SMALL LOCA - INJECTION FAILURE	4.2E-8	2.3E-7	4.4E-7	1.4E-6	1.1
SBO-BATT2	SBO (U1, U2) - BATTERY DEPLETION	0	0	4.3E-7	1.7E-6	1.1
SBO-Q2	SBO (U1, U2) - STUCK OPEN PORV	1.8E-9	5.9E-8	3.2E-7	1.3E-6	0.8
AD ₆	LARGE LOCA - INJECTION FAILURE	2.1E-8	1.2E-7	3.1E-7	1.1E-6	0.8
T ₇ D ₁ O _D	SGTR - INJECTION FAILURE - NO DEPRESS	6.6E-9	7.0E-8	2.1E-7	7.7E-7	0.5
T _{5A} LP	LOSS OF DC BUS-FAIL AFW-NO FEED AND BLEED	1.1E-9	2.6E-8	1.3E-7	4.5E-7	0.3
T _{5B} LP	LOSS OF DC BUS-FAIL AFW-NO FEED AND BLEED	1.1E-9	2.6E-8	1.3E-7	4.5E-7	0.3
T ₇ L ₃	SGTR - AFW FAILURE	4.8E-9	4.1E-8	1.1E-7	3.4E-7	0.3
T ₇ O _D Q _Q S	SGTR-NO DEPRESS-SG INTEG FAILS, PORV FAILS	8.8E-10	2.1E-8	1.1E-7	5.0E-7	0.3
T ₇ KR	SGTR - ATWS	3.2E-9	3.4E-8	1.0E-7	4.0E-7	0.2
TOTAL CORE DAMAGE FREQUENCY				4.0E-5	100	

Table E-2
Surry Plant Damage State Frequencies

Plant Damage State Group	Description	Frequency				% of Total
		5%	Median	Mean	95%	
PDS-1	Long Term Station Blackout	6.1E-7	8.2E-6	2.2E-5	9.5E-5	54.6
PDS-2	LOCA - Injection/Recirculation Failure	1.2E-6	3.8E-6	6.0E-6	1.6E-5	14.7
PDS-3	Station Blackout - AFW Failure	1.1E-7	1.7E-6	5.4E-6	2.3E-5	13.3
PDS-4	Interfacing LOCA	3.8E-11	4.9E-8	1.6E-6	5.3E-6	4.0
PDS-5	Transient - AFW and Feed/Bleed Failure	7.2E-8	6.9E-7	2.1E-6	6.0E-6	4.8
PDS-6	Anticipated Transient without Scram	3.2E-8	4.2E-7	1.6E-6	5.9E-6	3.8
PDS-7	Steam Generator Tube Rupture	1.2E-7	7.4E-7	<u>1.8E-6</u>	6.0E-6	4.8
Total Plant Damage State Frequency					4.0E-5	

SURRY TOTAL CORE DAMAGE MODEL

TOP EVENT SURRY-TOTAL CONTAINS 222 EVENTS IN 2774 CUT SETS

THE FREQUENCY OF TOP EVENT SURRY-TOTAL IS 3.30E-05

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SURRY-TOTAL

N	1000
MEAN	4.01E-05
STD DEV	5.73E-05
LOWER 5%	6.68E-06
LOWER 25%	1.35E-05
MEDIAN	2.28E-05
UPPER 25%	4.38E-05
UPPER 5%	1.29E-04

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

5% = 6.68E-06 ***LOG SCALE*** 95% = 1.29E-04
 |-----[-----*-----N-----M-----]-----|

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
 TEF = FREQUENCY OF THE TOP EVENT
 EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
 = FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
 = TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
 = PD x (1 - EV(J))
 = TEF(EVALUATED WITH EV(J) = 1) - TEF

SURRY TOTAL CORE DAMAGE MODAL
RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NOTQ	2307	9.73E-01 (6.0)	1.79E-05 (1.0)		
NOTL-SBOU1	1316	9.93E-01 (5.0)	1.33E-05 (2.0)		
OEP-DGN-FS-DG01	725	2.20E-02 (79.5)	8.22E-06 (3.0)	2.38E-07	4.38E-05
NRAC-7HR	986	5.00E-02 (60.0)	8.04E-06 (4.0)	2.84E-07	4.28E-05
NOTW2	54	8.15E-01 (10.0)	7.15E-06 (5.0)		
REC-XHE-FO-DGHWB	159	6.00E-01 (14.5)	6.90E-06 (6.0)	2.16E-07	3.66E-05
REC-XHE-FO-DGHWS	1407	8.00E-01 (11.0)	5.98E-06 (7.0)	0.00E+00	2.97E-05
REC-XHE-FO-DGEN	382	9.00E-01 (8.0)	5.68E-06 (8.0)	1.21E-07	2.87E-05
RCP-LOCA-750-90M	262	5.30E-01 (16.0)	5.20E-06 (9.0)	0.00E+00	3.16E-05
NRAC-216M	200	1.38E-01 (41.0)	5.00E-06 (10.0)	0.00E+00	2.99E-05
OEP-DGN-FS	299	2.20E-02 (79.5)	4.88E-06 (11.0)	2.08E-07	1.82E-05
OEP-DGN-FS-DG02	521	2.20E-02 (79.5)	4.38E-06 (12.0)	1.31E-07	2.36E-05
OEP-DGN-FS-DG03	526	2.20E-02 (79.5)	4.38E-06 (13.0)	1.32E-07	2.36E-05
NRAC-1HR	157	4.40E-01 (21.0)	4.24E-06 (14.0)	5.39E-08	2.15E-05
OEP-DGN-FR-6HDG1	639	1.20E-02 (91.0)	4.08E-06 (15.0)	2.80E-08	2.97E-05
NOTL-SBOU1U2	842	9.68E-01 (7.0)	3.24E-06 (16.0)		
QS-SBO	2435	2.70E-01 (28.5)	3.04E-06 (17.0)	5.45E-08	1.75E-05
REC-XHE-FO-SCOOL	597	1.25E-01 (43.0)	2.89E-06 (18.0)	3.71E-08	1.81E-05
BETA-2MOV	25	8.80E-02 (48.0)	2.72E-06 (19.0)	1.08E-07	8.72E-06
BETA-3DG	59	1.80E-02 (83.0)	2.66E-06 (20.0)	7.41E-08	1.08E-05
OEP-DGN-FR-6HDG3	467	1.20E-02 (91.0)	2.32E-06 (21.0)	1.58E-08	1.87E-05
SBO-PORV-DMD	128	4.50E-01 (20.0)	2.27E-06 (22.0)	1.17E-08	9.56E-06
BETA-2DG	271	3.80E-02 (69.0)	2.25E-06 (23.0)	8.69E-08	8.32E-06
NOTDG-CCF	240	5.20E-01 (17.0)	2.22E-06 (24.0)		
OEP-DGN-FR-6HDG2	458	1.20E-02 (91.0)	2.08E-06 (25.0)	1.48E-08	1.48E-05
AFW-XHE-FO-CST2	33	6.50E-02 (55.0)	1.97E-06 (26.0)	2.39E-08	1.16E-05
AFW-XHE-FO-UNIT2	151	3.80E-02 (70.0)	1.94E-06 (27.0)	8.10E-08	6.20E-06
OEP-DGN-MA-DG01	393	6.00E-03 (102.0)	1.85E-06 (28.0)	1.42E-08	7.34E-06
R	16	1.70E-01 (35.0)	1.51E-06 (29.5)	3.23E-08	5.87E-06
K	16	6.00E-05 (195.0)	1.51E-06 (29.5)	3.23E-08	5.87E-06
RCS-XHE-FO-DPRT7	15	2.90E-02 (77.0)	1.48E-06 (31.0)		
MCW-CCF-VF-SBO	573	6.00E-02 (58.0)	1.38E-06 (32.0)	1.51E-08	7.92E-06
REC-XHE-FO-DPRES	3	1.40E-02 (87.5)	1.35E-06 (33.0)	2.06E-08	4.88E-06
MSS-SRV-OO-ODSRV	12	1.00E+00 (2.5)	1.25E-06 (34.0)		
HPI-MOV-FT	8	3.00E-03 (121.0)	1.20E-06 (35.0)	2.03E-08	3.97E-06
PPS-SOV-OO-1455C	69	3.00E-02 (74.5)	1.20E-06 (36.5)	1.02E-08	5.12E-06
PPS-SOV-OO-1456	69	3.00E-02 (74.5)	1.20E-06 (36.5)	1.02E-08	5.12E-06
NRAC-HALFHR	182	8.00E-01 (14.5)	1.09E-06 (38.0)	1.83E-08	5.85E-06
OEP-CRB-FT-15H3	418	3.00E-03 (121.0)	1.06E-06 (39.0)	8.40E-09	4.22E-06
OEP-DGN-MA-DG02	279	6.00E-03 (102.0)	1.01E-06 (40.0)	7.46E-09	4.01E-06
RCP-LOCA-467-150	262	1.27E-01 (42.0)	9.74E-07 (41.0)	0.00E+00	8.42E-06
OEP-DGN-MA-DG03	273	6.00E-03 (102.0)	9.58E-07 (42.0)	7.13E-09	3.85E-06
NRAC-258M	200	1.08E-01 (47.0)	9.38E-07 (43.0)	0.00E+00	8.18E-06
AFW-PSF-FC-XCONN	25	1.50E-04 (178.0)	8.75E-07 (44.0)	3.74E-08	3.07E-06
Z	1	1.40E-02 (87.5)	8.43E-07 (45.0)	6.29E-09	3.16E-06
PORV-NOT-BLK	10	8.50E-01 (9.0)	8.30E-07 (46.0)	2.21E-08	3.30E-06
LPR-MOV-FT-1862A	13	5.20E-03 (105.5)	7.95E-07 (47.0)	1.80E-08	3.59E-06

NSLOCA	146	2.70E-01	(28.5)	7.25E-07	(48.0)	0.00E+00	3.90E-06
HPI-XHE-FO-FDBLD	14	7.10E-02	(52.0)	7.10E-07	(49.0)	1.42E-08	2.45E-06
PORV-BLK	6	1.50E-01	(38.5)	8.77E-07	(50.5)	1.15E-08	2.35E-06
SGTR-SGSRV-ODMD1	6	1.00E+00	(2.5)	6.77E-07	(50.5)		
LPI-MDP-FS	2	3.00E-03	(121.0)	6.75E-07	(52.5)	1.26E-08	2.53E-06
BETA-LPI	2	1.50E-01	(38.5)	6.75E-07	(52.5)	1.26E-08	2.53E-06
AFW-TDP-FR-2P6HR	92	3.00E-02	(74.5)	6.60E-07	(54.0)	5.15E-09	3.16E-06
LPI-MOV-PG-1890C	2	4.40E-04	(170.0)	6.60E-07	(55.0)	2.56E-08	3.97E-07
AFW-TDP-FS-FW2	104	1.10E-02	(93.5)	6.42E-07	(56.0)	6.45E-09	3.58E-06
AFW-CCF-LK-STMBD	21	1.00E-04	(181.5)	5.82E-07	(57.0)	8.09E-10	1.55E-06
SGTR-SGSRV-ODMD2	6	1.50E-01	(38.5)	5.75E-07	(58.0)	9.88E-09	2.10E-06
AFW-TDP-MA-FW2	97	1.00E-02	(95.5)	5.75E-07	(59.0)	4.70E-09	2.99E-06
OEP-CRB-FT-15J3	273	3.00E-03	(121.0)	5.65E-07	(60.0)	4.30E-09	2.37E-06
NRAC-6HR-AVG	77	1.94E-01	(34.0)	5.29E-07	(61.0)	1.64E-09	2.72E-06
PPS-XHE-FO-PORVS	11	4.40E-02	(62.5)	4.91E-07	(62.0)	1.09E-08	1.84E-06
LPR-MOV-FT-1880A	12	3.00E-03	(121.0)	4.58E-07	(63.0)	8.90E-09	1.63E-06
RMT-CCF-FA-MSCAL	2	3.00E-04	(172.0)	4.50E-07	(64.0)	1.41E-08	1.86E-06
PPS-MOV-FC-1536	30	3.00E-01	(26.0)	4.31E-07	(65.0)	1.35E-08	1.82E-06
PPS-MOV-FC-1535	27	3.00E-01	(26.0)	4.26E-07	(66.0)	1.33E-08	1.79E-06
LPR-MOV-FT-1890A	4	3.00E-03	(121.0)	4.09E-07	(67.0)	7.30E-09	1.52E-06
HPI-XHE-FO-UN2S3	18	4.40E-02	(62.5)	4.02E-07	(68.0)	2.28E-08	1.52E-06
PPS-MOV-FT-1535	16	4.00E-02	(66.0)	3.87E-07	(69.0)	1.20E-08	1.70E-06
HPI-XHE-FO-ALTS3	2	7.40E-02	(51.0)	3.32E-07	(70.0)	2.67E-09	1.24E-06
ACC-MOV-PG-1865C	1	6.50E-04	(162.5)	3.25E-07	(71.5)	3.03E-08	6.51E-07
ACC-MOV-PG-1865B	1	6.50E-04	(162.5)	3.25E-07	(71.5)	3.03E-08	6.51E-07
HPI-XHE-FO-ALT	2	6.10E-01	(13.0)	3.22E-07	(73.0)	3.64E-09	1.07E-06
AFW-XHE-FO-U1SBO	73	8.20E-02	(49.0)	2.84E-07	(74.0)	2.62E-09	1.58E-06
REC-XHE-FO-DGTMB	18	5.00E-01	(18.5)	2.78E-07	(75.0)	6.63E-10	9.35E-07
MSS-XHE-FO-BLOCK	4	6.40E-02	(56.5)	2.54E-07	(77.0)	5.03E-09	9.31E-07
MSS-SOV-OO-ODADV	4	1.00E+00	(2.5)	2.54E-07	(77.0)		
SGTR-SGADV-ODMD	4	1.00E+00	(2.5)	2.54E-07	(77.0)		
HPI-CKV-FT-CV225	5	1.00E-04	(181.5)	2.10E-07	(79.0)	3.77E-08	5.82E-07
HPI-CKV-FT-CV410	5	1.00E-04	(181.5)	2.08E-07	(80.5)	3.52E-08	5.90E-07
HPI-CKV-FT-CV25	5	1.00E-04	(181.5)	2.08E-07	(80.5)	3.52E-08	5.90E-07
HPI-MOV-FT-1350	1	3.00E-03	(121.0)	2.02E-07	(82.0)	8.17E-10	7.56E-07
NRAC-201M	62	1.50E-01	(38.5)	1.95E-07	(83.0)	0.00E+00	1.00E-06
RCS-XHE-FO-DPT7D	12	4.00E-01	(22.0)	1.95E-07	(84.0)	6.57E-09	7.72E-07
AFW-MDP-FS	26	6.30E-03	(99.0)	1.73E-07	(85.5)	2.52E-09	7.08E-07
BETA-AFW	26	5.60E-02	(59.0)	1.73E-07	(85.5)	2.52E-09	7.08E-07
REC-XHE-FO-DGTMS	217	7.00E-01	(12.0)	1.66E-07	(87.0)	0.00E+00	6.86E-07
HPI-XHE-FO-UN2S2	7	3.10E-01	(24.0)	1.63E-07	(88.0)	7.61E-09	6.53E-07
PPS-MOV-FT-1536	15	4.00E-02	(66.0)	1.45E-07	(89.0)	3.02E-09	5.02E-07
AFW-TDP-FR-2P24H	23	1.20E-01	(45.0)	1.26E-07	(90.0)	1.57E-09	5.07E-07
RCS-PORV-ODMD	10	5.00E-01	(18.5)	1.22E-07	(91.0)	8.79E-10	5.04E-07
LPR-MOV-FT-1862B	11	5.20E-03	(105.5)	1.09E-07	(92.0)	1.02E-09	8.24E-07
OEP-DGN-FR-DG01	23	2.00E-03	(136.5)	1.02E-07	(93.0)	1.89E-10	3.52E-07
AFW-MDP-FS-FW3A	24	6.30E-03	(99.0)	1.00E-07	(94.0)	2.39E-09	3.39E-07
AFW-MDP-FS-FW3B	23	6.30E-03	(99.0)	9.93E-08	(95.0)	2.25E-09	3.36E-07
HPI-XVM-PG-XV24	4	4.00E-05	(199.5)	8.23E-08	(96.0)	1.40E-08	2.26E-07
LPR-CCF-PG-SUMP	5	5.00E-05	(196.0)	7.75E-08	(97.0)	2.02E-09	2.87E-07
LPI-MDP-FS-SI1B	14	3.00E-03	(121.0)	7.41E-08	(98.5)	1.12E-09	3.67E-07
LPI-MDP-FS-SI1A	14	3.00E-03	(121.0)	7.41E-08	(98.5)	1.12E-09	3.67E-07
NRAC-248M	262	1.15E-01	(46.0)	6.74E-08	(100.0)	0.00E+00	1.60E-07
PPS-XHE-FO-EMB0R	1	1.00E-03	(152.0)	6.73E-08	(101.0)	2.58E-10	2.40E-07
NRAC-150M	262	2.10E-01	(32.5)	6.40E-08	(102.5)	0.00E+00	0.00E+00
RCP-LOCA-1440-90	262	4.30E-03	(107.0)	6.40E-08	(102.5)	0.00E+00	0.00E+00

LPR-MOV-FT-1860B	10	3.00E-03	(121.0)	6.24E-08	(104.0)	6.67E-10	4.25E-07
AFW-CKV-OO-CV142	8	1.00E-03	(152.0)	6.10E-08	(105.0)	4.56E-10	2.55E-07
LPR-XHE-FO-HOTLG	2	4.00E-05	(199.5)	6.00E-08	(108.0)	1.78E-09	2.18E-07
PPS-MOV-OO-1536	3	4.00E-02	(66.0)	5.78E-08	(107.5)	4.23E-10	2.43E-07
PPS-MOV-OO-1535	3	4.00E-02	(66.0)	5.78E-08	(107.5)	4.23E-10	2.43E-07
RCP-LOCA-183-210	262	1.61E-02	(84.5)	5.70E-08	(109.5)	0.00E+00	0.00E+00
RCP-LOCA-183-150	262	1.61E-02	(84.5)	5.70E-08	(109.5)	0.00E+00	0.00E+00
RWT-TNK-LF-RWST	5	2.70E-06	(207.0)	5.27E-08	(111.0)	1.26E-09	2.01E-07
OEP-DGN-FR-DG02	14	2.00E-03	(136.5)	5.13E-08	(112.0)	8.00E-11	1.78E-07
AFW-CKV-OO-CV172	23	1.00E-03	(152.0)	5.09E-08	(113.0)	3.10E-09	1.90E-07
OEP-DGN-FR-DG03	12	2.00E-03	(136.5)	5.06E-08	(114.0)	8.06E-11	1.76E-07
ACC-CKV-FT-CV145	1	1.00E-04	(181.5)	5.00E-08	(116.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV128	1	1.00E-04	(181.5)	5.00E-08	(116.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV130	1	1.00E-04	(181.5)	5.00E-08	(116.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV147	1	1.00E-04	(181.5)	5.00E-08	(116.5)	6.43E-09	1.63E-07
RCP-LOCA-183-90	262	1.40E-02	(87.5)	4.96E-08	(119.0)	0.00E+00	0.00E+00
PPS-MOV-FT	7	4.00E-02	(66.0)	4.22E-08	(120.0)	8.06E-10	1.68E-07
LPI-MDP-MA-SI1B	10	2.00E-03	(136.5)	4.04E-08	(121.5)	6.04E-10	1.58E-07
LPI-MDP-MA-SI1A	10	2.00E-03	(136.5)	4.04E-08	(121.5)	6.04E-10	1.58E-07
IAS-CCF-LF-INAIR	3	2.70E-05	(205.0)	3.72E-08	(123.0)	5.11E-10	1.35E-07
AFW-TDP-FR-6HRU2	22	3.00E-02	(74.5)	3.58E-08	(124.0)	3.12E-11	3.18E-07
BETA-STR	5	2.63E-01	(30.0)	3.34E-08	(125.0)	6.46E-09	1.01E-07
RCP-LOCA-581-150	262	4.00E-03	(108.5)	3.27E-08	(126.0)	0.00E+00	0.00E+00
SIS-ACT-FA-SISA	8	1.60E-03	(144.0)	2.86E-08	(127.5)	7.94E-10	2.16E-07
SIS-ACT-FA-SISB	8	1.60E-03	(144.0)	2.86E-08	(127.5)	7.94E-10	2.16E-07
AFW-CKV-OO-CV157	7	1.00E-03	(152.0)	2.56E-08	(129.0)	7.36E-10	8.48E-08
OEP-CRB-FT-25H3	106	3.00E-03	(121.0)	2.46E-08	(130.0)	2.20E-11	1.45E-07
CPC-STR-PG-3HR	1	8.00E-05	(190.5)	2.37E-08	(131.0)		
REC-XHE-FO-GAGRV	2	3.00E-01	(26.0)	2.25E-08	(132.0)	1.79E-10	7.97E-08
HPI-CKV-OO-CV258	2	1.00E-03	(152.0)	2.24E-08	(133.0)	1.96E-09	7.24E-08
AFW-TDP-FS-U2FW2	22	1.10E-02	(93.5)	2.18E-08	(134.0)	3.56E-11	1.98E-07
HPI-MDP-FR-1A24H	2	1.60E-03	(144.0)	2.16E-08	(135.0)	1.95E-09	6.93E-08
AFW-MDP-MA-FW3B	7	2.00E-03	(136.5)	2.12E-08	(136.5)	4.79E-11	6.59E-08
AFW-MDP-MA-FW3A	7	2.00E-03	(136.5)	2.12E-08	(136.5)	4.79E-11	6.59E-08
HPI-MOV-FT-1115B	5	3.00E-03	(121.0)	1.92E-08	(138.0)	5.07E-11	2.29E-07
AFW-TDP-MA-U2FW2	20	1.00E-02	(95.5)	1.89E-08	(139.0)	3.37E-11	1.26E-07
HPI-MOV-FT-1115E	3	3.00E-03	(121.0)	1.69E-08	(141.0)	1.47E-11	2.20E-07
HPI-MOV-FT-1115D	3	3.00E-03	(121.0)	1.69E-08	(141.0)	1.47E-11	2.20E-07
HPI-MOV-FT-1115C	3	3.00E-03	(121.0)	1.69E-08	(141.0)	1.47E-11	2.20E-07
LPR-MOV-FT-1890B	2	3.00E-03	(121.0)	1.35E-08	(143.0)	1.23E-11	1.59E-07
UNIT2-LOW-POWER	20	3.50E-01	(23.0)	1.29E-08	(144.0)		
ACP-BAC-ST-4KV1H	5	9.00E-05	(190.5)	1.18E-08	(145.0)	3.81E-10	4.74E-08
CPC-XHE-FO-REALN	5	7.00E-02	(53.5)	1.10E-08	(146.0)	4.93E-10	4.35E-08
HPI-MOV-FT-1867D	5	3.00E-03	(121.0)	1.07E-08	(147.0)	1.59E-10	3.96E-08
PPS-SOV-FT-1456	4	1.00E-03	(152.0)	1.07E-08	(148.5)	3.66E-10	3.54E-08
PPS-SOV-FT-1455C	4	1.00E-03	(152.0)	1.07E-08	(148.5)	3.68E-10	3.54E-08
ACP-BAC-ST-1H1	3	9.00E-05	(190.5)	1.06E-08	(150.0)	2.77E-10	3.90E-08
CON-VFC-RP-COREM	6	2.00E-02	(82.0)	1.01E-08	(151.0)	7.48E-10	3.17E-08
HPI-XHE-FO-ALTIN	2	5.70E-03	(104.0)	9.69E-09	(152.0)	1.54E-10	4.34E-08
LPI-MDP-FR-B21HR	4	6.30E-04	(165.0)	8.32E-09	(153.5)	9.43E-11	2.93E-08
LPI-MDP-FR-A21HR	4	6.30E-04	(165.0)	8.32E-09	(153.5)	9.43E-11	2.93E-08
MSS-XHE-FO-1SDHR	1	1.40E-02	(87.5)	8.12E-09	(155.5)	1.24E-10	3.09E-08
MSS-CKV-FT-SGDHR	1	2.00E-03	(136.5)	8.12E-09	(155.5)	1.24E-10	3.09E-08
CPC-STR-PG-24H	1	7.20E-04	(159.5)	7.58E-09	(157.0)		
SWS-XHE-FO-OPEN	3	2.40E-01	(31.0)	7.56E-09	(158.5)	4.66E-10	2.42E-08
SWS-FT-3ABCD	3	6.30E-04	(165.0)	7.56E-09	(158.5)		

PPS-MOV-FC-OPER	4	2.70E-03 (131.0)	6.52E-09 (160.0)	1.33E-11	2.76E-08
ACP-BAC-ST-1H1-2	1	9.00E-05 (190.5)	6.06E-09 (161.0)	6.02E-11	2.23E-08
CPC-MDP-FS-SW10B	3	8.00E-03 (97.0)	5.78E-09 (162.0)	4.30E-10	1.96E-08
AFW-ACT-FA-PMP3B	3	6.00E-04 (167.5)	5.51E-09 (163.5)	1.69E-11	1.60E-08
AFW-ACT-FA-PMP3A	3	6.00E-04 (167.5)	5.51E-09 (163.5)	1.69E-11	1.60E-08
OEP-DGN-FC-DG3U2	3	3.40E-02 (71.0)	5.42E-09 (165.0)	8.97E-11	1.95E-08
CPC-MDP-FR-SWA3H	2	4.80E-04 (169.0)	4.80E-09 (168.0)	3.38E-10	1.50E-08
LPI-MDP-FR-B24HR	4	7.20E-04 (159.5)	4.75E-09 (167.5)	5.27E-11	1.99E-08
LPI-MDP-FR-A24HR	4	7.20E-04 (159.5)	4.75E-09 (167.5)	5.27E-11	1.99E-08
BETA-SRV	1	7.00E-02 (53.5)	4.71E-09 (169.5)	5.25E-11	1.74E-08
PPS-SOV-FT	1	1.00E-03 (152.0)	4.71E-09 (169.5)	5.25E-11	1.74E-08
LPI-CKV-OO-CV58	2	1.00E-03 (152.0)	4.50E-09 (171.5)	8.17E-11	1.91E-08
LPI-CKV-OO-CV50	2	1.00E-03 (152.0)	4.50E-09 (171.5)	8.17E-11	1.91E-08
RMT-ACT-FA-RMTSB	3	1.60E-03 (144.0)	4.37E-09 (173.5)	7.13E-11	3.79E-08
RMT-ACT-FA-RMTSA	3	1.60E-03 (144.0)	4.37E-09 (173.5)	7.13E-11	3.79E-08
ACP-TFM-NO-1H1	2	4.00E-05 (199.5)	4.25E-09 (175.0)	1.78E-10	1.63E-08
CPC-MDP-FR-SWA24	3	3.80E-03 (110.5)	3.97E-09 (176.0)	1.35E-10	1.56E-08
DCP-BDC-ST-BUS1B	3	9.00E-05 (190.5)	3.52E-09 (177.5)	3.33E-11	1.35E-08
DCP-BDC-ST-BUS1A	3	9.00E-05 (190.5)	3.52E-09 (177.5)	3.33E-11	1.35E-08
QS-UNIT2	6	1.60E-01 (36.0)	3.31E-09 (179.0)	2.89E-11	1.74E-08
AFW-TNK-VF-CST	3	1.00E-06 (208.0)	2.76E-09 (180.0)	8.44E-11	1.05E-08
HPI-MOV-PG-1350	1	4.00E-05 (199.5)	2.69E-09 (181.0)	4.77E-11	1.08E-08
HPI-MOV-FT-1867C	2	3.00E-03 (121.0)	2.23E-09 (182.0)	9.41E-12	7.51E-09
CPC-CKV-OO-CV113	1	1.00E-03 (152.0)	2.17E-09 (183.0)	7.76E-11	8.77E-09
CPC-MDP-FR-CCA24	2	7.20E-04 (159.5)	2.06E-09 (184.0)	8.97E-12	6.85E-09
CVC-MDP-FR-2A1HR	1	3.00E-05 (203.5)	2.02E-09 (185.0)	8.51E-12	6.51E-09
MSS-XHE-FO-1SAFW	1	6.80E-06 (208.0)	1.97E-09 (186.0)	4.39E-11	7.32E-09
AFW-MDP-FR-3B6HR	3	1.80E-04 (174.0)	1.85E-09 (187.5)	1.83E-12	4.44E-09
AFW-MDP-FR-3A6HR	3	1.80E-04 (174.0)	1.85E-09 (187.5)	1.83E-12	4.44E-09
O	1300	4.90E-02 (61.0)	1.65E-09 (189.0)	-9.53E-08	6.02E-08
CPC-STR-PG-6HR	2	1.80E-04 (174.0)	1.61E-09 (190.0)		
HPI-MDP-FR-1A6HR	1	4.00E-04 (171.0)	1.60E-09 (191.0)	5.94E-11	5.71E-09
CPC-MDP-FS-CC2B	1	3.00E-03 (121.0)	1.24E-09 (192.0)	2.69E-12	4.35E-09
NRAC-234M	62	1.23E-01 (44.0)	1.21E-09 (193.0)	0.00E+00	0.00E+00
ACP-BAC-ST-4KV1J	2	9.00E-05 (190.5)	1.18E-09 (194.0)	9.07E-12	3.83E-09
RMT-XHE-FO-MANS1	2	8.40E-02 (56.5)	1.06E-09 (195.0)	5.10E-12	3.57E-09
AFW-XHE-FO-U2SBO	4	7.50E-02 (50.0)	1.06E-09 (196.0)	6.60E-12	4.72E-09
CPC-MDP-MA-SW10B	1	2.00E-03 (136.5)	9.60E-10 (197.0)	1.51E-11	3.61E-09
CPC-MDP-MA-CC2B	1	2.00E-03 (136.5)	8.24E-10 (198.0)	1.35E-12	2.64E-09
BETA-HPI	1	2.10E-01 (32.5)	7.69E-10 (199.5)	1.80E-11	3.14E-09
HPI-MDP-FS	1	4.00E-03 (108.5)	7.69E-10 (199.5)	1.80E-11	3.14E-09
CPC-STR-PG-2A3HR	1	8.00E-05 (190.5)	7.20E-10 (201.0)	9.84E-12	2.43E-09
CPC-MDP-FR-SWB24	1	3.80E-03 (110.5)	5.78E-10 (202.0)	5.84E-12	3.57E-09
AFW-CKV-FT-CV157	1	1.00E-04 (181.5)	5.40E-10 (203.5)	1.01E-12	1.80E-09
AFW-CKV-FT-CV172	1	1.00E-04 (181.5)	5.40E-10 (203.5)	1.01E-12	1.80E-09
CPC-STR-PG-1HR	1	3.00E-05 (203.5)	5.31E-10 (205.0)		
AFW-XVM-PG-XV183	1	4.00E-05 (199.5)	2.16E-10 (206.5)	4.05E-13	6.29E-10
AFW-XVM-PG-XV168	1	4.00E-05 (199.5)	2.16E-10 (206.5)	4.05E-13	6.29E-10
DGN-FTO	1460	3.39E-02 (72.0)	-5.19E-07 (208.0)	-2.96E-08	-8.17E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
------------	-------	-------------	-----------------------	----------	----------

IE-T1	2463	7.70E-02	(4.0)	2.02E-05	(1.0)	9.09E-07	1.12E-04
IE-S1	57	1.00E-03	(9.5)	3.31E-08	(2.0)	3.58E-07	9.73E-08
IE-A	49	5.00E-04	(11.0)	2.10E-06	(3.0)	2.80E-07	5.49E-06
IE-T7	39	1.00E-02	(6.0)	1.92E-08	(4.0)	1.42E-07	6.12E-08
IE-T2	65	9.40E-01	(3.0)	1.48E-08	(5.0)	4.82E-08	4.88E-08
IE-TN	1	5.90E+00	(2.0)	8.43E-07	(6.0)	6.29E-09	3.16E-06
IE-S3	20	1.30E-02	(5.0)	6.39E-07	(7.0)	4.24E-08	2.35E-08
IE-T	14	6.60E+00	(1.0)	5.65E-07	(8.0)	9.48E-09	2.82E-08
IE-S2	13	1.00E-03	(9.5)	4.33E-07	(9.0)	4.35E-08	1.39E-06
IE-V-TRAIN-3	1	4.00E-07	(13.0)	4.00E-07	(11.0)	1.27E-11	1.82E-06
IE-V-TRAIN-2	1	4.00E-07	(13.0)	4.00E-07	(11.0)	1.27E-11	1.82E-06
IE-V-TRAIN-1	1	4.00E-07	(13.0)	4.00E-07	(11.0)	1.27E-11	1.82E-08
IE-T5E	25	5.00E-03	(7.5)	1.38E-07	(13.5)	1.20E-09	4.52E-07
IE-T5A	25	5.00E-03	(7.5)	1.38E-07	(13.5)	1.20E-09	4.52E-07

SURRY TOTAL CORE DAMAGE MODAL
RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
K	18	6.00E-05	(195.0)	2.52E-02	(1.0)	1.45E-03	9.56E-02
RWT-TNK-LF-RWST	5	2.70E-06	(207.0)	1.95E-02	(2.0)	7.83E-03	3.88E-02
AFW-PSF-FC-XCONN	25	1.50E-04	(176.0)	5.83E-03	(3.0)	4.48E-04	1.89E-02
AFW-CCF-LK-STMBD	21	1.00E-04	(181.5)	5.82E-03	(4.0)	4.48E-04	1.88E-02
AFW-TNK-VF-CST	3	1.00E-06	(208.0)	2.78E-03	(5.0)	1.45E-04	1.00E-02
HPI-CKV-FT-CV225	5	1.00E-04	(181.5)	2.10E-03	(6.0)	8.68E-04	4.13E-03
HPI-CKV-FT-CV25	5	1.00E-04	(181.5)	2.08E-03	(7.5)	7.31E-04	4.38E-03
HPI-CKV-FT-CV410	5	1.00E-04	(181.5)	2.08E-03	(7.5)	7.31E-04	4.38E-03
HPI-XVM-PG-XV24	4	4.00E-05	(199.5)	2.06E-03	(9.0)	7.13E-04	4.35E-03
LPR-CCF-PG-SUMP	5	5.00E-05	(186.0)	1.55E-03	(10.0)	6.08E-04	3.05E-03
LPR-XHE-FO-HOTLG	2	4.00E-05	(199.5)	1.50E-03	(11.0)	5.89E-04	2.98E-03
RMT-CCF-FA-MSCAL	2	3.00E-04	(172.0)	1.50E-03	(12.0)	5.89E-04	2.98E-03
LPI-MOV-PG-1890C	2	4.40E-04	(170.0)	1.50E-03	(13.0)	5.89E-04	2.98E-03
IAS-CCF-LF-INAIR	3	2.70E-05	(205.0)	1.38E-03	(14.0)	1.59E-04	4.35E-03
ACC-CKV-FT-CV130	1	1.00E-04	(181.5)	5.00E-04	(16.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV128	1	1.00E-04	(181.5)	5.00E-04	(16.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV145	1	1.00E-04	(181.5)	5.00E-04	(16.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV147	1	1.00E-04	(181.5)	5.00E-04	(16.5)	1.33E-04	1.20E-03
ACC-MOV-PG-1865B	1	6.50E-04	(162.5)	5.00E-04	(19.5)	1.33E-04	1.20E-03
ACC-MOV-PG-1865C	1	6.50E-04	(162.5)	5.00E-04	(19.5)	1.33E-04	1.20E-03
HPI-MOV-FT	8	3.00E-03	(121.0)	3.98E-04	(21.0)	7.12E-05	1.07E-03
OEP-DGN-FS-DG01	725	2.20E-02	(79.5)	3.65E-04	(22.0)	2.26E-05	1.12E-03
OEP-CRB-FT-15H3	418	3.00E-03	(121.0)	3.54E-04	(23.0)	2.25E-05	1.12E-03
OEP-DGN-FR-6HDG1	839	1.20E-02	(91.0)	3.38E-04	(24.0)	2.33E-05	1.04E-03
OEP-DGN-MA-DG01	393	6.00E-03	(102.0)	3.07E-04	(25.0)	1.78E-05	1.01E-03
MSS-XHE-FO-1SAFW	1	6.80E-06	(206.0)	2.90E-04	(26.0)	7.74E-05	6.97E-04
CPC-STR-PG-3HR	1	9.00E-05	(180.5)	2.83E-04	(27.0)		
LPI-MDP-FS	2	3.00E-03	(121.0)	2.24E-04	(28.0)	3.90E-05	6.03E-04
OEP-DGN-FS	299	2.20E-02	(79.5)	2.17E-04	(29.0)	1.52E-05	6.54E-04
OEP-DGN-FS-DG02	521	2.20E-02	(79.5)	1.95E-04	(30.0)	1.25E-05	6.02E-04
OEP-DGN-FS-DG03	526	2.20E-02	(79.5)	1.95E-04	(31.0)	1.27E-05	6.00E-04
OEP-DGN-FR-6HDG3	467	1.20E-02	(91.0)	1.91E-04	(32.0)	1.38E-05	6.11E-04
OEP-CRB-FT-15J3	273	3.00E-03	(121.0)	1.88E-04	(33.0)	1.34E-05	6.04E-04
OEP-DGN-FR-6HDG2	458	1.20E-02	(91.0)	1.72E-04	(34.0)	1.04E-05	5.32E-04
OEP-DGN-MA-DG02	279	6.00E-03	(102.0)	1.68E-04	(35.0)	9.77E-06	5.67E-04
OEP-DGN-MA-DG03	273	6.00E-03	(102.0)	1.59E-04	(36.0)	9.16E-06	5.56E-04
NRAC-7HR	986	5.00E-02	(60.0)	1.53E-04	(37.0)	8.19E-06	8.47E-04
LPR-MOV-FT-1860A	12	3.00E-03	(121.0)	1.52E-04	(38.0)	3.23E-05	3.92E-04
LPR-MOV-FT-1862A	13	5.20E-03	(105.5)	1.52E-04	(39.0)	3.22E-05	3.92E-04
BETA-3DG	59	1.80E-02	(83.0)	1.45E-04	(40.0)	6.07E-06	5.00E-04
LPR-MOV-FT-1890A	4	3.00E-03	(121.0)	1.38E-04	(41.0)	2.41E-05	3.66E-04
ACP-BAC-ST-4KV1H	5	9.00E-05	(180.5)	1.31E-04	(42.0)	1.34E-05	4.02E-04
ACP-BAC-ST-1H1	3	9.00E-05	(180.5)	1.18E-04	(43.0)	8.94E-06	3.82E-04
ACP-TFM-NO-1H1	2	4.00E-05	(199.5)	1.08E-04	(44.0)	7.55E-06	3.48E-04
REC-XHE-FO-DPRES	3	1.40E-02	(87.5)	9.49E-05	(45.0)	1.53E-05	2.62E-04
CVC-MDP-FR-2A1HR	1	3.00E-05	(203.5)	6.73E-05	(46.5)	1.80E-06	2.49E-04
HPI-MOV-PG-1350	1	4.00E-05	(199.5)	6.73E-05	(46.5)	1.80E-06	2.49E-04

ACP-BAC-ST-1H1-2	1	9.00E-05	(190.5)	6.73E-05	(48.0)	1.80E-06	2.49E-04
PPS-XHE-FO-EMBOR	1	1.00E-03	(152.0)	6.73E-05	(49.0)	1.79E-06	2.48E-04
HPI-MOV-FT-1350	1	3.00E-03	(121.0)	6.71E-05	(50.0)	1.80E-06	2.48E-04
AFW-CKV-OO-CV142	8	1.00E-03	(152.0)	6.08E-05	(51.0)	5.78E-07	2.43E-04
Z	1	1.40E-02	(87.5)	5.93E-05	(52.0)	1.60E-06	2.16E-04
AFW-TDP-FS-FW2	104	1.10E-02	(93.5)	5.77E-05	(53.0)	5.41E-06	2.42E-04
AFW-TDP-MA-FW2	97	1.00E-02	(95.5)	5.69E-05	(54.0)	3.67E-06	2.51E-04
BETA-2DG	271	3.80E-02	(69.0)	5.69E-05	(55.0)	3.16E-06	1.85E-04
AFW-XHE-FO-UNIT2	151	3.60E-02	(70.0)	5.20E-05	(56.0)	6.80E-06	1.57E-04
OEP-DGN-FR-DG01	23	2.00E-03	(136.5)	5.10E-05	(57.0)	5.27E-07	1.85E-04
AFW-CKV-OO-CV172	23	1.00E-03	(152.0)	5.09E-05	(58.0)	5.70E-06	1.80E-04
RCS-XHE-FO-DPRT7	15	2.90E-02	(77.0)	4.95E-05	(59.0)		
DCP-BDC-ST-BUS1A	3	9.00E-05	(190.5)	3.91E-05	(60.5)	1.05E-06	1.49E-04
DCP-BDC-ST-BUS1B	3	9.00E-05	(190.5)	3.91E-05	(60.5)	1.05E-06	1.49E-04
PPS-SOV-OO-1455C	69	3.00E-02	(74.5)	3.87E-05	(62.5)	2.38E-06	1.79E-04
PPS-SOV-OO-1456	69	3.00E-02	(74.5)	3.87E-05	(62.5)	2.38E-06	1.79E-04
NRAC-216M	200	1.38E-01	(41.0)	3.13E-05	(64.0)	0.00E+00	1.96E-04
AFW-XHE-FO-CST2	33	6.50E-02	(55.0)	2.83E-05	(65.0)	7.87E-07	1.38E-04
BETA-2MOV	25	8.80E-02	(48.0)	2.82E-05	(66.0)	2.21E-06	9.84E-05
AFW-MDP-FS	26	6.30E-03	(99.0)	2.74E-05	(67.0)	6.22E-07	1.09E-04
OEP-DGN-FR-DG02	14	2.00E-03	(136.5)	2.56E-05	(68.0)	1.82E-07	9.71E-05
AFW-CKV-OO-CV157	7	1.00E-03	(152.0)	2.55E-05	(69.0)	1.20E-06	9.30E-05
OEP-DGN-FR-DG03	12	2.00E-03	(136.5)	2.53E-05	(70.0)	1.83E-07	9.02E-05
LPI-MDP-FS-SI1B	14	3.00E-03	(121.0)	2.46E-05	(71.5)	4.22E-06	6.98E-05
LPI-MDP-FS-SI1A	14	3.00E-03	(121.0)	2.46E-05	(71.5)	4.22E-06	6.98E-05
HPI-CKV-OO-CV258	2	1.00E-03	(152.0)	2.24E-05	(73.0)	3.70E-06	6.78E-05
MCW-CCF-VF-SBO	573	6.00E-02	(58.0)	2.16E-05	(74.0)	4.62E-07	1.26E-04
AFW-TDP-FR-2P6HR	92	3.00E-02	(74.5)	2.13E-05	(75.0)	1.18E-06	9.66E-05
LPR-MOV-FT-1862B	11	5.20E-03	(105.5)	2.08E-05	(76.0)	2.79E-06	6.36E-05
LPR-MOV-FT-1860B	10	3.00E-03	(121.0)	2.07E-05	(77.0)	2.74E-06	6.46E-05
REC-XHE-FO-SCHOOL	597	1.25E-01	(43.0)	2.02E-05	(78.0)	3.91E-07	1.10E-04
LPI-MDP-MA-SI1B	10	2.00E-03	(136.5)	2.01E-05	(79.5)	2.81E-06	5.71E-05
LPI-MDP-MA-SI1A	10	2.00E-03	(136.5)	2.01E-05	(79.5)	2.81E-06	5.71E-05
SIS-ACT-FA-SISA	8	1.60E-03	(144.0)	1.79E-05	(81.5)	2.76E-06	5.46E-05
SIS-ACT-FA-SISB	8	1.60E-03	(144.0)	1.79E-05	(81.5)	2.76E-06	5.46E-05
CPC-STR-PG-1HR	1	3.00E-05	(203.5)	1.77E-05	(83.0)		
AFW-MDP-FS-FW3A	24	6.30E-03	(99.0)	1.58E-05	(84.0)	7.09E-07	4.99E-05
AFW-MDP-FS-FW3B	23	6.30E-03	(99.0)	1.57E-05	(85.0)	6.62E-07	4.98E-05
RCP-LOCA-1440-90	262	4.30E-03	(107.0)	1.48E-05	(86.0)	5.15E-07	7.58E-05
HPI-MDP-FR-1A24H	2	1.60E-03	(144.0)	1.35E-05	(87.0)	1.84E-06	3.93E-05
LPI-MDP-FR-B21HR	4	6.30E-04	(165.0)	1.32E-05	(88.5)	1.30E-06	4.11E-05
LPI-MDP-FR-A21HR	4	6.30E-04	(165.0)	1.32E-05	(88.5)	1.30E-06	4.11E-05
ACP-BAC-ST-4KV1J	2	9.00E-05	(190.5)	1.31E-05	(90.0)	3.06E-07	4.46E-05
SWS-CCF-FT-3ABCD	3	6.30E-04	(165.0)	1.20E-05	(91.0)		
PPS-SOV-FT-1456	4	1.00E-03	(152.0)	1.07E-05	(92.5)	6.57E-07	3.57E-05
PPS-SOV-FT-1455C	4	1.00E-03	(152.0)	1.07E-05	(92.5)	6.57E-07	3.57E-05
PPS-XHE-FO-PORVS	11	4.40E-02	(62.5)	1.07E-05	(94.0)	5.15E-07	3.47E-05
AFW-MDP-MA-FW3B	7	2.00E-03	(136.5)	1.06E-05	(95.5)	1.63E-07	3.36E-05
AFW-MDP-MA-FW3A	7	2.00E-03	(136.5)	1.06E-05	(95.5)	1.63E-07	3.36E-05
CPC-STR-PG-24H	1	7.20E-04	(159.5)	1.05E-05	(97.0)		
CPC-MDP-FR-SWA3H	2	4.80E-04	(169.0)	1.00E-05	(98.0)	1.23E-06	3.25E-05
PPS-MOV-FT-1535	16	4.00E-02	(66.0)	9.30E-06	(99.0)	4.59E-07	4.24E-05
HPI-XHE-FO-FDBLD	14	7.10E-02	(52.0)	9.29E-06	(100.0)	4.25E-07	2.89E-05
AFW-MDP-FR-3B6HR	3	1.80E-04	(174.0)	9.18E-06	(101.5)	6.33E-08	2.95E-05
AFW-MDP-FR-3A6HR	3	1.80E-04	(174.0)	9.18E-06	(101.5)	6.33E-08	2.95E-05
AFW-ACT-FA-PMP3B	3	6.00E-04	(167.5)	9.17E-06	(103.5)	6.33E-08	2.95E-05

AFW-ACT-FA-PMP3A	3	6.00E-04	(167.5)	9.17E-06	(103.5)	8.33E-08	2.95E-05
CPC-STR-PG-6HR	2	1.80E-04	(174.0)	8.95E-06	(105.0)		
HPI-XHE-FO-UN2S3	18	4.40E-02	(62.5)	8.74E-06	(106.0)	1.28E-06	2.57E-05
QS-SBO	2435	2.70E-01	(28.5)	8.21E-06	(107.0)	2.14E-07	3.92E-05
OEP-CRB-FT-25H3	106	3.00E-03	(121.0)	8.19E-06	(108.0)	3.00E-08	4.93E-05
RCP-LOCA-561-150	262	4.00E-03	(108.5)	8.14E-06	(109.0)	3.59E-07	4.29E-05
CPC-STR-PG-2A3HR	1	9.00E-05	(180.5)	8.00E-06	(110.0)	9.10E-07	2.73E-05
NRAC-258M	200	1.08E-01	(47.0)	7.75E-06	(111.0)	0.00E+00	5.03E-05
R	16	1.70E-01	(35.0)	7.37E-06	(112.0)	3.48E-07	3.12E-05
RCP-LOCA-467-150	262	1.27E-01	(42.0)	6.70E-06	(113.0)	0.00E+00	3.68E-05
LPI-MDP-FR-B24HR	4	7.20E-04	(159.5)	6.60E-06	(114.5)	6.52E-07	2.15E-05
LPI-MDP-FR-A24HR	4	7.20E-04	(159.5)	6.60E-06	(114.5)	6.52E-07	2.15E-05
HPI-MOV-FT-1115B	5	3.00E-03	(121.0)	6.37E-06	(116.0)	3.88E-07	2.35E-05
HPI-MOV-FT-1115D	3	3.00E-03	(121.0)	5.63E-06	(118.0)	1.25E-07	2.09E-05
HPI-MOV-FT-1115E	3	3.00E-03	(121.0)	5.63E-06	(118.0)	1.25E-07	2.09E-05
HPI-MOV-FT-1115C	3	3.00E-03	(121.0)	5.63E-06	(118.0)	1.25E-07	2.09E-05
AFW-XVM-PG-XV183	1	4.00E-05	(199.5)	5.40E-06	(120.5)	1.45E-08	1.81E-05
AFW-XVM-PG-XV168	1	4.00E-05	(199.5)	5.40E-06	(120.5)	1.45E-08	1.81E-05
AFW-CKV-FT-CV157	1	1.00E-04	(181.5)	5.40E-06	(122.5)	1.45E-08	1.81E-05
AFW-CKV-FT-CV172	1	1.00E-04	(181.5)	5.40E-06	(122.5)	1.45E-08	1.81E-05
NRAC-1HR	157	4.40E-01	(21.0)	5.39E-06	(124.0)	7.06E-08	3.05E-05
PPS-SOV-FT	1	1.00E-03	(152.0)	4.71E-06	(125.0)	8.54E-08	1.69E-05
RCP-LOCA-750-90M	262	5.30E-01	(18.0)	4.61E-06	(126.0)	0.00E+00	2.89E-05
REC-XHE-FO-DGHWB	159	6.00E-01	(14.5)	4.60E-06	(127.0)	6.18E-08	2.27E-05
LPI-CKV-OO-CV58	2	1.00E-03	(152.0)	4.50E-06	(128.5)	1.45E-07	1.69E-05
LPI-CKV-OO-CV50	2	1.00E-03	(152.0)	4.50E-06	(128.5)	1.45E-07	1.69E-05
LPR-MOV-FT-1890B	2	3.00E-03	(121.0)	4.49E-06	(130.0)	1.12E-07	1.72E-05
HPI-XHE-FO-ALTS3	2	7.40E-02	(51.0)	4.18E-06	(131.0)	7.18E-08	1.59E-05
MSS-CKV-FT-SGDHR	1	2.00E-03	(136.5)	4.05E-06	(132.0)	1.00E-07	1.67E-05
HPI-MDP-FR-1A6HR	1	4.00E-04	(171.0)	4.00E-06	(133.0)	2.30E-07	1.29E-05
PORV-BLK	6	1.50E-01	(38.5)	3.84E-06	(134.0)	1.41E-07	1.25E-05
BETA-LPI	2	1.50E-01	(38.5)	3.83E-06	(135.0)	1.11E-07	1.49E-05
MSS-XHE-FO-BLOCK	4	6.40E-02	(56.5)	3.72E-06	(136.0)	1.52E-07	1.18E-05
HPI-MOV-FT-1867D	5	3.00E-03	(121.0)	3.57E-06	(137.0)	4.57E-07	1.12E-05
RCP-LOCA-183-90	262	1.40E-02	(87.5)	3.49E-06	(138.0)	1.27E-07	2.03E-05
RCP-LOCA-183-210	262	1.61E-02	(84.5)	3.49E-06	(138.5)	8.75E-08	1.99E-05
RCP-LOCA-183-150	262	1.61E-02	(84.5)	3.49E-06	(139.5)	9.22E-08	2.03E-05
PPS-MOV-FT-1536	15	4.00E-02	(66.0)	3.48E-06	(141.0)	1.24E-07	1.18E-05
SGTR-SGSRV-ODMD2	6	1.50E-01	(38.5)	3.26E-06	(142.0)	1.18E-07	1.01E-05
AFW-XHE-FO-U1SBO	73	8.20E-02	(49.0)	3.18E-06	(143.0)	5.48E-08	1.67E-05
BETA-AFW	26	5.60E-02	(59.0)	2.92E-06	(144.0)	7.09E-08	1.21E-05
CPC-MDP-FR-CCA24	2	7.20E-04	(159.5)	2.86E-06	(145.0)	7.55E-08	1.08E-05
SBO-PORV-DMD	128	4.50E-01	(20.0)	2.77E-06	(146.0)	1.31E-08	1.29E-05
RMT-ACT-FA-RMTSB	3	1.60E-03	(144.0)	2.73E-06	(147.5)	2.79E-07	8.82E-06
RMT-ACT-FA-RMTSA	3	1.60E-03	(144.0)	2.73E-06	(147.5)	2.79E-07	8.82E-06
PPS-MOV-FC-OPER	4	2.70E-03	(131.0)	2.41E-06	(149.0)	2.51E-08	1.03E-05
NRAC-8HR-AVG	77	1.94E-01	(34.0)	2.20E-06	(150.0)	1.15E-08	9.32E-06
CPC-CKV-OO-CV113	1	1.00E-03	(152.0)	2.17E-06	(151.0)	1.18E-07	8.73E-06
NOTDG-CCF	240	5.20E-01	(17.0)	2.05E-06	(152.0)		
AFW-TDP-FS-U2FW2	22	1.10E-02	(93.5)	1.96E-06	(153.0)	3.25E-08	1.01E-05
NSLOCA	146	2.70E-01	(28.5)	1.96E-06	(154.0)	0.00E+00	1.06E-05
AFW-TDP-MA-U2FW2	20	1.00E-02	(95.5)	1.87E-06	(155.0)	2.94E-08	8.97E-06
HPI-XHE-FO-ALTIN	2	5.70E-03	(104.0)	1.89E-06	(156.0)	2.75E-07	4.99E-06
NOTW2	54	8.15E-01	(10.0)	1.62E-06	(157.0)		
REC-XHE-FO-DGHWS	1407	8.00E-01	(11.0)	1.49E-06	(158.0)	0.00E+00	7.99E-06
PPS-MOV-OO-1536	3	4.00E-02	(66.0)	1.39E-06	(159.5)	1.51E-08	5.96E-06

PPS-MOV-OO-1535	3	4.00E-02	(66.0)	1.39E-06	(159.5)	1.51E-08	5.98E-06
AFW-TDP-FR-6HRU2	22	3.00E-02	(74.5)	1.16E-06	(161.0)	8.19E-09	6.27E-06
NRAC-201M	62	1.50E-01	(38.5)	1.11E-06	(162.0)	0.00E+00	6.38E-06
CPC-MDP-FR-SWA24	3	3.80E-03	(110.5)	1.04E-06	(163.0)	6.32E-08	3.81E-06
PPS-MOV-FT	7	4.00E-02	(66.0)	1.01E-06	(164.0)	3.07E-08	4.26E-06
PPS-MOV-FC-1536	30	3.00E-01	(26.0)	1.01E-06	(165.0)	5.19E-08	3.07E-06
PPS-MOV-FC-1535	27	3.00E-01	(26.0)	9.93E-07	(166.0)	4.90E-08	3.02E-06
AFW-TDP-FR-2P24H	23	1.20E-01	(45.0)	9.21E-07	(167.0)	2.08E-08	3.91E-06
HPI-MOV-FT-1867C	2	3.00E-03	(121.0)	7.42E-07	(168.0)	1.60E-08	2.47E-06
NRAC-HALFHR	182	6.00E-01	(14.5)	7.24E-07	(169.0)	1.07E-08	3.98E-06
CPC-MDP-FS-SW10B	3	8.00E-03	(97.0)	7.16E-07	(170.0)	1.11E-07	2.09E-06
REC-XHE-FO-DGEN	382	9.00E-01	(8.0)	6.31E-07	(171.0)	3.01E-09	2.96E-06
MSS-XHE-FO-ISDHR	1	1.40E-02	(87.5)	5.72E-07	(172.0)	7.83E-08	1.62E-06
NRAC-246M	262	1.15E-01	(46.0)	5.18E-07	(173.0)	0.00E+00	1.30E-06
NOTQ	2307	9.73E-01	(6.0)	4.96E-07	(174.0)		
CON-VFC-RP-COREM	6	2.00E-02	(82.0)	4.93E-07	(175.0)	8.78E-08	1.33E-06
CPC-MDP-MA-SW10B	1	2.00E-03	(136.5)	4.79E-07	(176.0)	6.83E-08	1.43E-06
CPC-MDP-MA-CC2B	1	2.00E-03	(136.5)	4.11E-07	(177.0)	4.82E-09	1.70E-06
CPC-MDP-FS-CC2B	1	3.00E-03	(121.0)	4.11E-07	(178.0)	4.82E-09	1.70E-06
HPI-XHE-FO-UN2S2	7	3.10E-01	(24.0)	3.62E-07	(179.0)	2.74E-08	1.25E-06
RCS-XHE-FO-DPT7D	12	4.00E-01	(22.0)	2.92E-07	(180.0)	1.07E-08	1.08E-06
REC-XHE-FO-DGTMB	18	5.00E-01	(18.5)	2.78E-07	(181.0)	5.61E-10	1.14E-06
NRAC-150M	262	2.10E-01	(32.5)	2.41E-07	(182.0)	0.00E+00	0.00E+00
HPI-XHE-FO-ALT	2	6.10E-01	(13.0)	2.06E-07	(183.0)	1.18E-09	7.78E-07
HPI-MDP-FS	1	4.00E-03	(108.5)	1.91E-07	(184.0)	7.96E-09	7.31E-07
OEP-DGN-FC-DG3U2	3	3.40E-02	(71.0)	1.54E-07	(185.0)	4.12E-09	5.61E-07
CPC-MDP-FR-SWB24	1	3.80E-03	(110.5)	1.52E-07	(186.0)	3.31E-09	6.45E-07
PORV-NOT-BLK	10	8.50E-01	(9.0)	1.46E-07	(187.0)	8.89E-10	5.93E-07
CPC-XHE-FO-REALN	5	7.00E-02	(53.5)	1.46E-07	(188.0)	1.52E-08	5.28E-07
RCS-PORV-ODMD	10	5.00E-01	(18.5)	1.22E-07	(189.0)	7.02E-10	4.79E-07
NOTL-SBOU1U2	842	9.68E-01	(7.0)	1.07E-07	(190.0)		
NOTL-SBOU1	1316	9.93E-01	(5.0)	9.40E-08	(191.0)		
BETA-STR	5	2.83E-01	(30.0)	9.36E-08	(192.0)	2.52E-08	2.24E-07
REC-XHE-FO-DGTMS	217	7.00E-01	(12.0)	7.11E-08	(193.0)	0.00E+00	2.45E-07
BETA-SRV	1	7.00E-02	(53.5)	6.26E-08	(194.0)	1.12E-09	2.36E-07
REC-XHE-FO-GAGRV	2	3.00E-01	(26.0)	5.24E-08	(195.0)	6.04E-10	2.04E-07
O	1300	4.90E-02	(61.0)	3.19E-08	(196.0)	-1.83E-06	1.42E-06
UNIT2-LOW-POWER	20	3.50E-01	(23.0)	2.40E-08	(197.0)		
SWS-XHE-FO-OPEN	3	2.40E-01	(31.0)	2.39E-08	(198.0)	3.85E-09	6.38E-08
QS-UNIT2	6	1.60E-01	(36.0)	1.74E-08	(199.0)	1.86E-10	1.28E-07
RMT-XHE-FO-MANS1	2	6.40E-02	(56.5)	1.56E-08	(200.0)	1.46E-10	6.27E-08
AFW-XHE-FO-U2SBO	4	7.50E-02	(50.0)	1.30E-08	(201.0)	1.87E-10	5.49E-08
NRAC-234M	62	1.23E-01	(44.0)	8.62E-09	(202.0)	0.00E+00	0.00E+00
BETA-HPI	1	2.10E-01	(32.5)	2.88E-09	(203.0)	7.81E-11	1.10E-08
MSS-SRV-OO-ODSRV	12	1.00E+00	(2.5)	0.00E+00	(205.5)		
MSS-SOV-OO-ODADV	4	1.00E+00	(2.5)	0.00E+00	(205.5)		
SGTR-SGSRV-ODMD1	6	1.00E+00	(2.5)	0.00E+00	(205.5)		
SGTR-SGADV-ODMD	4	1.00E+00	(2.5)	0.00E+00	(205.5)		
DGN-FTO	1460	3.39E-02	(72.0)	-1.48E-05	(208.0)	-8.84E-05	-4.84E-07

SURRY TOTAL CORE DAMAGE MODAL
UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y .05/TE .05*	Y .95/TE .95*
OEP-DGN-FS	299	2.20E-02	(79.5)	20.7	(2.5)	1.23	0.75
OEP-DGN-FS-DG02	521	2.20E-02	(79.5)	20.7	(2.5)	1.23	0.75
OEP-DGN-FS-DG01	725	2.20E-02	(79.5)	20.7	(2.5)	1.23	0.75
OEP-DGN-FS-DG03	528	2.20E-02	(79.5)	20.7	(2.5)	1.23	0.75
OEP-DGN-FR-DG02	14	2.00E-03	(136.5)	18.9	(6.0)	1.00	1.00
OEP-DGN-FR-DG03	12	2.00E-03	(136.5)	18.9	(6.0)	1.00	1.00
OEP-DGN-FR-DG01	23	2.00E-03	(136.5)	18.9	(6.0)	1.00	1.00
OEP-DGN-FR-6HDG1	639	1.20E-02	(91.0)	18.9	(9.0)	1.14	0.80
OEP-DGN-FR-6HDG3	467	1.20E-02	(91.0)	18.9	(9.0)	1.14	0.80
OEP-DGN-FR-6HDG2	458	1.20E-02	(91.0)	18.9	(9.0)	1.14	0.80
NRAC-7HR	986	5.00E-02	(60.0)	5.4	(11.0)	1.04	0.99
NRAC-201M	62	1.50E-01	(38.5)	5.1	(12.0)	1.00	1.00
NRAC-216M	200	1.38E-01	(41.0)	5.0	(13.0)	1.01	0.99
NRAC-234M	62	1.23E-01	(44.0)	5.0	(14.0)	1.00	1.00
NRAC-258M	200	1.08E-01	(47.0)	4.9	(15.0)	1.00	1.00
NRAC-246M	262	1.15E-01	(46.0)	4.9	(16.0)	1.00	1.00
NRAC-HALFHR	182	6.00E-01	(14.5)	4.9	(17.0)	1.01	1.00
NRAC-1HR	157	4.40E-01	(21.0)	4.9	(18.0)	1.01	0.99
NRAC-150M	262	2.10E-01	(32.5)	4.7	(19.0)	1.00	1.00
Z	1	1.40E-02	(87.5)	4.4	(20.0)	1.04	0.99
OEP-DGN-MA-DG03	273	6.00E-03	(102.0)	3.6	(22.0)	1.03	1.04
OEP-DGN-MA-DG02	279	6.00E-03	(102.0)	3.6	(22.0)	1.03	1.04
OEP-DGN-MA-DG01	393	6.00E-03	(102.0)	3.6	(22.0)	1.03	1.04
HPI-MOV-FT-1115E	3	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
LPR-MOV-FT-1890B	2	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
LPR-MOV-FT-1860A	12	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
HPI-MOV-FT-1867C	2	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
LPR-MOV-FT-1860B	10	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
HPI-MOV-FT-1867D	5	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
HPI-MOV-FT-1115B	5	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
HPI-MOV-FT-1115C	3	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
HPI-MOV-FT-1350	1	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
HPI-MOV-FT-1115D	3	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
LPR-MOV-FT-1890A	4	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
HPI-MOV-FT	8	3.00E-03	(121.0)	3.6	(29.5)	1.12	0.98
REC-XHE-FO-DGHS1407	8	8.00E-01	(11.0)	3.1	(36.0)	1.01	1.00
REC-XHE-FO-DGTMB	18	5.00E-01	(18.5)	3.1	(37.0)	1.00	1.00
REC-XHE-FO-DGHWB	159	6.00E-01	(14.5)	3.1	(38.0)	1.02	1.00
REC-XHE-FO-DGEN	382	9.00E-01	(8.0)	2.9	(39.0)	1.01	1.01
REC-XHE-FO-DGTMS	217	7.00E-01	(12.0)	2.8	(40.0)	1.00	1.00
QS-UNIT2	6	1.60E-01	(36.0)	2.3	(41.0)	1.00	1.00
PPS-SOV-OO-1455C	69	3.00E-02	(74.5)	2.2	(42.5)	1.03	0.99
PPS-SOV-OO-1456	69	3.00E-02	(74.5)	2.2	(42.5)	1.03	0.99
QS-SBO	2435	2.70E-01	(28.5)	2.1	(44.0)	1.03	1.02
AFW-XHE-FO-UNIT2	151	3.60E-02	(70.0)	1.9	(45.0)	1.06	1.00
REC-XHE-FO-GAGRV	2	3.00E-01	(26.0)	1.7	(46.0)	1.00	1.00
AFW-CCF-LK-STMBD	21	1.00E-04	(181.5)	1.5	(47.0)	1.05	1.00

BETA-SRV	1	7.00E-02	(53.5)	1.5	(48.0)	1.00	1.00
NSLOCA	146	2.70E-01	(28.5)	1.5	(49.0)	0.99	1.01
ACP-TFM-NO-1H1	2	4.00E-05	(199.5)	1.4	(50.0)	1.00	1.00
OEP-CRB-FT-25H3	106	3.00E-03	(121.0)	1.3	(52.0)	1.00	0.98
OEP-CRB-FT-15J3	273	3.00E-03	(121.0)	1.3	(52.0)	1.00	0.98
OEP-CRB-FT-15H3	418	3.00E-03	(121.0)	1.3	(52.0)	1.00	0.98
LPR-MOV-FT-1862A	13	5.20E-03	(105.5)	1.3	(54.5)	1.03	1.01
LPR-MOV-FT-1862B	11	5.20E-03	(105.5)	1.3	(54.5)	1.03	1.01
PORV-BLK	6	1.50E-01	(38.5)	1.2	(56.0)	1.02	1.00
O	1300	4.90E-02	(61.0)	1.1	(57.0)	1.00	1.00
REC-XHE-FO-SCOOOL	597	1.25E-01	(43.0)	1.0	(58.0)	1.01	0.99
PPS-MOV-FC-1536	30	3.00E-01	(26.0)	1.0	(59.5)	0.99	1.00
PPS-MOV-FC-1535	27	3.00E-01	(28.0)	1.0	(59.5)	0.99	1.00
R	16	1.70E-01	(35.0)	1.0	(61.0)	1.00	0.99
REC-XHE-FO-DPRES	3	1.40E-02	(87.5)	1.0	(62.0)	1.08	1.00
AFW-ACT-FA-PMP3B	3	6.00E-04	(167.5)	0.9	(63.5)	1.00	1.00
AFW-ACT-FA-PMP3A	3	6.00E-04	(167.5)	0.9	(63.5)	1.00	1.00
PPS-XHE-FO-EMBOR	1	1.00E-03	(152.0)	0.9	(65.0)	1.00	1.00
BETA-2DG	271	3.80E-02	(69.0)	0.9	(66.0)	1.01	1.02
MSS-XHE-FO-1SDHR	1	1.40E-02	(87.5)	0.9	(67.0)	1.00	1.00
RCP-LOCA-750-90M	262	5.30E-01	(16.0)	0.9	(68.0)	1.04	0.97
NRAC-6HR-AVG	77	1.94E-01	(34.0)	0.8	(69.0)	1.00	1.01
PPS-XHE-FO-PORVS	11	4.40E-02	(82.5)	0.8	(70.0)	1.00	1.00
BETA-2MOV	25	8.80E-02	(48.0)	0.8	(71.0)	1.04	1.00
AFW-MDP-MA-FW3A	7	2.00E-03	(136.5)	0.8	(74.5)	1.00	1.00
CPC-MDP-MA-SW10B	1	2.00E-03	(136.5)	0.8	(74.5)	1.00	1.00
CPC-MDP-MA-CC2B	1	2.00E-03	(136.5)	0.8	(74.5)	1.00	1.00
AFW-MDP-MA-FW3B	7	2.00E-03	(136.5)	0.8	(74.5)	1.00	1.00
LPI-MDP-MA-SI1B	10	2.00E-03	(136.5)	0.8	(74.5)	1.00	1.00
LPI-MDP-MA-SI1A	10	2.00E-03	(136.5)	0.8	(74.5)	1.00	1.00
AFW-PSF-FC-XCONN	25	1.50E-04	(176.0)	0.7	(78.0)	1.00	1.00
RCS-XHE-FO-DPT7D	12	4.00E-01	(22.0)	0.7	(79.0)	1.00	1.00
MCW-CCF-VF-SBO	573	6.00E-02	(58.0)	0.7	(80.0)	1.00	1.00
HPI-XHE-FO-FDBLD	14	7.10E-02	(52.0)	0.7	(81.0)	1.02	0.99
SBO-PORV-DMD	128	4.50E-01	(20.0)	0.7	(82.0)	0.99	1.00
BETA-3DG	59	1.80E-02	(83.0)	0.7	(83.0)	1.00	0.99
CPC-STR-PG-2A3HR	1	9.00E-05	(190.5)	0.7	(84.0)	1.00	1.00
AFW-XVM-PG-XV168	1	4.00E-05	(199.5)	0.7	(86.0)	1.00	1.00
HPI-XVM-PG-XV24	4	4.00E-05	(199.5)	0.7	(86.0)	1.00	1.00
AFW-XVM-PG-XV183	1	4.00E-05	(199.5)	0.7	(86.0)	1.00	1.00
CVC-MDP-FR-2A1HR	1	3.00E-05	(203.5)	0.7	(88.0)	1.00	1.00
LPI-MDP-FS-SI1A	14	3.00E-03	(121.0)	0.6	(90.5)	1.04	1.00
CPC-MDP-FS-CC2B	1	3.00E-03	(121.0)	0.6	(90.5)	1.04	1.00
LPI-MDP-FS-SI1B	14	3.00E-03	(121.0)	0.6	(90.5)	1.04	1.00
LPI-MDP-FS	2	3.00E-03	(121.0)	0.6	(90.5)	1.04	1.00
SWS-XHE-FO-OPEN	3	2.40E-01	(31.0)	0.6	(93.0)	1.00	1.00
AFW-MDP-FR-3B6HR	3	1.80E-04	(174.0)	0.6	(94.5)	1.00	1.00
AFW-MDP-FR-3A6HR	3	1.80E-04	(174.0)	0.6	(94.5)	1.00	1.00
RCP-LOCA-183-150	262	1.61E-02	(84.5)	0.6	(96.0)	1.00	1.00
HPI-XHE-FO-ALTS3	2	7.40E-02	(51.0)	0.5	(97.0)	1.00	1.00
MSS-XHE-FO-1SAFW	1	6.80E-06	(206.0)	0.5	(98.0)	1.00	1.00
LPI-MDP-FR-B21HR	4	6.30E-04	(165.0)	0.5	(99.5)	1.00	1.00
LPI-MDP-FR-A21HR	4	6.30E-04	(165.0)	0.5	(99.5)	1.00	1.00
ACP-BAC-ST-1H1	3	9.00E-06	(190.5)	0.5	(103.5)		
ACP-BAC-ST-4KV1J	2	9.00E-05	(190.5)	0.5	(103.5)		
ACP-BAC-ST-4KV1H	5	9.00E-05	(190.5)	0.5	(103.5)		

DCP-BDC-ST-BUS1B	3	9.00E-05	(190.5)	0.5	(103.5)
DCP-BDC-ST-BUS1A	3	9.00E-05	(190.5)	0.5	(103.5)
ACP-BAC-ST-1H1-2	1	9.00E-05	(190.5)	0.5	(103.5)
LPI-MDP-FR-A24HR	4	7.20E-04	(159.5)	0.5	(108.0)
CPC-MDP-FR-CCA24	2	7.20E-04	(159.5)	0.5	(108.0)
LPI-MDP-FR-B24HR	4	7.20E-04	(159.5)	0.5	(108.0)
HPI-XHE-FO-UN2S3	18	4.40E-02	(62.5)	0.5	(110.0)
AFW-MDP-FS-FW3B	23	6.30E-03	(99.0)	0.5	(112.0)
AFW-MDP-FS-FW3A	24	6.30E-03	(99.0)	0.5	(112.0)
AFW-MDP-FS	26	6.30E-03	(99.0)	0.5	(112.0)
LPI-MOV-PG-1890C	2	4.40E-04	(170.0)	0.5	(114.0)
BETA-AFW	26	5.60E-02	(59.0)	0.4	(115.0)
CPC-MDP-FS-SW10B	3	8.00E-03	(97.0)	0.4	(116.0)
SGTR-SGSRV-ODMD2	6	1.50E-01	(38.5)	0.4	(117.0)
AFW-CKV-FT-CV157	1	1.00E-04	(181.5)	0.4	(122.0)
ACC-CKV-FT-CV145	1	1.00E-04	(181.5)	0.4	(122.0)
ACC-CKV-FT-CV128	1	1.00E-04	(181.5)	0.4	(122.0)
HPI-CKV-FT-CV410	5	1.00E-04	(181.5)	0.4	(122.0)
HPI-CKV-FT-CV25	5	1.00E-04	(181.5)	0.4	(122.0)
HPI-CKV-FT-CV225	5	1.00E-04	(181.5)	0.4	(122.0)
ACC-CKV-FT-CV130	1	1.00E-04	(181.5)	0.4	(122.0)
AFW-CKV-FT-CV172	1	1.00E-04	(181.5)	0.4	(122.0)
ACC-CKV-FT-CV147	1	1.00E-04	(181.5)	0.4	(122.0)
RMT-CCF-FA-MSCAL	2	3.00E-04	(172.0)	0.4	(127.0)
DGN-FTO	1460	3.39E-02	(72.0)	0.4	(128.0)
BETA-LPI	2	1.50E-01	(38.5)	0.4	(129.0)
MSS-CKV-FT-SGDHR	1	2.00E-03	(136.5)	0.4	(130.0)
HPI-XHE-FO-ALTIN	2	5.70E-03	(104.0)	0.4	(131.0)
CPC-MDP-FR-SWB24	1	3.80E-03	(110.5)	0.4	(132.5)
CPC-MDP-FR-SWA24	3	3.80E-03	(110.5)	0.4	(132.5)
CPC-CKV-OO-CV113	1	1.00E-03	(152.0)	0.4	(137.0)
LPI-CKV-OO-CV58	2	1.00E-03	(152.0)	0.4	(137.0)
LPI-CKV-OO-CV50	2	1.00E-03	(152.0)	0.4	(137.0)
AFW-CKV-OO-CV172	23	1.00E-03	(152.0)	0.4	(137.0)
AFW-CKV-OO-CV157	7	1.00E-03	(152.0)	0.4	(137.0)
HPI-CKV-OO-CV258	2	1.00E-03	(152.0)	0.4	(137.0)
AFW-CKV-OO-CV142	8	1.00E-03	(152.0)	0.4	(137.0)
MSS-XHE-FO-BLOCK	4	6.40E-02	(56.5)	0.3	(141.0)
AFW-TDP-FR-2P24H	23	1.20E-01	(45.0)	0.3	(142.0)
AFW-TDP-MA-U2FW2	20	1.00E-02	(95.5)	0.3	(143.5)
AFW-TDP-MA-FW2	97	1.00E-02	(95.5)	0.3	(143.5)
ACC-MOV-PG-1865C	1	6.50E-04	(162.5)	0.3	(145.5)
ACC-MOV-PG-1865B	1	6.50E-04	(162.5)	0.3	(145.5)
AFW-XHE-FO-CST2	33	6.50E-02	(55.0)	0.2	(147.0)
AFW-XHE-FO-U1SBO	73	8.20E-02	(49.0)	0.2	(148.0)
RCP-LOCA-581-150	262	4.00E-03	(108.5)	0.2	(149.0)
PORV-NOT-BLK	10	8.50E-01	(9.0)	0.2	(150.0)
RCP-LOCA-487-150	262	1.27E-01	(42.0)	0.2	(151.0)
HPI-MDP-FS	1	4.00E-03	(108.5)	0.2	(152.0)
PPS-SOV-FT-1456	4	1.00E-03	(152.0)	0.1	(154.0)
PPS-SOV-FT-1455C	4	1.00E-03	(152.0)	0.1	(154.0)
PPS-SOV-FT	1	1.00E-03	(152.0)	0.1	(154.0)
RCP-LOCA-183-210	262	1.81E-02	(84.5)	0.0	(156.0)
RCP-LOCA-1440-90	262	4.30E-03	(107.0)	0.0	(157.0)
RCP-LOCA-183-80	262	1.40E-02	(87.5)	0.0	(158.0)
AFW-TDP-FS-FW2	104	1.10E-02	(93.5)	0.0	(175.5)

AFW-TDP-FR-6HRU2	22	3.00E-02	(74.5)	0.0	(175.5)
AFW-TDP-FR-2P6HR	92	3.00E-02	(74.5)	0.0	(175.5)
LPR-XHE-FO-HOTLG	2	4.00E-05	(199.5)	0.0	(175.5)
CPC-MDP-FR-SWA3H	2	4.80E-04	(169.0)	0.0	(175.5)
LPR-CCF-PG-SUMP	5	5.00E-05	(196.0)	0.0	(175.5)
SIS-ACT-FA-SISB	8	1.60E-03	(144.0)	0.0	(175.5)
SIS-ACT-FA-SISA	8	1.60E-03	(144.0)	0.0	(175.5)
CON-VFC-RP-COREM	6	2.00E-02	(82.0)	0.0	(175.5)
RWT-TNK-LF-RWST	5	2.70E-06	(207.0)	0.0	(175.5)
RMT-XHE-FO-MANS1	2	6.40E-02	(56.5)	0.0	(175.5)
BETA-STR	5	2.63E-01	(30.0)	0.0	(175.5)
RMT-ACT-FA-RMTSB	3	1.60E-03	(144.0)	0.0	(175.5)
RMT-ACT-FA-RMTSA	3	1.60E-03	(144.0)	0.0	(175.5)
K	16	6.00E-05	(195.0)	0.0	(175.5)
IAS-CCF-LF-INAIR	3	2.70E-05	(205.0)	0.0	(175.5)
BETA-HPI	1	2.10E-01	(32.5)	0.0	(175.5)
RCS-PORV-ODMD	10	5.00E-01	(18.5)	0.0	(175.5)
HPI-XHE-FO-UN2S2	7	3.10E-01	(24.0)	0.0	(175.5)
HPI-XHE-FO-ALT	2	6.10E-01	(13.0)	0.0	(175.5)
HPI-MOV-PG-1350	1	4.00E-05	(199.5)	0.0	(175.5)
PPS-MOV-OO-1536	3	4.00E-02	(66.0)	0.0	(175.5)
PPS-MOV-OO-1535	3	4.00E-02	(66.0)	0.0	(175.5)
PPS-MOV-FT-1538	15	4.00E-02	(66.0)	0.0	(175.5)
PPS-MOV-FT-1535	16	4.00E-02	(66.0)	0.0	(175.5)
PPS-MOV-FT	7	4.00E-02	(66.0)	0.0	(175.5)
PPS-MOV-FC-OPER	4	2.70E-03	(131.0)	0.0	(175.5)
AFW-XHE-FO-U2SBO	4	7.50E-02	(50.0)	0.0	(175.5)
HPI-MDP-FR-1A6HR	1	4.00E-04	(171.0)	0.0	(175.5)
HPI-MDP-FR-1A24H	2	1.60E-03	(144.0)	0.0	(175.5)
OEP-DGN-FC-DG3U2	3	3.40E-02	(71.0)	0.0	(175.5)
AFW-TNK-VF-CST	3	1.00E-06	(208.0)	0.0	(175.5)
CPC-XHE-FO-REALN	5	7.00E-02	(53.5)	0.0	(175.5)
AFW-TDP-FS-U2FW2	22	1.10E-02	(93.5)	0.0	(175.5)
NOTW2	54	8.15E-01	(10.0)	0.0	(175.5)
CPC-STR-PG-3HR	1	9.00E-05	(190.5)	0.0	(175.5)
NOTQ	2307	9.73E-01	(8.0)	0.0	(175.5)
NOTL-SBOU1U2	842	9.68E-01	(7.0)	0.0	(175.5)
NOTL-SBOU1	1316	9.93E-01	(5.0)	0.0	(175.5)
NOTDG-CCF	240	5.20E-01	(17.0)	0.0	(175.5)
CPC-STR-PG-24H	1	7.20E-04	(159.5)	0.0	(175.5)
CPC-STR-PG-1HR	1	3.00E-05	(203.5)	0.0	(175.5)
MSS-SRV-OO-ODSRV	12	1.00E+00	(2.5)	0.0	(175.5)
MSS-SOV-OO-ODADV	4	1.00E+00	(2.5)	0.0	(175.5)
UNIT2-LOW-POWER	20	3.50E-01	(23.0)	0.0	(175.5)
SWS-CCF-FT-3ABCD	3	6.30E-04	(165.0)	0.0	(175.5)
SGTR-SGSRV-ODMD1	8	1.00E+00	(2.5)	0.0	(175.5)
SGTR-SGADV-ODMD	4	1.00E+00	(2.5)	0.0	(175.5)
RCS-XHE-FO-DPRT7	15	2.90E-02	(77.0)	0.0	(175.5)
CPC-STR-PG-6HR	2	1.80E-04	(174.0)	0.0	(175.5)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

% REDUCTION IN
THE UNCERTAINTY

INIT EVENT	OCCUR	FREQ	(RANK)	OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	2463	7.70E-02	(4.0)	12.6	(1.0)	1.19	0.99
IE-V-TRAIN-3	1	4.00E-07	(13.0)	4.5	(3.0)	1.16	1.00
IE-V-TRAIN-1	1	4.00E-07	(13.0)	4.5	(3.0)	1.16	1.00
IE-V-TRAIN-2	1	4.00E-07	(13.0)	4.5	(3.0)	1.16	1.00
IE-S1	57	1.00E-03	(9.5)	0.8	(5.0)	1.04	0.99
IE-A	49	5.00E-04	(11.0)	0.7	(6.0)	1.06	1.01
IE-TN	1	5.90E+00	(2.0)	0.6	(7.0)	1.01	1.01
IE-T	14	6.60E+00	(1.0)	0.4	(8.0)		
IE-T7	39	1.00E-02	(6.0)	0.4	(9.0)		
IE-T2	65	9.40E-01	(3.0)	0.0	(12.0)		
IE-S2	13	1.00E-03	(9.5)	0.0	(12.0)		
IE-T5B	25	5.00E-03	(7.5)	0.0	(12.0)		
IE-T5A	25	5.00E-03	(7.5)	0.0	(12.0)		
IE-S3	20	1.30E-02	(5.0)	0.0	(12.0)		

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SURRY TOTAL CORE DAMAGE MODEL

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SURRY-TOTAL WITH TOP EVENT FREQUENCY 3.30E-05

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1805	10	1.17E-06	0.03537	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
3					NRAC-216M	* /O	* OEP-DGN-FS	* /QS-SBO	*
4					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
5	2589	4	8.43E-07	0.06092	IE-TN	* K	* R	* Z	+
6	141	10	6.21E-07	0.07974	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
7					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
8					/QS-SBO	* REC-XHE-FO-DGHWB	+		
9	140	10	6.21E-07	0.09857	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
10					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
11					/QS-SBO	* REC-XHE-FO-DGHWB	+		
12	2764	6	6.09E-07	0.11703	IE-T7	* MSS-SRV-OO-ODSRV	* PORV-BLK	* RCS-XHE-FO-DPRT7	*
13					REC-XHE-FO-DPRES	* SGTR-SGSRV-ODMD1	+		
14	142	10	5.77E-07	0.13453	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
15					NOTQ	* NOTW2	* NRAC-7HR	* OEP-DGN-FS	*
16					/QS-SBO	* REC-XHE-FO-DGHWB	+		
17	2765	6	5.18E-07	0.15023	IE-T7	* MSS-SRV-OO-ODSRV	* PORV-NOT-BLK	* RCS-XHE-FO-DPRT7	*
18					REC-XHE-FO-DPRES	* SGTR-SGSRV-ODMD2	+		
19	79	3	4.58E-07	0.16410	BETA-2MOV	* IE-S1	* LPR-MOV-FT-1862A	+	
20	1806	9	4.54E-07	0.17786	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
21					NRAC-216M	* OEP-DGN-FS	* QS-SBO	* RCP-LOCA-750-90M	*
22					REC-XHE-FO-DGHWS	+			
23	64	3	4.50E-07	0.19150	BETA-LPI	* IE-S1	* LPI-MDP-FS	+	
24	65	2	4.40E-07	0.20484	IE-S1	* LPI-MOV-PG-1880C	+		
25	2773	1	4.00E-07	0.21697	IE-V-TRAIN-2	+			
26	2772	1	4.00E-07	0.22910	IE-V-TRAIN-1	+			
27	2774	1	4.00E-07	0.24123	IE-V-TRAIN-3	+			
28	2618	4	3.60E-07	0.25215	AFW-PSF-FC-XCONN	* AFW-XHE-FO-UNIT2	* HPI-XHE-FO-FDBLD	* IE-T2	+
29	144	10	3.39E-07	0.26242	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
30					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
31					/QS-SBO	* REC-XHE-FO-DGHWB	+		
32	146	10	3.39E-07	0.27269	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
33					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
34					/QS-SBO	* REC-XHE-FO-DGHWB	+		
35	145	10	3.39E-07	0.28296	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
36					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
37					/QS-SBO	* REC-XHE-FO-DGHWB	+		
38	143	10	3.39E-07	0.29323	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
39					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
40					/QS-SBO	* REC-XHE-FO-DGHWB	+		
41	1	2	3.25E-07	0.30308	ACC-MOV-PG-1865C	* IE-A	+		
42	2	2	3.25E-07	0.31293	ACC-MOV-PG-1865B	* IE-A	+		
43	147	9	3.08E-07	0.32227	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
44					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
45					/QS-SBO	+			
46	77	2	3.00E-07	0.33136	IE-S1	* RMT-CCF-FA-MSCAL	+		

47	50	3	2.64E-07	0.33937	BETA-2MOV	*	HPI-MOV-FT	*	IE-S1	+
48	78	3	2.64E-07	0.34737	BETA-2MOV	*	IE-S1	*	LPR-MOV-FT-1860A	+
49	80	3	2.64E-07	0.35538	BETA-2MOV	*	IE-S1	*	LPR-MOV-FT-1890A	+
50	120	4	2.54E-07	0.36308	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALTS3	*
51	341	9	2.43E-07	0.37046	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*
52					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
53					REC-XHE-FO-DGEN	+				
54	340	9	2.43E-07	0.37784	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*
55					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
56					REC-XHE-FO-DGEN	+				
57	2575	6	2.42E-07	0.38519	IE-T	*	K	*	PPS-MOV-FC-1535	*
58					PPS-MOV-FT-1535	*	R	+		
59	2619	4	2.40E-07	0.39247	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*
60	148	10	2.30E-07	0.39944	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
61					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*
62					QS-SBO	*	REC-XHE-FO-DGHWB	+		
63	149	10	2.30E-07	0.40640	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
64					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*
65					QS-SBO	*	REC-XHE-FO-DGHWB	+		
66	24	3	2.29E-07	0.41334	BETA-2MOV	*	IE-A	*	LPR-MOV-FT-1862A	+
67	342	9	2.26E-07	0.42020	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*
68					NOTQ	*	NRAC-1HR	*	OEP-DGN-FS	*
69					REC-XHE-FO-DGEN	+				
70	7	3	2.25E-07	0.42702	BETA-LPI	*	IE-A	*	LPI-MDP-FS	+
71	2639	4	2.23E-07	0.43379	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T2	*
72	2766	7	2.21E-07	0.44049	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*
73					RCS-XHE-FO-DPRT7	*	REC-XHE-FO-DPRES	*	SGTR-SGADV-ODMD	+
74	8	2	2.20E-07	0.44716	IE-A	*	LPI-MOV-PG-1890C	+		
75	1915	10	2.19E-07	0.45379	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*
76					NRAC-258M	*	/O	*	OEP-DGN-FS	*
77					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
78	150	10	2.14E-07	0.46027	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
79					NOTQ	*	NOTW2	*	NRAC-7HR	*
80					QS-SBO	*	REC-XHE-FO-DGHWB	+		
81	2576	4	2.02E-07	0.46639	HPI-MOV-FT-1350	*	IE-T	*	K	*
82	151	10	1.85E-07	0.47199	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
83					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*
84					/QS-SBO	*	REC-XHE-FO-DGHWB	+		
85	742	12	1.77E-07	0.47735	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
86					NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
87					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*
88	741	12	1.77E-07	0.48270	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
89					NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
90					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*
91	152	10	1.69E-07	0.48783	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
92					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG02	*
93					/QS-SBO	*	REC-XHE-FO-DGHWB	+		
94	155	10	1.69E-07	0.49297	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
95					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG03	*
96					/QS-SBO	*	REC-XHE-FO-DGHWB	+		
97	154	10	1.69E-07	0.49810	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
98					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*
99					/QS-SBO	*	REC-XHE-FO-DGHWB	+		
100	153	10	1.69E-07	0.50324	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
101					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*
102					/QS-SBO	*	REC-XHE-FO-DGHWB	+		

103	743	12	1.64E-07	0.50822	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
104					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS	*
105					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
106	300	10	1.61E-07	0.51311	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
107					NRAC-7HR	* NSLOCA	* /O	* OEP-DGN-FS	*
108					/QS-SBO	* REC-XHE-FO-DGHWB	+		
109	51	4	1.61E-07	0.51800	BETA-2MOV	* HPI-MOV-FT	* HPI-XHE-FO-ALT	* IE-S1	+
110	107	4	1.61E-07	0.52288	BETA-2MOV	* HPI-MOV-FT	* HPI-XHE-FO-ALT	* IE-S2	+
111	121	4	1.51E-07	0.52746	BETA-2MOV	* HPI-MOV-FT	* HPI-XHE-FO-UN2S3	* IE-S3	+
112	22	2	1.50E-07	0.53200	IE-A	* RMT-CCF-FA-MSCAL	+		
113	2640	4	1.49E-07	0.53652	AFW-CCF-LK-STMBD	* AFW-XHE-FO-UNIT2	* IE-T2	* PPS-XHE-FO-PORVS	+
114	617	10	1.40E-07	0.54075	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
115					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1458	* /QS-SBO	*
116					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
117	619	10	1.40E-07	0.54498	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
118					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
119					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
120	620	10	1.40E-07	0.54921	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
121					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*
122					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
123	618	10	1.40E-07	0.55344	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
124					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1456	* /QS-SBO	*
125					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
126	345	9	1.33E-07	0.55747	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
127					NRAC-1HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* QS-SBO	*
128					REC-XHE-FO-DGEN	+			
129	344	9	1.33E-07	0.56149	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
130					NRAC-1HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	* QS-SBO	*
131					REC-XHE-FO-DGEN	+			
132	346	9	1.33E-07	0.56552	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
133					NRAC-1HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* QS-SBO	*
134					REC-XHE-FO-DGEN	+			
135	343	9	1.33E-07	0.56955	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
136					NRAC-1HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* QS-SBO	*
137					REC-XHE-FO-DGEN	+			
138	25	3	1.32E-07	0.57355	BETA-2MOV	* IE-A	* LPR-MOV-FT-1890A	+	
139	23	3	1.32E-07	0.57755	BETA-2MOV	* IE-A	* LPR-MOV-FT-1860A	+	
140	622	10	1.30E-07	0.58148	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
141					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1455C	* /QS-SBO	*
142					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
143	621	10	1.30E-07	0.58542	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
144					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1456	* /QS-SBO	*
145					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
146	158	10	1.25E-07	0.58921	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
147					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
148					QS-SBO	* REC-XHE-FO-DGHWB	+		
149	157	10	1.25E-07	0.59301	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
150					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
151					QS-SBO	* REC-XHE-FO-DGHWB	+		
152	156	10	1.25E-07	0.59681	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
153					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
154					QS-SBO	* REC-XHE-FO-DGHWB	+		
155	159	10	1.25E-07	0.60061	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
156					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
157					QS-SBO	* REC-XHE-FO-DGHWB	+		
158	710	9	1.15E-07	0.60410	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	*

159				OEP-DGN-FS	*	PPS-SOV-00-1456	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
160				SBO-PORV-DMD	+						
161	709	9	1.15E-07	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NRAC-1HR	*
162				OEP-DGN-FS	*	PPS-SOV-00-1455C	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
163				SBO-PORV-DMD	+						
164	180	9	1.14E-07	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
165				NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*
166				QS-SBO	+						
167	2745	3	1.02E-07	IE-T7	*	K	*	R	+		
168	52	2	1.00E-07	HPI-CKV-FT-CV25	*	IE-S1	+				
169	108	2	1.00E-07	HPI-CKV-FT-CV225	*	IE-S2	+				
170	54	2	1.00E-07	HPI-CKV-FT-CV410	*	IE-S1	+				
171	53	2	1.00E-07	HPI-CKV-FT-CV225	*	IE-S1	+				
172	746	12	9.63E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
173				NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
174				/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
175	745	12	9.63E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
176				NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
177				/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
178	747	12	9.63E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
179				NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
180				/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
181	744	12	9.63E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
182				NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
183				/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
184	182	10	9.24E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
185				NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
186				/QS-SBO	*	REC-XHE-FO-DGHWB	+				
187	161	10	9.24E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
188				NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
189				/QS-SBO	*	REC-XHE-FO-DGHWB	+				
190	1816	9	8.51E-08	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
191				NRAC-258M	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-467-150	*
192				REC-XHE-FO-DGHWS	+						
193	749	12	8.48E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
194				NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
195				OEP-DGN-FS-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
196	748	12	8.48E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
197				NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
198				OEP-DGN-FS-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
199	165	10	8.47E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
200				NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
201				/QS-SBO	*	REC-XHE-FO-DGHWB	+				
202	163	10	8.47E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
203				NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
204				/QS-SBO	*	REC-XHE-FO-DGHWB	+				
205	164	10	8.47E-08	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
206				NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
207				/QS-SBO	*	REC-XHE-FO-DGHWB	+				
208	109	4	8.18E-08	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
209	347	8	8.05E-08	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
210				NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
211	750	12	7.88E-08	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	+
212				NOTL-SBOU1	*	NOTQ	*	NRAC-216M	*	/O	*
213				OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
214	2733	5	7.81E-08	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALTS3	*	IE-T7	*

215					RCS-XHE-FO-DPT7D +						
216	167	10	7.70E-08	0.67099	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
217					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03
218					/QS-SBO	*	REC-XHE-FO-DGTMB	+			
219	168	9	7.70E-08	0.67332	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
220					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3
221					/QS-SBO	+					
222	168	10	7.70E-08	0.67566	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
223					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01
224					/QS-SBO	*	REC-XHE-FO-DGTMB	+			
225	169	9	7.70E-08	0.67799	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
226					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1
227					/QS-SBO	+					
228	348	9	7.24E-08	0.68019	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ
229					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO
230					REC-XHE-FO-DGEN	+					
231	751	11	6.87E-08	0.68227	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
232					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO
233					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
234	752	11	6.87E-08	0.68435	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
235					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO
236					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
237	170	10	6.83E-08	0.68642	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
238					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2
239					QS-SBO	*	REC-XHE-FO-DGHWB	+			
240	2577	4	6.73E-08	0.68846	IE-T	*	K	*	PPS-XHE-FO-EMBOR	*	R
241	351	9	6.64E-08	0.69048	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ
242					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO
243					REC-XHE-FO-DGEN	+					
244	350	9	6.64E-08	0.69249	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ
245					NRAC-1HR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO
246					REC-XHE-FO-DGEN	+					
247	352	9	6.64E-08	0.69450	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ
248					NRAC-1HR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO
249					REC-XHE-FO-DGEN	+					
250	349	9	6.64E-08	0.69652	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ
251					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO
252					REC-XHE-FO-DGEN	+					
253	753	11	6.57E-08	0.69851	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
254					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3
255					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOL	+	
256	1807	10	6.53E-08	0.70049	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ
257					NRAC-201M	*	O	*	OEP-DGN-FS	*	/QS-SBO
258					RCP-LOCA-7J0-90M	*	REC-XHE-FO-DGHWS	+			
259	754	11	6.39E-08	0.70243	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1
260					NOTQ	*	NRAC-216M	*	OEP-DGN-FS	*	QS-SBO
261					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
262	2641	8	6.30E-08	0.70434	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW
263					IE-T2	*	PPS-XHE-FO-PORVS	+			
264	301	9	6.28E-08	0.70624	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ
265					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS	*	QS-SBO
266					REC-XHE-FO-DGHWB	+					
267	174	10	6.26E-08	0.70814	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ
268					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01
269					QS-SBO	*	REC-XHE-FO-DGHWB	+			
270	171	10	6.26E-08	0.71004	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ

271					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
272					QS-SBO	*	REC-XHE-FO-DGHWB	+				
273	173	10	6.26E-08	0.71194	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
274					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
275					QS-SBO	*	REC-XHE-FO-DGHWB	+				
276	172	10	6.26E-08	0.71384	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
277					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
278					QS-SBO	*	REC-XHE-FO-DGHWB	+				
279	2642	5	6.09E-08	0.71568	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T2	*	PPS-MOV-FC-1535	*
280					PPS-MOV-FC-1535	+						
281	2643	5	6.09E-08	0.71753	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T2	*	PPS-MOV-FC-1536	*
282					PPS-MOV-FC-1536	+						
283	123	3	5.72E-08	0.71927	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S3	*	IE-S3	+		
284	122	3	5.72E-08	0.72100	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S3	*	IE-S3	+		
285	353	9	5.62E-08	0.72270	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
286					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
287					REC-XHE-FO-DGEN	+						
288	354	9	5.62E-08	0.72441	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
289					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
290					REC-XHE-FO-DGEN	+						
291	2746	3	5.40E-08	0.72604	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T7	+		
292	755	12	5.26E-08	0.72764	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
293					NRAC-218M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
294					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
295	355	9	5.22E-08	0.72922	AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
296					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*	QS-SBO	*
297					REC-XHE-FO-DGEN	+						
298	623	10	5.16E-08	0.73079	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
299					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	QS-SBO	*
300					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+				
301	625	10	5.16E-08	0.73235	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
302					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
303					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+				
304	626	10	5.16E-08	0.73391	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
305					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1456	*	QS-SBO	*
306					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+				
307	624	10	5.16E-08	0.73548	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
308					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1456	*	QS-SBO	*
309					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+				
310	357	9	5.11E-08	0.73703	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
311					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
312					REC-XHE-FO-DGEN	+						
313	356	9	5.11E-08	0.73858	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
314					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
315					REC-XHE-FO-DGEN	+						
316	6	2	5.00E-08	0.74009	ACC-CKV-FT-CV130	*	IE-A	+				
317	4	2	5.00E-08	0.74161	ACC-CKV-FT-CV147	*	IE-A	+				
318	3	2	5.00E-08	0.74312	ACC-CKV-FT-CV128	*	IE-A	+				
319	81	2	5.00E-08	0.74464	IE-S1	*	LPR-CCF-PG-SUMP	+				
320	5	2	5.00E-08	0.74616	ACC-CKV-FT-CV145	*	IE-A	+				
321	374	9	4.95E-08	0.74766	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
322					NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
323					REC-XHE-FO-DGEN	+						
324	375	9	4.95E-08	0.74916	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
325					NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
326					REC-XHE-FO-DGEN	+						

327	758	12	4.82E-08	0.75062	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
328					NRAC-216M	* /O	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
329					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
330	759	12	4.82E-08	0.75208	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
331					NRAC-216M	* /O	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
332					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
333	756	12	4.82E-08	0.75354	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
334					NRAC-216M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
335					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
336	757	12	4.82E-08	0.75500	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
337					NRAC-216M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
338					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
339	828	10	4.80E-08	0.75646	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
340					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1456	* QS-SBO	*
341					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
342	627	10	4.80E-08	0.75791	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
343					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1455C	* QS-SBO	*
344					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
345	362	9	4.75E-08	0.75935	AFW-TDP-MA-FW2	* BETA-2DG	* IE-T1	* NOTDG-CCF	*
346					NOTQ	* NRAC-HALFHR	* OEP-DGN-FS	* QS-SBO	*
347					REC-XHE-FO-DGEN	+			*
348	2734	5	4.65E-08	0.76076	BETA-2MOV	* HPI-MOV-FT	* HPI-XHE-FO-UN2S3	* IE-T7	*
349					RCS-XHE-FO-DPT7D	+			*
350	763	12	4.62E-08	0.76216	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
351					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
352					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
353	782	12	4.62E-08	0.76357	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
354					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
355					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
356	761	12	4.62E-08	0.76497	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
357					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG3	*
358					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
359	780	12	4.62E-08	0.76637	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
360					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG2	*
361					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
362	175	10	4.62E-08	0.76777	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
363					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	*
364					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
365	376	9	4.61E-08	0.76917	AFW-TDP-FR-2P6HR	* BETA-2DG	* IE-T1	* NOTDG-CCF	*
366					NOTQ	* NRAC-6HR-AVG	* OEP-DGN-FS	* QS-SBO	*
367					REC-XHE-FO-DGEN	+			*
368	711	9	4.26E-08	0.77046	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	*
369					OEP-DGN-FS	* PPS-SOV-OO-1455C	* QS-SBO	* REC-XHE-FO-DGEN	*
370					SBO-PORV-DMD	+			*
371	712	9	4.26E-08	0.77175	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	*
372					OEP-DGN-FS	* PPS-SOV-OO-1456	* QS-SBO	* REC-XHE-FO-DGEN	*
373					SBO-PORV-DMD	+			*
374	2644	5	4.06E-08	0.77298	AFW-CCF-LK-STMBD	* AFW-XHE-FO-UNIT2	* IE-T2	* PPS-MOV-FC-1536	*
375					PPS-MOV-FT-1536	+			*
376	2645	5	4.06E-08	0.77421	AFW-CCF-LK-STMBD	* AFW-XHE-FO-UNIT2	* IE-T2	* PPS-MOV-FC-1535	*
377					PPS-MOV-FT-1535	+			*
378	82	2	4.00E-08	0.77543	IE-S1	* LPR-XHE-FO-HOTLG	+		*
379	55	2	4.00E-08	0.77664	HPI-XVM-PG-XV24	* IE-S1	+		*
380	631	10	3.81E-08	0.77779	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
381					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1456	* /QS-SBO	*
382					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*

383	636	10	3.81E-08	0.77895	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
384					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*
385					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
386	633	10	3.81E-08	0.78010	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
387					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1456	* /QS-SBO	*
388					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
389	634	10	3.81E-08	0.78125	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
390					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
391					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
392	632	10	3.81E-08	0.78241	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
393					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1456	* /QS-SBO	*
394					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
395	635	10	3.81E-08	0.78356	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
396					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
397					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
398	629	10	3.81E-08	0.78471	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
399					OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1456	* /QS-SBO	*
400					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
401	630	10	3.81E-08	0.78587	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
402					OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
403					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
404	766	11	3.75E-08	0.78700	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
405					NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* QS-SBO	*
406					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
407	767	11	3.75E-08	0.78814	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
408					NRAC-216M	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* QS-SBO	*
409					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
410	765	11	3.75E-08	0.78928	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
411					NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	* QS-SBO	*
412					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
413	764	11	3.75E-08	0.79041	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
414					NRAC-216M	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* QS-SBO	*
415					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
416	361	9	3.62E-08	0.79151	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
417					NRAC-1HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG02	* QS-SBO	*
418					REC-XHE-FO-DGEN	+			
419	358	9	3.62E-08	0.79261	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
420					NRAC-1HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01	* QS-SBO	*
421					REC-XHE-FO-DGEN	+			
422	359	9	3.62E-08	0.79371	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
423					NRAC-1HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03	* QS-SBO	*
424					REC-XHE-FO-DGEN	+			
425	360	9	3.62E-08	0.79481	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*
426					NRAC-1HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-MA-DG01	* QS-SBO	*
427					REC-XHE-FO-DGEN	+			
428	2747	3	3.60E-08	0.79590	AFW-CCF-LK-STMBD	* AFW-XHE-FO-UNIT2	* IE-T7	+	
429	124	2	3.51E-08	0.79696	IE-S3	* RWT-TNK-LF-RWST	+		
430	177	10	3.42E-08	0.79800	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
431					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-MA-DG01	*
432					QS-SBO	* REC-XHE-FO-DGHWB	+		
433	176	10	3.42E-08	0.79903	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
434					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG02	*
435					QS-SBO	* REC-XHE-FO-DGHWB	+		
436	2683	4	3.40E-08	0.80006	AFW-MDP-FS-FW3B	* AFW-TDP-FR-2P6HR	* AFW-XHE-FO-UNIT2	* IE-T5A	+
437	2708	4	3.40E-08	0.80110	AFW-MDP-FS-FW3A	* AFW-TDP-FR-2P6HR	* AFW-XHE-FO-UNIT2	* IE-T5B	+
438	365	9	3.32E-08	0.80210	AFW-XHE-FO-CST2	* /DGN-FTO	* IE-T1	* NOTQ	*

439					NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
440					REC-XHE-FO-DGEN	+						
441	363	9	3.32E-08	0.80311	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
442					NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
443					REC-XHE-FO-DGEN	+						
444	364	9	3.32E-08	0.80412	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
445					NRAC-1HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
446					REC-XHE-FO-DGEN	+						
447	894	12	3.31E-08	0.80512	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
448					NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
449					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
450	893	12	3.31E-08	0.80612	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
451					NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
452					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
453	768	11	3.30E-08	0.80712	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
454					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
455					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
456	769	11	3.30E-08	0.80812	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
457					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
458					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
459	770	11	3.15E-08	0.80908	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
460					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
461					OEP-DGN-FR-6HDG3	*	/QS-SBO	*	RCP-LOCA-750-90M	+		
462	1808	11	3.14E-08	0.81003	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
463					/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
464					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
465	179	10	3.13E-08	0.81098	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
466					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
467					QS-SBO	*	REC-XHE-FO-DGHWB	+				
468	178	10	3.13E-08	0.81193	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
469					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
470					QS-SBO	*	REC-XHE-FO-DGHWB	+				
471	180	10	3.13E-08	0.81288	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
472					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
473					QS-SBO	*	REC-XHE-FO-DGHWB	+				
474	110	3	3.10E-08	0.81382	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S2	*	IE-S2	+		
475	111	3	3.10E-08	0.81476	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S2	*	IE-S2	+		
476	895	12	3.08E-08	0.81569	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
477					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS	*
478					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
479	771	11	3.07E-08	0.81662	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
480					NOTL-SBOU1	*	NOTQ	*	NRAC-216M	*	OEP-DGN-FS	*
481					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
482	366	9	3.06E-08	0.81755	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
483					NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
484					REC-XHE-FO-DGEN	+						
485	368	9	3.06E-08	0.81848	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
486					NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
487					REC-XHE-FO-DGEN	+						
488	367	9	3.06E-08	0.81941	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
489					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
490					REC-XHE-FO-DGEN	+						
491	181	10	2.85E-08	0.82027	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
492					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*
493					QS-SBO	*	REC-XHE-FO-DGTMB	+				
494	184	9	2.85E-08	0.82114	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

495					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1	*
496					QS-SBO	+						
497	183	9	2.85E-08	0.82200	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
498					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3	*
499					QS-SBO	+						
500	182	10	2.85E-08	0.82286	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
501					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
502					QS-SBO	+	REC-XHE-FO-DGTMB	+				
503	372	9	2.79E-08	0.82371	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
504					NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
505					REC-XHE-FO-DGEN	+						
506	371	9	2.79E-08	0.82455	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
507					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
508					REC-XHE-FO-DGEN	+						
509	370	9	2.79E-08	0.82540	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
510					NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
511					REC-XHE-FO-DGEN	+						
512	369	9	2.79E-08	0.82624	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
513					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
514					REC-XHE-FO-DGEN	+						
515	83	3	2.70E-08	0.82706	IE-S1	*	LPR-MOV-FT-1862A	*	LPR-MOV-FT-1862B	+		
516	392	9	2.70E-08	0.82788	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
517					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
518					REC-XHE-FO-DGEN	+						
519	391	9	2.70E-08	0.82870	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
520					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
521					REC-XHE-FO-DGEN	+						
522	390	9	2.70E-08	0.82952	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
523					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
524					REC-XHE-FO-DGEN	+						
525	389	9	2.70E-08	0.83034	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
526					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
527					REC-XHE-FO-DGEN	+						
528	2709	3	2.70E-08	0.83116	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+		
529	2684	3	2.70E-08	0.83198	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+		
530	2620	5	2.64E-08	0.83278	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*
531					IE-T2	+						
532	773	12	2.63E-08	0.83357	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
533					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
534					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
535	772	12	2.63E-08	0.83437	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
536					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
537					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
538	2755	8	2.61E-08	0.83516	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-OO-1536	*
539					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
540	2754	8	2.61E-08	0.83595	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-OO-1535	*
541					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
542	774	10	2.55E-08	0.83673	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
543					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	*
544					RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOL	+				
545	2621	6	2.54E-08	0.83750	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
546					HPI-XHE-FO-FDBLD	*	IE-T2	+				
547	775	12	2.52E-08	0.83826	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
548					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
549					OEP-DGN-FR-6HDG2	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
550	26	2	2.50E-08	0.83902	IE-A	*	LPR-CCF-PG-SUMP	+				

551	186	12	2.45E-08	0.83976	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
552					NRAC-7HR	* NSLOCA	* /O	* OEP-DGN-FS-DG01	*
553					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	* REC-XHE-FO-SCOOL	+
554	185	12	2.45E-08	0.84050	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
555					NRAC-7HR	* NSLOCA	* /O	* OEP-DGN-FS-DG01	*
556					OEP-DGN-FS-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	* REC-XHE-FO-SCOOL	+
557	776	12	2.41E-08	0.84123	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
558					NRAC-216M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	*
559					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
560	778	12	2.41E-08	0.84196	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
561					NRAC-216M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	*
562					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
563	777	12	2.41E-08	0.84269	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
564					NRAC-216M	* /O	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	*
565					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
566	56	3	2.37E-08	0.84341	BETA-STR	* CPC-STR-PG-3HR	* IE-S1	+	*
567	780	12	2.31E-08	0.84411	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
568					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS-DG01	*
569					OEP-DGN-MA-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
570	782	12	2.31E-08	0.84481	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
571					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS-DG02	*
572					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
573	781	12	2.31E-08	0.84552	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
574					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS-DG03	*
575					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
576	779	12	2.31E-08	0.84622	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
577					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS-DG01	*
578					OEP-DGN-MA-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
579	187	10	2.31E-08	0.84692	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
580					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-MA-DG02	*
581					/QS-SBO	* REC-XHE-FO-DGHWB	+	*	*
582	784	12	2.30E-08	0.84761	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
583					NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03	*
584					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOOL	+
585	783	12	2.30E-08	0.84831	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
586					NRAC-216M	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01	*
587					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOOL	+
588	125	3	2.29E-08	0.84900	HPI-XHE-FO-UN2S3	* HPI-XVM-PG-XV24	* IE-S3	+	*
589	188	12	2.27E-08	0.84969	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
590					NOTQ	* NRAC-7HR	* NSLOCA	* /O	*
591					OEP-DGN-FS	* /QS-SBO	* REC-XHE-FO-DGHWB	* REC-XHE-FO-SCOOL	+
592	2756	8	2.22E-08	0.85037	IE-T7	* MSS-SRV-OO-ODSRV	* PORV-NOT-BLK	* PPS-MOV-OO-1535	*
593					PPS-SOV-OO-1456	* RCS-PORV-ODMD	* RCS-XHE-FO-DPRT7	* SGTR-SGSRV-ODMD2	+
594	2757	8	2.22E-08	0.85104	IE-T7	* MSS-SRV-OO-ODSRV	* PORV-NOT-BLK	* PPS-MOV-OO-1536	*
595					PPS-SOV-OO-1455C	* RCS-PORV-ODMD	* RCS-XHE-FO-DPRT7	* SGTR-SGSRV-ODMD2	+
596	2578	7	2.13E-08	0.85169	BETA-2MOV	* IE-T	* K	* PPS-MOV-FC-1535	*
597					PPS-MOV-FC-1536	* PPS-MOV-FT	* R	+	*
598	302	9	2.09E-08	0.85232	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
599					NSLOCA	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* QS-SBO	*
600					REC-XHE-FO-DGHWB	+			
601	126	3	2.08E-08	0.85295	HPI-CKV-OO-CV258	* HPI-MDP-FR-1A24H	* IE-S3	+	*
602	785	11	2.04E-08	0.85357	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
603					NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	* QS-SBO	*
604					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	*
605	27	2	2.00E-08	0.85418	IE-A	* LPR-XHE-FO-HOTLG	+		
606	191	9	1.92E-08	0.85476	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*

607					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-CRB-FT-15J3	*
608					/QS-SBO	+						
609	190	10	1.92E-08	0.85534	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
610					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*
611					/QS-SBO	*	REC-XHE-FO-DGTMB	+				
612	189	10	1.92E-08	0.85593	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
613					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*
614					/QS-SBO	*	REC-XHE-FO-DGTMB	+				
615	638	10	1.90E-08	0.85650	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
616					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
617					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
618	641	10	1.90E-08	0.85708	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
619					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
620					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
621	640	10	1.90E-08	0.85766	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
622					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
623					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
624	637	10	1.90E-08	0.85823	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
625					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*
626					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
627	642	10	1.90E-08	0.85881	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
628					OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
629					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
630	638	10	1.90E-08	0.85939	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
631					OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
632					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
633	788	11	1.87E-08	0.85996	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
634					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
635					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
636	786	11	1.87E-08	0.86052	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
637					NRAC-216M	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
638					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
639	787	11	1.87E-08	0.86109	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
640					NRAC-216M	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
641					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
642	789	11	1.87E-08	0.86166	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
643					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
644					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
645	377	8	1.86E-08	0.86222	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
646					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
647	2590	4	1.83E-08	0.86278	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	PPS-XHE-FO-PORVS	+
648	373	9	1.81E-08	0.86333	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
649					NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
650					REC-XHE-FO-DGEN	+						
651	896	12	1.81E-08	0.86388	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
652					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
653					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
654	898	12	1.81E-08	0.86442	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
655					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
656					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
657	897	12	1.81E-08	0.86497	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
658					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
659					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
660	898	12	1.81E-08	0.86552	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
661					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
662					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+

663	2710	3	1.80E-08	0.86606	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
664	2685	3	1.80E-08	0.86661	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
665	793	11	1.80E-08	0.86718	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	+
666					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	+
667					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
668	791	11	1.80E-08	0.86770	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	+
669					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG3	+
670					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
671	790	11	1.80E-08	0.86825	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	+
672					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG2	+
673					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
674	792	11	1.80E-08	0.86879	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	+
675					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	+
676					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
677	2736	4	1.76E-08	0.86933	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S3	*	IE-T7	+
678	2735	4	1.76E-08	0.86986	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S3	*	IE-T7	+
679	2646	7	1.72E-08	0.87038	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	+
680					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+
681	2647	7	1.72E-08	0.87090	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	+
682					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+
683	1809	11	1.71E-08	0.87142	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	+
684					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	+
685					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
686	1810	11	1.71E-08	0.87194	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	+
687					/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	+
688					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
689	1811	11	1.71E-08	0.87246	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	+
690					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	+
691					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
692	192	10	1.71E-08	0.87298	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	+
693					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	+
694					QS-SBO	*	REC-XHE-FO-DGHWB	+	IE-T1	+
695	378	8	1.69E-08	0.87349	AFW-TDP-MA-FW2	*	/DGN-FTO	*	OEP-DGN-FR-6HDG3	+
696					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	IE-T1	+
697	379	9	1.67E-08	0.87399	AFW-TDP-FS-FW2	*	/DGN-FTO	*	OEP-DGN-FR-6HDG2	+
698					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	NOTQ	+
699					REC-XHE-FO-DGEN	+	IE-T1	*	NOTL-SBOU1	+
700	794	11	1.64E-08	0.87449	/DGN-FTO	*	NRAC-216M	*	OEP-CRB-FT-15J3	+
701					NRAC-216M	*	/O	*	REC-XHE-FO-SCOOL	+
702					/QS-SBO	*	RCP-LOCA-750-90M	*	NOTL-SBOU1	+
703	795	11	1.64E-08	0.87499	/DGN-FTO	*	IE-T1	*	OEP-CRB-FT-15H3	+
704					NRAC-216M	*	/O	*	REC-XHE-FO-SCOOL	+
705					/QS-SBO	*	RCP-LOCA-750-90M	*	AFW-XHE-FO-UNIT2	+
706	2648	5	1.64E-08	0.87549	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	IE-T2	+
707					PPS-XHE-FO-PORVS	+	/DGN-FTO	*	IE-T1	+
708	404	8	1.64E-08	0.87598	AFW-TDP-FR-2P6HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	+
709					NRAC-6HR-AVG	*	IE-T1	*	MCW-CCF-VF-SBO	+
710	901	12	1.59E-08	0.87647	/DGN-FTO	*	NRAC-258M	*	OEP-DGN-FS-DG01	+
711					NOTQ	*	/QS-SBO	*	RCP-LOCA-467-150	+
712					OEP-DGN-FS-DG02	*	IE-T1	*	MCW-CCF-VF-SBO	+
713	900	12	1.59E-08	0.87695	/DGN-FTO	*	NRAC-258M	*	/O	+
714					NOTQ	*	OEP-DGN-FS-DG03	*	RCP-LOCA-467-150	+
715					OEP-DGN-FS-DG03	*	IE-S1	*	LPR-MOV-FT-1862B	+
716	84	3	1.56E-08	0.87742	IE-S1	*	LPI-MDP-FS-SI1B	*	LPR-MOV-FT-1862A	+
717	85	3	1.56E-08	0.87789	IE-S1	*	LPI-MDP-FS-SI1A	*	LPR-MOV-FT-1862B	+
718	86	3	1.56E-08	0.87837	IE-S1	*		*		+

719	87	3	1.56E-08	0.87884	IE-S1	*	LPR-MOV-FT-1860B	*	LPR-MOV-FT-1862A	+	NOTL-SBOU1U2	*
720	1814	12	1.54E-08	0.87931	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	OEP-DGN-FR-6HDG1	*
721					NOTQ	*	NRAC-216M	*	/O	*	REC-XHE-FO-DGHWS	+
722					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	NOTL-SBOU1U2	*
723	1813	12	1.54E-08	0.87977	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	OEP-DGN-FR-6HDG2	*
724					NOTQ	*	NRAC-216M	*	/O	*	REC-XHE-FO-DGHWS	+
725					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	NOTL-SBOU1U2	*
726	1812	12	1.54E-08	0.88024	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	OEP-DGN-FR-6HDG3	*
727					NOTQ	*	NRAC-216M	*	/O	*	REC-XHE-FO-DGHWS	+
728					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	NOTQ	*
729	382	9	1.53E-08	0.88070	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	QS-SBO	*
730					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*		*
731					REC-XHE-FO-DGEN	+		*	IE-T1	*	NOTQ	*
732	381	9	1.53E-08	0.88117	AFW-TDP-FS-FW2	*	/DGN-FTO	*	OEP-DGN-MA-DG01	*	QS-SBO	*
733					NRAC-HALFHR	*	OEP-DGN-FS-DG02	*	IE-T1	*	NOTQ	*
734					REC-XHE-FO-DGEN	+		*	OEP-DGN-MA-DG02	*	QS-SBO	*
735	380	9	1.53E-08	0.88163	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
736					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
737					REC-XHE-FO-DGEN	+		*	IE-T1	*	NOTQ	*
738	383	9	1.53E-08	0.88210	AFW-TDP-FS-FW2	*	/DGN-FTO	*	OEP-DGN-MA-DG03	*	QS-SBO	*
739					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	IE-T1	*	NOTQ	*
740					REC-XHE-FO-DGEN	+		*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
741	384	9	1.52E-08	0.88256	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
742					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
743					REC-XHE-FO-DGEN	+		*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*
744	2622	5	1.51E-08	0.88302	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*
745					IE-T2	+		*	AFW-XHE-FO-UNIT2	*		*
746	2623	5	1.51E-08	0.88347	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
747					IE-T2	+		*	NRAC-258M	*	/O	*
748	902	12	1.48E-08	0.88392	BETA-2DG	*	IE-T1	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
749					NOTL-SBOU1	*	NOTQ	*	IE-T1	*	NOTQ	*
750					OEP-DGN-FS	*	/QS-SBO	*	OEP-DGN-FR-6HDG1	*	QS-SBO	*
751	409	9	1.47E-08	0.88437	AFW-TDP-FR-2P8HR	*	/DGN-FTO	*		*		*
752					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*
753					REC-XHE-FO-DGEN	+		*	IE-T7	*		*
754	2770	6	1.47E-08	0.88481	IAS-CCF-LF-INAIR	*	IE-T7	*	SGTR-SGADV-ODMD	+		*
755					PORV-NOT-BLK	*		*	IE-T1	*	NOTL-SBOU1U2	*
756	2245	10	1.44E-08	0.88525	BETA-3DG	*	IE-T1	*		*	NOTQ	*
757					NRAC-150M	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
758					RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	+		*		*
759	646	10	1.41E-08	0.88568	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
760					OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*	QS-SBO	*
761					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+		*		*
762	647	10	1.41E-08	0.88610	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
763					OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	QS-SBO	*
764					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+		*		*
765	645	10	1.41E-08	0.88653	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
766					OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	QS-SBO	*
767					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+		*		*
768	648	10	1.41E-08	0.88696	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
769					OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	QS-SBO	*
770					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+		*		*
771	650	10	1.41E-08	0.88738	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
772					OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*	QS-SBO	*
773					REC-XHE-FO-DGEN	+	SBO-PORV-DMD	+		*		*
774	649	10	1.41E-08	0.88781	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*

775					OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
776					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
777	643	10	1.41E-08	0.88824	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
778					OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	QS-SBO	*
779					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
780	644	10	1.41E-08	0.88866	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
781					OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	QS-SBO	*
782					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
783	388	9	1.39E-08	0.88909	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
784					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
785					REC-XHE-FO-DGEN	+						
786	386	9	1.39E-08	0.88951	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
787					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
788					REC-XHE-FO-DGEN	+						
789	385	9	1.39E-08	0.88993	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
790					NRAC-HALFHR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
791					REC-XHE-FO-DGEN	+						
792	387	9	1.38E-08	0.89035	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
793					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
794					REC-XHE-FO-DGEN	+						
795	28	3	1.35E-08	0.89076	IE-A	*	LPR-MOV-FT-1862A	*	LPR-MOV-FT-1862B	+		*
796	418	9	1.35E-08	0.89117	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
797					NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
798					REC-XHE-FO-DGEN	+						
799	417	9	1.35E-08	0.89158	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
800					NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
801					REC-XHE-FO-DGEN	+						
802	419	9	1.35E-08	0.89199	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
803					NRAC-6HR-AVG	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
804					REC-XHE-FO-DGEN	+						
805	420	9	1.35E-08	0.89240	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
806					NRAC-6HR-AVG	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
807					REC-XHE-FO-DGEN	+						
808	195	12	1.33E-08	0.89281	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
809					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG3	*
810					OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
811	193	12	1.33E-08	0.89321	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
812					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG1	*
813					OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
814	196	12	1.33E-08	0.89362	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
815					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG1	*
816					OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
817	194	12	1.33E-08	0.89402	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
818					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG2	*
819					OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
820	798	12	1.31E-08	0.89442	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
821					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*
822					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
823	903	11	1.29E-08	0.89481	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
824					NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
825					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		*
826	904	11	1.29E-08	0.89520	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
827					NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
828					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		*
829	2135	10	1.28E-08	0.89559	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
830					NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*

831					RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	+				
832	2025	10	1.28E-08	0.89598	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
833					NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
834					RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	+				
835	658	10	1.27E-08	0.89636	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
836					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
837					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
838	654	10	1.27E-08	0.89675	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
839					OEP-DGN-FR-DG03	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
840					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
841	657	10	1.27E-08	0.89713	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
842					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
843					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
844	656	10	1.27E-08	0.89752	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
845					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*
846					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
847	651	10	1.27E-08	0.89790	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
848					OEP-DGN-FR-DG02	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
849					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
850	655	10	1.27E-08	0.89829	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
851					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
852					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
853	652	10	1.27E-08	0.89867	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
854					OEP-DGN-FR-DG02	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
855					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
856	653	10	1.27E-08	0.89905	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
857					OEP-DGN-FR-DG03	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
858					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
859	797	12	1.26E-08	0.89944	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
860					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
861					OEP-DGN-MA-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
862	798	12	1.26E-08	0.89982	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
863					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG2	*
864					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
865	2686	4	1.25E-08	0.90020	AFW-MDP-FS-FW3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
866	2711	4	1.25E-08	0.90058	AFW-MDP-FS-FW3A	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
867	393	10	1.25E-08	0.90095	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
868					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
869					/QS-SBO	*	REC-XHE-FO-DGEN	+				
870	394	10	1.25E-08	0.90133	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
871					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
872					/QS-SBO	*	REC-XHE-FO-DGEN	+				
873	112	3	1.24E-08	0.90171	HPI-XHE-FO-UN2S2	*	HPI-XVM-PG-XV24	*	IE-S2	+		*
874	905	11	1.23E-08	0.90208	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
875					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*
876					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-SCOOL	+		*
877	799	10	1.23E-08	0.90245	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
878					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*
879					QS-SBO	*	RCP-LOCA-750-90M	+				
880	1815	10	1.22E-08	0.90282	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
881					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	QS-SBO	*
882					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
883	2591	4	1.22E-08	0.90319	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	PPS-XHE-FO-PORVS	+
884	2767	6	1.22E-08	0.90356	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*
885					REC-XHE-FO-GAGRV	*	SGTR-SGSRV-ODMD1	+				
886	197	11	1.21E-08	0.90393	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

887				NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG1	*
888				OEP-DGN-FR-6HDG3	*	/QS-SBO	*	REC-XHE-FO-SCOO	+	NOTQ	*
889	1917	10	1.20E-08	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	/QS-SBO	*
890				NRAC-246M	*	O	*	OEP-DGN-FS	*		*
891				RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+				
892	906	11	1.20E-08	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
893				NOTQ	*	NRAC-258M	*	OEP-DGN-FS	*	QS-SBO	*
894				RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+	REC-XHE-FO-SCOO	+		
895	198	12	1.17E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
896				NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
897				OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
898	199	12	1.17E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
899				NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
900				OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
901	396	10	1.16E-08	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	BETA-2DG	*	IE-T1	*
902				NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
903				/QS-SBO	*	REC-XHE-FO-DGEN	+				
904	801		1.16E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
905				NOTQ	*	NRAC-216M	*	/O	*	OEP-CRB-FT-15J3	*
906				OEP-DGN-FS-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
907	800	12	1.16E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
908				NOTQ	*	NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*
909				OEP-DGN-FS-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
910	802	12	1.16E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
911				NOTQ	*	NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*
912				OEP-DGN-FS-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
913	2712	4	1.13E-08	AFW-MDP-FS-FW3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
914	2687	4	1.13E-08	AFW-MDP-FS-FW3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
915	397	10	1.13E-08	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
916				NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
917				/QS-SBO	*	REC-XHE-FO-DGEN	+				
918	398	10	1.13E-08	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
919				NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
920				/QS-SBO	*	REC-XHE-FO-DGEN	+				
921	2355	10	1.12E-08	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
922				NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
923				RCP-LOCA-183-90	*	REC-XHE-FO-DGHWS	+				
924	803	12	1.10E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
925				NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
926				OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+
927	804	12	1.10E-08	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
928				NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG3	*
929				OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+
930	425	10	1.10E-08	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
931				NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
932				/QS-SBO	*	REC-XHE-FO-DGEN	+				
933	426	10	1.10E-08	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
934				NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
935				/QS-SBO	*	REC-XHE-FO-DGEN	+				
936	200	12	1.09E-08	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
937				NOTL-SBOU1	*	NOTQ	*	NRAC-7HR	*	NSLOCA	*
938				/O	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
939	2737	3	1.08E-08	IE-T7	*	RCS-XHE-FO-DPT7D	*	RWT-TNK-LF-RWST	+		
940	2713	4	1.08E-08	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
941	2688	4	1.08E-08	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
	399	10	1.05E-08	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	BETA-2DG	*	IE-T1	*

943					NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
944					/QS-SBO	*	REC-XHE-FO-DGEN	+				
945	89	3	1.04E-08	0.91177	IE-S1	*	LPI-MDP-MA-SI1A	*	LPR-MOV-FT-1862B	+		
946	88	3	1.04E-08	0.91208	IE-S1	*	LPI-MDP-MA-SI1B	*	LPR-MOV-FT-1862A	+		
947	2768	6	1.03E-08	0.91239	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*
948					REC-XHE-FO-GAGRV	*	SGTR-SGSRV-ODMD2	+				
949	2738	4	1.02E-08	0.91270	IE-T7	*	RCS-XHE-FO-DPT7D	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+
950	806	11	1.02E-08	0.91301	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
951					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
952					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		
953	805	11	1.02E-08	0.91332	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
954					NRAC-216M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
955					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		
956	430	10	1.02E-08	0.91363	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	BETA-2DG	*	IE-T1	*
957					NOTDG-CCF	*	NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*
958					/QS-SBO	*	REC-XHE-FO-DGEN	+				
959	808	12	9.89E-09	0.91393	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
960					NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
961					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
962	809	12	9.89E-09	0.91423	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
963					NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
964					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
965	907	12	9.86E-09	0.91453	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
966					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
967					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
968	807	11	9.81E-09	0.91483	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
969					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
970					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
971	202	11	9.51E-09	0.91512	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
972					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
973					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOO1	+		
974	201	11	9.51E-09	0.91541	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
975					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
976					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOO1	+		
977	2759	9	9.47E-09	0.91569	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
978					PPS-MOV-OO-1536	*	PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*
979					SGTR-SGADV-ODMD	+						
980	2758	9	9.47E-09	0.91598	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
981					PPS-MOV-OO-1535	*	PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*
982					SGTR-SGADV-ODMD	+						
983	811	11	9.37E-09	0.91626	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
984					NRAC-216M	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
985					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		
986	810	11	9.37E-09	0.91655	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
987					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
988					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		
989	812	11	9.37E-09	0.91683	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
990					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
991					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		
992	1818	11	9.33E-09	0.91712	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
993					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
994					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
995	1816	11	9.33E-09	0.91740	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
996					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*
997					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
998	1817	11	9.33E-09	0.91768	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*

999					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*
1000					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1001	2624	6	9.32E-09	0.91798	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
1002					HPI-XHE-FO-FD8LD	*	IE-T2	+				
1003	813	12	9.20E-09	0.91824	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
1004					NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FS	*
1005					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
1006	395	9	9.05E-09	0.91852	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
1007					NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	QS-SBO	*
1008					REC-XHE-FO-DGEN	+						
1009	911	12	9.03E-09	0.91879	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1010					NRAC-258M	*	/O	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
1011					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
1012	909	12	9.03E-09	0.91907	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1013					NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
1014					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
1015	908	12	9.03E-09	0.91934	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1016					NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
1017					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
1018	910	12	9.03E-09	0.91961	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1019					NRAC-258M	*	/O	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*
1020					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
1021	90	3	9.00E-09	0.91989	IE-S1	*	LPI-MDP-FS-SI1B	*	LPR-MOV-FT-1860A	+		
1022	57	3	9.00E-09	0.92016	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	IE-S1	+		
1023	92	3	9.00E-09	0.92043	IE-S1	*	LPR-MOV-FT-1890A	*	LPR-MOV-FT-1890B	+		
1024	91	3	9.00E-09	0.92070	IE-S1	*	LPI-MDP-FS-SI1A	*	LPR-MOV-FT-1860B	+		
1025	93	3	9.00E-09	0.92098	IE-S1	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1860B	+		
1026	66	3	9.00E-09	0.92125	IE-S1	*	LPI-MDP-FS-SI1A	*	LPI-MDP-FS-SI1B	+		
1027	58	3	9.00E-09	0.92152	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	IE-S1	+		
1028	817	11	8.99E-09	0.92180	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1029					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
1030					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1031	815	11	8.99E-09	0.92207	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1032					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
1033					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1034	816	11	8.99E-09	0.92234	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1035					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
1036					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1037	814	11	8.99E-09	0.92261	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1038					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*
1039					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1040	818	11	8.94E-09	0.92289	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1041					NRAC-216M	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1042					RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOO1	+		
1043	819	11	8.94E-09	0.92316	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1044					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	QS-SBO	*
1045					RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOO1	+		
1046	203	11	8.84E-09	0.92342	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
1047					NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS	*
1048					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOO1	+		
1049	912	12	8.67E-09	0.92369	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1050					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG2	*
1051					OEP-DGN-FS-DG01	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1052	915	12	8.67E-09	0.92395	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1053					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*
					OEP-DGN-FS-DG01	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+

1055	914	12	8.67E-09	0.92421	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
1056					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FR-6HDG1	*
1057					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
1058	913	12	8.67E-09	0.92448	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
1059					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FR-6HDG3	*
1060					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
1061	1821	11	8.56E-09	0.92474	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1062					/O	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
1063					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
1064	1820	11	8.56E-09	0.92499	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1065					/O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG02	*
1066					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
1067	1819	11	8.56E-09	0.92525	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1068					/O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG03	*
1069					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
1070	204	10	8.54E-09	0.92551	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1071					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-MA-DG02	*
1072					QS-SBO	* REC-XHE-FO-DGHWB	+		
1073	2625	6	8.48E-09	0.92577	AFW-MDP-FS	* AFW-TDP-MA-FW2	* AFW-XHE-FO-UNIT2	* BETA-AFW	*
1074					HPI-XHE-FO-FDBLD	* IE-T2	+		
1075	403	9	8.36E-09	0.92602	AFW-TDP-FS-FW2	* /DGN-FTO	* IE-T1	* NOTQ	*
1076					NRAC-HALFHR	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01	* QS-SBO	*
1077					REC-XHE-FO-DGEN	+			
1078	400	9	8.36E-09	0.92628	AFW-TDP-FS-FW2	* /DGN-FTO	* IE-T1	* NOTQ	*
1079					NRAC-HALFHR	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03	* QS-SBO	*
1080					REC-XHE-FO-DGEN	+			
1081	402	9	8.36E-09	0.92653	AFW-TDP-FS-FW2	* /DGN-FTO	* IE-T1	* NOTQ	*
1082					NRAC-HALFHR	* OEP-DGN-FR-6HDG2	* OEP-DGN-MA-DG01	* QS-SBO	*
1083					REC-XHE-FO-DGEN	+			
1084	401	9	8.36E-09	0.92678	AFW-TDP-FS-FW2	* /DGN-FTO	* IE-T1	* NOTQ	*
1085					NRAC-HALFHR	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG02	* QS-SBO	*
1086					REC-XHE-FO-DGEN	+			
1087	303	10	8.32E-09	0.92704	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
1088					NRAC-7HR	* NSLOCA	* O	* OEP-DGN-FS	*
1089					/QS-SBO	* REC-XHE-FO-DGHWB	+		
1090	2789	4	8.12E-09	0.92728	IE-T7	* MSS-CKV-FT-SGDHR	* MSS-XHE-FO-1SDHR	* RCS-XHE-FO-DPRT7	+
1091	821	11	7.88E-09	0.92752	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
1092					NOTQ	* NRAC-216M	* /O	* OEP-CRB-FT-15J3	*
1093					OEP-DGN-FR-6HDG1	* /QS-SBO	* RCP-LOCA-750-90M	+	
1094	820	11	7.88E-09	0.92776	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
1095					NOTQ	* NRAC-216M	* /O	* OEP-CRB-FT-15H3	*
1096					OEP-DGN-FR-6HDG3	* /QS-SBO	* RCP-LOCA-750-90M	+	
1097	558	9	7.84E-09	0.92800	AFW-XHE-FO-CST2	* BETA-2DG	* BETA-3DG	* IE-T1	*
1098					NOTQ	* NRAC-1HR	* OEP-DGN-FS	* QS-SBO	*
1099					REC-XHE-FO-DGEN	+			
1100	30	3	7.80E-09	0.92823	IE-A	* LPI-MDP-FS-S11B	* LPR-MOV-FT-1862A	+	
1101	32	3	7.80E-09	0.92847	IE-A	* LPR-MOV-FT-1860B	* LPR-MOV-FT-1862A	+	
1102	29	3	7.80E-09	0.92871	IE-A	* LPR-MOV-FT-1860A	* LPR-MOV-FT-1862B	+	
1103	31	3	7.80E-09	0.92894	IE-A	* LPI-MDP-FS-S11A	* LPR-MOV-FT-1862B	+	
1104	1823	12	7.68E-09	0.92918	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
1105					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS	*
1106					OEP-DGN-MA-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
1107	1824	12	7.68E-09	0.92941	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
1108					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS	*
1109					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
1110	1822	12	7.68E-09	0.92964	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*

1111				NOTQ	*	NRAC-218M	*	/O	*	OEP-DGN-FS	*
1112				OEP-DGN-MA-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
1113	408	9	7.60E-09	0.92987		/DGN-FTO	*	IE-T1	*	NOTQ	*
1114				NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	QS-SBO	*
1115				REC-XHE-FO-DGEN	+						
1116	407	9	7.60E-09	0.93010		/DGN-FTO	*	IE-T1	*	NOTQ	*
1117				NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1118				REC-XHE-FO-DGEN	+						
1119	406	9	7.60E-09	0.93033		/DGN-FTO	*	IE-T1	*	NOTQ	*
1120				NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
1121				REC-XHE-FO-DGEN	+						
1122	405	9	7.60E-09	0.93056		/DGN-FTO	*	IE-T1	*	NOTQ	*
1123				NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1124				REC-XHE-FO-DGEN	+						
1125	127	5	7.58E-09	0.93079		CPC-STR-PG-24H	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S3	*
1126				IE-S3	+						
1127	128	3	7.41E-09	0.93102		HPI-XHE-FO-ALTIN	*	IE-S3	+	NOTQ	*
1128	437	9	7.37E-09	0.93124		/DGN-FTO	*	IE-T1	*	QS-SBO	*
1129				NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*		
1130				REC-XHE-FO-DGEN	+						
1131	436	9	7.37E-09	0.93147		/DGN-FTO	*	IE-T1	*	NOTQ	*
1132				NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1133				REC-XHE-FO-DGEN	+						
1134	439	9	7.37E-09	0.93169		/DGN-FTO	*	IE-T1	*	NOTQ	*
1135				NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
1136				REC-XHE-FO-DGEN	+						
1137	438	9	7.37E-09	0.93191		/DGN-FTO	*	IE-T1	*	NOTQ	*
1138				NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1139				REC-XHE-FO-DGEN	+						
1140	2465	10	7.34E-09	0.93214		IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
1141				BETA-3DG	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
1142				NRAC-246M	*						
1143	205	12	7.28E-09	0.93236		REC-XHE-FO-DGHWS	+	NOTL-SBOU1	*	NOTQ	*
1144				/DGN-FTO	*	IE-T1	*	/O	*	OEP-DGN-FR-6HDG1	*
1145				NRAC-7HR	*	NSLOCA	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
1146	208	9	7.12E-09	0.93257		/QS-SBO	*	NOTL-SBOU1	*	NOTQ	*
1147				OEP-DGN-FR-6HDG2	*	IE-T1	*	OEP-CRB-FT-15H3	*	OEP-CRB-FT-15J3	*
1148				/DGN-FTO	*	NRAC-7HR	*	NOTL-SBOU1	*	NOTQ	*
1149	206	10	7.12E-09	0.93279		QS-SBO	+	OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*
1150				NOTW2	*	REC-XHE-FO-DGTMB	+	NOTL-SBOU1	*	NOTQ	*
1151				QS-SBO	*	IE-T1	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*
1152	207	10	7.12E-09	0.93300		NRAC-7HR	*	NOTL-SBOU1	*	NOTQ	*
1153				/DGN-FTO	*	REC-XHE-FO-DGTMB	+	PPS-SOV-OO-1455C	*	QS-SBO	*
1154				NOTW2	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1155	2739	4	7.04E-09	0.93322		NRAC-7HR	*	PPS-SOV-OO-1455C	*	QS-SBO	*
1156	661	10	7.04E-09	0.93343		REC-XHE-FO-DGTMB	+	NOTL-SBOU1	*	NRAC-1HR	*
1157				HPI-XHE-FO-UN2S3	*	HPI-XVM-PG-XV24	*	PPS-SOV-OO-1455C	*	QS-SBO	*
1158				/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1159	662	10	7.04E-09	0.93364		OEP-CRB-FT-15H3	*	PPS-SOV-OO-1455C	*	QS-SBO	*
1160				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+	NOTL-SBOU1	*	NRAC-1HR	*
1161				/DGN-FTO	*	IE-T1	*	PPS-SOV-OO-1455C	*	QS-SBO	*
1162	659	10	7.04E-09	0.93386		OEP-DGN-FS-DG01	*	NOTL-SBOU1	*	NRAC-1HR	*
1163				OEP-CRB-FT-15J3	*	SBO-PORV-DMD	+	PPS-SOV-OO-1456	*	QS-SBO	*
1164				REC-XHE-FO-DGEN	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1165	660	10	7.04E-09	0.93407		OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
1166				/DGN-FTO	*	SBO-PORV-DMD	+				
				OEP-CRB-FT-15H3	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
					*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*

1167					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1168	663	10	7.04E-09	0.93428	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1169					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1456	*	QS-SBO	*
1170					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1171	664	10	7.04E-09	0.93450	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1172					OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1456	*	QS-SBO	*
1173					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1174	916	11	7.03E-09	0.93471	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1175					NRAC-258M	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
1176					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
1177	917	11	7.03E-09	0.93492	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1178					NRAC-258M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
1179					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
1180	919	11	7.03E-09	0.93514	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1181					NRAC-258M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
1182					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
1183	918	11	7.03E-09	0.93535	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1184					NRAC-258M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
1185					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
1186	411	9	6.97E-09	0.93556	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
1187					NRAC-HALFHR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
1188					REC-XHE-FO-DGEN	+						
1189	410	9	6.97E-09	0.93577	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NCTQ	*
1190					NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
1191					REC-XHE-FO-DGEN	+						
1192	412	9	6.97E-09	0.93598	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
1193					NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
1194					REC-XHE-FO-DGEN	+						
1195	416	10	6.79E-09	0.93619	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1196					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1197					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1198	414	10	6.79E-09	0.93639	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1199					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
1200					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1201	415	10	6.79E-09	0.93660	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1202					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1203					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1204	413	10	6.79E-09	0.93681	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1205					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1206					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1207	447	9	6.76E-09	0.93701	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
1208					NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
1209					REC-XHE-FO-DGEN	+						
1210	445	9	6.76E-09	0.93722	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
1211					NRAC-6HR-AVG	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
1212					REC-XHE-FO-DGEN	+						
1213	446	9	6.76E-09	0.93742	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
1214					NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
1215					REC-XHE-FO-DGEN	+						
1216	210	12	6.67E-09	0.93762	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1217					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FS-DG01	*
1218					OEP-DGN-MA-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
1219	211	12	6.67E-09	0.93783	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1220					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FS-DG01	*
1221					OEP-DGN-MA-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
1222	209	12	6.67E-09	0.93803	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

1223					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FS-DG02	*
1224					OEP-DGN-MA-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
1225	212	12	6.67E-09	0.93823	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1226					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FS-DG03	*
1227					OEP-DGN-MA-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
1228	1826	10	6.65E-09	0.93843	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1229					OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	QS-SBO	*
1230					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1231	1825	10	6.65E-09	0.93863	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1232					OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
1233					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1234	1827	10	6.65E-09	0.93884	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1235					OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
1236					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1237	822	12	6.57E-09	0.93903	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1238					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*
1239					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
1240	215	12	6.40E-09	0.93923	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1241					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
1242					OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
1243	216	12	6.40E-09	0.93942	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1244					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
1245					OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
1246	214	12	6.40E-09	0.93962	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1247					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
1248					OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
1249	213	12	6.40E-09	0.93981	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1250					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
1251					OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
1252	823	10	6.39E-09	0.94000	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1253					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3	*	QS-SBO	*
1254					RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOL	+				
1255	824	10	6.39E-09	0.94020	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1256					NRAC-216M	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1	*	QS-SBO	*
1257					RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOL	+				
1258	1828	10	6.36E-09	0.94039	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1259					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*
1260					/QS-SBO	*	RCP-LOCA-750-90M	+				
1261	825	12	6.31E-09	0.94058	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1262					NOTQ	*	NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*
1263					OEP-DGN-FR-6HDG2	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
1264	921	11	6.18E-09	0.94077	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1265					NOTQ	*	NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
1266					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1267	920	11	6.18E-09	0.94096	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1268					NOTQ	*	NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
1269					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1270	421	10	6.18E-09	0.94114	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1271					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1272					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1273	423	10	6.18E-09	0.94133	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1274					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
1275					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1276	424	10	6.18E-09	0.94152	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1277					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1278					/QS-SBO	*	REC-XHE-FO-DGEN	+				

1279	422	10	6.18E-09	0.94171	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1280					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1281					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1282	2579	4	6.06E-09	0.94189	ACP-BAC-ST-1H1-2	*	IE-T	*	K	*	R	+
1283	2580	4	6.06E-09	0.94207	ACP-BAC-ST-4KV1H	*	IE-T	*	K	*	R	+
1284	2581	4	6.06E-09	0.94226	ACP-BAC-ST-1H1	*	IE-T	*	K	*	R	+
1285	94	3	6.00E-09	0.94244	IE-S1	*	LPI-MDP-MA-SI1A	*	LPR-MOV-FT-1860B	+		
1286	95	3	6.00E-09	0.94262	IE-S1	*	LPI-MDP-MA-SI1B	*	LPR-MOV-FT-1860A	+		
1287	68	3	6.00E-09	0.94280	IE-S1	*	LPI-MDP-FS-SI1A	*	LPI-MDP-MA-SI1B	+		
1288	67	3	6.00E-09	0.94299	IE-S1	*	LPI-MDP-FS-SI1B	*	LPI-MDP-MA-SI1A	+		
1289	455	10	5.99E-09	0.94317	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1290					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1291					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1292	454	10	5.99E-09	0.94335	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1293					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1294					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1295	453	10	5.99E-09	0.94353	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1296					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
1297					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1298	452	10	5.99E-09	0.94371	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1299					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1300					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1301	1829	11	5.98E-09	0.94389	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
1302					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*
1303					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1304	1831	11	5.98E-09	0.94407	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
1305					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*
1306					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1307	1830	11	5.98E-09	0.94426	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
1308					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*
1309					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1310	922	11	5.91E-09	0.94444	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1311					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*
1312					OEP-DGN-FR-6HDG3	*	/QS-SBO	*	RCP-LOCA-467-150	+		
1313	1918	11	5.88E-09	0.94461	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*
1314					/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
1315					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1316	217	11	5.82E-09	0.94479	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1317					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	
1318					OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	/QS-SBO	+		
1319	923	11	5.75E-09	0.94496	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
1320					NOTL-SBOU1	*	NOTQ	*	NRAC-258M	*	OEP-DGN-FS	*
1321					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1322	826	12	5.75E-09	0.94514	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1323					NRAC-216M	*	/O	*	OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*
1324					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
1325	827	12	5.75E-09	0.94531	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1326					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*
1327					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
1328	2246	9	5.60E-09	0.94546	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
1329					NRAC-150M	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-1440-90	*
1330					REC-XHE-FO-DGHWS	+						
1331	588	9	5.54E-09	0.94565	AFW-XHE-FO-CST2	*	IE-T1	*	NOTQ	*	NRAC-1HR	*
1332					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	QS-SBO	*
1333					REC-XHE-FO-DGEN	+						
1334	828	12	5.40E-09	0.94581	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

1335					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1336					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+
1337	831	12	5.40E-09	0.94598	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1338					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1339					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+
1340	830	12	5.40E-09	0.94614	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1341					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
1342					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+
1343	829	12	5.40E-09	0.94631	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1344					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1345					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+
1346	2649	6	5.36E-09	0.94647	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	IE-T2	*
1347					PPS-MOV-FC-1536	*	PPS-MOV-FT	+				
1348	2650	6	5.36E-09	0.94663	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	IE-T2	*
1349					PPS-MOV-FC-1535	*	PPS-MOV-FT	+				
1350	34	3	5.20E-09	0.94679	IE-A	*	LPI-MDP-MA-S11A	*	LPR-MOV-FT-1862B	+		
1351	33	3	5.20E-09	0.94695	IE-A	*	LPI-MDP-MA-S11B	*	LPR-MOV-FT-1862A	+		
1352	668	10	5.19E-09	0.94710	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1353					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
1354					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1355	667	10	5.19E-09	0.94726	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1356					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
1357					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1358	669	10	5.19E-09	0.94742	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1359					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
1360					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1361	670	10	5.19E-09	0.94757	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1362					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*
1363					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1364	666	10	5.19E-09	0.94773	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1365					OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
1366					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1367	665	10	5.19E-09	0.94789	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1368					OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
1369					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1370	221	11	5.19E-09	0.94805	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1371					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1372					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOO	+		
1373	220	11	5.19E-09	0.94820	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1374					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
1375					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOO	+		
1376	218	11	5.19E-09	0.94836	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1377					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1378					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOO	+		
1379	219	11	5.19E-09	0.94852	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1380					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1381					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOO	+		
1382	2592	6	5.16E-09	0.94868	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
1383					IE-T1	*	PPS-XHE-FO-PORVS	+				
1384	129	4	5.15E-09	0.94883	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
1385	130	4	5.15E-09	0.94899	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
1386	832	11	5.11E-09	0.94914	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1387					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
1388					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+		
1389	429	9	5.11E-09	0.94930	AFW-CKV-OO-CV172	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*

1447	678	10	4.69E-09	0.95270	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
1448					OEP-DGN-FR-DG03	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1455C	* QS-SBO	*
1449					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
1450	671	10	4.69E-09	0.95284	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
1451					OEP-DGN-FR-DG01	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1456	* QS-SBO	*
1452					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
1453	673	10	4.69E-09	0.95298	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
1454					OEP-DGN-FR-DG03	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1456	* QS-SBO	*
1455					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
1456	674	10	4.69E-09	0.95313	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
1457					OEP-DGN-FR-DG02	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1455C	* QS-SBO	*
1458					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
1459	677	10	4.69E-09	0.95327	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
1460					OEP-DGN-FR-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* QS-SBO	*
1461					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
1462	672	10	4.69E-09	0.95341	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
1463					OEP-DGN-FR-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1456	* QS-SBO	*
1464					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
1465	675	10	4.69E-09	0.95355	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
1466					OEP-DGN-FR-DG02	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1456	* QS-SBO	*
1467					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		*
1468	1833	11	4.67E-09	0.95369	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1469					/O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
1470					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
1471	1837	11	4.67E-09	0.95383	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1472					/O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
1473					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
1474	1836	11	4.67E-09	0.95398	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1475					/O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
1476					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
1477	1832	11	4.67E-09	0.95412	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1478					/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG02	*
1479					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
1480	1835	11	4.67E-09	0.95426	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1481					/O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
1482					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
1483	1834	11	4.67E-09	0.95440	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1484					/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG03	*
1485					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
1486	224	11	4.56E-09	0.95454	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
1487					NOTQ	* NRAC-7HR	* NSLOCA	* OEP-DGN-FS-DG01	*
1488					OEP-DGN-FS-DG03	* QS-SBO	* REC-XHE-FO-DGHWB	+	*
1489	223	11	4.56E-09	0.95468	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
1490					NOTQ	* NRAC-7HR	* NSLOCA	* OEP-DGN-FS-DG01	*
1491					OEP-DGN-FS-DG02	* QS-SBO	* REC-XHE-FO-DGHWB	+	*
1492	929	12	4.52E-09	0.95481	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1493					NRAC-258M	* /O	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	*
1494					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
1495	928	12	4.52E-09	0.95495	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1496					NRAC-258M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	*
1497					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
1498	930	12	4.52E-09	0.95509	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1499					NRAC-258M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	*
1500					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
1501	37	3	4.50E-09	0.95522	IE-A	* LPR-MOV-FT-1890A	* LPR-MOV-FT-1890B	+	*
1502	38	3	4.50E-09	0.95536	IE-A	* LPI-MDP-FS-S11A	* LPR-MOV-FT-1860B	+	*

1503	9	3	4.50E-09	0.95550	IE-A	*	LPI-MDP-FS-SI1A	*	LPI-MDP-FS-SI1B	+		
1504	35	3	4.50E-09	0.95563	IE-A	*	LPI-MDP-FS-SI1B	*	LPR-MOV-FT-1860A	+		
1505	38	3	4.50E-09	0.95577	IE-A	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1860B	+		
1506	839	11	4.50E-09	0.95591	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1507					NOTQ	*	NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
1508					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1509	837	11	4.50E-09	0.95604	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1510					NOTQ	*	NRAC-216M	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
1511					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1512	838	11	4.50E-09	0.95618	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1513					NOTQ	*	NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
1514					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1515	2854	6	4.47E-09	0.95631	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T2	*
1516					PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+				
1517	2653	6	4.47E-09	0.95645	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T2	*
1518					PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+				
1519	840	12	4.41E-09	0.95658	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
1520					NOTL-SBOU1	*	NOTQ	*	NRAC-201M	*	O	*
1521					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
1522	304	11	4.34E-09	0.95672	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-7HR	*
1523					NSLOCA	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
1524					OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWS	+		
1525	2356	9	4.34E-09	0.95685	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
1526					NRAC-7HR	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-183-90	*
1527					REC-XHE-FO-DGHWS	+						
1528	932	12	4.34E-09	0.95698	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1529					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*
1530					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1531	934	12	4.34E-09	0.95711	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1532					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS-DG02	*
1533					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1534	933	12	4.34E-09	0.95724	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1535					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS-DG03	*
1536					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1537	931	12	4.34E-09	0.95737	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1538					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*
1539					OEP-DGN-MA-DG02	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1540	936	12	4.31E-09	0.95750	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1541					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*
1542					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
1543	935	12	4.31E-09	0.95763	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1544					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
1545					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
1546	841	11	4.29E-09	0.95777	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1547					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
1548					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+		
1549	842	11	4.29E-09	0.95790	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1550					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*
1551					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+		
1552	1840	11	4.28E-09	0.95802	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1553					/O	*	OEP-CRB-FT-25H3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
1554					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1555	1838	11	4.28E-09	0.95815	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1556					/O	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
1557					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
1558	1839	11	4.28E-09	0.95828	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*

1559					/O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*
1560					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
1561	225	11	4.24E-09	0.95841	BETA-2DG	* IE-T1	* MCW-CCF-VF-SBO	* NOTDG-CCF	*
1562					NOTL-SBOU1	* NOTQ	* NRAC-7HR	* NSLOCA	*
1563					OEP-DGN-FS	* QS-SBO	* REC-XHE-FO-DGHWB	+	*
1564	432	9	4.12E-09	0.95854	AFW-TDP-FS-FW2	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
1565					NOTQ	* NRAC-HALFHR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
1566					/QS-SBO	+			*
1567	843	11	4.11E-09	0.95866	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1568					NRAC-216M	* /O	* OEP-CRB-FT-15H3	* OEP-CRB-FT-15J3	*
1569					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-SCOOL	+	*
1570	458	10	4.02E-09	0.95878	AFW-TDP-FR-2P6HR	* AFW-TDP-FR-6HRU2	* /DGN-FTO	* IE-T1	*
1571					NOTQ	* NRAC-6HR-AVG	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
1572					/QS-SBO	* REC-XHE-FO-DGEN	+		*
1573	457	10	4.02E-09	0.95891	AFW-TDP-FR-2P6HR	* AFW-TDP-FR-6HRU2	* /DGN-FTO	* IE-T1	*
1574					NOTQ	* NRAC-6HR-AVG	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
1575					/QS-SBO	* REC-XHE-FO-DGEN	+		*
1576	2688	4	3.96E-09	0.95903	AFW-MDP-MA-FW3B	* AFW-TDP-FS-FW2	* AFW-XHE-FO-UNIT2	* IE-T5A	+
1577	2748	4	3.96E-09	0.95915	AFW-CKV-OO-CV142	* AFW-TDP-FS-FW2	* AFW-XHE-FO-UNIT2	* IE-T7	+
1578	2714	4	3.96E-09	0.95927	AFW-MDP-MA-FW3A	* AFW-TDP-FS-FW2	* AFW-XHE-FO-UNIT2	* IE-T5B	+
1579	59	3	3.84E-09	0.95938	CPC-MDP-FR-SWA3H	* CPC-MDP-FS-SW10B	* IE-S1	+	*
1580	937	11	3.83E-09	0.95950	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1581					NRAC-258M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	* QS-SBO	*
1582					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	*
1583	2749	5	3.81E-09	0.95961	AFW-MDP-FS	* AFW-TDP-FR-2P6HR	* AFW-XHE-FO-UNIT2	* BETA-AFW	*
1584					IE-T7	+			*
1585	433	9	3.80E-09	0.95973	AFW-TDP-MA-FW2	* /DGN-FTO	* IE-T1	* NOTQ	*
1586					NRAC-HALFHR	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	* QS-SBO	*
1587					REC-XHE-FO-DGEN	+			*
1588	434	9	3.74E-09	0.95984	AFW-TDP-MA-FW2	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
1589					NOTQ	* NRAC-HALFHR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
1590					/QS-SBO	+			*
1591	484	10	3.74E-09	0.95996	AFW-TDP-FR-2P6HR	* AFW-TDP-FR-6HRU2	* BETA-2DG	* IE-T1	*
1592					NOTDG-CCF	* NOTQ	* NRAC-6HR-AVG	* OEP-DGN-FS	*
1593					/QS-SBO	* REC-XHE-FO-DGEN	+		*
1594	435	10	3.71E-09	0.96007	AFW-TDP-FS-FW2	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
1595					NOTQ	* NRAC-HALFHR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
1596					/QS-SBO	* REC-XHE-FO-DGEN	+		*
1597	465	9	3.69E-09	0.96018	AFW-TDP-FR-2P6HR	* /DGN-FTO	* IE-T1	* NOTQ	*
1598					NRAC-6HR-AVG	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	* QS-SBO	*
1599					REC-XHE-FO-DGEN	+			*
1600	844	11	3.68E-09	0.96029	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1601					NRAC-201M	* O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
1602					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-SCOOL	+	*
1603	227	12	3.64E-09	0.96040	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1604					NRAC-7HR	* NSLOCA	* /O	* OEP-DGN-FR-6HDG1	*
1605					OEP-DGN-MA-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	* REC-XHE-FO-SCOOL	+
1606	226	12	3.64E-09	0.96051	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
1607					NRAC-7HR	* NSLOCA	* /O	* OEP-DGN-FR-6HDG2	*
1608					OEP-DGN-MA-DG01	* /QS-SBO	* REC-XHE-FO-DGHWB	* REC-XHE-FO-SCOOL	+
1609	466	9	3.63E-09	0.96062	AFW-TDP-FR-2P6HR	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
1610					NOTQ	* NRAC-6HR-AVG	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
1611					/QS-SBO	+			*
1612	1842	10	3.63E-09	0.96073	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
1613					OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG03	* QS-SBO	*
1614					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		*

1615	1841	10	3.63E-09	0.96084	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1616					OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
1617					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1618	1843	10	3.63E-09	0.96095	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1619					OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
1620					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1621	2715	4	3.60E-09	0.96106	AFW-MDP-MA-FW3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
1622	2690	4	3.60E-09	0.96117	AFW-MDP-MA-FW3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
1623	2656	6	3.57E-09	0.96128	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	IE-T2	*
1624					PPS-MOV-FC-1535	*	PPS-MOV-FT	+				
1625	2655	6	3.57E-09	0.96139	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	IE-T2	*
1626					PPS-MOV-FC-1536	*	PPS-MOV-FT	+				
1627	940	11	3.51E-09	0.96149	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1628					NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
1629					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+		
1630	938	11	3.51E-09	0.96160	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1631					NRAC-258M	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1632					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+		
1633	939	11	3.51E-09	0.96171	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1634					NRAC-258M	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1635					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+		
1636	941	11	3.51E-09	0.96181	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1637					NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
1638					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO	+		
1639	131	3	3.51E-09	0.96192	ACP-BAC-ST-4KV1H	*	HPI-MOV-FT-1867D	*	IE-S3	+		
1640	132	3	3.51E-09	0.96203	ACP-BAC-ST-1H1	*	HPI-MOV-FT-1867D	*	IE-S3	+		
1641	228	12	3.49E-09	0.96213	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1642					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
1643					OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
1644	885	10	3.46E-09	0.96224	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1645					OEP-DGN-FR-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
1646					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1647	879	10	3.46E-09	0.96234	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1648					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
1649					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1650	880	10	3.46E-09	0.96245	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1651					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
1652					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1653	886	10	3.46E-09	0.96255	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1654					OEP-DGN-FR-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
1655					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1656	884	10	3.46E-09	0.96266	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1657					OEP-DGN-FR-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
1658					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1659	883	10	3.46E-09	0.96276	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1660					OEP-DGN-FR-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
1661					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1662	882	10	3.46E-09	0.96287	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1663					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
1664					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1665	881	10	3.46E-09	0.96297	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
1666					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*
1667					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
1668	443	10	3.40E-09	0.96307	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1669					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
1670					/QS-SBO	*	REC-XHE-FO-DGEN	+				

1671	440	10	3.40E-09	0.96318	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1672					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
1673					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1674	441	10	3.40E-09	0.96328	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1675					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
1676					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1677	442	10	3.40E-09	0.96338	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1678					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*
1679					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1680	2658	4	3.38E-09	0.96349	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T2	*	PPS-SOV-FT-1456	+
1681	2657	4	3.38E-09	0.96359	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T2	*	PPS-SOV-FT-1455C	+
1682	943	11	3.37E-09	0.96369	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1683					NOTQ	*	NRAC-258M	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1684					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1685	942	11	3.37E-09	0.96379	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1686					NOTQ	*	NRAC-258M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1687					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1688	944	11	3.37E-09	0.96390	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1689					NOTQ	*	NRAC-258M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1690					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1691	945	11	3.37E-09	0.96400	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1692					NOTQ	*	NRAC-258M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
1693					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
1694	444	10	3.37E-09	0.96410	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1695					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
1696					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1697	230	12	3.33E-09	0.96420	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1698					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-CRB-FT-15H3	*
1699					OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
1700	229	12	3.33E-09	0.96430	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1701					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-CRB-FT-15H3	*
1702					OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
1703	231	12	3.33E-09	0.96440	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1704					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-CRB-FT-15J3	*
1705					OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
1706	1846	10	3.33E-09	0.96450	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1707					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG03	*	QS-SBO	*
1708					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1709	1844	10	3.33E-09	0.96460	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1710					OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
1711					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1712	1845	10	3.33E-09	0.96471	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1713					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG02	*	QS-SBO	*
1714					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
1715	2596	5	3.33E-09	0.96481	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	PPS-MOV-FC-1536	*
1716					PPS-MOV-FT-1536	+						
1717	2595	5	3.33E-09	0.96491	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	PPS-MOV-FC-1535	*
1718					PPS-MOV-FT-1535	+						
1719	97	3	3.28E-09	0.96501	IE-S1	*	LPI-MDP-FR-B21HR	*	LPR-MOV-FT-1862A	+		
1720	96	3	3.28E-09	0.96511	IE-S1	*	LPI-MDP-FR-A21HR	*	LPR-MOV-FT-1862B	+		
1721	476	10	3.27E-09	0.96521	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
1722					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
1723					/QS-SBO	*	REC-XHE-FO-DGEN	+				
1724	2716	4	3.24E-09	0.96530	AFW-ACT-FA-PMP3A	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
1725	2691	4	3.24E-09	0.96540	AFW-ACT-FA-PMP3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
1726	1921	11	3.21E-09	0.96550	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*

1727 /O
 1728 /QS-SBO
 1729 1919 11 3.21E-09 0.96560 IE-T1
 1730 /O
 1731 /QS-SBO
 1732 1920 11 3.21E-09 0.96569 IE-T1
 1733 /O
 1734 /QS-SBO
 1735 235 12 3.20E-09 0.96579 /DGN-FTO
 1736 NOTQ
 1737 OEP-DGN-FS-DG01
 1738 234 12 3.20E-09 0.96589 /DGN-FTO
 1739 NOTQ
 1740 OEP-DGN-FS-DG01
 1741 232 12 3.20E-09 0.96598 /DGN-FTO
 1742 NOTQ
 1743 OEP-DGN-FS-DG02
 1744 233 12 3.20E-09 0.96608 /DGN-FTO
 1745 NOTQ
 1746 OEP-DGN-FS-DG03
 1747 71 3 3.20E-09 0.96618 IE-S1
 1748 72 3 3.20E-09 0.96628 IE-S1
 1749 845 12 3.15E-09 0.96637 /DGN-FTO
 1750 NOTQ
 1751 OEP-DGN-MA-DG02
 1752 714 10 3.10E-09 0.96647 IE-T1
 1753 OEP-DGN-FS-DG02
 1754 REC-XHE-FO-DGEN
 1755 713 10 3.10E-09 0.96656 IE-T1
 1756 OEP-DGN-FS-DG02
 1757 REC-XHE-FO-DGEN
 1758 451 10 3.09E-09 0.96665 AFW-TDP-MA-FW2
 1759 NOTQ
 1760 /QS-SBO
 1761 450 10 3.09E-09 0.96675 AFW-TDP-MA-FW2
 1762 NOTQ
 1763 /QS-SBO
 1764 449 10 3.09E-09 0.96684 AFW-TDP-MA-FW2
 1765 NOTQ
 1766 /QS-SBO
 1767 448 10 3.09E-09 0.96693 AFW-TDP-MA-FW2
 1768 NOTQ
 1769 /QS-SBO
 1770 946 11 3.08E-09 0.96703 /DGN-FTO
 1771 NRAC-258M
 1772 /QS-SBO
 1773 947 11 3.08E-09 0.96712 /DGN-FTO
 1774 NRAC-258M
 1775 /QS-SBO
 1776 847 10 3.07E-09 0.96721 /DGN-FTO
 1777 NOTQ
 1778 QS-SBO
 1779 846 10 3.07E-09 0.96731 /DGN-FTO
 1780 NOTQ
 1781 QS-SBO
 1782 239 11 3.03E-09 0.96740 /DGN-FTO

/O * OEP-DGN-FR-6HDG2 *
 /QS-SBO * RCP-LOCA-467-150 *
 IE-T1 * NOTL-SBOU1U2 *
 /O * OEP-DGN-FR-6HDG1 *
 /QS-SBO * RCP-LOCA-467-150 *
 IE-T1 * NOTL-SBOU1U2 *
 /O * OEP-DGN-FR-6HDG3 *
 /QS-SBO * RCP-LOCA-467-150 *
 /DGN-FTO * IE-T1 *
 NOTQ * NRAC-7HR *
 OEP-DGN-FS-DG01 * OEP-DGN-MA-DG02 *
 /DGN-FTO * IE-T1 *
 NOTQ * NRAC-7HR *
 OEP-DGN-FS-DG01 * OEP-DGN-MA-DG03 *
 /DGN-FTO * IE-T1 *
 NOTQ * NRAC-7HR *
 OEP-DGN-FS-DG02 * OEP-DGN-MA-DG01 *
 /DGN-FTO * IE-T1 *
 NOTQ * NRAC-7HR *
 OEP-DGN-FS-DG03 * OEP-DGN-MA-DG01 *
 IE-S1 * LPI-MDP-MA-S11B *
 IE-S1 * LPI-MDP-MA-S11A *
 /DGN-FTO * IE-T1 *
 NOTQ * NRAC-216M *
 OEP-DGN-MA-DG02 * /QS-SBO *
 IE-T1 * NOTL-SBOU1U2 *
 OEP-DGN-FS-DG03 * OEP-DGN-FS-DG03 *
 SBO-PORV-DMD * SBO-PORV-DMD *
 NOTL-SBOU1U2 * NOTL-SBOU1U2 *
 OEP-DGN-FS-DG03 * OEP-DGN-FS-DG03 *
 SBO-PORV-DMD * SBO-PORV-DMD *
 AFW-XHE-FO-U1SBO * AFW-XHE-FO-U1SBO *
 NRAC-HALFHR * NRAC-HALFHR *
 REC-XHE-FO-DGEN * REC-XHE-FO-DGEN *
 AFW-XHE-FO-U1SBO * AFW-XHE-FO-U1SBO *
 NRAC-HALFHR * NRAC-HALFHR *
 REC-XHE-FO-DGEN * REC-XHE-FO-DGEN *
 AFW-XHE-FO-U1SBO * AFW-XHE-FO-U1SBO *
 NRAC-HALFHR * NRAC-HALFHR *
 REC-XHE-FO-DGEN * REC-XHE-FO-DGEN *
 IE-T1 * IE-T1 *
 /O * /O *
 RCP-LOCA-467-150 * RCP-LOCA-467-150 *
 IE-T1 * IE-T1 *
 /O * /O *
 RCP-LOCA-467-150 * RCP-LOCA-467-150 *
 IE-T1 * IE-T1 *
 NRAC-216M * NRAC-216M *
 RCP-LOCA-750-90M * RCP-LOCA-750-90M *
 IE-T1 * IE-T1 *
 NRAC-216M * NRAC-216M *
 RCP-LOCA-750-90M * RCP-LOCA-750-90M *
 IE-T1 * IE-T1 *

OEP-DGN-FS-DG01 * OEP-DGN-FS-DG03 *
 REC-XHE-FO-DGHSW + REC-XHE-FO-DGHSW +
 NOTQ * NOTQ *
 OEP-DGN-FS-DG02 * OEP-DGN-FS-DG03 *
 REC-XHE-FO-DGHSW + REC-XHE-FO-DGHSW +
 NOTQ * NOTQ *
 OEP-DGN-FS-DG01 * OEP-DGN-FS-DG02 *
 REC-XHE-FO-DGHSW + REC-XHE-FO-DGHSW +
 MCW-CCF-VF-SBO * MCW-CCF-VF-SBO *
 NSLOCA * NSLOCA *
 /QS-SBO * /QS-SBO *
 MCW-CCF-VF-SBO * MCW-CCF-VF-SBO *
 NSLOCA * NSLOCA *
 /QS-SBO * /QS-SBO *
 MCW-CCF-VF-SBO * MCW-CCF-VF-SBO *
 NSLOCA * NSLOCA *
 /QS-SBO * /QS-SBO *
 MCW-CCF-VF-SBO * MCW-CCF-VF-SBO *
 NSLOCA * NSLOCA *
 /QS-SBO * /QS-SBO *
 SIS-ACT-FA-SISA + SIS-ACT-FA-SISA +
 SIS-ACT-FA-SISB + SIS-ACT-FA-SISB +
 MCW-CCF-VF-SBO * MCW-CCF-VF-SBO *
 /O * /O *
 RCP-LOCA-750-90M * RCP-LOCA-750-90M *
 NRAC-1HR * NRAC-1HR *
 PPS-SOV-OO-1456 * PPS-SOV-OO-1456 *
 /QS-SBO * /QS-SBO *
 NRAC-1HR * NRAC-1HR *
 PPS-SOV-OO-1455C * PPS-SOV-OO-1455C *
 /DGN-FTO * /DGN-FTO *
 OEP-DGN-FS-DG01 * OEP-DGN-FS-DG01 *
 IE-T1 * IE-T1 *
 OEP-DGN-MA-DG03 * OEP-DGN-MA-DG03 *
 /DGN-FTO * /DGN-FTO *
 OEP-DGN-FS-DG03 * OEP-DGN-FS-DG03 *
 IE-T1 * IE-T1 *
 OEP-DGN-MA-DG01 * OEP-DGN-MA-DG01 *
 /DGN-FTO * /DGN-FTO *
 OEP-DGN-FS-DG02 * OEP-DGN-FS-DG02 *
 IE-T1 * IE-T1 *
 OEP-DGN-MA-DG01 * OEP-DGN-MA-DG01 *
 /DGN-FTO * /DGN-FTO *
 OEP-DGN-FS-DG01 * OEP-DGN-FS-DG01 *
 IE-T1 * IE-T1 *
 OEP-DGN-MA-DG02 * OEP-DGN-MA-DG02 *
 NOTQ * NOTQ *
 OEP-DGN-FR-6HDG1 * OEP-DGN-FR-6HDG1 *
 REC-XHE-FO-SCOOL + REC-XHE-FO-SCOOL +
 NOTL-SBOU1 * NOTL-SBOU1 *
 OEP-DGN-FR-6HDG3 * OEP-DGN-FR-6HDG3 *
 REC-XHE-FO-SCOOL + REC-XHE-FO-SCOOL +
 MCW-CCF-VF-SBO * MCW-CCF-VF-SBO *
 OEP-CRB-FT-15J3 * OEP-CRB-FT-15J3 *
 NOTL-SBOU1 * NOTL-SBOU1 *
 OEP-DGN-FR-6HDG1 * OEP-DGN-FR-6HDG1 *
 MCW-CCF-VF-SBO * MCW-CCF-VF-SBO *
 OEP-CRB-FT-15H3 * OEP-CRB-FT-15H3 *
 NOTL-SBOU1 * NOTL-SBOU1 *
 OEP-DGN-FR-6HDG3 * OEP-DGN-FR-6HDG3 *
 NOTQ * NOTQ *

1783
 1784
 1785 236 12 3.03E-09 0.96749
 1786
 1787
 1788 238 11 3.03E-09 0.96758
 1789
 1790
 1791 237 12 3.03E-09 0.96767
 1792
 1793
 1794 573 9 3.02E-09 0.96777
 1795
 1796
 1797 572 9 3.02E-09 0.96786
 1798
 1799
 1800 574 9 3.02E-09 0.96795
 1801
 1802
 1803 119 4 3.02E-09 0.96804
 1804 76 4 3.02E-09 0.96813
 1805 40 3 3.00E-09 0.96822
 1806 73 3 3.00E-09 0.96831
 1807 74 3 3.00E-09 0.96841
 1808 39 3 3.00E-09 0.96850
 1809 11 3 3.00E-09 0.96859
 1810 10 3 3.00E-09 0.96868
 1811 485 10 3.00E-09 0.96877
 1812
 1813
 1814 487 10 3.00E-09 0.96886
 1815
 1816
 1817 488 10 3.00E-09 0.96895
 1818
 1819
 1820 486 10 3.00E-09 0.96904
 1821
 1822
 1823 1848 11 2.99E-09 0.96913
 1824
 1825
 1826 1847 11 2.99E-09 0.96922
 1827
 1828
 1829 1849 11 2.99E-09 0.96931
 1830
 1831
 1832 848 12 2.94E-09 0.96940
 1833
 1834
 1835 1923 12 2.88E-09 0.96949
 1836
 1837
 1838 1924 12 2.88E-09 0.96958

NRAC-7HR * NSLOCA * /O * OEP-CRB-FT-15J3 *
 OEP-DGN-FR-6HDG1 * /QS-SBO * REC-XHE-FO-SCOOL + *
 /DGN-FTO * IE-T1 * NOTL-SBOU1 * NOTQ *
 NRAC-7HR * NSLOCA * /O * OEP-DGN-FR-6HDG1 *
 OEP-DGN-MA-DG03 * /QS-SBO * REC-XHE-FO-DGTMB * REC-XHE-FO-SCOOL + *
 /DGN-FTO * IE-T1 * NOTL-SBOU1 * NOTQ *
 NRAC-7HR * NSLOCA * /O * OEP-CRB-FT-15H3 *
 OEP-DGN-FR-6HDG3 * /QS-SBO * REC-XHE-FO-SCOOL + *
 /DGN-FTO * IE-T1 * NOTL-SBOU1 * NOTQ *
 NRAC-7HR * NSLOCA * /O * OEP-DGN-FR-6HDG3 *
 OEP-DGN-MA-DG01 * /QS-SBO * REC-XHE-FO-DGTMB * REC-XHE-FO-SCOOL + *
 AFW-XHE-FO-CST2 * IE-T1 * NOTQ * NRAC-1HR *
 OEP-DGN-FR-6HDG3 * OEP-DGN-FS-DG01 * OEP-DGN-FS-DG02 * QS-SBO *
 REC-XHE-FO-DGEN + *
 AFW-XHE-FO-CST2 * IE-T1 * NOTQ * NRAC-1HR *
 OEP-DGN-FR-6HDG1 * OEP-DGN-FS-DG02 * OEP-DGN-FS-DG03 * QS-SBO *
 REC-XHE-FO-DGEN + *
 AFW-XHE-FO-CST2 * IE-T1 * NOTQ * NRAC-1HR *
 OEP-DGN-FR-6HDG2 * OEP-DGN-FS-DG01 * OEP-DGN-FS-DG03 * QS-SBO *
 REC-XHE-FO-DGEN + *
 CON-VFC-RP-COREM * IE-S2 * SWS-CCF-FT-3ABCD * SWS-XHE-FO-OPEN + *
 CON-VFC-RP-COREM * IE-S1 * SWS-CCF-FT-3ABCD * SWS-XHE-FO-OPEN + *
 IE-A * LPI-MDP-MA-SI1B * LPR-MOV-FT-1860A + *
 IE-S1 * LPI-CKV-OO-CV50 * LPI-MDP-FS-SI1B + *
 IE-S1 * LPI-CKV-OO-CV58 * LPI-MDP-FS-SI1A + *
 IE-A * LPI-MDP-MA-SI1A * LPR-MOV-FT-1860B + *
 IE-A * LPI-MDP-FS-SI1A * LPI-MDP-MA-SI1B + *
 IE-A * LPI-MDP-FS-SI1B * LPI-MDP-MA-SI1A + *
 AFW-TDP-FR-2P6HR * AFW-XHE-FO-U1SBO * /DGN-FTO * IE-T1 *
 NOTQ * NRAC-6HR-AVG * OEP-DGN-FS-DG01 * OEP-DGN-MA-DG02 *
 /QS-SBO * REC-XHE-FO-DGEN + *
 AFW-TDP-FR-2P6HR * AFW-XHE-FO-U1SBO * /DGN-FTO * IE-T1 *
 NOTQ * NRAC-6HR-AVG * OEP-DGN-FS-DG01 * OEP-DGN-MA-DG03 *
 /QS-SBO * REC-XHE-FO-DGEN + *
 AFW-TDP-FR-2P6HR * AFW-XHE-FO-U1SBO * /DGN-FTO * IE-T1 *
 NOTQ * NRAC-6HR-AVG * OEP-DGN-FS-DG03 * OEP-DGN-MA-DG01 *
 /QS-SBO * REC-XHE-FO-DGEN + *
 AFW-TDP-FR-2P6HR * AFW-XHE-FO-U1SBO * /DGN-FTO * IE-T1 *
 NOTQ * NRAC-6HR-AVG * OEP-DGN-FS-DG02 * OEP-DGN-MA-DG01 *
 /QS-SBO * REC-XHE-FO-DGEN + *
 BETA-2DG * IE-T1 * NOTDG-CCF * NOTL-SBOU1U2 *
 NOTQ * NRAC-216M * OEP-DGN-FS * OEP-DGN-MA-DG02 *
 QS-SBO * RCP-LOCA-750-90M * REC-XHE-FO-DGHWS + *
 BETA-2DG * IE-T1 * NOTDG-CCF * NOTL-SBOU1U2 *
 NOTQ * NRAC-216M * OEP-DGN-FS * OEP-DGN-MA-DG03 *
 QS-SBO * RCP-LOCA-750-90M * REC-XHE-FO-DGHWS + *
 BETA-2DG * IE-T1 * NOTDG-CCF * NOTL-SBOU1U2 *
 NOTQ * NRAC-216M * OEP-DGN-FS * OEP-DGN-MA-DG01 *
 QS-SBO * RCP-LOCA-750-90M * REC-XHE-FO-DGHWS + *
 /DGN-FTO * IE-T1 * NOTL-SBOU1 * NOTQ *
 NRAC-201M * O * OEP-DGN-FR-6HDG1 * OEP-DGN-FR-6HDG2 *
 /QS-SBO * RCP-LOCA-750-90M * REC-XHE-FO-DGHWS * REC-XHE-FO-SCOOL + *
 BETA-2DG * IE-T1 * NOTDG-CCF * NOTL-SBOU1U2 *
 NOTQ * NRAC-258M * /O * OEP-DGN-FR-6HDG2 *
 OEP-DGN-FS * /QS-SBO * RCP-LOCA-467-150 * REC-XHE-FO-DGHWS + *
 BETA-2DG * IE-T1 * NOTDG-CCF * NOTL-SBOU1U2 *

1838					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*
1840					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1841	1922	12	2.88E-09	0.98966	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
1842					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG3	*
1843					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1844	2626	6	2.86E-09	0.98975	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*
1845					HPI-XHE-FO-FDBLD	*	IE-T2	+				
1846	2466	9	2.85E-09	0.96984	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
1847					NRAC-248M	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-561-150	*
1848					REC-XHE-FO-DGHWS	+						
1849	240	11	2.83E-09	0.96992	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1850					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
1851					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
1852	114	4	2.79E-09	0.97001	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
1853	113	4	2.79E-09	0.97009	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
1854	456	9	2.79E-09	0.97018	AFW-CKV-OO-CV172	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
1855					NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
1856					REC-XHE-FO-DGEN	+						
1857	850	12	2.76E-09	0.97026	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1858					NOTQ	*	NRAC-218M	*	/O	*	OEP-CRB-FT-15H3	*
1859					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+
1860	849	12	2.76E-09	0.97034	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1861					NOTQ	*	NRAC-218M	*	/O	*	OEP-CRB-FT-15J3	*
1862					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+
1863	576	10	2.72E-09	0.97043	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
1864					NOTQ	*	NRAC-1HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*
1865					QS-SBO	*	REC-XHE-FO-DGEN	+				
1866	577	10	2.72E-09	0.97051	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
1867					NOTQ	*	NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*
1868					QS-SBO	*	REC-XHE-FO-DGEN	+				
1869	575	10	2.72E-09	0.97059	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
1870					NOTQ	*	NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*
1871					QS-SBO	*	REC-XHE-FO-DGEN	+				
1872	60	2	2.70E-09	0.97067	IE-S1	*	RWT-TNK-LF-RWST	+				
1873	115	2	2.70E-09	0.97076	IE-S2	*	RWT-TNK-LF-RWST	+				
1874	852	12	2.70E-09	0.97084	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1875					NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
1876					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
1877	854	12	2.70E-09	0.97092	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1878					NRAC-201M	*	O	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*
1879					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
1880	853	12	2.70E-09	0.97100	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1881					NRAC-201M	*	O	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
1882					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
1883	851	12	2.70E-09	0.97108	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1884					NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
1885					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
1886	2584	4	2.69E-09	0.97116	ACP-TFM-NO-1H1	*	IE-T	*	K	*	R	+
1887	2583	4	2.69E-09	0.97125	HPI-MOV-PG-1350	*	IE-T	*	K	*	R	+
1888	242	11	2.59E-09	0.97132	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1889					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
1890					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
1891	243	11	2.59E-09	0.97140	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1892					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
1893					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
1894	244	11	2.59E-09	0.97148	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

1895				NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	
1896				QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+			
1897	241	11	2.59E-09	0.97156	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1898				NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	
1899				QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+			
1900	856	12	2.59E-09	0.97184	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1901				NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FR-6HDG2	*	
1902				OEP-DGN-FS-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	
1903	855	12	2.59E-09	0.97172	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1904				NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	
1905				OEP-DGN-FS-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	
1906	857	12	2.59E-09	0.97180	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1907				NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FR-6HDG3	*	
1908				OEP-DGN-FS-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	
1909	858	12	2.59E-09	0.97187	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1910				NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	
1911				OEP-DGN-FS-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	
1912	116	3	2.56E-09	0.97195	IE-S2	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+		
1913	61	3	2.56E-09	0.97203	IE-S1	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+		
1914	98	3	2.56E-09	0.97211	IE-S1	*	RMT-ACT-FA-RMTSA	*	RMT-ACT-FA-RMTSB	+		
1915	2662	6	2.56E-09	0.97218	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T2	*
1916				PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+					
1917	2660	6	2.56E-09	0.97226	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T2	*
1918				PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+					
1919	2659	6	2.56E-09	0.97234	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T2	*
1920				PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+					
1921	2661	6	2.56E-09	0.97242	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T2	*
1922				PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+					
1923	859	11	2.55E-09	0.97249	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1924				NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	QS-SBO	*	
1925				RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+			
1926	2597	6	2.54E-09	0.97257	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
1927				OEP-DGN-FC-DG3U2	*	PPS-MOV-FC-1536	+					
1928	247	11	2.49E-09	0.97265	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1929				NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG1	*	
1930				OEP-DGN-FS-DG03	*	QS-SBO	*	REC-XHE-FO-DGHWB	+			
1931	248	11	2.49E-09	0.97272	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1932				NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG3	*	
1933				OEP-DGN-FS-DG01	*	QS-SBO	*	REC-XHE-FO-DGHWB	+			
1934	246	11	2.49E-09	0.97280	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1935				NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG1	*	
1936				OEP-DGN-FS-DG02	*	QS-SBO	*	REC-XHE-FO-DGHWB	+			
1937	245	11	2.49E-09	0.97287	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1938				NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG2	*	
1939				OEP-DGN-FS-DG01	*	QS-SBO	*	REC-XHE-FO-DGHWB	+			
1940	1850	9	2.47E-09	0.97295	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
1941				OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*	QS-SBO	*	
1942				RCP-LOCA-750-90M	+							
1943	948	12	2.46E-09	0.97302	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
1944				NRAC-258M	*	O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*	
1945				/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
1946	860	11	2.45E-09	0.97310	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1947				NOTQ	*	NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*	
1948				QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+			
1949	2627	4	2.40E-09	0.97317	AFW-TNK-VF-CST	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*	IE-T2	+
1950	13	3	2.40E-09	0.97324	IE-A	*	LPI-MDP-FS-S11B	*	SIS-ACT-FA-SISA	+		

1951	12	3	2.40E-09	0.97332	IE-A	* LPI-MDP-FS-SI1A	* SIS-ACT-FA-SISB	+		
1952	306	11	2.37E-09	0.97339	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
1953					NSLOCA	* /O	* OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1954					OEP-DGN-FS-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+		
1955	305	11	2.37E-09	0.97346	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
1956					NSLOCA	* /O	* OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1957					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+		
1958	307	11	2.37E-09	0.97353	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
1959					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1960					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+		
1961	949	12	2.37E-09	0.97360	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1962					NOTQ	* NRAC-258M	* /O	*	OEP-DGN-FR-6HDG1	*
1963					OEP-DGN-MA-DG02	* /QS-SBO	* RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1964	950	12	2.37E-09	0.97368	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1965					NOTQ	* NRAC-258M	* /O	*	OEP-DGN-FR-6HDG2	*
1966					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
1967	1852	11	2.33E-09	0.97375	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-216M	*
1968					/O	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*
1969					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
1970	1851	11	2.33E-09	0.97382	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-216M	*
1971					/O	* OEP-CRB-FT-25H3	* OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
1972					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
1973	1855	11	2.33E-09	0.97389	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-216M	*
1974					/O	* OEP-CRB-FT-15J3	* OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
1975					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
1976	1853	11	2.33E-09	0.97396	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-216M	*
1977					/O	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*
1978					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
1979	1854	11	2.33E-09	0.97403	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-216M	*
1980					/O	* OEP-CRB-FT-15J3	* OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
1981					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
1982	1856	11	2.33E-09	0.97410	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-216M	*
1983					/O	* OEP-CRB-FT-25H3	* OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
1984					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
1985	2663	5	2.30E-09	0.97417	AFW-MDP-FS-FW3A	* AFW-TDP-FR-2P24H	* AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1B	*
1986					IE-T2	+				
1987	2664	5	2.30E-09	0.97424	AFW-MDP-FS-FW3B	* AFW-TDP-FR-2P24H	* AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1A	*
1988					IE-T2	+				
1989	951	10	2.30E-09	0.97431	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1990					NOTQ	* NRAC-258M	* OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*
1991					QS-SBO	* RCP-LOCA-467-150	+			
1992	1925	10	2.29E-09	0.97438	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-258M	*
1993					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*	QS-SBO	*
1994					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+			
1995	2740	4	2.28E-09	0.97445	HPI-CKV-FT-CV225	* HPI-XHE-FO-ALTIN	* IE-T7	*	RCS-XHE-FO-DPT7D	+
1996	2751	4	2.27E-09	0.97452	AFW-CKV-OO-CV157	* AFW-MDP-FS-FW3A	* AFW-XHE-FO-UNIT2	*	IE-T7	+
1997	2750	4	2.27E-09	0.97459	AFW-CKV-OO-CV172	* AFW-MDP-FS-FW3B	* AFW-XHE-FO-UNIT2	*	IE-T7	+
1998	249	10	2.26E-09	0.97465	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
1999					NOTQ	* NRAC-7HR	* NSLOCA	*	OEP-DGN-FR-6HDG1	*
2000					OEP-DGN-FR-6HDG3	* QS-SBO	+			
2001	862	11	2.24E-09	0.97472	/DGN-FTO	* IE-T1	* NOTL-SBOU1	*	NOTQ	*
2002					NRAC-216M	* OEP-CRB-FT-15H3	* OEP-DGN-MA-DG03	*	QS-SBO	*
2003					RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOOL	+		
2004	861	11	2.24E-09	0.97478	/DGN-FTO	* IE-T1	* NOTL-SBOU1	*	NOTQ	*
2005					NRAC-216M	* OEP-CRB-FT-15J3	* OEP-DGN-MA-DG01	*	QS-SBO	*
2006					RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOOL	+		

2007	1857	11	2.23E-09	0.97486	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
2008					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
2009					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+		
2010	1858	11	2.23E-09	0.97492	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
2011					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG03	*
2012					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+		
2013	1859	11	2.23E-09	0.97499	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
2014					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG02	*
2015					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+		
2016	498	10	2.19E-09	0.97506	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	IE-T1	*
2017					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
2018					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2019	497	10	2.19E-09	0.97512	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	IE-T1	*
2020					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
2021					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2022	500	10	2.19E-09	0.97519	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	IE-T1	*
2023					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
2024					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2025	499	10	2.19E-09	0.97526	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	IE-T1	*
2026					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
2027					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2028	1350	12	2.18E-09	0.97532	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2029					NRAC-150M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2030					/QS-SBO	*	RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2031	1349	12	2.18E-09	0.97539	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2032					NRAC-150M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2033					/QS-SBO	*	RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2034	133	4	2.17E-09	0.97546	CPC-CKV-OO-CV113	*	CPC-MDP-FR-SWA24	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
2035	954	12	2.17E-09	0.97552	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2036					NOTQ	*	NRAC-258M	*	/O	*	OEP-CRB-FT-15H3	*
2037					OEP-DGN-FS-DG02	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
2038	953	12	2.17E-09	0.97559	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2039					NOTQ	*	NRAC-258M	*	/O	*	OEP-CRB-FT-15J3	*
2040					OEP-DGN-FS-DG01	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
2041	952	12	2.17E-09	0.97565	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2042					NOTQ	*	NRAC-258M	*	/O	*	OEP-CRB-FT-15H3	*
2043					OEP-DGN-FS-DG03	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
2044	309	12	2.13E-09	0.97572	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2045					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2046					OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2047	308	12	2.13E-09	0.97578	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2048					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2049					OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2050	310	12	2.13E-09	0.97585	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2051					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2052					OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2053	958	12	2.07E-09	0.97591	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2054					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG3	*
2055					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGTMS	+
2056	955	12	2.07E-09	0.97597	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2057					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*
2058					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGTMS	+
2059	1351	12	2.03E-09	0.97603	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
2060					NOTQ	*	NRAC-150M	*	/O	*	OEP-DGN-FS	*
2061					/QS-SBO	*	RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2062	2585	4	2.02E-09	0.97609	CVC-MDP-FR-2A1HR	*	IE-T	*	K	*	R	+

2063	2692	4	1.98E-09	0.97615	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
2064	2717	4	1.98E-09	0.97621	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
2065	2771	3	1.97E-09	0.97627	IE-T7	*	MSS-XHE-FO-1SAFW	*	RCS-XHE-FO-DPRT7	+		
2066	863	11	1.97E-09	0.97633	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2067					NOTQ	*	NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*
2068					OEP-CRB-FT-15J3	*	/QS-SBO	*	RCP-LOCA-750-90M	+		
2069	1198	12	1.94E-09	0.97639	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2070					NRAC-7HR	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2071					/QS-SBO	*	RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
2072	1197	12	1.94E-09	0.97645	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2073					NRAC-7HR	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2074					/QS-SBO	*	RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
2075	1046	12	1.94E-09	0.97651	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2076					NRAC-7HR	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2077					/QS-SBO	*	RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
2078	1045	12	1.94E-09	0.97657	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2079					NRAC-7HR	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2080					/QS-SBO	*	RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
2081	2665	7	1.93E-09	0.97663	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
2082					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+		
2083	2666	7	1.93E-09	0.97669	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
2084					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+		
2085	690	9	1.92E-09	0.97675	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2086					OEP-CRB-FT-15J3	*	OEP-DGN-FR-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
2087					SBO-PORV-DMD	+						
2088	689	9	1.92E-09	0.97680	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2089					OEP-CRB-FT-15H3	*	OEP-DGN-FR-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
2090					SBO-PORV-DMD	+						
2091	687	9	1.92E-09	0.97686	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2092					OEP-CRB-FT-15H3	*	OEP-DGN-FR-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*
2093					SBO-PORV-DMD	+						
2094	688	9	1.92E-09	0.97692	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2095					OEP-CRB-FT-15J3	*	OEP-DGN-FR-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
2096					SBO-PORV-DMD	+						
2097	692	10	1.92E-09	0.97698	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2098					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	QS-SBO	*
2099					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2100	691	10	1.92E-09	0.97704	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2101					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
2102					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2103	958	11	1.92E-09	0.97710	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2104					NRAC-258M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
2105					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		
2106	957	11	1.92E-09	0.97715	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2107					NRAC-258M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
2108					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		
2109	2718	5	1.91E-09	0.97721	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2110					IE-T5B	+						
2111	2693	5	1.91E-09	0.97727	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2112					IE-T5A	+						
2113	459	9	1.90E-09	0.97733	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
2114					NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	QS-SBO	*
2115					REC-XHE-FO-DGEN	+						
2116	102	3	1.89E-09	0.97738	IE-S1	*	LPI-MDP-FR-B21HR	*	LPR-MOV-FT-1860A	+		
2117	101	3	1.89E-09	0.97744	IE-S1	*	LPI-MDP-FR-A21HR	*	LPI-MDP-FS-S11B	+		
2118	100	3	1.89E-09	0.97750	IE-S1	*	LPI-MDP-FR-A21HR	*	LPR-MOV-FT-1860B	+		

2119	99	3	1.89E-09	0.97756	IE-S1	*	LPI-MDP-FR-B21HR	*	LPI-MDP-FS-S11A	+
2120	42	3	1.87E-09	0.97761	IE-A	*	LPI-MDP-FR-B24HR	*	LPR-MOV-FT-1862A	+
2121	41	3	1.87E-09	0.97767	IE-A	*	LPI-MDP-FR-A24HR	*	LPR-MOV-FT-1862B	+
2122	463	10	1.85E-09	0.97773	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*
2123					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*
2124					/QS-SBO	*	REC-XHE-FO-DGEN	+		
2125	462	10	1.85E-09	0.97778	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*
2126					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*
2127					/QS-SBO	*	REC-XHE-FO-DGEN	+		
2128	461	10	1.85E-09	0.97784	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*
2129					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*
2130					/QS-SBO	*	REC-XHE-FO-DGEN	+		
2131	460	10	1.85E-09	0.97789	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*
2132					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*
2133					/QS-SBO	*	REC-XHE-FO-DGEN	+		
2134	507	9	1.84E-09	0.97795	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*
2135					NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*
2136					REC-XHE-FO-DGEN	+			NOTQ	*
2137	959	11	1.84E-09	0.97801	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*
2138					NOTQ	*	NRAC-258M	*	OEP-DGN-FR-6HDG1	*
2139					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
2140	250	12	1.82E-09	0.97806	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
2141					NRAC-7HR	*	NSLOCA	*	/O	*
2142					OEP-DGN-FR-6HDG2	*	/QS-SBO	*	REC-XHE-FO-DGHWS	*
2143	960	12	1.82E-09	0.97812	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
2144					NRAC-246M	*	O	*	OEP-DGN-FS-DG01	*
2145					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*
2146	961	12	1.82E-09	0.97817	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*
2147					NRAC-246M	*	O	*	OEP-DGN-FS-DG01	*
2148					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*
2149	1863	10	1.81E-09	0.97823	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
2150					OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG03	*
2151					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2152	1861	10	1.81E-09	0.97828	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
2153					OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG02	*
2154					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2155	1860	10	1.81E-09	0.97834	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
2156					OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
2157					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2158	1865	10	1.81E-09	0.97839	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
2159					OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
2160					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2161	1864	10	1.81E-09	0.97845	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
2162					OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
2163					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2164	1862	10	1.81E-09	0.97850	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
2165					OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*
2166					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2167	557	9	1.81E-09	0.97856	AFW-TDP-FS-FW2	*	BETA-2DG	*	BETA-3DG	*
2168					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
2169					REC-XHE-FO-DGEN	+			IE-T1	*
2170	1047	12	1.81E-09	0.97861	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
2171					NOTQ	*	NRAC-7HR	*	/O	*
2172					/QS-SBO	*	RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	+
2173	1199	12	1.81E-09	0.97867	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
2174					NOTQ	*	NRAC-7HR	*	/O	*
									NOTL-SBOU1	*
									OEP-DGN-FS	*
									REC-XHE-FO-SCOOL	+
									NOTL-SBOU1	*
									OEP-DGN-FS	*

2175					/QS-SBO	*	RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2176	864	11	1.77E-09	0.97872	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2177					NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*
2178					OEP-DGN-FR-6HDG3	*	/QS-SBO	*	RCP-LOCA-750-90M	+		
2179	2761	8	1.76E-09	0.97877	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-FC-OPER	*
2180					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
2181	2760	8	1.76E-09	0.97883	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-FC-OPER	*
2182					PPS-SOV-OO-1456	*	RCS-PGRV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
2183	1866	11	1.76E-09	0.97888	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-201M	*
2184					O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
2185					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2186	964	11	1.76E-09	0.97893	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2187					NRAC-258M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
2188					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
2189	963	11	1.76E-09	0.97899	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2190					NRAC-258M	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
2191					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
2192	962	11	1.76E-09	0.97904	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2193					NRAC-258M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
2194					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
2195	1928	11	1.75E-09	0.97909	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*
2196					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
2197					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
2198	1926	11	1.75E-09	0.97914	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*
2199					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*
2200					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
2201	1927	11	1.75E-09	0.97920	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*
2202					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*
2203					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
2204	251	12	1.75E-09	0.97925	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2205					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2206					OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2207	252	12	1.75E-09	0.97930	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2208					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2209					OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2210	894	10	1.73E-09	0.97936	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2211					OEP-CRB-FT-15H3	*	OEP-DGN-FR-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
2212					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2213	693	10	1.73E-09	0.97941	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2214					OEP-CRB-FT-15H3	*	OEP-DGN-FR-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
2215					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2216	558	10	1.71E-09	0.97946	AFW-TDP-FS-FW2	*	BETA-2DG	*	BETA-3DG	*	IE-T1	*
2217					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*
2218					REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+				
2219	469	10	1.70E-09	0.97951	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2220					NOTQ	*	NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
2221					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2222	468	10	1.70E-09	0.97956	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2223					NOTQ	*	NRAC-HALFHR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
2224					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2225	467	10	1.70E-09	0.97961	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2226					NOTQ	*	NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
2227					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2228	2598	6	1.70E-09	0.97967	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
2229					OEP-DGN-FC-DG3U2	*	PPS-MOV-FC-1536	+				
2230	1502	12	1.69E-09	0.97972	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

2231					NRAC-7HR	* /O				* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
2232					/QS-SBO	* RCP-LOCA-183-90				* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2233	1501	12	1.69E-09	0.97977	/DGN-FTO	* IE-T1				* NOTL-SBOU1	* NOTQ	*
2234					NRAC-7HR	* /O				* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
2235					/QS-SBO	* RCP-LOCA-183-90				* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2236	965	12	1.69E-09	0.97982	BETA-2DG	* IE-T1				* NOTDG-CCF	* NOTL-SBOU1	*
2237					NOTQ	* NRAC-246M				* O	* OEP-DGN-FS	*
2238					/QS-SBO	* RCP-LOCA-467-150				* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2239	311	10	1.69E-09	0.97987	IE-T1	* NOTL-SBOU1U2				* NOTQ	* NRAC-7HR	*
2240					NSLOCA	* OEP-DGN-FS-DG01				* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*
2241					QS-SBO	* REC-XHE-FO-DGHWS	+					
2242	968	11	1.69E-09	0.97992	/DGN-FTO	* IE-T1				* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2243					NOTQ	* NRAC-258M				* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
2244					QS-SBO	* RCP-LOCA-467-150				* REC-XHE-FO-DGHWS		
2245	966	11	1.69E-09	0.97997	/DGN-FTO	* IE-T1				* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2246					NOTQ	* NRAC-258M				* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
2247					QS-SBO	* RCP-LOCA-467-150				* REC-XHE-FO-DGHWS		
2248	967	11	1.69E-09	0.98002	/DGN-FTO	* IE-T1				* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2249					NOTQ	* NRAC-258M				* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
2250					QS-SBO	* RCP-LOCA-467-150				* REC-XHE-FO-DGHWS		
2251	969	11	1.69E-09	0.98008	/DGN-FTO	* IE-T1				* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2252					NOTQ	* NRAC-258M				* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
2253					QS-SBO	* RCP-LOCA-467-150				* REC-XHE-FO-DGHWS		
2254	473	10	1.68E-09	0.98013	AFW-TDP-MA-FW2	* AFW-XHE-FO-U1SBO				* /DGN-FTO	* IE-T1	*
2255					NOTQ	* NRAC-HALFHR				* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG02	*
2256					/QS-SBO	* REC-XHE-FO-DGEN	+					
2257	471	10	1.68E-09	0.98018	AFW-TDP-MA-FW2	* AFW-XHE-FO-U1SBO				* /DGN-FTO	* IE-T1	*
2258					NOTQ	* NRAC-HALFHR				* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03	*
2259					/QS-SBO	* REC-XHE-FO-DGEN	+					
2260	470	10	1.68E-09	0.98023	AFW-TDP-MA-FW2	* AFW-XHE-FO-U1SBO				* /DGN-FTO	* IE-T1	*
2261					NOTQ	* NRAC-HALFHR				* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01	*
2262					/QS-SBO	* REC-XHE-FO-DGEN	+					
2263	472	10	1.68E-09	0.98028	AFW-TDP-MA-FW2	* AFW-XHE-FO-U1SBO				* /DGN-FTO	* IE-T1	*
2264					NOTQ	* NRAC-HALFHR				* OEP-DGN-FR-6HDG2	* OEP-DGN-MA-DG01	*
2265					/QS-SBO	* REC-XHE-FO-DGEN	+					
2266	971	11	1.68E-09	0.98033	/DGN-FTO	* IE-T1				* NOTL-SBOU1	* NOTQ	*
2267					NRAC-258M	* OEP-DGN-FR-6HDG1				* OEP-DGN-MA-DG03	* QS-SBO	*
2268					RCP-LOCA-467-150	* REC-XHE-FO-DGTMS				* REC-XHE-FO-SCOOL		
2269	970	11	1.68E-09	0.98038	/DGN-FTO	* IE-T1				* NOTL-SBOU1	* NOTQ	*
2270					NRAC-258M	* OEP-DGN-FR-6HDG3				* OEP-DGN-MA-DG01	* QS-SBO	*
2271					RCP-LOCA-467-150	* REC-XHE-FO-DGTMS				* REC-XHE-FO-SCOOL		
2272	474	10	1.67E-09	0.98043	AFW-TDP-FS-FW2	* AFW-TDP-FS-U2FW2				* /DGN-FTO	* IE-T1	*
2273					NOTQ	* NRAC-HALFHR				* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
2274					/QS-SBO	* REC-XHE-FO-DGEN	+					
2275	475	10	1.67E-09	0.98048	AFW-TDP-FS-FW2	* AFW-TDP-FS-U2FW2				* /DGN-FTO	* IE-T1	*
2276					NOTQ	* NRAC-HALFHR				* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
2277					/QS-SBO	* REC-XHE-FO-DGEN	+					
2278	1868	10	1.66E-09	0.98053	IE-T1	* NOTL-SBOU1U2				* NOTQ	* NRAC-216M	*
2279					OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01				* OEP-DGN-FS-DG02	* QS-SBO	*
2280					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+					
2281	1867	10	1.66E-09	0.98058	IE-T1	* NOTL-SBOU1U2				* NOTQ	* NRAC-216M	*
2282					OEP-CRB-FT-25H3	* OEP-DGN-FS-DG01				* OEP-DGN-FS-DG03	* QS-SBO	*
2283					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+					
2284	1869	10	1.66E-09	0.98063	IE-T1	* NOTL-SBOU1U2				* NOTQ	* NRAC-216M	*
2285					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02				* OEP-DGN-FS-DG03	* QS-SBO	*
2286					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+					

2287	2600	6	1.85E-09	0.98068	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T1 *	NRAC-HALFHR *
2288					OEP-DGN-FS-DG01 *	PPS-MOV-FC-1535 +		
2289	2599	8	1.85E-09	0.98073	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T1 *	NRAC-HALFHR *
2290					OEP-DGN-FS-DG03 *	PPS-MOV-FC-1536 +		
2291	559	9	1.64E-09	0.98078	AFW-TDP-MA-FW2 *	BETA-2DG *	BETA-3DG *	IE-T1 *
2292					NOTQ *	NRAC-HALFHR *	OEP-DGN-FS *	QS-SBO *
2293					REC-XHE-FO-DGEN +			
2294	524	10	1.63E-09	0.98083	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-U1SBO *	/DGN-FTO *	IE-T1 *
2295					NOTQ *	NRAC-6HR-AVG *	OEP-DGN-FR-6HDG3 *	OEP-DGN-MA-DG01 *
2296					/QS-SBO *	REC-XHE-FO-DGEN +		
2297	523	10	1.63E-09	0.98088	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-U1SBO *	/DGN-FTO *	IE-T1 *
2298					NOTQ *	NRAC-6HR-AVG *	OEP-DGN-FR-6HDG2 *	OEP-DGN-MA-DG01 *
2299					/QS-SBO *	REC-XHE-FO-DGEN +		
2300	522	10	1.63E-09	0.98093	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-U1SBO *	/DGN-FTO *	IE-T1 *
2301					NOTQ *	NRAC-6HR-AVG *	OEP-DGN-FR-6HDG1 *	OEP-DGN-MA-DG03 *
2302					/QS-SBO *	REC-XHE-FO-DGEN +		
2303	521	10	1.63E-09	0.98098	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-U1SBO *	/DGN-FTO *	IE-T1 *
2304					NOTQ *	NRAC-6HR-AVG *	OEP-DGN-FR-6HDG1 *	OEP-DGN-MA-DG02 *
2305					/QS-SBO *	REC-XHE-FO-DGEN +		
2306	1930	11	1.60E-09	0.98103	IE-T1 *	NOTL-SBOU1U2 *	NOTQ *	NRAC-258M *
2307					/O *	OEP-DGN-FS-DG01 *	OEP-DGN-FS-DG03 *	OEP-DGN-MA-DG02 *
2308					/QS-SBO *	RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS +	
2309	1929	11	1.80E-09	0.98108	IE-T1 *	NOTL-SBOU1U2 *	NOTQ *	NRAC-258M *
2310					/O *	OEP-DGN-FS-DG01 *	OEP-DGN-FS-DG02 *	OEP-DGN-MA-DG03 *
2311					/QS-SBO *	RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS +	
2312	1931	11	1.80E-09	0.98113	IE-T1 *	NOTL-SBOU1U2 *	NOTQ *	NRAC-258M *
2313					/O *	OEP-DGN-FS-DG02 *	OEP-DGN-FS-DG03 *	OEP-DGN-MA-DG01 *
2314					/QS-SBO *	RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS +	
2315	253	12	1.80E-09	0.98118	/DGN-FTO *	IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
2316					NOTQ *	NRAC-7HR *	NSLOCA *	/O *
2317					OEP-CRB-FT-15H3 *	OEP-DGN-FS-DG02 *	/QS-SBO *	REC-XHE-FO-DGHWB +
2318	254	12	1.80E-09	0.98123	/DGN-FTO *	IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
2319					NOTQ *	NRAC-7HR *	NSLOCA *	/O *
2320					OEP-CRB-FT-15J3 *	OEP-DGN-FS-DG01 *	/QS-SBO *	REC-XHE-FO-DGHWB +
2321	255	12	1.80E-09	0.98127	/DGN-FTO *	IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
2322					NOTQ *	NRAC-7HR *	NSLOCA *	/O *
2323					OEP-CRB-FT-15H3 *	OEP-DGN-FS-DG03 *	/QS-SBO *	REC-XHE-FO-DGHWB +
2324	14	3	1.80E-09	0.98132	IE-A *	LPI-MDP-MA-SI1B *	SIS-ACT-FA-SISA +	
2325	15	3	1.80E-09	0.98137	IE-A *	LPI-MDP-MA-SI1A *	SIS-ACT-FA-SISB +	
2326	2741	4	1.80E-09	0.98142	HPI-CKV-OO-CV258 *	HPI-MDP-FR-1A6HR *	IE-T7 *	RCS-XHE-FO-DPT7D +
2327	865	10	1.60E-09	0.98147	/DGN-FTO *	IE-T1 *	NOTL-SBOU1 *	NOTQ *
2328					NRAC-216M *	OEP-CRB-FT-15H3 *	OEP-CRB-FT-15J3 *	QS-SBO *
2329					RCP-LOCA-750-90M *	REC-XHE-FO-SCOOL +		
2330	561	9	1.59E-09	0.98152	AFW-TDP-FR-2P6HR *	BETA-2DG *	BETA-3DG *	IE-T1 *
2331					NOTQ *	NRAC-6HR-AVG *	OEP-DGN-FS *	QS-SBO *
2332					REC-XHE-FO-DGEN +			
2333	1872	10	1.59E-09	0.98156	IE-T1 *	NOTL-SBOU1U2 *	NOTQ *	NRAC-216M *
2334					/O *	OEP-CRB-FT-15H3 *	OEP-DGN-FR-6HDG2 *	OEP-DGN-FR-6HDG3 *
2335					/QS-SBO *	RCP-LOCA-750-90M +		
2336	1871	10	1.59E-09	0.98161	IE-T1 *	NOTL-SBOU1U2 *	NOTQ *	NRAC-216M *
2337					/O *	OEP-CRB-FT-15J3 *	OEP-DGN-FR-6HDG1 *	OEP-DGN-FR-6HDG2 *
2338					/QS-SBO *	RCP-LOCA-750-90M +		
2339	1870	10	1.59E-09	0.98166	IE-T1 *	NOTL-SBOU1U2 *	NOTQ *	NRAC-216M *
2340					/O *	OEP-CRB-FT-25H3 *	OEP-DGN-FR-6HDG1 *	OEP-DGN-FR-6HDG3 *
2341					/QS-SBO *	RCP-LOCA-750-90M +		
2342	2667	7	1.58E-09	0.98171	AFW-MDP-FS *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	BETA-AFW *

2343					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+		
2344	2668	7	1.58E-09	0.98176	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2345					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+		
2346	1503	12	1.57E-09	0.98180	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
2347					NOTQ	*	NRAC-7HR	*	/O	*	OEP-DGN-FS	*
2348					/QS-SBO	*	RCP-LOCA-183-90	*	REC-XHE-FO-DGHS	*	REC-XHE-FO-SCool	+
2349	134	3	1.58E-09	0.98185	ACP-TFM-NO-1H1	*	HPI-MOV-FT-1867D	*	IE-S3	+		
2350	560	10	1.56E-09	0.98190	AFW-TDP-MA-FW2	*	BETA-2DG	*	BETA-3DG	*	IE-T1	*
2351					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*
2352					REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+				
2353	477	10	1.55E-09	0.98195	AFW-TDP-FS-FW2	*	AFW-TDP-FS-U2FW2	*	BETA-2DG	*	IE-T1	*
2354					NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
2355					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2356	480	10	1.54E-09	0.98199	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2357					NOTQ	*	NRAC-HALFHR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
2358					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2359	479	10	1.54E-09	0.98204	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2360					NOTQ	*	NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
2361					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2362	478	10	1.54E-09	0.98209	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2363					NOTQ	*	NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
2364					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2365	484	10	1.52E-09	0.98213	AFW-TDP-FS-FW2	*	AFW-TDP-MA-U2FW2	*	/DGN-FTO	*	IE-T1	*
2366					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2367					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2368	482	10	1.52E-09	0.98218	AFW-TDP-FS-U2FW2	*	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*
2369					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2370					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2371	481	10	1.52E-09	0.98222	AFW-TDP-FS-FW2	*	AFW-TDP-MA-U2FW2	*	/DGN-FTO	*	IE-T1	*
2372					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2373					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2374	483	10	1.52E-09	0.98227	AFW-TDP-FS-U2FW2	*	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*
2375					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2376					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2377	720	11	1.52E-09	0.98232	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2378					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*	PPS-SOV-OO-1456	*
2379					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
2380	719	11	1.52E-09	0.98236	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2381					NRAC-1HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*	PPS-SOV-OO-1456	*
2382					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
2383	718	11	1.52E-09	0.98241	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2384					NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*	PPS-SOV-OO-1456	*
2385					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
2386	717	11	1.52E-09	0.98245	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2387					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*
2388					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
2389	716	11	1.52E-09	0.98250	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2390					NRAC-1HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*
2391					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
2392	715	11	1.52E-09	0.98255	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2393					NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*
2394					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
2395	2670	8	1.51E-09	0.98259	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*
2396					BETA-AFW	*	IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT	+
2397	2669	8	1.51E-09	0.98264	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*
2398					BETA-AFW	*	IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT	+

E-65

2399	21	4	1.51E-09	0.98268	CON-VFC-RP-COREM	*	IE-A	*	SWS-CCF-FT-3ABCD	*	SWS-XHE-FO-OPEN	+
2400	563	10	1.51E-09	0.98273	AFW-TDP-FR-2P6HR	*	BETA-2DG	*	BETA-3DG	*	IE-T1	*
2401					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*	/QS-SBO	*
2402					REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+				
2403	17	3	1.50E-09	0.98278	IE-A	*	LPI-CKV-OO-CV58	*	LPI-MDP-FS-SI1A	+		
2404	16	3	1.50E-09	0.98282	IE-A	*	LPI-CKV-OO-CV50	*	LPI-MDP-FS-SI1B	+		
2405	531	10	1.50E-09	0.98287	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2406					NOTQ	*	NRAC-6HR-AVG	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
2407					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2408	530	10	1.50E-09	0.98291	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2409					NOTQ	*	NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
2410					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2411	529	10	1.50E-09	0.98296	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2412					NOTQ	*	NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
2413					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2414	2762	8	1.50E-09	0.98300	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-FC-OPER	*
2415					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
2416	2763	8	1.50E-09	0.98305	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-FC-OPER	*
2417					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
2418	972	11	1.48E-09	0.98309	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2419					NOTQ	*	NRAC-258M	*	/O	*	OEP-CRB-FT-15H3	*
2420					OEP-DGN-FR-6HDG3	*	/QS-SBO	*	RCP-LOCA-467-150	+		
2421	973	11	1.48E-09	0.98314	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2422					NOTQ	*	NRAC-258M	*	/O	*	OEP-CRB-FT-15J3	*
2423					OEP-DGN-FR-6HDG1	*	/QS-SBO	*	RCP-LOCA-467-150	+		
2424	534	10	1.47E-09	0.98318	AFW-TDP-FR-6HRU2	*	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*
2425					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2426					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2427	535	10	1.47E-09	0.98323	AFW-TDP-FR-2P6HR	*	AFW-TDP-FS-U2FW2	*	/DGN-FTO	*	IE-T1	*
2428					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2429					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2430	533	10	1.47E-09	0.98327	AFW-TDP-FR-6HRU2	*	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*
2431					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2432					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2433	532	10	1.47E-09	0.98332	AFW-TDP-FR-2P6HR	*	AFW-TDP-FS-U2FW2	*	/DGN-FTO	*	IE-T1	*
2434					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2435					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2436	867	12	1.47E-09	0.98336	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2437					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
2438					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2439	866	12	1.47E-09	0.98341	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2440					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
2441					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2442	257	12	1.46E-09	0.98345	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2443					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2444					OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	/QS-SBO	*	REC-XHE-FO-DGTMB	+
2445	258	11	1.46E-09	0.98349	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2446					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2447					OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3	*	/QS-SBO	+		
2448	259	11	1.46E-09	0.98354	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2449					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2450					OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1	*	/QS-SBO	+		
2451	256	12	1.46E-09	0.98358	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2452					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2453					OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	/QS-SBO	*	REC-XHE-FO-DGTMB	+
2454	1934	12	1.44E-09	0.98363	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*

2455					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS	*
2456					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
2457	1933	12	1.44E-09	0.98367	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2458					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS	*
2459					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
2460	1932	12	1.44E-09	0.98371	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2461					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS	*
2462					OEP-DGN-MA-DG02	*	/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+
2463	2672	6	1.43E-09	0.98376	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2464					IE-T2	*	PPS-SOV-FT-1455C	+				
2465	2671	6	1.43E-09	0.98380	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2466					IE-T2	*	PPS-SOV-FT-1456	+				
2467	2674	7	1.43E-09	0.98384	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2468					IE-T2	*	PPS-MOV-FC-1535	+	PPS-MOV-FT-1535	+		
2469	2673	7	1.43E-09	0.98389	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2470					IE-T2	*	PPS-MOV-FC-1536	+	PPS-MOV-FT-1536	+		
2471	261	11	1.41E-09	0.98393	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2472					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
2473					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
2474	260	11	1.41E-09	0.98397	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2475					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
2476					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
2477	868	12	1.41E-09	0.98402	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2478					NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*
2479					OEP-DGN-FR-6HDG2	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
2480	489	10	1.41E-09	0.98406	AFW-TDP-FS-FW2	*	AFW-TDP-MA-U2FW2	*	BETA-2DG	*	IE-T1	*
2481					NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
2482					/QS-SBO	*	REC-XHE-FO-DGEN	+			IE-T1	*
2483	490	10	1.41E-09	0.98410	AFW-TDP-FS-U2FW2	*	AFW-TDP-MA-FW2	*	BETA-2DG	*	OEP-DGN-FS	*
2484					NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*		
2485					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2486	2602	7	1.41E-09	0.98414	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2487					IE-T1	*	PPS-MOV-FC-1535	+	PPS-MOV-FT-1535	+		
2488	2601	7	1.41E-09	0.98419	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2489					IE-T1	*	PPS-MOV-FC-1536	+	PPS-MOV-FT-1536	+		
2490	2752	5	1.40E-09	0.98423	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2491					IE-T7	+						
2492	491	9	1.39E-09	0.98427	AFW-CKV-OO-CV172	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
2493					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
2494					REC-XHE-FO-DGEN	+						
2495	493	10	1.38E-09	0.98431	AFW-TDP-MA-FW2	*	AFW-TDP-MA-U2FW2	*	/DGN-FTO	*	IE-T1	*
2496					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2497					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2498	492	10	1.38E-09	0.98435	AFW-TDP-MA-FW2	*	AFW-TDP-MA-U2FW2	*	/DGN-FTO	*	IE-T1	*
2499					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2500					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2501	537	10	1.37E-09	0.98440	AFW-TDP-FR-2P6HR	*	AFW-TDP-FS-U2FW2	*	BETA-2DG	*	IE-T1	*
2502					NOTDG-CCF	*	NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*
2503					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2504	536	10	1.37E-09	0.98444	AFW-TDP-FR-6HRU2	*	AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*
2505					NOTDG-CCF	*	NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*
2506					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2507	262	11	1.36E-09	0.98448	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2508					NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FR-6HDG1	*
2509					OEP-DGN-FR-6HDG2	*	QS-SBO	*	REC-XHE-FO-DGHWB	+		
2510	580	10	1.36E-09	0.98452	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*

2511					NOTQ	*	NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG02	*
2512					QS-SBO	*	REC-XHE-FO-DGEN	+				
2513	581	10	1.36E-09	0.98456	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
2514					NOTQ	*	NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG01	*
2515					QS-SBO	*	REC-XHE-FO-DGEN	+				
2516	579	10	1.36E-09	0.98460	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
2517					NOTQ	*	NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG03	*
2518					QS-SBO	*	REC-XHE-FO-DGEN	+				
2519	18	2	1.35E-09	0.98464	IE-A	*	RWT-TNK-LF-RWST	+				
2520	871	12	1.35E-09	0.98468	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2521					NRAC-201M	*	O	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
2522					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2523	870	12	1.35E-09	0.98473	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2524					NRAC-201M	*	O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
2525					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2526	869	12	1.35E-09	0.98477	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2527					NRAC-201M	*	O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
2528					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2529	2603	5	1.34E-09	0.98481	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
2530					PPS-XHE-FO-PORVS	+						
2531	2629	5	1.34E-09	0.98485	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1867C	*
2532					IE-T2	+						
2533	2628	5	1.34E-09	0.98489	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1115B	*
2534					IE-T2	+						
2535	541	10	1.34E-09	0.98493	AFW-TDP-FR-6HRU2	*	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*
2536					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2537					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2538	540	10	1.34E-09	0.98497	AFW-TDP-FR-2P6HR	*	AFW-TDP-MA-U2FW2	*	/DGN-FTO	*	IE-T1	*
2539					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
2540					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2541	539	10	1.34E-09	0.98501	AFW-TDP-FR-2P6HR	*	AFW-TDP-MA-U2FW2	*	/DGN-FTO	*	IE-T1	*
2542					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2543					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2544	538	10	1.34E-09	0.98505	AFW-TDP-FR-6HRU2	*	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*
2545					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
2546					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2547	263	11	1.30E-09	0.98509	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2548					NRAC-7HR	*	NSLOCA	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
2549					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
2550	265	11	1.30E-09	0.98513	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2551					NRAC-7HR	*	NSLOCA	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
2552					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
2553	264	11	1.30E-09	0.98517	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2554					NRAC-7HR	*	NSLOCA	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
2555					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
2556	875	12	1.30E-09	0.98521	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2557					NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FS-DG02	*
2558					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
2559	874	12	1.30E-09	0.98525	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2560					NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*
2561					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
2562	873	12	1.30E-09	0.98529	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2563					NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FS-DG03	*
2564					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
2565	872	12	1.30E-09	0.98533	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2566					NOTQ	*	NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*

2567					OEP-DGN-MA-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
2568	313	11	1.29E-09	0.98536	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-7HR	*
2569					NSLOCA	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
2570					OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+		
2571	314	11	1.29E-09	0.98540	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-7HR	*
2572					NSLOCA	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*
2573					OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+		
2574	312	11	1.29E-09	0.98544	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-7HR	*
2575					NSLOCA	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*
2576					OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+		
2577	877	12	1.29E-09	0.98548	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2578					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*
2579					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
2580	876	12	1.29E-09	0.98552	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2581					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
2582					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
2583	494	10	1.28E-09	0.98556	AFW-TDP-MA-FW2	*	AFW-TDP-MA-U2FW2	*	BETA-2DG	*	IE-T1	*
2584					NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
2585					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2586	696	9	1.28E-09	0.98560	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2587					OEP-DGN-FR-DG01	*	OEP-DGN-FR-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*
2588					SBO-PORV-DMD	+						
2589	695	9	1.28E-09	0.98564	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2590					OEP-DGN-FR-DG01	*	OEP-DGN-FR-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
2591					SBO-PORV-DMD	+						
2592	43	3	1.28E-09	0.98568	IE-A	*	RMT-ACT-FA-RMTSA	*	RMT-ACT-FA-RMTSB	+		
2593	19	3	1.28E-09	0.98572	IE-A	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+		
2594	704	10	1.28E-09	0.98575	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2595					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*	QS-SBO	*
2596					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2597	703	10	1.28E-09	0.98579	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2598					OEP-DGN-FR-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	QS-SBO	*
2599					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2600	702	10	1.28E-09	0.98583	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2601					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*	QS-SBO	*
2602					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2603	701	10	1.28E-09	0.98587	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2604					OEP-DGN-FR-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	QS-SBO	*
2605					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2606	700	10	1.28E-09	0.98591	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2607					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	QS-SBO	*
2608					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2609	699	10	1.28E-09	0.98595	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2610					OEP-DGN-FR-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
2611					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2612	698	10	1.28E-09	0.98599	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2613					OEP-DGN-FR-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	QS-SBO	*
2614					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2615	697	10	1.28E-09	0.98603	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
2616					OEP-DGN-FR-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	QS-SBO	*
2617					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
2618	2753	5	1.27E-09	0.98606	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
2619					IE-T7	+						
2620	104	3	1.26E-09	0.98610	IE-S1	*	LPI-MDP-FR-A21HR	*	LPI-MDP-MA-S11B	+		
2621	103	3	1.26E-09	0.98614	IE-S1	*	LPI-MDP-FR-B21HR	*	LPI-MDP-MA-S11A	+		
2622	267	12	1.26E-09	0.98618	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

2623					NRAC-7HR	*	NSLOCA	*	O	*	OEP-DGN-FS-DG01	*
2624					OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOOL	+
2625	268	12	1.26E-09	0.98622	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2626					NRAC-7HR	*	NSLOCA	*	O	*	OEP-DGN-FS-DG01	*
2627					OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOOL	+
2628	1937	10	1.25E-09	0.98626	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*
2629					OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
2630					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+				
2631	1936	10	1.25E-09	0.98629	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*
2632					OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	QS-SBO	*
2633					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+				
2634	1935	10	1.25E-09	0.98633	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*
2635					OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
2636					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+				
2637	546	10	1.25E-09	0.98637	AFW-TDP-FR-2P6HR	*	AFW-TDP-MA-U2FW2	*	BETA-2DG	*	IE-T1	*
2638					NOTDG-CCF	*	NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*
2639					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2640	547	10	1.25E-09	0.98641	AFW-TDP-FR-6HRU2	*	AFW-TDP-MA-FW2	*	BETA-2DG	*	IE-T1	*
2641					NOTDG-CCF	*	NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*
2642					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2643	269	11	1.24E-09	0.98644	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2644					NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*
2645					OEP-DGN-MA-DG03	*	QS-SBO	*	REC-XHE-FO-DGHWB	+		
2646	270	11	1.24E-09	0.98648	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2647					NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG02	*
2648					OEP-DGN-MA-DG01	*	QS-SBO	*	REC-XHE-FO-DGHWB	+		
2649	271	11	1.24E-09	0.98652	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2650					NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG03	*
2651					OEP-DGN-MA-DG01	*	QS-SBO	*	REC-XHE-FO-DGHWB	+		
2652	268	11	1.24E-09	0.98656	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2653					NOTQ	*	NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*
2654					OEP-DGN-MA-DG02	*	QS-SBO	*	REC-XHE-FO-DGHWB	+		
2655	135	4	1.24E-09	0.98659	CPC-MDP-FR-CCA24	*	CPC-MDP-FS-CC2B	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
2656	974	12	1.23E-09	0.98663	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2657					NRAC-258M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*
2658					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
2659	878	11	1.23E-09	0.98667	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2660					NOTQ	*	NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*
2661					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
2662	136	5	1.22E-09	0.98671	CPC-MDP-FR-SWA24	*	CPC-MDP-FS-SW10B	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S3	*
2663					IE-S3	+						
2664	586	10	1.21E-09	0.98674	AFW-TDP-FS-FW2	*	IE-T1	*	NOTQ	*	NRAC-HALFHR	*
2665					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	/QS-SBO	*
2666					REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+				
2667	975	10	1.20E-09	0.98678	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2668					NRAC-258M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3	*	QS-SBO	*
2669					RCP-LOCA-467-150	*	REC-XHE-FO-SCOOOL	+				
2670	976	10	1.20E-09	0.98682	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2671					NRAC-258M	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1	*	QS-SBO	*
2672					RCP-LOCA-467-150	*	REC-XHE-FO-SCOOOL	+				
2673	549	10	1.20E-09	0.98685	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	IE-T1	*
2674					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*
2675					/QS-SBO	*	REC-XHE-FO-DGEN	+				
2676	548	10	1.20E-09	0.98689	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	IE-T1	*
2677					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
2678					/QS-SBO	*	REC-XHE-FO-DGEN	+				

2679	1938	10	1.19E-09	0.98692	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-258M	*
2680					/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	* OEP-DGN-FR-6HDG3	*
2681					/QS-SBO	* RCP-LOCA-467-150	+		
2682	1352	12	1.19E-09	0.98696	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2683					NRAC-150M	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
2684					/QS-SBO	* RCP-LOCA-1440-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
2685	1355	12	1.19E-09	0.98700	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2686					NRAC-150M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
2687					/QS-SBO	* RCP-LOCA-1440-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
2688	1354	12	1.19E-09	0.98703	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2689					NRAC-150M	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
2690					/QS-SBO	* RCP-LOCA-1440-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
2691	1353	12	1.19E-09	0.98707	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2692					NRAC-150M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
2693					/QS-SBO	* RCP-LOCA-1440-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
2694	2719	4	1.19E-09	0.98710	AFW-ACT-FA-PMP3A	* AFW-TDP-FS-FW2	* AFW-XHE-FO-UNIT2	* IE-T5B	+
2695	2694	4	1.19E-09	0.98714	AFW-ACT-FA-PMP3B	* AFW-TDP-FS-FW2	* AFW-XHE-FO-UNIT2	* IE-T5A	+
2696	315	11	1.18E-09	0.98718	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
2697					NSLOCA	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
2698					OEP-DGN-MA-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
2699	316	11	1.18E-09	0.98721	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
2700					NSLOCA	* /O	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*
2701					OEP-DGN-MA-DG01	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
2702	317	11	1.18E-09	0.98725	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
2703					NSLOCA	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
2704					OEP-DGN-MA-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
2705	977	12	1.18E-09	0.98728	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2706					NOTQ	* NRAC-258M	* /O	* OEP-CRB-FT-15H3	*
2707					OEP-DGN-FR-6HDG2	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
2708	272	11	1.18E-09	0.98732	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2709					NRAC-7HR	* NSLOCA	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03	*
2710					QS-SBO	* REC-XHE-FO-DGTMB	* REC-XHE-FO-SCOO	+	
2711	273	11	1.18E-09	0.98736	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2712					NRAC-7HR	* NSLOCA	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01	*
2713					QS-SBO	* REC-XHE-FO-DGTMB	* REC-XHE-FO-SCOO	+	
2714	275	10	1.18E-09	0.98739	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2715					NRAC-7HR	* NSLOCA	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG3	*
2716					QS-SBO	* REC-XHE-FO-SCOO	+		
2717	274	10	1.18E-09	0.98743	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2718					NRAC-7HR	* NSLOCA	* OEP-CRB-FT-15J3	* OEP-DGN-FR-6HDG1	*
2719					QS-SBO	* REC-XHE-FO-SCOO	+		
2720	2604	7	1.18E-09	0.98746	AFW-MDP-FS-FW3A	* AFW-TDP-FS-FW2	* AFW-XHE-FO-UNIT2	* IE-T1	*
2721					NRAC-HALFHR	* OEP-DGN-FC-DG3U2	* PPS-MOV-FC-1536	+	
2722	318	10	1.17E-09	0.98750	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
2723					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
2724					OEP-DGN-FR-6HDG3	* /QS-SBO	+		
2725	276	12	1.17E-09	0.98753	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
2726					NOTQ	* NRAC-7HR	* NSLOCA	* O	*
2727					OEP-DGN-FS	* /QS-SBO	* REC-XHE-FO-DGHWB	* REC-XHE-FO-SCOO	+
2728	1878	11	1.17E-09	0.98757	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
2729					/O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG02	*
2730					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2731	1877	11	1.17E-09	0.98760	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
2732					/O	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
2733					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2734	1876	11	1.17E-09	0.98764	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*

2735					/O	* OEP-CRB-FT-25H3	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
2736					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2737	1874	11	1.17E-09	0.98788	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
2738					/O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG03	*
2739					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2740	1873	11	1.17E-09	0.98771	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
2741					/O	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
2742					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2743	1875	11	1.17E-09	0.98775	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
2744					/O	* OEP-CRB-FT-25H3	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
2745					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2746	706	10	1.15E-09	0.98778	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
2747					OEP-DGN-FR-DG01	* OEP-DGN-FR-DG02	* PPS-SOV-OO-1456	* /QS-SBO	*
2748					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
2749	705	10	1.15E-09	0.98782	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
2750					OEP-DGN-FR-DG01	* OEP-DGN-FR-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
2751					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
2752	722	10	1.15E-09	0.98785	IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	* OEP-DGN-FS-DG01	*
2753					OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1456	* QS-SBO	*
2754					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
2755	721	10	1.15E-09	0.98789	IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	* OEP-DGN-FS-DG01	*
2756					OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* QS-SBO	*
2757					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
2758	2721	4	1.13E-09	0.98792	AFW-CKV-OO-CV157	* AFW-MDP-FS-FW3A	* AFW-XHE-FO-UNIT2	* IE-T5B	+
2759	2695	4	1.13E-09	0.98795	AFW-CKV-OO-CV172	* AFW-MDP-FS-FW3B	* AFW-XHE-FO-UNIT2	* IE-T5A	+
2760	2696	4	1.13E-09	0.98799	AFW-CKV-OO-CV157	* AFW-MDP-FS-FW3A	* AFW-XHE-FO-UNIT2	* IE-T5A	+
2761	2720	4	1.13E-09	0.98802	AFW-CKV-OO-CV172	* AFW-MDP-FS-FW3B	* AFW-XHE-FO-UNIT2	* IE-T5B	+
2762	496	10	1.13E-09	0.98806	AFW-CKV-OO-CV172	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
2763					NOTQ	* NRAC-HALFHR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
2764					/QS-SBO	* REC-XHE-FO-DGEN	+		
2765	495	10	1.13E-09	0.98809	AFW-CKV-OO-CV172	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
2766					NOTQ	* NRAC-HALFHR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
2767					/QS-SBO	* REC-XHE-FO-DGEN	+		
2768	614	9	1.13E-09	0.98813	AFW-TDP-FR-2P6HR	* IE-T1	* NOTQ	* NRAC-6HR-AVG	*
2769					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* QS-SBO	*
2770					REC-XHE-FO-DGEN	+			
2771	1940	11	1.12E-09	0.98816	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
2772					NOTQ	* NRAC-258M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS	*
2773					QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+	
2774	1939	11	1.12E-09	0.98819	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
2775					NOTQ	* NRAC-258M	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS	*
2776					QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+	
2777	1941	11	1.12E-09	0.98823	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
2778					NOTQ	* NRAC-258M	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS	*
2779					QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+	
2780	1654	12	1.11E-09	0.98826	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2781					NRAC-246M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
2782					/QS-SBO	* RCP-LOCA-561-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2783	1653	12	1.11E-09	0.98829	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2784					NRAC-246M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
2785					/QS-SBO	* RCP-LOCA-561-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2786	588	10	1.10E-09	0.98833	AFW-TDP-MA-FW2	* IE-T1	* NOTQ	* NRAC-HALFHR	*
2787					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* /QS-SBO	*
2788					REC-XHE-FO-DGEN	* UNIT2-LOW-POWER	+		
2789	2605	6	1.10E-09	0.98836	AFW-CCF-LK-STMBD	* AFW-XHE-FO-UNIT2	* IE-T1	* NRAC-HALFHR	*
2790					OEP-DGN-FS-DG01	* PPS-MOV-FC-1535	+		

2791	2606	6	1.10E-09	0.98839	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
2792					OEP-DGN-FS-DG03	*	PPS-MOV-FC-1536	+			IE-T1	*
2793	551	10	1.10E-09	0.98843	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	OEP-DGN-MA-DG02	*
2794					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*		
2795					/QS-SBO	*	REC-XHE-FO-DGEN	+			IE-T1	*
2796	554	10	1.10E-09	0.98846	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	OEP-DGN-MA-DG01	*
2797					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG02	*		
2798					/QS-SBO	*	REC-XHE-FO-DGEN	+			IE-T1	*
2799	553	10	1.10E-09	0.98849	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	OEP-DGN-MA-DG01	*
2800					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG03	*		
2801					/QS-SBO	*	REC-XHE-FO-DGEN	+			IE-T1	*
2802	552	10	1.10E-09	0.98853	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	/DGN-FTO	*	OEP-DGN-MA-DG03	*
2803					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*		
2804					/QS-SBO	*	REC-XHE-FO-DGEN	+			IE-T1	*
2805	47	3	1.08E-09	0.98856	IE-A	*	LPI-MDP-FR-B24HR	*	LPR-MOV-FT-1860A	+		
2806	46	3	1.08E-09	0.98859	IE-A	*	LPI-MDP-FR-A24HR	*	LPI-MDP-FS-SI1B	+		
2807	45	3	1.08E-09	0.98863	IE-A	*	LPI-MDP-FR-A24HR	*	LPR-MOV-FT-1860B	+		
2808	44	3	1.08E-09	0.98866	IE-A	*	LPI-MDP-FR-B24HR	*	LPI-MDP-FS-SI1A	+		
2809	2743	4	1.08E-09	0.98869	ACP-BAC-ST-4KV1H	*	HPI-MOV-FT-1867D	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
2810	2742	4	1.08E-09	0.98872	ACP-BAC-ST-1H1	*	HPI-MOV-FT-1867D	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
2811	2722	4	1.08E-09	0.98876	AFW-ACT-FA-PMP3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
2812	2697	4	1.08E-09	0.98879	AFW-ACT-FA-PMP3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
2813	978	12	1.08E-09	0.98882	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2814					NRAC-258M	*	/O	*	OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*
2815					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
2816	979	12	1.08E-09	0.98885	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2817					NRAC-258M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*
2818					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
2819	880	11	1.07E-09	0.98889	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2820					NOTQ	*	NRAC-218M	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*
2821					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+		
2822	879	11	1.07E-09	0.98892	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2823					NOTQ	*	NRAC-218M	*	OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*
2824					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+		
2825	321	12	1.06E-09	0.98895	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2826					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2827					OEP-DGN-FS	*	OEP-DGN-MA-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2828	320	12	1.06E-09	0.98898	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2829					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2830					OEP-DGN-FS	*	OEP-DGN-MA-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2831	319	12	1.06E-09	0.98902	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
2832					NOTQ	*	NRAC-7HR	*	NSLOCA	*	/O	*
2833					OEP-DGN-FS	*	OEP-DGN-MA-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
2834	1201	12	1.06E-09	0.98905	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2835					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
2836					/QS-SBO	*	RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2837	1203	12	1.06E-09	0.98908	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2838					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
2839					/QS-SBO	*	RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2840	1200	12	1.06E-09	0.98911	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2841					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
2842					/QS-SBO	*	RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2843	1202	12	1.06E-09	0.98915	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2844					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
2845					/QS-SBO	*	RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2846	1051	12	1.06E-09	0.98918	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

2847					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
2848					/QS-SBO	*	RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2849	1050	12	1.06E-09	0.98921	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2850					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
2851					/QS-SBO	*	RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2852	1049	12	1.06E-09	0.98924	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2853					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
2854					/QS-SBO	*	RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2855	1048	12	1.06E-09	0.98927	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2856					NRAC-7HR	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
2857					/QS-SBO	*	RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2858	501	10	1.05E-09	0.98931	AFW-CKV-00-CV172	*	AFW-XHE-FO-U1SBO	*	BETA-2DG	*	IE-T1	*
2859					NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
2860					/QS-SBO	*	REC-XHE-FO-DGEN	+	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*
2861	2630	6	1.05E-09	0.98934	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	IE-T2	+		
2862					HPI-XHE-FO-FDBLD	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2863	1358	12	1.05E-09	0.98937	/DGN-FTO	*	NRAC-150M	*	/O	*	OEP-DGN-FS-DG01	*
2864					NOTQ	*	/QS-SBO	*	RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	+
2865					OEP-DGN-FS-DG03	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
2866	1357	12	1.05E-09	0.98940	/DGN-FTO	*	NRAC-150M	*	/O	*	OEP-DGN-FS-DG01	*
2867					NOTQ	*	/QS-SBO	*	RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	+
2868					OEP-DGN-FS-DG02	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
2869	1655	12	1.03E-09	0.98943	BETA-2DG	*	NRAC-246M	*	/O	*	OEP-DGN-FS	*
2870					NOTQ	*	RCP-LOCA-561-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2871					/QS-SBO	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*
2872	502	9	1.03E-09	0.98946	AFW-TDP-FS-FW2	*	NOTQ	*	NRAC-HALFHR	*	OEP-CRB-FT-15H3	*
2873					NOTQ	+						
2874					/QS-SBO	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
2875	503	9	1.03E-09	0.98949	AFW-TDP-FS-FW2	*	NRAC-HALFHR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1	*
2876					NOTQ	+						
2877					/QS-SBO	*	CPC-STR-PG-6HR	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S2	*
2878	117	5	1.03E-09	0.98953	BETA-STR	*	IE-S2	*	LPR-CCF-PG-SUMP	+		
2879					IE-S2	+	IE-S1	*	LPR-CCF-PG-SUMP	+		
2880	118	3	1.00E-09	0.98956	CON-VFC-RP-COREM	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2881	75	3	1.00E-09	0.98959	CON-VFC-RP-COREM	*	O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
2882	983	12	9.91E-10	0.98962	/DGN-FTO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2883					NRAC-246M	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2884					/QS-SBO	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
2885	980	12	9.91E-10	0.98965	/DGN-FTO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2886					NRAC-246M	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2887					/QS-SBO	*	O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
2888	981	12	9.91E-10	0.98968	/DGN-FTO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2889					NRAC-246M	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2890					/QS-SBO	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
2891	982	12	9.91E-10	0.98971	/DGN-FTO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2892					NRAC-246M	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
2893					/QS-SBO	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG01	*
2894	1358	12	9.73E-10	0.98974	BETA-2DG	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
2895					NOTL-SBOU1	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
2896					OEP-DGN-FS	*	NOTQ	*	NRAC-150M	*	/O	*
2897	2723	4	9.72E-10	0.98977	AFW-MDP-FR-3A6HR	*	/QS-SBO	*	RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	+
2898	2698	4	9.72E-10	0.98980	AFW-MDP-FR-3B6HR	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
2899	62	3	9.60E-10	0.98982	CPC-MDP-FR-SWA3H	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
2900	1881	11	9.58E-10	0.98985	IE-T1	*	CPC-MDP-MA-SW10B	*	IE-S1	+		
2901					O	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-201M	*
2902					/QS-SBO	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
							RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		

2903	1880	11	9.58E-10	0.98988	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-201M	*
2904					O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*
2905					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2906	1879	11	9.58E-10	0.98991	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-201M	*
2907					O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
2908					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
2909	984	11	9.58E-10	0.98994	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2910					NRAC-258M	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	* QS-SBO	*
2911					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
2912	2631	6	9.54E-10	0.98997	AFW-MDP-FS-FW3A	* AFW-MDP-FS-FW3B	* AFW-TDP-MA-FW2	* AFW-XHE-FO-UNIT2	*
2913					HPI-XHE-FO-FDBLD	* IE-T2	+		
2914	504	9	9.36E-10	0.99000	AFW-TDP-MA-FW2	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
2915					NOTQ	* NRAC-HALFHR	* OEP-CRB-FT-15J3	* OEP-DGN-FR-6HDG1	*
2916					/QS-SBO	+			
2917	505	9	9.36E-10	0.99003	AFW-TDP-MA-FW2	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
2918					NOTQ	* NRAC-HALFHR	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG3	*
2919					/QS-SBO	+			
2920	1204	12	9.33E-10	0.99005	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2921					NOTQ	* NRAC-7HR	* /O	* OEP-DGN-FS-DG01	*
2922					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-183-210	* REC-XHE-FO-DGHWS	+
2923	1205	12	9.33E-10	0.99008	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2924					NOTQ	* NRAC-7HR	* /O	* OEP-DGN-FS-DG01	*
2925					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-183-210	* REC-XHE-FO-DGHWS	+
2926	1053	12	9.33E-10	0.99011	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2927					NOTQ	* NRAC-7HR	* /O	* OEP-DGN-FS-DG01	*
2928					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-183-150	* REC-XHE-FO-DGHWS	+
2929	1052	12	9.33E-10	0.99014	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2930					NOTQ	* NRAC-7HR	* /O	* OEP-DGN-FS-DG01	*
2931					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-183-150	* REC-XHE-FO-DGHWS	+
2932	506	10	9.27E-10	0.99017	AFW-TDP-FS-FW2	* AFW-XHE-FO-U1SBO	* /DGN-FTO	* IE-T1	*
2933					NOTQ	* NRAC-HALFHR	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	*
2934					/QS-SBO	* REC-XHE-FO-DGEN	+		
2935	1507	12	9.22E-10	0.99020	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2936					NRAC-7HR	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
2937					/QS-SBO	* RCP-LOCA-183-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2938	1506	12	9.22E-10	0.99022	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2939					NRAC-7HR	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
2940					/QS-SBO	* RCP-LOCA-183-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2941	1505	12	9.22E-10	0.99025	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2942					NRAC-7HR	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
2943					/QS-SBO	* RCP-LOCA-183-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2944	1504	12	9.22E-10	0.99028	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
2945					NRAC-7HR	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
2946					/QS-SBO	* RCP-LOCA-183-90	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
2947	324	10	9.21E-10	0.99031	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
2948					NSLOCA	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
2949					QS-SBO	* REC-XHE-FO-DGHWB	+		
2950	323	10	9.21E-10	0.99034	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
2951					NSLOCA	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
2952					QS-SBO	* REC-XHE-FO-DGHWB	+		
2953	322	10	9.21E-10	0.99036	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
2954					NSLOCA	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*
2955					QS-SBO	* REC-XHE-FO-DGHWB	+		
2956	985	11	9.20E-10	0.99039	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
2957					NOTQ	* NRAC-258M	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG02	*
2958					QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+	

SEQUENCE SBO-BATT

TOP EVENT SBO-BATT CONTAINS 27 EVENTS IN 160 CUT SETS

THE FREQUENCY OF TOP EVENT SBO-BATT IS 7.57E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SBO-BATT

N	1000
MEAN	1.05E-05
STD DEV	2.44E-05
LOWER 5%	2.44E-07
LOWER 25%	1.25E-06
MEDIAN	3.33E-06
UPPER 25%	9.56E-06
UPPER 5%	4.08E-05

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE SBO-BATT
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NRAC-7HP	160	5.00E-02 (11.0)	7.57E-06 (2.0)	2.44E-07	4.08E-05
NOTQ	160	9.73E-01 (2.0)	7.57E-06 (2.0)		
NOTL-SBOU1	160	9.93E-01 (1.0)	7.57E-06 (2.0)		
NOTW2	54	8.15E-01 (3.0)	7.15E-06 (4.0)		
REC-XHE-FO-DGHWB	120	6.00E-01 (4.0)	6.60E-06 (5.0)	1.94E-07	3.53E-05
OEP-DGN-FS-DG01	48	2.20E-02 (16.5)	3.40E-06 (6.0)	8.45E-08	1.74E-05
OEP-DGN-FR-6HDG1	45	1.20E-02 (20.0)	2.06E-06 (7.0)	1.30E-08	1.47E-05
OEP-DGN-FS-DG02	27	2.20E-02 (16.5)	1.76E-06 (8.5)	4.28E-08	8.77E-06
OEP-DGN-FS-DG03	27	2.20E-02 (16.5)	1.76E-06 (8.5)	4.28E-08	8.77E-06
OEP-DGN-FR-6HDG3	26	1.20E-02 (20.0)	1.16E-06 (10.0)	7.06E-09	8.64E-06
OEP-DGN-FR-6HDG2	24	1.20E-02 (20.0)	9.61E-07 (11.0)	5.84E-09	5.88E-06
NOTDG-CCF	8	5.20E-01 (5.0)	8.39E-07 (13.0)		
OEP-DGN-FS	8	2.20E-02 (16.5)	8.39E-07 (13.0)	2.82E-08	3.37E-06
BETA-2DG	8	3.80E-02 (13.0)	8.39E-07 (13.0)	2.82E-08	3.37E-06
OEP-DGN-MA-DG01	27	6.00E-03 (23.0)	7.64E-07 (15.0)	4.46E-09	3.05E-06
OEP-CRB-FT-15H3	32	3.00E-03 (25.5)	5.11E-07 (16.0)	3.44E-09	2.27E-06
NSLOCA	106	2.70E-01 (7.5)	4.27E-07 (17.0)	0.00E+00	2.65E-06
OEP-DGN-MA-DG02	15	6.00E-03 (23.0)	4.12E-07 (18.0)	2.47E-09	1.72E-06
OEP-DGN-MA-DG03	15	6.00E-03 (23.0)	3.84E-07 (19.0)	2.32E-09	1.55E-06
REC-XHE-FO-SCOO1	58	1.25E-01 (9.0)	2.91E-07 (20.0)	0.00E+00	1.88E-06
OEP-CRB-FT-15J3	18	3.00E-03 (25.5)	2.89E-07 (21.0)	2.00E-09	1.36E-06
REC-XHE-FO-DGTMB	18	5.00E-01 (8.0)	2.78E-07 (22.0)	6.63E-10	9.35E-07
MCW-CCF-VF-SBO	48	6.00E-02 (10.0)	1.36E-07 (23.0)	0.00E+00	7.18E-07
QS-SBO	160	2.70E-01 (7.5)	9.20E-10 (24.0)	-5.96E-10	3.85E-09
O	61	4.90E-02 (12.0)	-6.75E-09 (25.0)	-2.82E-08	0.00E+00
DGN-FTO	152	3.39E-02 (14.0)	-2.36E-07 (26.0)	-1.33E-06	-3.05E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	160	7.70E-02 (1.0)	7.57E-06 (1.0)	2.44E-07	4.08E-05

SEQUENCE SBO-BATT
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
OEP-CRB-FT-15H3	32	3.00E-03	(25.5)	1.70E-04	(1.0)	9.67E-06	5.30E-04
OEP-DGN-FR-6HDG1	45	1.20E-02	(20.0)	1.69E-04	(2.0)	9.67E-06	5.22E-04
OEP-DGN-FS-DG01	48	2.20E-02	(16.5)	1.51E-04	(3.0)	7.82E-06	4.50E-04
NRAC-7HR	180	5.00E-02	(11.0)	1.44E-04	(4.0)	5.90E-06	7.99E-04
OEP-DGN-MA-DG01	27	6.00E-03	(23.0)	1.27E-04	(5.0)	5.78E-06	4.06E-04
OEP-CRB-FT-15J3	18	3.00E-03	(25.5)	9.60E-05	(6.0)	5.96E-06	3.17E-04
OEP-DGN-FR-6HDG3	26	1.20E-02	(20.0)	9.57E-05	(7.0)	6.21E-06	3.13E-04
OEP-DGN-FR-6HDG2	24	1.20E-02	(20.0)	7.91E-05	(8.0)	3.93E-06	2.43E-04
OEP-DGN-FS-DG03	27	2.20E-02	(16.5)	7.84E-05	(9.5)	3.91E-06	2.40E-04
OEP-DGN-FS-DG02	27	2.20E-02	(16.5)	7.84E-05	(9.5)	3.91E-06	2.40E-04
OEP-DGN-MA-DG02	15	6.00E-03	(23.0)	6.83E-05	(11.0)	3.14E-06	2.20E-04
OEP-DGN-MA-DG03	15	6.00E-03	(23.0)	6.37E-05	(12.0)	2.82E-06	2.12E-04
OEP-DGN-FS	8	2.20E-02	(16.5)	3.73E-05	(13.0)	1.78E-06	1.22E-04
BETA-2DG	8	3.80E-02	(13.0)	2.12E-05	(14.0)	1.06E-06	7.19E-05
REC-XHE-FO-DGHWB	120	6.00E-01	(4.0)	4.40E-06	(15.0)	6.15E-08	2.20E-05
MCW-CCF-VF-SBO	48	6.00E-02	(10.0)	2.14E-06	(16.0)	0.00E+00	1.30E-05
REC-XHE-FO-SCOO	58	1.25E-01	(9.0)	2.04E-06	(17.0)	0.00E+00	1.20E-05
NOTW2	54	8.15E-01	(3.0)	1.62E-06	(18.0)		
NSLOCA	106	2.70E-01	(7.5)	1.16E-06	(19.0)	0.00E+00	6.02E-06
NOTDG-CCF	8	5.20E-01	(5.0)	7.75E-07	(20.0)		
REC-XHE-FO-DGTMB	18	5.00E-01	(6.0)	2.78E-07	(21.0)	5.81E-10	1.14E-06
NOTQ	180	9.73E-01	(2.0)	2.10E-07	(22.0)		
NOTL-SBOU1	180	9.93E-01	(1.0)	5.34E-08	(23.0)		
QS-SBO	160	2.70E-01	(7.5)	2.49E-09	(24.0)	-2.40E-09	1.52E-08
O	61	4.80E-02	(12.0)	-1.31E-07	(25.0)	-5.12E-07	0.00E+00
DGN-FTO	152	3.39E-02	(14.0)	-6.74E-06	(26.0)	-3.76E-05	-1.74E-07

E-77

SEQUENCE SBO-BATT
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
OEP-DGN-FR-6HDG2	24	1.20E-02 (20.0)	21.8 (2.0)	1.79	0.70
OEP-DGN-FR-6HDG1	45	1.20E-02 (20.0)	21.8 (2.0)	1.79	0.70
OEP-DGN-FR-6HDG3	26	1.20E-02 (20.0)	21.8 (2.0)	1.79	0.70
OEP-DGN-FS-DG03	27	2.20E-02 (16.5)	21.6 (5.5)	1.45	0.73
OEP-DGN-FS	8	2.20E-02 (16.5)	21.6 (5.5)	1.45	0.73
OEP-DGN-FS-DG02	27	2.20E-02 (16.5)	21.6 (5.5)	1.45	0.73
OEP-DGN-FS-DG01	48	2.20E-02 (16.5)	21.6 (5.5)	1.45	0.73
REC-XHE-FO-DGTMB	18	5.00E-01 (6.0)	13.3 (8.0)	0.99	1.00
REC-XHE-FO-DGHWB	120	6.00E-01 (4.0)	13.0 (9.0)	1.27	1.00
NRAC-7HR	160	5.00E-02 (11.0)	11.6 (10.0)	1.25	1.05
OEP-DGN-MA-DG03	15	6.00E-03 (23.0)	3.3 (12.0)	1.10	1.02
OEP-DGN-MA-DG01	27	6.00E-03 (23.0)	3.3 (12.0)	1.10	1.02
OEP-DGN-MA-DG02	15	6.00E-03 (23.0)	3.3 (12.0)	1.10	1.02
OEP-CRB-FT-15J3	18	3.00E-03 (25.5)	1.9 (14.5)	1.07	1.00
OEP-CRB-FT-15H3	32	3.00E-03 (25.5)	1.9 (14.5)	1.07	1.00
BETA-2DG	8	3.80E-02 (13.0)	1.1 (16.0)	0.96	0.98
O	61	4.90E-02 (12.0)	0.9 (17.0)	1.00	1.00
REC-XHE-FO-SCOOL	58	1.25E-01 (9.0)	0.6 (18.0)	1.01	0.99
QS-SBO	160	2.70E-01 (7.5)	0.4 (19.0)		
NSLOCA	106	2.70E-01 (7.5)	0.0 (20.0)		
MCW-CCF-VF-SBO	48	6.00E-02 (10.0)	0.0 (21.5)		
DGN-FTO	152	3.39E-02 (14.0)	0.0 (21.5)		
NOTW2	54	8.15E-01 (3.0)			
NOTQ	160	9.73E-01 (2.0)			
NOTL-SBOU1	160	9.93E-01 (1.0)			
NOTDG-CCF	8	5.20E-01 (5.0)			

E-78

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	160	7.70E-02 (1.0)	27.4 (1.0)	1.76	0.99

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE SBO-BATT

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-BATT WITH TOP EVENT FREQUENCY 7.57E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	10	6.21E-07	0.08197	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
3					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03
4					/QS-SBO	* REC-XHE-FO-DGHWB	+	
5	2	10	6.21E-07	0.16394	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
6					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02
7					/QS-SBO	* REC-XHE-FO-DGHWB	+	
8	3	10	5.77E-07	0.24015	BETA-2DG	* 1E-T1	* NOTDG-CCF	* NOTL-SBOU1
9					NOTQ	* NOTW2	* NRAC-7HR	* OEP-DGN-FS
10					/QS-SBO	* REC-XHE-FO-DGHWB	+	
11	6	10	3.39E-07	0.28487	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
12					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01
13					/QS-SBO	* REC-XHE-FO-DGHWB	+	
14	5	10	3.39E-07	0.32958	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
15					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03
16					/QS-SBO	* REC-XHE-FO-DGHWB	+	
17	7	10	3.39E-07	0.37429	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
18					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01
19					/QS-SBO	* REC-XHE-FO-DGHWB	+	
20	4	10	3.39E-07	0.41900	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
21					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02
22					/QS-SBO	* REC-XHE-FO-DGHWB	+	
23	8	9	3.08E-07	0.45965	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
24					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3
25					/QS-SBO	+		
26	10	10	2.30E-07	0.48997	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
27					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03
28					QS-SBO	* REC-XHE-FO-DGHWB	+	
29	9	10	2.30E-07	0.52029	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
30					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02
31					QS-SBO	* REC-XHE-FO-DGHWB	+	
32	11	10	2.14E-07	0.54847	BETA-2DG	* 1E-T1	* NOTDG-CCF	* NOTL-SBOU1
33					NOTQ	* NOTW2	* NRAC-7HR	* OEP-DGN-FS
34					QS-SBO	* REC-XHE-FO-DGHWB	+	
35	12	10	1.85E-07	0.57286	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
36					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2
37					/QS-SBO	* REC-XHE-FO-DGHWB	+	
38	15	10	1.69E-07	0.59522	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
39					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03
40					/QS-SBO	* REC-XHE-FO-DGHWB	+	
41	14	10	1.69E-07	0.61757	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
42					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02
43					/QS-SBO	* REC-XHE-FO-DGHWB	+	
44	13	10	1.69E-07	0.63993	/DGN-FTO	* 1E-T1	* NOTL-SBOU1	* NOTQ
45					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01
46					/QS-SBO	* REC-XHE-FO-DGHWB	+	

47	16	10	1.69E-07	0.66229	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
48					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
49					/QS-SBO	* REC-XHE-FO-DGHWB	+		
50	20	10	1.25E-07	0.67882	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
51					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
52					QS-SBO	* REC-XHE-FO-DGHWB	+		
53	18	10	1.25E-07	0.69536	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
54					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
55					QS-SBO	* REC-XHE-FO-DGHWB	+		
56	17	10	1.25E-07	0.71190	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
57					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
58					QS-SBO	* REC-XHE-FO-DGHWB	+		
59	19	10	1.25E-07	0.72844	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
60					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
61					QS-SBO	* REC-XHE-FO-DGHWB	+		
62	21	9	1.14E-07	0.74347	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
63					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
64					QS-SBO	+			
65	23	10	9.24E-08	0.75566	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
66					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-MA-DG01	*
67					QS-SBO	* REC-XHE-FO-DGHWB	+		
68	22	10	9.24E-08	0.76786	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
69					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG02	*
70					QS-SBO	* REC-XHE-FO-DGHWB	+		
71	26	10	8.47E-08	0.77904	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
72					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	*
73					QS-SBO	* REC-XHE-FO-DGHWB	+		
74	25	10	8.47E-08	0.79021	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
75					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	*
76					QS-SBO	* REC-XHE-FO-DGHWB	+		
77	24	10	8.47E-08	0.80139	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
78					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	*
79					QS-SBO	* REC-XHE-FO-DGHWB	+		
80	28	10	7.70E-08	0.81155	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
81					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03	*
82					QS-SBO	* REC-XHE-FO-DGTMB	+		
83	29	9	7.70E-08	0.82172	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
84					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG3	*
85					QS-SBO	+			
86	27	10	7.70E-08	0.83188	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
87					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01	*
88					QS-SBO	* REC-XHE-FO-DGTMB	+		
89	30	9	7.70E-08	0.84204	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
90					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15J3	* OEP-DGN-FR-6HDG1	*
91					QS-SBO	+			
92	31	10	6.83E-08	0.85106	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
93					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
94					QS-SBO	* REC-XHE-FO-DGHWB	+		
95	32	10	6.26E-08	0.85933	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
96					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
97					QS-SBO	* REC-XHE-FO-DGHWB	+		
98	35	10	6.26E-08	0.86760	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
99					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
100					QS-SBO	* REC-XHE-FO-DGHWB	+		
101	33	10	6.26E-08	0.87587	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
102					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*

103					QS-SBO	* REC-XHE-FO-DGHWB +				
104	34	10	6.26E-08	0.88414	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
105					NOTW2	* NRAC-7HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03
106					QS-SBO	* REC-XHE-FO-DGHWB +				
107	36	10	4.62E-08	0.89023	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
108					NOTW2	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2
109					/QS-SBO	* REC-XHE-FO-DGHWB +				
110	38	10	3.42E-08	0.89474	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
111					NOTW2	* NRAC-7HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01
112					QS-SBO	* REC-XHE-FO-DGHWB +				
113	37	10	3.42E-08	0.89925	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
114					NOTW2	* NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02
115					QS-SBO	* REC-XHE-FO-DGHWB +				
116	41	10	3.13E-08	0.90339	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
117					NOTW2	* NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01
118					QS-SBO	* REC-XHE-FO-DGHWB +				
119	40	10	3.13E-08	0.90752	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
120					NOTW2	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03
121					QS-SBO	* REC-XHE-FO-DGHWB +				
122	39	10	3.13E-08	0.91166	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
123					NOTW2	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02
124					QS-SBO	* REC-XHE-FO-DGHWB +				
125	45	9	2.85E-08	0.91541	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
126					NOTW2	* NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1
127					QS-SBO	+ IE-T1	*	NOTL-SBOU1	*	NOTQ
128	44	9	2.85E-08	0.91917	/DGN-FTO	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3
129					NOTW2	+ IE-T1	*	NOTL-SBOU1	*	NOTQ
130					QS-SBO	+ NRAC-7HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01
131	43	10	2.85E-08	0.92293	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
132					NOTW2	* NRAC-7HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01
133					QS-SBO	* REC-XHE-FO-DGTMB +				
134	42	10	2.85E-08	0.92669	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
135					NOTW2	* NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03
136					QS-SBO	* REC-XHE-FO-DGTMB +				
137	47	12	2.45E-08	0.92992	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
138					NRAC-7HR	* NSLOCA	*	/O	*	OEP-DGN-FS-DG01
139					OEP-DGN-FS-DG03	* /QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOOL +
140	46	12	2.45E-08	0.93315	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
141					NRAC-7HR	* NSLOCA	*	/O	*	OEP-DGN-FS-DG01
142					OEP-DGN-FS-DG02	* /QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOOL +
143	48	10	2.31E-08	0.93619	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
144					NOTW2	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02
145					/QS-SBO	* REC-XHE-FO-DGHWB +				
146	49	12	2.27E-08	0.93920	BETA-2DG	* IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1
147					NOTQ	* NRAC-7HR	*	NSLOCA	*	/O
148					OEP-DGN-FS	* /QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOOL +
149	52	9	1.92E-08	0.94174	/DGN-FTO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
150					NOTW2	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-CRB-FT-15J3
151					/QS-SBO	+ IE-T1	*	NOTL-SBOU1	*	NOTQ
152	51	10	1.92E-08	0.94428	/DGN-FTO	* NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01
153					NOTW2	* REC-XHE-FO-DGTMB +				
154					/QS-SBO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
155	50	10	1.92E-08	0.94682	/DGN-FTO	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03
156					NOTW2	* REC-XHE-FO-DGTMB +				
157					/QS-SBO	* IE-T1	*	NOTL-SBOU1	*	NOTQ
158	53	10	1.71E-08	0.94907	/DGN-FTO	* NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03

SEQUENCE SBO-SLOCA

TOP EVENT SBO-SLOCA CONTAINS 38 EVENTS IN 1064 CUT SETS

THE FREQUENCY OF TOP EVENT SBO-SLOCA IS 3.84E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SBO-SLOCA

N	1000
MEAN	5.31E-06
STD DEV	1.87E-05
LOWER 5%	0.00E+00
LOWER 25%	0.00E+00
MEDIAN	1.01E-06
UPPER 25%	4.13E-06
UPPER 5%	1.99E-05

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE SBO-SLOCA
RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NOTQ	1064	9.73E-01 (2.0)	3.84E-06 (1.5)		
NOTL-SBOU1	1064	9.93E-01 (1.0)	3.84E-06 (1.5)		
REC-XHE-FO-DGHWS	777	8.00E-01 (3.0)	3.42E-06 (3.0)	0.00E+00	1.72E-05
RCP-LOCA-750-90M	152	5.30E-01 (5.0)	3.10E-06 (4.0)	0.00E+00	1.73E-05
NRAC-216M	107	1.38E-01 (10.0)	2.89E-06 (5.0)	0.00E+00	1.65E-05
REC-XHE-FO-SCOOL	539	1.25E-01 (12.0)	2.60E-06 (6.0)	0.00E+00	1.43E-05
OEP-DGN-FS-DG01	294	2.20E-02 (22.5)	1.76E-06 (7.0)	0.00E+00	1.05E-05
MCW-CCF-VF-SBO	525	6.00E-02 (18.0)	1.25E-06 (8.0)	0.00E+00	7.40E-06
OEP-DGN-FR-6HDG1	294	1.20E-02 (29.0)	9.97E-07 (9.0)	0.00E+00	5.62E-06
OEP-DGN-FS-DG03	168	2.20E-02 (22.5)	9.14E-07 (10.5)	0.00E+00	5.29E-06
OEP-DGN-FS-DG02	168	2.20E-02 (22.5)	9.14E-07 (10.5)	0.00E+00	5.29E-06
RCP-LOCA-467-150	152	1.27E-01 (11.0)	5.82E-07 (12.0)	0.00E+00	3.71E-06
NRAC-258M	107	1.08E-01 (15.0)	5.60E-07 (13.0)	0.00E+00	3.50E-06
OEP-DGN-FR-6HDG3	168	1.20E-02 (29.0)	5.33E-07 (14.0)	0.00E+00	3.06E-06
OEP-DGN-FR-6HDG2	161	1.20E-02 (29.0)	4.98E-07 (15.0)	0.00E+00	2.79E-06
OEP-DGN-FS	42	2.20E-02 (22.5)	4.35E-07 (17.0)	0.00E+00	2.17E-06
BETA-2DG	42	3.80E-02 (19.0)	4.35E-07 (17.0)	0.00E+00	2.17E-06
NOTDG-CCF	42	5.20E-01 (6.0)	4.35E-07 (17.0)		
OEP-DGN-MA-DG01	196	6.00E-03 (32.0)	4.00E-07 (19.0)	0.00E+00	1.60E-06
OEP-CRB-FT-15H3	238	3.00E-03 (36.5)	2.46E-07 (20.0)	0.00E+00	9.65E-07
OEP-DGN-MA-DG02	112	6.00E-03 (32.0)	2.14E-07 (21.0)	0.00E+00	8.91E-07
OEP-DGN-MA-DG03	112	6.00E-03 (32.0)	2.03E-07 (22.0)	0.00E+00	8.51E-07
REC-XHE-FO-DGTMS	133	7.00E-01 (4.0)	1.50E-07 (23.0)	0.00E+00	5.67E-07
OEP-CRB-FT-15J3	133	3.00E-03 (36.5)	1.31E-07 (24.0)	0.00E+00	5.64E-07
NRAC-201M	45	1.50E-01 (9.0)	1.18E-07 (25.0)	0.00E+00	5.45E-07
NRAC-7HR	456	5.00E-02 (17.0)	9.77E-08 (26.0)	0.00E+00	0.00E+00
NRAC-246M	152	1.15E-01 (14.0)	4.05E-08 (27.0)	0.00E+00	8.93E-08
NRAC-150M	152	2.10E-01 (8.0)	3.82E-08 (28.5)	0.00E+00	0.00E+00
RCP-LOCA-1440-90	152	4.30E-03 (34.0)	3.82E-08 (28.5)	0.00E+00	0.00E+00
RCP-LOCA-183-210	152	1.61E-02 (25.5)	3.41E-08 (30.5)	0.00E+00	0.00E+00
RCP-LOCA-183-150	152	1.61E-02 (25.5)	3.41E-08 (30.5)	0.00E+00	0.00E+00
RCP-LOCA-183-90	152	1.40E-02 (27.0)	2.96E-08 (32.0)	0.00E+00	0.00E+00
RCP-LOCA-561-150	152	4.00E-03 (35.0)	1.95E-08 (33.0)	0.00E+00	0.00E+00
O	693	4.90E-02 (18.0)	8.66E-09 (34.0)	-3.06E-09	5.29E-08
NRAC-234M	45	1.23E-01 (13.0)	7.33E-10 (35.0)	0.00E+00	0.00E+00
QS-SBO	1064	2.70E-01 (7.0)	-4.15E-09 (36.0)	-3.22E-08	0.00E+00
DGN-FTO	1022	3.39E-02 (20.0)	-1.20E-07 (37.0)	-6.62E-07	0.00E+00

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	1064	7.70E-02 (1.0)	3.84E-06 (1.0)	0.00E+00	1.99E-05

SEQUENCE SBO-SLOCA
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
OEP-DGN-FR-6HDG1	294	1.20E-02	(29.0)	8.21E-05	(1.0)	0.00E+00	3.17E-04
OEP-CRB-FT-15H3	238	3.00E-03	(36.5)	8.18E-05	(2.0)	0.00E+00	3.22E-04
OEP-DGN-FS-DG01	294	2.20E-02	(22.5)	7.84E-05	(3.0)	0.00E+00	3.06E-04
OEP-DGN-MA-DG01	198	6.00E-03	(32.0)	6.63E-05	(4.0)	0.00E+00	2.69E-04
OEP-DGN-FR-6HDG3	168	1.20E-02	(29.0)	4.39E-05	(5.0)	0.00E+00	1.68E-04
OEP-CRB-FT-15J3	133	3.00E-03	(36.5)	4.36E-05	(6.0)	0.00E+00	1.71E-04
OEP-DGN-FR-6HDG2	161	1.20E-02	(29.0)	4.10E-05	(7.0)	0.00E+00	1.63E-04
OEP-DGN-FS-DG03	168	2.20E-02	(22.5)	4.06E-05	(8.5)	0.00E+00	1.60E-04
OEP-DGN-FS-DG02	168	2.20E-02	(22.5)	4.06E-05	(8.5)	0.00E+00	1.60E-04
OEP-DGN-MA-DG02	112	6.00E-03	(32.0)	3.54E-05	(10.0)	0.00E+00	1.42E-04
OEP-DGN-MA-DG03	112	6.00E-03	(32.0)	3.37E-05	(11.0)	0.00E+00	1.36E-04
MCW-CCF-VF-SBO	525	6.00E-02	(16.0)	1.95E-05	(12.0)	0.00E+00	1.14E-04
OEP-DGN-FS	42	2.20E-02	(22.5)	1.93E-05	(13.0)	0.00E+00	7.98E-05
NRAC-216M	107	1.38E-01	(10.0)	1.88E-05	(14.0)	0.00E+00	1.12E-04
REC-XHE-FO-SCOOL	539	1.25E-01	(12.0)	1.82E-05	(15.0)	0.00E+00	1.01E-04
BETA-2DG	42	3.80E-02	(19.0)	1.10E-05	(16.0)	0.00E+00	4.51E-05
RCP-LOCA-1440-90	152	4.30E-03	(34.0)	8.85E-06	(17.0)	1.90E-07	4.90E-05
RCP-LOCA-561-150	152	4.00E-03	(35.0)	4.86E-06	(18.0)	1.28E-07	2.63E-05
NRAC-258M	107	1.08E-01	(15.0)	4.82E-06	(19.0)	0.00E+00	2.81E-05
RCP-LOCA-467-150	152	1.27E-01	(11.0)	4.00E-06	(20.0)	0.00E+00	2.15E-05
RCP-LOCA-750-90M	152	5.30E-01	(5.0)	2.75E-06	(21.0)	0.00E+00	1.66E-05
RCP-LOCA-183-90	152	1.40E-02	(27.0)	2.08E-06	(22.0)	4.73E-08	1.11E-05
RCP-LOCA-183-210	152	1.51E-02	(25.5)	2.08E-06	(23.5)	3.72E-08	1.08E-05
RCP-LOCA-183-150	152	1.81E-02	(25.5)	2.08E-06	(23.5)	3.44E-08	1.11E-05
NRAC-7HR	456	5.00E-02	(17.0)	1.86E-06	(25.0)	0.00E+00	0.00E+00
REC-XHE-FO-DGHWS	777	8.00E-01	(3.0)	8.55E-07	(26.0)	0.00E+00	4.96E-06
NRAC-201M	45	1.50E-01	(9.0)	6.71E-07	(27.0)	0.00E+00	3.63E-06
NOTDG-CCF	42	5.20E-01	(6.0)	4.01E-07	(28.0)		
NRAC-246M	152	1.15E-01	(14.0)	3.12E-07	(29.0)	0.00E+00	7.04E-07
O	693	4.80E-02	(18.0)	1.68E-07	(30.0)	-9.58E-08	1.12E-06
NRAC-150M	152	2.10E-01	(8.0)	1.44E-07	(31.0)	0.00E+00	0.00E+00
NOTQ	1064	9.73E-01	(2.0)	1.07E-07	(32.0)		
REC-XHE-FO-DGTMS	133	7.00E-01	(4.0)	6.44E-08	(33.0)	0.00E+00	2.21E-07
NOTL-SBOU1	1064	9.93E-01	(1.0)	2.71E-08	(34.0)		
NRAC-234M	45	1.23E-01	(13.0)	5.23E-09	(35.0)	0.00E+00	0.00E+00
QS-SBO	1064	2.70E-01	(7.0)	-1.12E-08	(36.0)	-9.57E-08	0.00E+00
DGN-FTO	1022	3.39E-02	(20.0)	-3.41E-08	(37.0)	-1.82E-05	0.00E+00

SEQUENCE SBO-SLOCA
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
RCP-LOCA-750-90M	152	5.30E-01 (5.0)	44.3 (1.0)	NA	1.12
RCP-LOCA-467-150	152	1.27E-01 (11.0)	5.0 (2.0)	NA	0.99
OEP-DGN-FS-DG01	294	2.20E-02 (22.5)	2.3 (4.5)	NA	0.88
OEP-DGN-FS	42	2.20E-02 (22.5)	2.3 (4.5)	NA	0.88
OEP-DGN-FS-DG03	168	2.20E-02 (22.5)	2.3 (4.5)	NA	0.88
OEP-DGN-FS-DG02	168	2.20E-02 (22.5)	2.3 (4.5)	NA	0.88
OEP-DGN-FR-6HDG1	294	1.20E-02 (29.0)	2.0 (8.0)	NA	1.00
OEP-DGN-FR-6HDG2	161	1.20E-02 (29.0)	2.0 (8.0)	NA	1.00
OEP-DGN-FR-6HDG3	168	1.20E-02 (29.0)	2.0 (8.0)	NA	1.00
NRAC-216M	107	1.38E-01 (10.0)	1.5 (10.0)	NA	1.07
NRAC-150M	152	2.10E-01 (8.0)	1.3 (11.0)	NA	1.00
NRAC-7HR	456	5.00E-02 (17.0)	1.3 (12.0)	NA	1.00
NRAC-246M	152	1.15E-01 (14.0)	1.3 (13.0)	NA	1.00
NRAC-201M	45	1.50E-01 (9.0)	1.3 (14.0)	NA	1.03
NRAC-234M	45	1.23E-01 (13.0)	1.3 (15.0)	NA	1.00
NRAC-258M	107	1.08E-01 (15.0)	1.3 (16.0)	NA	1.00
REC-XHE-FO-DGTMS	133	7.00E-01 (4.0)	1.2 (17.0)	NA	1.00
REC-XHE-FO-DGHWS	777	8.00E-01 (3.0)	1.1 (18.0)	NA	1.02
RCP-LOCA-1440-90	152	4.30E-03 (34.0)	0.8 (19.0)	NA	1.01
O	693	4.80E-02 (18.0)	0.8 (20.0)	NA	1.00
OEP-CRB-FT-15H3	238	3.00E-03 (36.5)	0.8 (21.5)	NA	1.00
OEP-CRB-FT-15J3	133	3.00E-03 (36.5)	0.8 (21.5)	NA	1.00
MCW-CCF-VF-SBO	525	8.00E-02 (18.0)	0.7 (23.0)	NA	1.01
OEP-DGN-MA-DG03	112	6.00E-03 (32.0)	0.7 (25.0)	NA	1.08
OEP-DGN-MA-DG02	112	6.00E-03 (32.0)	0.7 (25.0)	NA	1.08
OEP-DGN-MA-DG01	196	6.00E-03 (32.0)	0.7 (25.0)	NA	1.08
DGN-FTO	1022	3.39E-02 (20.0)	0.5 (27.0)		
RCP-LOCA-183-210	152	1.61E-02 (25.5)	0.4 (28.0)		
REC-XHE-FO-SCOOL	539	1.25E-01 (12.0)	0.3 (29.0)		
BETA-2DG	42	3.80E-02 (19.0)	0.3 (30.0)		
RCP-LOCA-561-150	152	4.00E-03 (35.0)	0.2 (31.0)		
RCP-LOCA-183-150	152	1.61E-02 (25.5)	0.1 (32.0)		
RCP-LOCA-183-90	152	1.40E-02 (27.0)	0.1 (33.0)		
QS-SBO	1064	2.70E-01 (7.0)	0.0 (34.0)		
NOTQ	1064	9.73E-01 (2.0)			
NOTL-SBOU1	1064	9.93E-01 (1.0)			
NOTDG-CCF	42	5.20E-01 (6.0)			

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	1064	7.70E-02 (6.0)	1.6 (36.0)	NA	1.04

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS

SEQUENCE SBO-SLOCA

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-SLOCA WITH TOP EVENT FREQUENCY 3.84E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	12	1.77E-07	0.04599	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
3					NRAC-216M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
4					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
5	2	12	1.77E-07	0.09197	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
6					NRAC-216M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
7					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
8	3	12	1.64E-07	0.13472	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
9					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS	*
10					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
11	6	12	9.63E-08	0.15981	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
12					NRAC-216M	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
13					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
14	5	12	9.63E-08	0.18489	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
15					NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
16					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
17	4	12	9.63E-08	0.20997	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
18					NRAC-216M	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
19					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
20	7	12	9.63E-08	0.23505	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
21					NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
22					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
23	8	12	8.48E-08	0.25713	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
24					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS-DG01	*
25					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
26	9	12	8.48E-08	0.27920	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
27					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS-DG01	*
28					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
29	10	12	7.88E-08	0.28972	BETA-2DG	* IE-T1	* MCW-CCF-VF-SBO	* NOTDG-CCF	*
30					NOTL-SBOU1	* NOTQ	* NRAC-216M	* /O	*
31					OEP-DGN-FS	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
32	12	11	6.87E-08	0.31761	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
33					NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* QS-SBO	*
34					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
35	11	11	6.87E-08	0.33549	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
36					NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* QS-SBO	*
37					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
38	13	11	6.57E-08	0.35259	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
39					NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
40					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-SCOOL	+	
41	14	11	6.39E-08	0.36922	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
42					NOTQ	* NRAC-216M	* OEP-DGN-FS	* QS-SBO	*
43					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
44	15	12	5.26E-08	0.38290	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
45					NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
46					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+

47	17	12	4.82E-08	0.39544	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
48					NRAC-216M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
49					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
50	19	12	4.82E-08	0.40798	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
51					NRAC-216M	* /O	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
52					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
53	16	12	4.82E-08	0.42053	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
54					NRAC-216M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
55					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
56	18	12	4.82E-08	0.43307	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
57					NRAC-216M	* /O	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
58					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
59	23	12	4.82E-08	0.44511	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
60					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
61					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
62	20	12	4.82E-08	0.45715	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
63					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG2	*
64					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
65	22	12	4.82E-08	0.46919	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
66					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
67					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
68	21	12	4.82E-08	0.48123	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
69					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG3	*
70					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
71	24	11	3.75E-08	0.49098	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
72					NRAC-216M	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* QS-SBO	*
73					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	*	+
74	25	11	3.75E-08	0.50074	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
75					NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	* QS-SBO	*
76					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	*	+
77	26	11	3.75E-08	0.51049	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
78					NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* QS-SBO	*
79					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	*	+
80	27	11	3.75E-08	0.52025	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
81					NRAC-216M	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* QS-SBO	*
82					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	*	+
83	154	12	3.31E-08	0.52887	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
84					NRAC-258M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
85					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
86	153	12	3.31E-08	0.53750	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
87					NRAC-258M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
88					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
89	29	11	3.30E-08	0.54808	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
90					NOTQ	* NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
91					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	*	+
92	28	11	3.30E-08	0.55488	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
93					NOTQ	* NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
94					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	*	+
95	30	11	3.15E-08	0.56287	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
96					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
97					OEP-DGN-FR-6HDG3	* /QS-SBO	* RCP-LOCA-750-90M	*	+
98	155	12	3.08E-08	0.57089	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
99					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FS	*
100					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
101	31	11	3.07E-08	0.57887	BETA-2DG	* IE-T1	* MCW-CCF-VF-SBO	* NOTDG-CCF	*
102					NOTL-SBOU1	* NOTQ	* NRAC-216M	* OEP-DGN-FS	*

103					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
104	32	12	2.63E-08	0.58571	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
105					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
106					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
107	33	12	2.63E-08	0.59255	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
108					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
109					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
110	34	10	2.55E-08	0.59920	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
111					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	*
112					RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOOL	+				
113	35	12	2.52E-08	0.60577	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
114					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
115					OEP-DGN-FR-6HDG2	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
116	38	12	2.41E-08	0.61204	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
117					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
118					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
119	37	12	2.41E-08	0.61831	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
120					NRAC-216M	*	/O	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
121					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
122	36	12	2.41E-08	0.62458	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
123					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
124					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
125	39	12	2.31E-08	0.63060	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
126					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
127					OEP-DGN-MA-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
128	42	12	2.31E-08	0.63662	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
129					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG02	*
130					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
131	40	12	2.31E-08	0.64264	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
132					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
133					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
134	41	12	2.31E-08	0.64866	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
135					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG03	*
136					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
137	44	12	2.30E-08	0.65465	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
138					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*
139					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOOL	+
140	43	12	2.30E-08	0.66063	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
141					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
142					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOOL	+
143	45	11	2.04E-08	0.66596	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
144					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
145					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+		
146	48	11	1.87E-08	0.67083	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
147					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
148					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+		
149	49	11	1.87E-08	0.67571	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
150					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
151					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+		
152	47	11	1.87E-08	0.68059	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
153					NRAC-216M	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
154					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+		
155	46	11	1.87E-08	0.68547	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
156					NRAC-216M	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
157	157	12	1.81E-08	0.69017	/DGN-FTO	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+		
						*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

159					NRAC-258M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
160					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
161	158	12	1.81E-08	0.69487	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
162					NRAC-258M	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
163					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
164	158	12	1.81E-08	0.69958	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
165					NRAC-258M	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
166					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
167	159	12	1.81E-08	0.70428	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
168					NRAC-258M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
169					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
170	51	11	1.80E-08	0.70896	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
171					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
172					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
173	50	11	1.80E-08	0.71365	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
174					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
175					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
176	53	11	1.80E-08	0.71833	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
177					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
178					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
179	52	11	1.80E-08	0.72301	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
180					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
181					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
182	55	11	1.64E-08	0.72729	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
183					NRAC-216M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG3	*
184					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-SCOOL	+	
185	54	11	1.64E-08	0.73156	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
186					NRAC-216M	* /O	* OEP-CRB-FT-15J3	* OEP-DGN-FR-6HDG1	*
187					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-SCOOL	+	
188	160	12	1.59E-08	0.73570	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
189					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FS-DG01	*
190					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
191	161	12	1.59E-08	0.73984	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
192					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FS-DG01	*
193					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
194	162	12	1.48E-08	0.74369	BETA-2DG	* IE-T1	* MCW-CCF-VF-SBO	* NOTDG-CCF	*
195					NOTL-SBOU1	* NOTQ	* NRAC-258M	* /O	*
196					OEP-DGN-FS	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
197	56	12	1.31E-08	0.74711	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
198					NRAC-216M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	*
199					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
200	163	11	1.29E-08	0.75046	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
201					NRAC-258M	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* QS-SBO	*
202					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
203	164	11	1.29E-08	0.75382	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
204					NRAC-258M	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* QS-SBO	*
205					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
206	57	12	1.26E-08	0.75710	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
207					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
208					OEP-DGN-MA-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
209	58	12	1.26E-08	0.76039	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
210					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG2	*
211					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
212	165	11	1.23E-08	0.76359	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
213					NRAC-258M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
214					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-SCOOL	+	

215	59	10	1.23E-08	0.76678	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
216					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
217					QS-SBO	* RCP-LOCA-750-90M	+		
218	166	11	1.20E-08	0.76990	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
219					NOTQ	* NRAC-258M	* OEP-DGN-FS	* QS-SBO	*
220					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+	
221	62	12	1.16E-08	0.77291	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
222					NOTQ	* NRAC-216M	*/O	* OEP-CRB-FT-15H3	*
223					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
224	60	12	1.16E-08	0.77592	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
225					NOTQ	* NRAC-216M	*/O	* OEP-CRB-FT-15H3	*
226					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
227	61	12	1.16E-08	0.77893	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
228					NOTQ	* NRAC-216M	*/O	* OEP-CRB-FT-15J3	*
229					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
230	64	12	1.10E-08	0.78181	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
231					NOTQ	* NRAC-216M	*/O	* OEP-DGN-FR-6HDG3	*
232					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	+
233	63	12	1.10E-08	0.78468	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
234					NOTQ	* NRAC-216M	*/O	* OEP-DGN-FR-6HDG1	*
235					OEP-DGN-MA-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	+
236	65	11	1.02E-08	0.78734	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
237					NRAC-216M	* OEP-DGN-FR-6HDG2	* OEP-DGN-MA-DG01	* QS-SBO	*
238					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+	
239	66	11	1.02E-08	0.79000	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
240					NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG02	* QS-SBO	*
241					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+	
242	68	12	9.89E-09	0.79258	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
243					NRAC-201M	* O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
244					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
245	69	12	9.89E-09	0.79515	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
246					NRAC-201M	* O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
247					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
248	167	12	9.86E-09	0.79772	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
249					NRAC-258M	*/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
250					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
251	67	11	9.81E-09	0.80027	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
252					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
253					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
254	71	11	9.37E-09	0.80271	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
255					NRAC-216M	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	* QS-SBO	*
256					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+	
257	72	11	9.37E-09	0.80515	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
258					NRAC-216M	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	* QS-SBO	*
259					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+	
260	70	11	9.37E-09	0.80759	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
261					NRAC-216M	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	* QS-SBO	*
262					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+	
263	73	12	9.20E-09	0.80998	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
264					NOTQ	* NRAC-201M	* O	* OEP-DGN-FS	*
265					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
266	168	12	9.03E-09	0.81233	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
267					NRAC-258M	*/O	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
268					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOOL	+
269	169	12	9.03E-09	0.81469	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
270					NRAC-258M	*/O	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*

271					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
272	171	12	9.03E-09	0.81704	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
273					NRAC-258M	* /O	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
274					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
275	170	12	9.03E-09	0.81939	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
276					NRAC-258M	* /O	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
277					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
278	77	11	8.99E-09	0.82173	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
279					NOTQ	* NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
280					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
281	75	11	8.99E-09	0.82407	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
282					NOTQ	* NRAC-216M	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
283					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
284	74	11	8.99E-09	0.82641	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
285					NOTQ	* NRAC-216M	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
286					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
287	76	11	8.99E-09	0.82875	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
288					NOTQ	* NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
289					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	
290	79	11	8.94E-09	0.83108	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
291					NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03	* QS-SBO	*
292					RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOO	+	
293	78	11	8.94E-09	0.83341	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
294					NRAC-216M	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01	* QS-SBO	*
295					RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOO	+	
296	174	12	8.67E-09	0.83567	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
297					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FR-6HDG1	*
298					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
299	173	12	8.67E-09	0.83793	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
300					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FR-6HDG3	*
301					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
302	172	12	8.67E-09	0.84018	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
303					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FR-6HDG2	*
304					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
305	175	12	8.67E-09	0.84244	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
306					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FR-6HDG1	*
307					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+
308	81	11	7.88E-09	0.84449	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
309					NOTQ	* NRAC-216M	* /O	* OEP-CRB-FT-15J3	*
310					OEP-DGN-FR-6HDG1	* /QS-SBO	* RCP-LOCA-750-90M	+	
311	80	11	7.88E-09	0.84655	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
312					NOTQ	* NRAC-216M	* /O	* OEP-CRB-FT-15H3	*
313					OEP-DGN-FR-6HDG3	* /QS-SBO	* RCP-LOCA-750-90M	+	
314	177	11	7.03E-09	0.84838	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
315					NRAC-258M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	* QS-SBO	*
316					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
317	176	11	7.03E-09	0.85020	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
318					NRAC-258M	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* QS-SBO	*
319					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
320	178	11	7.03E-09	0.85203	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
321					NRAC-258M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* QS-SBO	*
322					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
323	179	11	7.03E-09	0.85386	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
324					NRAC-258M	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* QS-SBO	*
325					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
326	82	12	8.57E-09	0.85557	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*

327					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*
328					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
329	83	10	6.39E-09	0.85724	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
330					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3	*	QS-SBO	*
331					RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOL	+				
332	84	10	6.39E-09	0.85890	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
333					NRAC-216M	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1	*	QS-SBO	*
334					RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOL	+				
335	85	12	6.31E-08	0.86054	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
336					NOTQ	*	NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*
337					OEP-DGN-FR-6HDG2	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
338	181	11	6.18E-09	0.86215	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
339					NOTQ	*	NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
340					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
341	180	11	6.18E-09	0.86376	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
342					NOTQ	*	NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
343					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
344	182	11	5.91E-09	0.86530	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
345					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*
346					OEP-DGN-FR-6HDG3	*	/QS-SBO	*	RCP-LOCA-467-150	+		
347	183	11	5.75E-09	0.86680	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
348					NOTL-SBOU1	*	NOTQ	*	NRAC-258M	*	OEP-DGN-FS	*
349					QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+		
350	87	12	5.75E-09	0.86829	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
351					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*
352					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
353	88	12	5.75E-09	0.86979	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
354					NRAC-216M	*	/O	*	OEP-CRB-FT-15J3	*	OEP-DGN-MA-DG01	*
355					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOL	+
356	91	12	5.40E-09	0.87119	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
357					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
358					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
359	90	12	5.40E-09	0.87280	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
360					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
361					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
362	88	12	5.40E-09	0.87400	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
363					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
364					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
365	89	12	5.40E-09	0.87541	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
366					NRAC-201M	*	O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
367					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
368	92	11	5.11E-09	0.87674	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
369					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
370					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
371	184	12	4.93E-09	0.87802	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
372					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
373					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
374	185	12	4.93E-09	0.87931	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
375					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
376					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
377	83	11	4.91E-09	0.88058	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
378					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
379					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
380	94	11	4.91E-09	0.88186	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
381					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
382					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		

383	186	10	4.79E-09	0.88311	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ
384					NRAC-258M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	* QS-SBO
385					RCP-LOCA-467-150	* REC-XHE-FO-SCOOL		
386	95	12	4.75E-09	0.88434	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
387					NOTQ	* NRAC-201M	* O	* OEP-DGN-FS-DG01
388					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS
389	96	12	4.75E-09	0.88558	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
390					NOTQ	* NRAC-201M	* O	* OEP-DGN-FS-DG01
391					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS
392	187	12	4.73E-09	0.88681	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
393					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FR-6HDG1
394					OEP-DGN-FR-6HDG2	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS
395	188	12	4.52E-09	0.88799	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ
396					NRAC-258M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03
397					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL
398	190	12	4.52E-09	0.88916	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ
399					NRAC-258M	* /O	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02
400					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL
401	189	12	4.52E-09	0.89034	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ
402					NRAC-258M	* /O	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01
403					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL
404	99	11	4.50E-09	0.89151	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
405					NOTQ	* NRAC-216M	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03
406					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	
407	97	11	4.50E-09	0.89268	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
408					NOTQ	* NRAC-216M	* OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01
409					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	
410	98	11	4.50E-09	0.89385	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
411					NOTQ	* NRAC-216M	* OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02
412					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	
413	100	12	4.41E-09	0.89500	BETA-2DG	* IE-T1	* MCW-CCF-VF-SBO	* NOTDG-CCF
414					NOTL-SBOU1	* NOTQ	* NRAC-201M	* O
415					OEP-DGN-FS	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS
416	193	12	4.34E-09	0.89613	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
417					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FS-DG03
418					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS
419	194	12	4.34E-09	0.89726	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
420					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FS-DG02
421					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS
422	191	12	4.34E-09	0.89839	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
423					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FS-DG01
424					OEP-DGN-MA-DG02	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS
425	192	12	4.34E-09	0.89952	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
426					NOTQ	* NRAC-258M	* /O	* OEP-DGN-FS-DG01
427					OEP-DGN-MA-DG03	* /QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS
428	195	12	4.31E-09	0.90064	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ
429					NRAC-258M	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01
430					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOOL
431	196	12	4.31E-09	0.90176	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ
432					NRAC-258M	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03
433					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGTMS	* REC-XHE-FO-SCOOL
434	102	11	4.29E-09	0.90288	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
435					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG1	* OEP-DGN-MA-DG03
436					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGTMS	
437	101	11	4.29E-09	0.90399	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1
438					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG3	* OEP-DGN-MA-DG01

SEQUENCE SBO-L

TOP EVENT SBO-L CONTAINS 32 EVENTS IN 216 CUT SETS

THE FREQUENCY OF TOP EVENT SBO-L IS 3.50E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SBO-L

N	1000
MEAN	4.72E-06
STD DEV	1.34E-05
LOWER 5%	7.92E-08
LOWER 25%	3.87E-07
MEDIAN	1.31E-06
UPPER 25%	3.68E-06
UPPER 5%	2.05E-05

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE SBO-L
RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NOTQ	216	9.73E-01	(1.0)	3.50E-06 (1.0)		
REC-XHE-FO-DGEN	203	9.00E-01	(2.0)	3.36E-06 (2.0)	7.62E-08	1.76E-05
QS-SBO	216	2.70E-01	(6.0)	3.01E-06 (3.0)	5.41E-08	1.74E-05
NRAC-1HR	22	4.40E-01	(5.0)	1.93E-06 (4.5)	2.34E-08	1.13E-05
AFW-XHE-FO-CST2	22	6.50E-02	(9.0)	1.93E-06 (4.5)	2.34E-08	1.13E-05
OEP-DGN-FS-DG01	86	2.20E-02	(15.5)	1.70E-06 (6.0)	3.09E-08	8.82E-06
NRAC-HALFHR	127	6.00E-01	(3.0)	1.05E-06 (7.0)	1.49E-08	5.68E-06
OEP-DGN-FS-DG02	45	2.20E-02	(15.5)	8.72E-07 (8.0)	1.66E-08	4.58E-06
OEP-DGN-FR-6HDG1	59	1.20E-02	(19.0)	8.64E-07 (9.0)	4.30E-09	5.58E-06
OEP-DGN-FS-DG03	45	2.20E-02	(15.5)	8.46E-07 (10.0)	1.61E-08	4.43E-06
NRAC-6HR-AVG	67	1.94E-01	(7.0)	5.24E-07 (11.0)	1.56E-09	2.70E-06
AFW-TDP-MA-FW2	63	1.00E-02	(23.5)	5.17E-07 (12.0)	2.38E-09	2.64E-06
AFW-TDP-FR-2P6HR	61	3.00E-02	(12.5)	5.15E-07 (13.0)	1.53E-09	2.69E-06
AFW-TDP-FS-FW2	58	1.10E-02	(21.5)	5.13E-07 (14.0)	2.41E-09	2.59E-06
OEP-DGN-FR-6HDG2	34	1.20E-02	(19.0)	4.69E-07 (15.0)	2.42E-09	2.96E-06
OEP-DGN-FR-6HDG3	32	1.20E-02	(19.0)	4.56E-07 (16.0)	2.33E-09	3.03E-06
NOTDG-CCF	18	5.20E-01	(4.0)	4.25E-07 (18.0)		
OEP-DGN-FS	18	2.20E-02	(15.5)	4.25E-07 (18.0)	8.99E-09	1.66E-06
BETA-2DG	18	3.80E-02	(10.0)	4.25E-07 (18.0)	8.99E-09	1.66E-06
OEP-DGN-MA-DG01	30	6.00E-03	(26.0)	3.68E-07 (20.0)	1.88E-09	1.43E-06
AFW-XHE-FO-U1SBO	73	8.20E-02	(8.0)	2.84E-07 (21.0)	2.62E-09	1.58E-06
OEP-DGN-MA-DG02	19	6.00E-03	(26.0)	1.98E-07 (22.0)	1.08E-09	7.85E-07
OEP-DGN-MA-DG03	15	6.00E-03	(26.0)	1.84E-07 (23.0)	9.44E-10	7.14E-07
OEP-CRB-FT-15H3	22	3.00E-03	(28.5)	1.45E-07 (24.0)	7.36E-10	5.51E-07
OEP-CRB-FT-15J3	8	3.00E-03	(28.5)	5.36E-08 (25.0)	3.08E-10	2.11E-07
AFW-TDP-FR-6HRU2	19	3.00E-02	(12.5)	3.56E-08 (26.0)	3.11E-11	3.17E-07
AFW-CKV-OO-CV172	12	1.00E-03	(31.0)	2.49E-08 (27.0)	6.43E-10	1.14E-07
AFW-TDP-FS-U2FW2	19	1.10E-02	(21.5)	2.17E-08 (28.0)	3.54E-11	1.96E-07
AFW-TDP-MA-U2FW2	17	1.00E-02	(23.5)	1.87E-08 (29.0)	3.32E-11	1.25E-07
OEP-DGN-FR-DG01	1	2.00E-03	(30.0)	5.11E-09 (30.0)	6.69E-12	1.41E-06
DGN-FTO	198	3.39E-02	(11.0)	-1.08E-07 (31.0)	-8.13E-07	-8.91E-10

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	216	7.70E-02	(1.0)	3.50E-06 (1.0)	7.92E-08	2.05E-05

SEQUENCE SBO-L
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
OEP-DGN-FS-DG01	86	2.20E-02	(15.5)	7.54E-05	(1.0)	2.84E-06	2.86E-04
OEP-DGN-FR-6HDG1	59	1.20E-02	(19.0)	7.12E-05	(2.0)	2.64E-06	2.58E-04
OEP-DGN-MA-DG01	30	6.00E-03	(26.0)	6.11E-05	(3.0)	2.05E-06	2.26E-04
AFW-TDP-MA-FW2	63	1.00E-02	(23.5)	5.11E-05	(4.0)	2.15E-06	2.46E-04
OEP-CRB-FT-15H3	22	3.00E-03	(28.5)	4.83E-05	(5.0)	1.71E-06	1.69E-04
AFW-TDP-FS-FW2	58	1.10E-02	(21.5)	4.62E-05	(6.0)	1.88E-06	2.29E-04
OEP-DGN-FS-DG02	45	2.20E-02	(15.5)	3.88E-05	(7.0)	1.49E-06	1.45E-04
OEP-DGN-FR-6HDG2	34	1.20E-02	(19.0)	3.86E-05	(8.0)	1.46E-06	1.43E-04
OEP-DGN-FS-DG03	45	2.20E-02	(15.5)	3.76E-05	(9.0)	1.40E-06	1.40E-04
OEP-DGN-FR-6HDG3	32	1.20E-02	(19.0)	3.76E-05	(10.0)	1.40E-06	1.33E-04
OEP-DGN-MA-DG02	19	6.00E-03	(26.0)	3.29E-05	(11.0)	1.15E-06	1.23E-04
OEP-DGN-MA-DG03	15	6.00E-03	(26.0)	3.06E-05	(12.0)	1.03E-06	1.13E-04
AFW-XHE-FO-CST2	22	6.50E-02	(9.0)	2.78E-05	(13.0)	7.74E-07	1.36E-04
AFW-CKV-OO-CV172	12	1.00E-03	(31.0)	2.49E-05	(14.0)	9.30E-07	1.22E-04
OEP-DGN-FS	18	2.20E-02	(15.5)	1.89E-05	(15.0)	6.96E-07	7.39E-05
OEP-CRB-FT-15J3	8	3.00E-03	(28.5)	1.78E-05	(16.0)	5.95E-07	6.65E-05
AFW-TDP-FR-2P6HR	61	3.00E-02	(12.5)	1.67E-05	(17.0)	2.97E-07	8.96E-05
BETA-2DG	18	3.80E-02	(10.0)	1.08E-05	(18.0)	3.49E-07	4.24E-05
QS-SBO	216	2.70E-01	(6.0)	8.14E-06	(19.0)	2.29E-07	3.90E-05
AFW-XHE-FO-U1SBO	73	8.20E-02	(8.0)	3.18E-06	(20.0)	5.48E-08	1.67E-05
OEP-DGN-FR-DG01	1	2.00E-03	(30.0)	2.55E-06	(21.0)	1.74E-08	9.69E-06
NRAC-1HR	22	4.40E-01	(5.0)	2.46E-06	(22.0)	3.02E-08	1.41E-05
NRAC-6HR-AVG	67	1.94E-01	(7.0)	2.18E-06	(23.0)	1.12E-08	9.13E-06
AFW-TDP-FS-U2FW2	19	1.10E-02	(21.5)	1.95E-06	(24.0)	3.20E-08	9.99E-06
AFW-TDP-MA-U2FW2	17	1.00E-02	(23.5)	1.86E-06	(25.0)	2.92E-08	8.88E-06
AFW-TDP-FR-6HRU2	19	3.00E-02	(12.5)	1.15E-06	(26.0)	9.08E-09	6.15E-06
NRAC-HALFHR	127	6.00E-01	(3.0)	6.98E-07	(27.0)	8.10E-09	3.80E-06
NOTDG-CCF	18	5.20E-01	(4.0)	3.92E-07	(28.0)		
REC-XHE-FO-DGEN	203	9.00E-01	(2.0)	3.73E-07	(29.0)	1.76E-09	1.58E-06
NOTQ	216	9.73E-01	(1.0)	9.73E-08	(30.0)		
DGN-FTO	198	3.39E-02	(11.0)	-3.08E-06	(31.0)	-1.90E-05	-5.73E-08

SEQUENCE SBO-L
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
OEP-DGN-FS-DG02	45	2.20E-02	(14.5)	20.6	(2.5)	1.89	0.70
OEP-DGN-FS-DG03	45	2.20E-02	(14.5)	20.6	(2.5)	1.89	0.70
OEP-DGN-FS-DG01	86	2.20E-02	(14.5)	20.6	(2.5)	1.89	0.70
OEP-DGN-FS	18	2.20E-02	(14.5)	20.6	(2.5)	1.89	0.70
OEP-DGN-FR-6HDG2	34	1.20E-02	(18.0)	16.9	(6.0)	1.58	0.71
OEP-DGN-FR-6HDG1	59	1.20E-02	(18.0)	16.9	(6.0)	1.58	0.71
OEP-DGN-FR-6HDG3	32	1.20E-02	(18.0)	16.9	(6.0)	1.58	0.71
OEP-DGN-FR-DG01	1	2.00E-03	(29.0)	16.4	(8.0)	1.00	1.00
QS-SBO	216	2.70E-01	(5.0)	16.3	(9.0)	1.73	0.87
AFW-XHE-FO-CST2	22	6.50E-02	(8.0)	10.6	(10.0)	1.43	0.80
OEP-DGN-MA-DG02	19	6.00E-03	(25.0)	3.0	(12.0)	1.22	0.87
OEP-DGN-MA-DG01	30	6.00E-03	(25.0)	3.0	(12.0)	1.22	0.87
OEP-DGN-MA-DG03	15	6.00E-03	(25.0)	3.0	(12.0)	1.22	0.87
AFW-TDP-MA-U2FW2	17	1.00E-02	(22.5)	2.2	(14.5)	1.23	1.03
AFW-TDP-MA-FW2	63	1.00E-02	(22.5)	2.2	(14.5)	1.23	1.03
AFW-TDP-FS-U2FW2	19	1.10E-02	(20.5)	2.0	(16.5)	1.15	0.97
AFW-TDP-FS-FW2	58	1.10E-02	(20.5)	2.0	(16.5)	1.15	0.97
REC-XHE-FO-DGEN	203	9.00E-01	(2.0)	1.3	(18.0)	1.01	0.98
NRAC-6HR-AVG	87	9.60E-02	(6.0)	1.2	(19.0)	1.13	1.00
AFW-CKV-OO-CV172	12	1.00E-03	(30.0)	0.8	(20.0)	0.99	1.00
BETA-2DG	18	3.80E-02	(9.0)	0.8	(21.0)	0.97	0.99
OEP-CRB-FT-15J3	8	3.00E-03	(27.5)	0.6	(22.5)	1.10	1.00
OEP-CRB-FT-15H3	22	3.00E-03	(27.5)	0.6	(22.5)	1.10	1.00
DGN-FTO	198	3.39E-02	(10.0)	0.4	(24.0)		
NRAC-HALFHR	149	6.00E-01	(3.0)	0.3	(25.0)		
AFW-TDP-FR-6HRU2	19	3.00E-02	(11.5)	0.0	(27.0)		
AFW-XHE-FO-U1SBO	73	8.20E-02	(7.0)	0.0	(27.0)		
AFW-TDP-FR-2P6HR	61	3.00E-02	(11.5)	0.0	(27.0)		
NOTQ	216	9.73E-01	(1.0)				
NOTDG-CCF	18	5.20E-01	(4.0)				

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	216	7.70E-02	(1.0)	23.1	(1.0)	1.95	0.98

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE SBO-L

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-L WITH TOP EVENT FREQUENCY 3.50E-08

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	2	9	2.43E-07	0.06947	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
3					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
4					REC-XHE-FO-DGEN	+						
5	1	9	2.43E-07	0.13893	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
6					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
7					REC-XHE-FO-DGEN	+						
8	3	9	2.26E-07	0.20351	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
9					NOTQ	*	NRAC-1HR	*	OEP-DGN-FS	*	QS-SBO	*
10					REC-XHE-FO-DGEN	+						
11	6	9	1.33E-07	0.24140	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
12					NRAC-1HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
13					REC-XHE-FO-DGEN	+						
14	5	9	1.33E-07	0.27929	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
15					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
16					REC-XHE-FO-DGEN	+						
17	4	9	1.33E-07	0.31718	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
18					NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
19					REC-XHE-FO-DGEN	+						
20	7	9	1.33E-07	0.35507	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
21					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
22					REC-XHE-FO-DGEN	+						
23	8	8	8.05E-08	0.37804	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
24					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
25	9	9	7.24E-08	0.39871	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
26					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
27					REC-XHE-FO-DGEN	+						
28	11	9	6.64E-08	0.41785	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
29					NRAC-1HR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
30					REC-XHE-FO-DGEN	+						
31	10	9	6.64E-08	0.43860	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
32					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
33					REC-XHE-FO-DGEN	+						
34	13	9	6.64E-08	0.45554	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
35					NRAC-1HR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
36					REC-XHE-FO-DGEN	+						
37	12	9	6.64E-08	0.47449	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
38					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
39					REC-XHE-FO-DGEN	+						
40	15	9	5.62E-08	0.49052	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
41					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
42					REC-XHE-FO-DGEN	+						
43	14	9	5.62E-08	0.50855	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
44					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
45					REC-XHE-FO-DGEN	+						
46	16	9	5.22E-08	0.52145	AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*

47				NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*	QS-SBO	*
48				REC-XHE-FO-DGEN	+						
49	17	9	5.11E-08	0.53602		/DGN-FTO	*	IE-T1	*	NOTQ	*
50				AFW-TDP-MA-FW2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
51				NRAC-HALFHR	*						
52	18	9	5.11E-08	0.55060		/DGN-FTO	*	IE-T1	*	NOTQ	*
53				AFW-TDP-MA-FW2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
54				NRAC-HALFHR	*						
55	36	9	4.95E-08	0.56473		/DGN-FTO	*	IE-T1	*	NOTQ	*
56				REC-XHE-FO-DGEN	+	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
57				AFW-TDP-FR-2P6HR	*						
58	35	9	4.95E-08	0.57887		/DGN-FTO	*	IE-T1	*	NOTQ	*
59				NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
60				REC-XHE-FO-DGEN	+						
61	23	9	4.75E-08	0.59242		BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
62				AFW-TDP-MA-FW2	*	NRAC-HALFHR	*	OEP-DGN-FS	*	QS-SBO	*
63				NOTQ	*						
64	37	9	4.61E-08	0.60556		BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
65				REC-XHE-FO-DGEN	+	NRAC-6HR-AVG	*	OEP-DGN-FS	*	QS-SBO	*
66				AFW-TDP-FR-2P6HR	*						
67	22	9	3.62E-08	0.61589		/DGN-FTO	*	IE-T1	*	NOTQ	*
68				NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
69				REC-XHE-FO-DGEN	+						
70	21	9	3.62E-08	0.62623		/DGN-FTO	*	IE-T1	*	NOTQ	*
71				AFW-XHE-FO-CST2	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
72				NRAC-1HR	*						
73	20	9	3.62E-08	0.63656		/DGN-FTO	*	IE-T1	*	NOTQ	*
74				REC-XHE-FO-DGEN	+	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	QS-SBO	*
75				AFW-XHE-FO-CST2	*						
76	19	9	3.62E-08	0.64690		/DGN-FTO	*	IE-T1	*	NOTQ	*
77				NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*
78				REC-XHE-FO-DGEN	+						
79	24	9	3.32E-08	0.65637		/DGN-FTO	*	IE-T1	*	NOTQ	*
80				AFW-XHE-FO-CST2	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
81				NRAC-1HR	*						
82	25	9	3.32E-08	0.66584		/DGN-FTO	*	IE-T1	*	NOTQ	*
83				REC-XHE-FO-DGEN	+	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
84				AFW-XHE-FO-CST2	*						
85	26	9	3.32E-08	0.67531		/DGN-FTO	*	IE-T1	*	NOTQ	*
86				NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
87				REC-XHE-FO-DGEN	+						
88	28	9	3.06E-08	0.68406		/DGN-FTO	*	IE-T1	*	NOTQ	*
89				AFW-TDP-FS-FW2	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
90				NRAC-HALFHR	*						
91	29	9	3.06E-08	0.69280		/DGN-FTO	*	IE-T1	*	NOTQ	*
92				REC-XHE-FO-DGEN	+	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
93				AFW-TDP-FS-FW2	*						
94	27	9	3.06E-08	0.70155		/DGN-FTO	*	IE-T1	*	NOTQ	*
95				NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
96				REC-XHE-FO-DGEN	+						
97	33	9	2.79E-08	0.70949		/DGN-FTO	*	IE-T1	*	NOTQ	*
98				AFW-TDP-MA-FW2	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
99				NRAC-HALFHR	*						
100	32	9	2.79E-08	0.71744		/DGN-FTO	*	IE-T1	*	NOTQ	*
101				REC-XHE-FO-DGEN	+	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
102				NRAC-HALFHR	*						

103	30	9	2.79E-08	0.72539	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
104					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
105					REC-XHE-FO-DGEN	+						
106	31	9	2.79E-08	0.73334	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
107					NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
108					REC-XHE-FO-DGEN	+						
109	53	9	2.70E-08	0.74105	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
110					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
111					REC-XHE-FO-DGEN	+						
112	51	9	2.70E-08	0.74876	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
113					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
114					REC-XHE-FO-DGEN	+						
115	52	9	2.70E-08	0.75647	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
116					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
117					REC-XHE-FO-DGEN	+						
118	50	9	2.70E-08	0.76418	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
119					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
120					REC-XHE-FO-DGEN	+						
121	38	8	1.86E-08	0.76948	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
122					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
123	34	9	1.81E-08	0.77465	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
124					NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
125					REC-XHE-FO-DGEN	+						
126	39	8	1.69E-08	0.77947	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
127					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
128	40	9	1.67E-08	0.78424	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
129					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
130					REC-XHE-FO-DGEN	+						
131	65	8	1.64E-08	0.78891	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
132					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
133	43	9	1.53E-08	0.79328	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
134					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
135					REC-XHE-FO-DGEN	+						
136	41	9	1.53E-08	0.79765	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
137					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
138					REC-XHE-FO-DGEN	+						
139	44	9	1.53E-08	0.80203	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
140					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
141					REC-XHE-FO-DGEN	+						
142	42	9	1.53E-08	0.80640	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
143					NRAC-HALFHR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
144					REC-XHE-FO-DGEN	+						
145	45	9	1.52E-08	0.81073	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
146					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
147					REC-XHE-FO-DGEN	+						
148	70	9	1.47E-08	0.81494	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
149					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
150					REC-XHE-FO-DGEN	+						
151	46	9	1.39E-08	0.81891	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
152					NRAC-HALFHR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
153					REC-XHE-FO-DGEN	+						
154	49	9	1.39E-08	0.82289	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
155					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
156					REC-XHE-FO-DGEN	+						
157	48	9	1.39E-08	0.82686	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
158					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*

215					NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*
216					REC-XHE-FO-DGEN	+						
217	69	9	7.60E-09	0.88961	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
218					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	QS-SBO	*
219					REC-XHE-FO-DGEN	+						
220	68	9	7.60E-09	0.89178	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
221					NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*
222					REC-XHE-FO-DGEN	+						
223	67	9	7.60E-09	0.89394	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
224					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
225					REC-XHE-FO-DGEN	+						
226	66	9	7.60E-09	0.89611	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
227					NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
228					REC-XHE-FO-DGEN	+						
229	98	9	7.37E-09	0.89822	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
230					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	QS-SBO	*
231					REC-XHE-FO-DGEN	+						
232	99	9	7.37E-09	0.90032	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
233					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
234					REC-XHE-FO-DGEN	+						
235	100	9	7.37E-09	0.90242	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
236					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
237					REC-XHE-FO-DGEN	+						
238	97	9	7.37E-09	0.90452	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
239					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*
240					REC-XHE-FO-DGEN	+						
241	73	9	6.97E-09	0.90651	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
242					NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
243					REC-XHE-FO-DGEN	+						
244	72	9	6.97E-09	0.90850	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
245					NRAC-HALFHR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
246					REC-XHE-FO-DGEN	+						
247	71	9	6.97E-09	0.91049	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
248					NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
249					REC-XHE-FO-DGEN	+						
250	77	10	6.79E-09	0.91242	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
251					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
252					/QS-SBO	*	REC-XHE-FO-DGEN	+				
253	76	10	6.79E-09	0.91436	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
254					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
255					/QS-SBO	*	REC-XHE-FO-DGEN	+				
256	75	10	6.79E-09	0.91630	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
257					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
258					/QS-SBO	*	REC-XHE-FO-DGEN	+				
259	74	10	6.79E-09	0.91824	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
260					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
261					/QS-SBO	*	REC-XHE-FO-DGEN	+				
262	108	9	6.76E-09	0.92017	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
263					NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
264					REC-XHE-FO-DGEN	+						
265	106	9	6.76E-09	0.92210	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
266					NRAC-6HR-AVG	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
267					REC-XHE-FO-DGEN	+						
268	107	9	6.76E-09	0.92402	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
269					NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
270					REC-XHE-FO-DGEN	+						

SEQUENCE SBO-SLOCA2

TOP EVENT SBO-SLOCA2 CONTAINS 37 EVENTS IN 770 CUT SETS

THE FREQUENCY OF TOP EVENT SBO-SLOCA2 IS 2.59E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SBO-SLOCA2

N	1000
MEAN	3.34E-06
STD DEV	7.22E-06
LOWER 5%	0.00E+00
LOWER 25%	0.00E+00
MEDIAN	1.09E-06
UPPER 25%	3.44E-06
UPPER 5%	1.44E-05

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE SBO-SLOCA2
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NOTQ	770	9.73E-01 (1.0)	2.59E-06 (1.5)		
NOTL-SBOU1U2	770	9.68E-01 (2.0)	2.59E-06 (1.5)		
REC-XHE-FO-DGHWS	630	8.00E-01 (3.0)	2.56E-06 (3.0)	0.00E+00	1.27E-05
OEP-DGN-FS	147	2.20E-02 (19.5)	2.21E-06 (4.0)	0.00E+00	9.67E-06
RCP-LOCA-750-90M	110	5.30E-01 (5.0)	2.09E-06 (5.0)	0.00E+00	1.27E-05
BETA-3DG	21	1.80E-02 (22.0)	2.09E-06 (6.0)	0.00E+00	9.32E-06
NRAC-216M	93	1.38E-01 (10.0)	2.02E-06 (7.0)	0.00E+00	1.21E-05
RCP-LOCA-467-150	110	1.27E-01 (11.0)	3.93E-07 (8.0)	0.00E+00	2.60E-06
NRAC-258M	93	1.08E-01 (14.0)	3.78E-07 (9.0)	0.00E+00	2.48E-06
OEP-DGN-FS-DG03	231	2.20E-02 (19.5)	2.07E-07 (11.0)	0.00E+00	1.86E-06
OEP-DGN-FS-DG02	231	2.20E-02 (19.5)	2.07E-07 (11.0)	0.00E+00	1.86E-06
OEP-DGN-FS-DG01	231	2.20E-02 (19.5)	2.07E-07 (11.0)	0.00E+00	1.86E-06
OEP-DGN-FR-6HDG3	217	1.20E-02 (27.0)	1.40E-07 (14.0)	0.00E+00	1.23E-06
OEP-DGN-FR-6HDG2	217	1.20E-02 (27.0)	1.40E-07 (14.0)	0.00E+00	1.23E-06
OEP-DGN-FR-6HDG1	217	1.20E-02 (27.0)	1.40E-07 (14.0)	0.00E+00	1.23E-06
BETA-2DG	126	3.80E-02 (17.0)	1.24E-07 (16.5)	0.00E+00	4.88E-07
NOTDG-CCF	126	5.20E-01 (6.0)	1.24E-07 (16.5)		
NRAC-201M	17	1.50E-01 (9.0)	7.68E-08 (18.0)	0.00E+00	4.04E-07
NRAC-7HR	330	5.00E-02 (15.0)	6.60E-08 (19.0)	0.00E+00	0.00E+00
OEP-DGN-MA-DG03	112	6.00E-03 (30.0)	5.32E-08 (21.0)	0.00E+00	2.76E-07
OEP-DGN-MA-DG02	112	6.00E-03 (30.0)	5.32E-08 (21.0)	0.00E+00	2.76E-07
OEP-DGN-MA-DG01	112	6.00E-03 (30.0)	5.32E-08 (21.0)	0.00E+00	2.76E-07
NRAC-246M	110	1.15E-01 (13.0)	2.68E-08 (23.0)	0.00E+00	6.49E-08
RCP-LOCA-1440-90	110	4.30E-03 (32.0)	2.58E-08 (24.5)	0.00E+00	0.00E+00
NRAC-150M	110	2.10E-01 (8.0)	2.58E-08 (24.5)	0.00E+00	0.00E+00
OEP-CRB-FT-15J3	105	3.00E-03 (35.0)	2.40E-08 (27.0)	0.00E+00	1.45E-07
OEP-CRB-FT-15H3	105	3.00E-03 (35.0)	2.40E-08 (27.0)	0.00E+00	1.45E-07
OEP-CRB-FT-25H3	105	3.00E-03 (35.0)	2.40E-08 (27.0)	0.00E+00	1.45E-07
RCP-LOCA-183-210	110	1.61E-02 (23.5)	2.30E-08 (29.5)	0.00E+00	0.00E+00
RCP-LOCA-183-150	110	1.61E-02 (23.5)	2.30E-08 (29.5)	0.00E+00	0.00E+00
RCP-LOCA-183-90	110	1.40E-02 (25.0)	2.00E-08 (31.0)	0.00E+00	0.00E+00
REC-XHE-FO-DGTMS	84	7.00E-01 (4.0)	1.56E-08 (32.0)	0.00E+00	8.10E-08
RCP-LOCA-561-150	110	4.00E-03 (33.0)	1.32E-08 (33.0)	0.00E+00	0.00E+00
O	518	4.90E-02 (16.0)	1.58E-09 (34.0)	-2.85E-08	2.92E-08
NRAC-234M	17	1.23E-01 (12.0)	4.76E-10 (35.0)	0.00E+00	0.00E+00
QS-SBO	770	2.70E-01 (7.0)	-9.27E-09 (36.0)	-4.28E-08	0.00E+00

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	770	7.70E-02 (1.0)	2.59E-06 (1.0)	0.00E+00	1.44E-05

SEQUENCE SBO-SLOCA2
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
BETA-3DG	21	1.80E-02 (22.0)	1.14E-04 (1.0)	0.00E+00	4.25E-04
OEP-DGN-FS	147	2.20E-02 (18.5)	9.82E-05 (2.0)	0.00E+00	4.01E-04
NRAC-216M	93	1.38E-01 (10.0)	1.26E-05 (3.0)	0.00E+00	7.54E-05
OEP-DGN-FR-6HDG1	217	1.20E-02 (27.0)	1.15E-05 (5.0)	0.00E+00	6.41E-05
OEP-DGN-FR-6HDG2	217	1.20E-02 (27.0)	1.15E-05 (5.0)	0.00E+00	6.41E-05
OEP-DGN-FR-6HDG3	217	1.20E-02 (27.0)	1.15E-05 (5.0)	0.00E+00	6.41E-05
OEP-DGN-FS-DG03	231	2.20E-02 (19.5)	9.20E-06 (8.0)	0.00E+00	5.27E-05
OEP-DGN-FS-DG01	231	2.20E-02 (19.5)	9.20E-06 (8.0)	0.00E+00	5.27E-05
OEP-DGN-FS-DG02	231	2.20E-02 (19.5)	9.20E-06 (8.0)	0.00E+00	5.27E-05
OEP-DGN-MA-DG02	112	6.00E-03 (30.0)	8.81E-06 (11.0)	0.00E+00	5.18E-05
OEP-DGN-MA-DG01	112	6.00E-03 (30.0)	8.81E-06 (11.0)	0.00E+00	5.18E-05
OEP-DGN-MA-DG03	112	6.00E-03 (30.0)	8.81E-06 (11.0)	0.00E+00	5.18E-05
OEP-CRB-FT-15J3	105	3.00E-03 (35.0)	7.99E-06 (14.0)	0.00E+00	4.93E-05
OEP-CRB-FT-25H3	105	3.00E-03 (35.0)	7.99E-06 (14.0)	0.00E+00	4.93E-05
OEP-CRB-FT-15H3	105	3.00E-03 (35.0)	7.99E-06 (14.0)	0.00E+00	4.93E-05
RCP-LOCA-1440-90	110	4.30E-03 (32.0)	5.97E-06 (16.0)	2.09E-07	3.03E-05
RCP-LOCA-561-150	110	4.00E-03 (33.0)	3.28E-06 (17.0)	1.69E-07	1.69E-05
BETA-2DG	126	3.80E-02 (17.0)	3.13E-06 (18.0)	0.00E+00	1.34E-05
NRAC-258M	93	1.08E-01 (14.0)	3.13E-06 (19.0)	0.00E+00	2.29E-05
RCP-LOCA-467-150	110	1.27E-01 (11.0)	2.70E-06 (20.0)	0.00E+00	1.51E-05
RCP-LOCA-750-90M	110	5.30E-01 (5.0)	1.86E-06 (21.0)	0.00E+00	1.04E-05
RCP-LOCA-183-90	110	1.40E-02 (25.0)	1.41E-06 (22.0)	5.71E-08	7.78E-06
RCP-LOCA-183-210	110	1.61E-02 (23.5)	1.40E-06 (23.5)	3.99E-08	7.68E-06
RCP-LOCA-183-150	110	1.61E-02 (23.5)	1.40E-06 (23.5)	4.05E-08	7.78E-06
NRAC-7HR	330	5.00E-02 (15.0)	1.25E-06 (25.0)	0.00E+00	0.00E+00
REC-XHE-FO-DGHWS	630	8.00E-01 (3.0)	6.40E-07 (26.0)	0.00E+00	2.86E-06
NRAC-201M	17	1.50E-01 (9.0)	4.35E-07 (27.0)	0.00E+00	2.25E-06
NRAC-246M	110	1.15E-01 (13.0)	2.08E-07 (28.0)	0.00E+00	5.12E-07
NOTDG-CCF	126	5.20E-01 (8.0)	1.14E-07 (29.0)		
NRAC-150M	110	2.10E-01 (8.0)	9.70E-08 (30.0)	0.00E+00	0.00E+00
NOTL-SBOU1U2	770	9.68E-01 (2.0)	8.57E-08 (31.0)		
NOTQ	770	9.73E-01 (1.0)	7.19E-08 (32.0)		
O	518	4.90E-02 (16.0)	3.02E-08 (33.0)	-6.73E-07	5.42E-07
REC-XHE-FO-DGTMS	84	7.00E-01 (4.0)	6.89E-09 (34.0)	0.00E+00	2.42E-08
NRAC-234M	17	1.23E-01 (12.0)	3.39E-09 (35.0)	0.00E+00	0.00E+00
QS-SBO	770	2.70E-01 (7.0)	-2.51E-08 (36.0)	-1.50E-07	0.00E+00

E-105

SEQUENCE SBO-SLOCA2
 UNCERTAINTY IMPORTANCE BY BASE EVENT

E-106

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
RCP-LOCA-750-90M	110	5.30E-01	(5.0)	44.8	(1.0)	NA	0.98
RCP-LOCA-467-150	110	1.27E-01	(11.0)	5.3	(2.0)	NA	1.00
OEP-DGN-FS-DG03	231	2.20E-02	(19.5)	2.4	(4.5)	NA	0.77
OEP-DGN-FS	147	2.20E-02	(19.5)	2.4	(4.5)	NA	0.77
OEP-DGN-FS-DG01	231	2.20E-02	(19.5)	2.4	(4.5)	NA	0.77
OEP-DGN-FS-DG02	231	2.20E-02	(19.5)	2.4	(4.5)	NA	0.77
BETA-3DG	21	1.80E-02	(22.0)	1.7	(7.0)	NA	0.89
NRAC-216M	93	1.38E-01	(10.0)	1.5	(8.0)	NA	0.95
OEP-DGN-FR-6HDG3	217	1.20E-02	(27.0)	1.4	(10.0)	NA	0.84
OEP-DGN-FR-6HDG2	217	1.20E-02	(27.0)	1.4	(10.0)	NA	0.84
OEP-DGN-FR-6HDG1	217	1.20E-02	(27.0)	1.4	(10.0)	NA	0.84
REC-XHE-FO-DGTMS	84	7.00E-01	(4.0)	1.3	(12.0)	NA	1.00
NRAC-150M	110	2.10E-01	(8.0)	1.3	(13.0)	NA	1.00
NRAC-7HR	330	5.00E-02	(15.0)	1.3	(14.0)	NA	1.00
NRAC-258M	93	1.08E-01	(14.0)	1.3	(15.0)	NA	1.02
NRAC-201M	17	1.50E-01	(9.0)	1.3	(16.0)	NA	1.00
NRAC-246M	110	1.15E-01	(13.0)	1.3	(17.0)	NA	1.00
REC-XHE-FO-DGHWS	630	8.00E-01	(3.0)	1.2	(18.0)	NA	0.99
NRAC-234M	17	1.23E-01	(12.0)	1.2	(19.0)	NA	1.00
RCP-LOCA-1440-90	110	4.30E-03	(32.0)	0.8	(20.0)	NA	1.01
O	518	4.90E-02	(18.0)	0.7	(21.0)	NA	1.00
OEP-CRB-FT-15J3	105	3.00E-03	(35.0)	0.5	(23.0)	NA	0.95
OEP-CRB-FT-15H3	105	3.00E-03	(35.0)	0.5	(23.0)	NA	0.95
OEP-CRB-FT-25H3	105	3.00E-03	(35.0)	0.5	(23.0)	NA	0.95
OEP-DGN-MA-DG03	112	6.00E-03	(30.0)	0.4	(26.0)		
OEP-DGN-MA-DG02	112	6.00E-03	(30.0)	0.4	(26.0)		
OEP-DGN-MA-DG01	112	6.00E-03	(30.0)	0.4	(26.0)		
RCP-LOCA-183-210	110	1.61E-02	(23.5)	0.3	(28.0)		
BETA-2DG	126	3.80E-02	(17.0)	0.2	(29.0)		
RCP-LOCA-561-150	110	4.00E-03	(33.0)	0.2	(30.0)		
RCP-LOCA-183-150	110	1.61E-02	(23.5)	0.2	(31.0)		
RCP-LOCA-183-90	110	1.40E-02	(25.0)	0.1	(32.0)		
QS-SBO	770	2.70E-01	(7.0)	0.0	(33.0)		
NOTDG-CCF	126	5.20E-01	(8.0)				
NOTQ	770	9.73E-01	(1.0)				
NOTL-SBOU1U2	770	9.68E-01	(2.0)				

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	770	7.70E-02	(2.0)	1.8	(35.0)	NA	0.96

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE

SEQUENCE SBO-SLOCA2

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-SLOCA2 WITH TOP EVENT FREQUENCY 2.59E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	10	1.17E-06	0.45000	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
3					NRAC-216M	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
4					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
5	2	9	4.54E-07	0.62502	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
6					NRAC-216M	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-750-90M	*
7					REC-XHE-FO-DGHWS	+						
8	111	10	2.19E-07	0.70941	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
9					NRAC-258M	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
10					RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+				
11	112	9	8.51E-08	0.74223	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
12					NRAC-258M	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-467-150	*
13					REC-XHE-FO-DGHWS	+						
14	3	10	6.53E-08	0.76743	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
15					NRAC-201M	*	O	*	OEP-DGN-FS	*	/QS-SBO	*
16					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
17	4	11	3.14E-08	0.77953	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
18					/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
19					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
20	5	11	1.71E-08	0.78613	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
21					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
22					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
23	7	11	1.71E-08	0.79273	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
24					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
25					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
26	6	11	1.71E-08	0.79933	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
27					/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
28					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
29	8	12	1.54E-08	0.80526	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
30					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG3	*
31					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
32	9	12	1.54E-08	0.81119	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
33					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG2	*
34					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
35	10	12	1.54E-08	0.81711	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
36					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
37					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
38	441	10	1.44E-08	0.82267	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
39					NRAC-150M	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
40					RCP-LOCA-1440-90	*	REC-XHE-FO-DGHWS	+				
41	331	10	1.28E-08	0.82762	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
42					NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
43					RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	+				
44	221	10	1.28E-08	0.83258	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
45					NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
46					RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	+				

47	11	10	1.22E-08	0.83728	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
48					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* QS-SBO	*
49					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		*
50	113	10	1.20E-08	0.84191	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
51					NRAC-246M	* O	* OEP-DGN-FS	* /QS-SBO	*
52					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+		*
53	551	10	1.12E-08	0.84622	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
54					NRAC-7HR	* /O	* OEP-DGN-FS	* /QS-SBO	*
55					RCP-LOCA-183-90	* REC-XHE-FO-DGHWS	+		*
56	14	11	9.33E-09	0.84982	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
57					/O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
58					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
59	13	11	9.33E-09	0.85342	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
60					/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG03	*
61					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
62	12	11	9.33E-09	0.85702	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
63					/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG02	*
64					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
65	16	11	8.56E-09	0.86032	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
66					/O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG02	*
67					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
68	15	11	8.56E-09	0.86362	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
69					/O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG03	*
70					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
71	17	11	8.56E-09	0.86692	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
72					/O	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
73					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
74	20	12	7.68E-09	0.86988	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
75					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS	*
76					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
77	18	12	7.68E-09	0.87285	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
78					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS	*
79					OEP-DGN-MA-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
80	19	12	7.68E-09	0.87581	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
81					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FS	*
82					OEP-DGN-MA-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
83	661	10	7.34E-09	0.87864	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
84					NRAC-246M	* /O	* OEP-DGN-FS	* /QS-SBO	*
85					RCP-LOCA-561-150	* REC-XHE-FO-DGHWS	+		*
86	21	10	6.65E-09	0.88121	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
87					OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* QS-SBO	*
88					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		*
89	22	10	6.65E-09	0.88377	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
90					OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* QS-SBO	*
91					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		*
92	23	10	6.65E-09	0.88634	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
93					OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* QS-SBO	*
94					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		*
95	24	10	6.36E-09	0.88880	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-216M	*
96					/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	* OEP-DGN-FR-6HDG3	*
97					/QS-SBO	* RCP-LOCA-750-90M	+		*
98	27	11	5.98E-09	0.89110	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
99					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS	*
100					QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+	*
101	25	11	5.98E-09	0.89341	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
102					NOTQ	* NRAC-216M	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS	*

103					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
104	26	11	5.98E-09	0.89571	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*		
105					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*		
106					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
107	114	11	5.88E-09	0.89798	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-258M	*		
108					/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*		
109					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	+				
110	442	9	5.60E-09	0.90014	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*		
111					NRAC-150M	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-1440-90	*		
112					REC-XHE-FO-DGHWS	+								
113	332	9	4.99E-09	0.90207	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*		
114					NRAC-7HR	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-183-210	*		
115					REC-XHE-FO-DGHWS	+								
116	222	9	4.99E-09	0.90399	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*		
117					NRAC-7HR	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-183-150	*		
118					REC-XHE-FO-DGHWS	+								
119	30	11	4.67E-09	0.90579	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
120					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG03	*		
121					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
122	28	11	4.67E-09	0.90759	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
123					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG02	*		
124					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
125	32	11	4.67E-09	0.90939	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
126					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*		
127					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
128	31	11	4.67E-09	0.91119	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
129					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*		
130					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
131	29	11	4.67E-09	0.91299	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
132					/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*		
133					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
134	33	11	4.67E-09	0.91479	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
135					/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*		
136					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
137	552	9	4.34E-09	0.91647	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*		
138					NRAC-7HR	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-183-90	*		
139					REC-XHE-FO-DGHWS	+								
140	34	11	4.28E-09	0.91812	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
141					/O	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*		
142					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
143	35	11	4.28E-09	0.91977	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
144					/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*		
145					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
146	36	11	4.28E-09	0.92142	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
147					/O	*	OEP-CRB-FT-25H3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*		
148					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				
149	39	10	3.63E-09	0.92282	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
150					OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*	QS-SBO	*		
151					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+						
152	38	10	3.63E-09	0.92422	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
153					OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*	QS-SBO	*		
154					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+						
155	37	10	3.63E-09	0.92562	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		
156					OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*		
157					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+						
158	41	10	3.33E-09	0.92690	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*		

SEQUENCE V

TOP EVENT V CONTAINS 3 EVENTS IN 3 CUT SETS

THE FREQUENCY OF TOP EVENT V IS 1.20E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT V

N	1000
MEAN	1.62E-06
STD DEV	6.02E-06
LOWER 5%	3.77E-11
LOWER 25%	3.31E-09
MEDIAN	4.88E-08
UPPER 25%	3.72E-07
UPPER 5%	5.26E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

5% =	3.77E-11	***LOG SCALE***	95% =	5.26E-06
-----[-----*-----]		-----N-M-----		

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
 = FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

- FOR BASE EVENTS AND INITIATING EVENTS:
RISK REDUCTION = PD x EV(J)
 = TEF - TEF(EVALUATED WITH EV(J) = 0)
- FOR BASE EVENTS ONLY:
RISK INCREASE = PD - RISK REDUCTION
 = PD x (1 - EV(J))
 = TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE V

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-V-TRAIN-2	1	4.00E-07 (2.0)	4.00E-07 (2.0)	1.26E-11	1.75E-06
IE-V-TRAIN-3	1	4.00E-07 (2.0)	4.00E-07 (2.0)	1.26E-11	1.75E-06
IE-V-TRAIN-1	1	4.00E-07 (2.0)	4.00E-07 (2.0)	1.26E-11	1.75E-06

SEQUENCE V

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
IE-V-TRAIN-2	1	4.00E-07 (2.0)	100.0	(2.0)
IE-V-TRAIN-3	1	4.00E-07 (2.0)	100.0	(2.0)
IE-V-TRAIN-1	1	4.00E-07 (2.0)	100.0	(2.0)

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE V

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
FOR TOP EVENT V WITH TOP EVENT FREQUENCY 1.20E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	2	1	4.00E-07	0.33333	IE-V-TRAIN-2	+
3	3	1	4.00E-07	0.66667	IE-V-TRAIN-3	+
4	1	1	4.00E-07	1.00000	IE-V-TRAIN-1	.

SEQUENCE SBO-Q

TOP EVENT SBO-Q CONTAINS 23 EVENTS IN 92 CUT SETS

THE FREQUENCY OF TOP EVENT SBO-Q IS 1.92E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SBO-Q

N	1000
MEAN	2.21E-08
STD DEV	8.99E-08
LOWER 5%	9.09E-09
LOWER 25%	8.31E-08
MEDIAN	3.35E-07
UPPER 25%	1.21E-06
UPPER 5%	8.68E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE SBO-Q
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
SBO-PORV-DMD	92	4.50E-01 (4.0)	1.92E-06 (2.0)	9.09E-09	8.68E-06
NRAC-1HR	92	4.40E-01 (5.0)	1.92E-06 (2.0)	9.09E-09	8.68E-06
NOTL-SBOU1	92	9.93E-01 (1.0)	1.92E-06 (2.0)		
REC-XHE-FO-DGEN	86	9.00E-01 (2.0)	1.91E-06 (4.0)	8.95E-09	8.64E-06
OEP-DGN-FS-DG01	28	2.20E-02 (12.5)	1.09E-06 (5.0)	4.17E-09	5.03E-06
PPS-SOV-OO-1456	46	3.00E-02 (9.5)	9.61E-07 (6.5)	4.55E-09	4.34E-06
PPS-SOV-OO-1455C	46	3.00E-02 (9.5)	9.61E-07 (6.5)	4.55E-09	4.34E-06
OEP-DGN-FS-DG03	16	2.20E-02 (12.5)	5.73E-07 (8.5)	2.32E-09	2.63E-06
OEP-DGN-FS-DG02	16	2.20E-02 (12.5)	5.73E-07 (8.5)	2.32E-09	2.63E-06
BETA-2DG	4	3.80E-02 (7.0)	3.55E-07 (11.0)	1.67E-09	1.42E-06
OEP-DGN-FS	4	2.20E-02 (12.5)	3.55E-07 (11.0)	1.67E-09	1.42E-06
NOTDG-CCF	4	5.20E-01 (3.0)	3.55E-07 (11.0)		
OEP-DGN-MA-DG01	18	6.00E-03 (16.0)	2.38E-07 (13.0)	2.76E-10	7.10E-07
OEP-CRB-FT-15H3	20	3.00E-03 (18.5)	1.37E-07 (14.0)	1.95E-10	3.85E-07
OEP-DGN-MA-DG02	12	6.00E-03 (16.0)	1.28E-07 (15.0)	1.39E-10	4.04E-07
OEP-DGN-MA-DG03	10	6.00E-03 (16.0)	1.24E-07 (16.0)	1.39E-10	3.71E-07
OEP-DGN-FR-DG01	22	2.00E-03 (21.0)	9.72E-08 (17.0)	1.49E-10	3.39E-07
OEP-CRB-FT-15J3	8	3.00E-03 (18.5)	6.63E-08 (18.0)	9.69E-11	1.87E-07
OEP-DGN-FR-DG02	14	2.00E-03 (21.0)	5.13E-08 (19.0)	8.00E-11	1.78E-07
OEP-DGN-FR-DG03	12	2.00E-03 (21.0)	5.06E-08 (20.0)	8.06E-11	1.76E-07
QS-SBO	92	2.70E-01 (6.0)	-1.23E-08 (21.0)	-9.84E-08	-2.83E-12
DGN-FTO	88	3.39E-02 (8.0)	-5.50E-08 (22.0)	-2.47E-07	-1.36E-10

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	92	7.70E-02 (1.0)	1.92E-06 (1.0)	9.09E-09	8.68E-06

SEQUENCE SBO-Q
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
OEP-DGN-FS-DG01	28	2.20E-02 (12.5)	4.87E-05 (1.0)	3.52E-07	1.91E-04
OEP-DGN-FR-DG01	22	2.00E-03 (21.0)	4.85E-05 (2.0)	3.58E-07	1.79E-04
OEP-CRB-FT-15H3	20	3.00E-03 (18.5)	4.57E-05 (3.0)	3.46E-07	1.70E-04
OEP-DGN-MA-DG01	18	6.00E-03 (16.0)	3.94E-05 (4.0)	3.25E-07	1.48E-04
PPS-SOV-OO-1455C	46	3.00E-02 (9.5)	3.11E-05 (5.5)	1.05E-06	1.54E-04
PPS-SOV-OO-1456	46	3.00E-02 (9.5)	3.11E-05 (5.5)	1.05E-06	1.54E-04
OEP-DGN-FR-DG02	14	2.00E-03 (21.0)	2.56E-05 (7.0)	1.82E-07	9.71E-05
OEP-DGN-FS-DG03	16	2.20E-02 (12.5)	2.55E-05 (8.5)	1.79E-07	1.04E-04
OEP-DGN-FS-DG02	16	2.20E-02 (12.5)	2.55E-05 (8.5)	1.79E-07	1.04E-04
OEP-DGN-FR-DG03	12	2.00E-03 (21.0)	2.53E-05 (10.0)	1.83E-07	9.02E-05
OEP-CRB-FT-15J3	8	3.00E-03 (18.5)	2.21E-05 (11.0)	1.71E-07	7.17E-05
OEP-DGN-MA-DG02	12	6.00E-03 (16.0)	2.12E-05 (12.0)	1.67E-07	8.02E-05
OEP-DGN-MA-DG03	10	6.00E-03 (16.0)	2.06E-05 (13.0)	1.66E-07	7.45E-05
OEP-DGN-FS	4	2.20E-02 (12.5)	1.58E-05 (14.0)	1.15E-07	5.41E-05
BETA-2DG	4	3.80E-02 (7.0)	9.00E-06 (15.0)	6.55E-08	3.34E-05
NRAC-1HR	92	4.40E-01 (5.0)	2.45E-06 (16.0)	1.10E-08	9.80E-06
SBO-PORV-DMD	92	4.50E-01 (4.0)	2.35E-06 (17.0)	9.19E-09	1.07E-05
NOTDG-CCF	4	5.20E-01 (3.0)	3.28E-07 (18.0)		
REC-XHE-FO-DGEN	36	9.00E-01 (2.0)	2.12E-07 (19.0)	2.49E-10	9.14E-07
NOTL-SBOU1	92	9.93E-01 (1.0)	1.36E-08 (20.0)		
QS-SBO	92	2.70E-01 (6.0)	-3.33E-08 (21.0)	-8.67E-08	-3.59E-11
DGN-FTO	88	3.39E-02 (8.0)	-1.57E-06 (22.0)	-7.51E-06	-6.85E-09

SEQUENCE SBO-Q
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
PPS-SOV-OO-1456	46	3.00E-02 (9.5)	44.8 (1.5)	7.31	1.12
PPS-SOV-OO-1455C	46	3.00E-02 (9.5)	44.8 (1.5)	7.31	1.12
QS-SBO	92	2.70E-01 (6.0)	43.8 (3.0)	0.99	1.00
OEP-DGN-FS	4	2.20E-02 (12.5)	20.2 (5.5)	1.75	0.97
OEP-DGN-FS-DG01	28	2.20E-02 (12.5)	20.2 (5.5)	1.75	0.97
OEP-DGN-FS-DG03	16	2.20E-02 (12.5)	20.2 (5.5)	1.75	0.97
OEP-DGN-FS-DG02	16	2.20E-02 (12.5)	20.2 (5.5)	1.75	0.97
SBO-PORV-DMD	92	4.50E-01 (4.0)	14.8 (8.0)	1.92	1.10
OEP-DGN-MA-DG01	18	6.00E-03 (16.0)	2.7 (10.0)	1.32	0.93
OEP-DGN-MA-DG03	10	6.00E-03 (16.0)	2.7 (10.0)	1.32	0.93
OEP-DGN-MA-DG02	12	6.00E-03 (16.0)	2.7 (10.0)	1.32	0.93
OEP-DGN-FR-DG03	12	2.00E-03 (21.0)	1.6 (13.0)	1.02	0.98
OEP-DGN-FR-DG02	14	2.00E-03 (21.0)	1.6 (13.0)	1.02	0.98
OEP-DGN-FR-DG01	22	2.00E-03 (21.0)	1.6 (13.0)	1.02	0.98
REC-XHE-FO-DGEN	86	9.00E-01 (2.0)	1.2 (15.0)	1.02	0.97
BETA-2DG	4	3.80E-02 (7.0)	1.0 (16.0)	1.12	1.01
NRAC-1HR	92	4.40E-01 (5.0)	0.6 (17.0)	0.97	0.92
OEP-CRB-FT-15J3	8	3.00E-03 (18.5)	0.4 (18.5)		
OEP-CRB-FT-15H3	20	3.00E-03 (18.5)	0.4 (18.5)		
DGN-FTO	88	3.38E-02 (8.0)	0.0 (20.0)		
NOTDG-CCF	4	5.20E-01 (3.0)			
NOTL-SBOU1	92	9.93E-01 (1.0)			

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	92	7.70E-02 (1.0)	18.1 (1.0)	1.85	0.97

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE SBO-Q

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-Q WITH TOP EVENT FREQUENCY 1.92E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

E-118

2	2	10	1.40E-07	0.07258	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
3					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1458	*	/QS-SBO	*
4					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
5	3	10	1.40E-07	0.14515	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
6					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
7					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
8	4	10	1.40E-07	0.21773	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
9					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
10					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
11	1	10	1.40E-07	0.29030	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
12					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
13					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
14	6	10	1.30E-07	0.35778	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
15					NRAC-1HR	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
16					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
17	5	10	1.30E-07	0.42525	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
18					NRAC-1HR	*	OEP-DGN-FS	*	PPS-SOV-OO-1456	*	/QS-SBO	*
19					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
20	7	10	5.16E-08	0.45209	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
21					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	QS-SBO	*
22					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
23	10	10	5.16E-08	0.47894	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
24					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1456	*	QS-SBO	*
25					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
26	9	10	5.16E-08	0.50578	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
27					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
28					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
29	8	10	5.16E-08	0.53262	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
30					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1456	*	QS-SBO	*
31					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
32	12	10	4.80E-08	0.55758	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
33					NRAC-1HR	*	OEP-DGN-FS	*	PPS-SOV-OO-1458	*	QS-SBO	*
34					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
35	11	10	4.80E-08	0.58253	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
36					NRAC-1HR	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*	QS-SBO	*
37					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
38	15	10	3.81E-08	0.60233	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
39					OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
40					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
41	14	10	3.81E-08	0.62212	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
42					OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
43					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
44	16	10	3.81E-08	0.64191	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
45					OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
46					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				

47	18	10	3.81E-08	0.66171	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
48					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
49					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
50	13	10	3.81E-08	0.68150	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
51					OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1456	* /QS-SBO	*
52					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
53	19	10	3.81E-08	0.70129	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
54					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
55					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
56	17	10	3.81E-08	0.72109	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
57					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1456	* /QS-SBO	*
58					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
59	20	10	3.81E-08	0.74088	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
60					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*
61					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
62	26	10	1.90E-08	0.75078	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
63					OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
64					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
65	25	10	1.90E-08	0.76067	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
66					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1456	* /QS-SBO	*
67					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
68	24	10	1.90E-08	0.77057	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
69					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*
70					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
71	23	10	1.90E-08	0.78047	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
72					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
73					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
74	21	10	1.90E-08	0.79036	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
75					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1456	* /QS-SBO	*
76					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
77	22	10	1.90E-08	0.80026	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
78					OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1456	* /QS-SBO	*
79					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
80	30	10	1.41E-08	0.80758	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
81					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1456	* QS-SBO	*
82					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
83	29	10	1.41E-08	0.81490	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
84					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1456	* QS-SBO	*
85					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
86	28	10	1.41E-08	0.82222	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
87					OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1456	* QS-SBO	*
88					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
89	31	10	1.41E-08	0.82954	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
90					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1455C	* QS-SBO	*
91					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
92	27	10	1.41E-08	0.83686	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
93					OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1455C	* QS-SBO	*
94					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
95	34	10	1.41E-08	0.84419	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
96					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1455C	* QS-SBO	*
97					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
98	33	10	1.41E-08	0.85151	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
99					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1455C	* QS-SBO	*
100					REC-XHE-FO-DGEN	* SBO-PORV-DMD			
101	32	10	1.41E-08	0.85883	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
102					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1456	* QS-SBO	*

103					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
104	42	10	1.27E-08	0.86542	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
105					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*		*
106					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
107	41	10	1.27E-08	0.87202	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
108					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*		*
109					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
110	40	10	1.27E-08	0.87862	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
111					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*		*
112					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
113	39	10	1.27E-08	0.88522	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
114					OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*		*
115					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
116	38	10	1.27E-08	0.89182	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
117					OEP-DGN-FR-DG03	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*		*
118					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
119	37	10	1.27E-08	0.89841	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
120					OEP-DGN-FR-DG03	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*		*
121					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
122	36	10	1.27E-08	0.90501	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
123					OEP-DGN-FR-DG02	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*		*
124					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
125	35	10	1.27E-08	0.91161	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
126					OEP-DGN-FR-DG02	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*		*
127					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
128	48	10	7.04E-09	0.91527	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
129					OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1456	*	QS-SBO	*		*
130					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
131	47	10	7.04E-09	0.91893	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
132					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1456	*	QS-SBO	*		*
133					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
134	46	10	7.04E-09	0.92259	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
135					OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1455C	*	QS-SBO	*		*
136					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
137	45	10	7.04E-09	0.92625	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
138					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	QS-SBO	*		*
139					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
140	44	10	7.04E-09	0.92991	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
141					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*		*
142					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
143	43	10	7.04E-09	0.93357	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
144					OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1456	*	QS-SBO	*		*
145					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
146	54	10	5.19E-09	0.93627	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
147					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*		*
148					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
149	53	10	5.19E-09	0.93897	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
150					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*		*
151					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
152	52	10	5.19E-09	0.94167	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
153					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*		*
154					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
155	51	10	5.19E-09	0.94437	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*
156					OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*		*
157					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+						
158	50	10	5.19E-09	0.94707	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*		*

SEQUENCE S1-H1

TOP EVENT S1-H1-CM CONTAINS 20 EVENTS IN 30 CUT SETS

THE FREQUENCY OF TOP EVENT S1-H1-CM IS 1.55E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT S1-H1-CM

N	1000
MEAN	1.74E-06
STD DEV	4.43E-06
LOWER 5%	1.09E-07
LOWER 25%	3.62E-07
MEDIAN	7.67E-07
UPPER 25%	1.63E-06
UPPER 5%	5.58E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE S1-H1
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
BETA-2MOV	3	8.80E-02	(1.0)	9.86E-07 (1.0)	2.62E-08	3.15E-06
LPR-MOV-FT-1862A	7	5.20E-03	(3.5)	5.30E-07 (2.0)	7.86E-09	2.52E-06
LPR-MOV-FT-1860A	6	3.00E-03	(7.5)	3.05E-07 (3.0)	4.56E-09	1.15E-06
RMT-CCF-FA-MSCAL	1	3.00E-04	(17.0)	3.00E-07 (4.0)	7.36E-09	1.25E-06
LPR-MOV-FT-1890A	2	3.00E-03	(7.5)	2.73E-07 (5.0)	4.02E-09	1.00E-06
LPR-MOV-FT-1862B	6	5.20E-03	(3.5)	7.24E-08 (6.0)	5.93E-10	5.40E-07
LPR-CCF-PG-SUMP	1	5.00E-05	(18.0)	5.00E-08 (7.0)	1.14E-09	2.05E-07
LPR-MOV-FT-1860B	5	3.00E-03	(7.5)	4.15E-08 (8.0)	3.88E-10	2.63E-07
LPR-XHE-FO-HOTLG	1	4.00E-05	(19.0)	4.00E-08 (9.0)	9.44E-10	1.40E-07
LPI-MDP-FS-S11B	3	3.00E-03	(7.5)	2.65E-08 (10.5)	2.40E-10	9.57E-08
LPI-MDP-FS-S11A	3	3.00E-03	(7.5)	2.65E-08 (10.5)	2.40E-10	9.57E-08
LPI-MDP-MA-S11B	3	2.00E-03	(11.5)	1.77E-08 (12.5)	1.41E-10	7.80E-08
LPI-MDP-MA-S11A	3	2.00E-03	(11.5)	1.77E-08 (12.5)	1.41E-10	7.80E-08
LPR-MOV-FT-1890B	1	3.00E-03	(7.5)	9.00E-09 (14.0)	7.37E-12	1.08E-07
LPI-MDP-FR-B21HR	4	6.30E-04	(15.5)	8.32E-09 (15.5)	9.43E-11	2.93E-08
LPI-MDP-FR-A21HR	4	6.30E-04	(15.5)	8.32E-09 (15.5)	9.43E-11	2.93E-08
RMT-ACT-FA-RMTSB	2	1.60E-03	(13.5)	3.09E-09 (17.5)	4.32E-11	2.51E-08
RMT-ACT-FA-RMTSA	2	1.60E-03	(13.5)	3.09E-09 (17.5)	4.32E-11	2.51E-08
RMT-XHE-FO-MANS1	2	6.40E-02	(2.0)	1.06E-09 (19.0)	5.10E-12	3.57E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-S1	30	1.00E-03	(1.0)	1.55E-06 (1.0)	1.09E-07	5.58E-06

SEQUENCE S1-H1
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
LPR-XHE-FO-HOTLG	1	4.00E-05	(19.0)	1.00E-03	(1.5)	2.66E-04	2.40E-03
LPR-CCF-PG-SUMP	1	5.00E-05	(18.0)	1.00E-03	(1.5)	2.66E-04	2.40E-03
RMT-CCF-FA-MSCAL	1	3.00E-04	(17.0)	1.00E-03	(3.0)	2.66E-04	2.40E-03
LPR-MOV-FT-1860A	6	3.00E-03	(7.5)	1.02E-04	(4.0)	1.54E-05	2.91E-04
LPR-MOV-FT-1862A	7	5.20E-03	(3.5)	1.01E-04	(5.0)	1.55E-05	2.92E-04
LPR-MOV-FT-1890A	2	3.00E-03	(7.5)	9.07E-05	(6.0)	1.30E-05	2.73E-04
LPR-MOV-FT-1862B	6	5.20E-03	(3.5)	1.39E-05	(7.0)	1.47E-06	4.35E-05
LPR-MOV-FT-1860B	5	3.00E-03	(7.5)	1.38E-05	(8.0)	1.44E-06	4.28E-05
LPI-MDP-FR-B21HR	4	6.30E-04	(15.5)	1.32E-05	(9.5)	1.30E-06	4.11E-05
LPI-MDP-FR-A21HR	4	6.30E-04	(15.5)	1.32E-05	(9.5)	1.30E-06	4.11E-05
BETA-2MOV	3	8.80E-02	(1.0)	1.02E-05	(11.0)	5.06E-07	3.49E-05
LPI-MDP-MA-S11B	3	2.00E-03	(11.5)	8.81E-06	(12.5)	5.94E-07	2.82E-05
LPI-MDP-MA-S11A	3	2.00E-03	(11.5)	8.81E-06	(12.5)	5.94E-07	2.82E-05
LPI-MDP-FS-S11B	3	3.00E-03	(7.5)	8.80E-06	(14.5)	5.93E-07	2.82E-05
LPI-MDP-FS-S11A	3	3.00E-03	(7.5)	8.80E-06	(14.5)	5.93E-07	2.82E-05
LPR-MOV-FT-1890B	1	3.00E-03	(7.5)	2.99E-06	(16.0)	6.55E-08	1.10E-05
RMT-ACT-FA-RMTSB	2	1.60E-03	(13.5)	1.93E-06	(17.5)	1.51E-07	6.17E-06
RMT-ACT-FA-RMTSA	2	1.60E-03	(13.5)	1.93E-06	(17.5)	1.51E-07	6.17E-06
RMT-XHE-FO-MANS1	2	6.40E-02	(2.0)	1.56E-08	(18.0)	1.46E-10	6.27E-08

SEQUENCE S1-H1
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
LPR-MOV-FT-1862A	7	5.20E-03	(3.5)	23.4	(1.5)	1.80	0.90
LPR-MOV-FT-1862B	6	5.20E-03	(3.5)	23.4	(1.5)	1.80	0.90
LPR-MOV-FT-1860A	6	3.00E-03	(7.5)	19.8	(4.5)	1.85	0.99
LPR-MOV-FT-1890B	1	3.00E-03	(7.5)	19.8	(4.5)	1.85	0.99
LPR-MCV-FT-1860B	5	3.00E-03	(7.5)	19.8	(4.5)	1.85	0.99
LPR-MOV-FT-1890A	2	3.00E-03	(7.5)	19.8	(4.5)	1.85	0.99
RMT-CCF-FA-MSCAL	1	3.00E-04	(17.0)	10.3	(7.0)	1.87	0.92
BETA-2MOV	3	8.80E-02	(1.0)	8.8	(8.0)	1.17	0.97
LPR-XHE-FO-HOTLG	1	4.00E-05	(19.0)	1.2	(9.0)	1.06	1.01
LPI-MDP-MA-S11B	3	2.00E-03	(11.5)	1.0	(10.5)	1.02	1.00
LPI-MDP-MA-S11A	3	2.00E-03	(11.5)	1.0	(10.5)	1.02	1.00
LPI-MDP-FS-S11B	3	3.00E-03	(7.5)	0.8	(12.5)	1.02	1.01
LPI-MDP-FS-S11A	3	3.00E-03	(7.5)	0.8	(12.5)	1.02	1.01
LPR-CCF-PG-SUMP	1	5.00E-05	(18.0)	0.7	(14.0)	1.09	1.01
LPI-MDP-FR-B21HR	4	6.30E-04	(15.5)	0.0	(17.0)		
RMT-XHE-FO-MANS1	2	6.40E-02	(2.0)	0.0	(17.0)		
RMT-ACT-FA-RMTSB	2	1.60E-03	(13.5)	0.0	(17.0)		
RMT-ACT-FA-RMTSA	2	1.60E-03	(13.5)	0.0	(17.0)		
LPI-MDP-FR-A21HR	4	6.30E-04	(15.5)	0.0	(17.0)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-S1	30	1.00E-03	(1.0)	32.6	(1.0)	1.98	1.01

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE S1-H1

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT S1-H1-CM WITH TOP EVENT FREQUENCY 1.55E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	3	3	4.58E-07	0.29445	BETA-2MOV	* IE-S1	* LPR-MOV-FT-1862A +
3	1	2	3.00E-07	0.48749	IE-S1	* RMT-CCF-FA-MSCAL +	
4	4	3	2.64E-07	0.65736	BETA-2MOV	* IE-S1	* LPR-MOV-FT-1890A +
5	2	3	2.64E-07	0.82723	BETA-2MOV	* IE-S1	* LPR-MOV-FT-1860A +
6	5	2	5.00E-08	0.85941	IE-S1	* LPR-CCF-PG-SUMP +	
7	6	2	4.00E-08	0.88514	IE-S1	* LPR-XHE-FO-HOTLG +	
8	7	3	2.70E-08	0.90254	IE-S1	* LPR-MOV-FT-1862A +	* LPR-MOV-FT-1862B +
9	10	3	1.56E-08	0.91258	IE-S1	* LPI-MDP-FS-S11A +	* LPR-MOV-FT-1862B +
10	9	3	1.56E-08	0.92282	IE-S1	* LPI-MDP-FS-S11B +	* LPR-MOV-FT-1862A +
11	11	3	1.56E-08	0.93266	IE-S1	* LPR-MOV-FT-1860B +	* LPR-MOV-FT-1862A +
12	8	3	1.56E-08	0.94270	IE-S1	* LPR-MOV-FT-1860A +	* LPR-MOV-FT-1862B +
13	12	3	1.04E-08	0.94939	IE-S1	* LPI-MDP-MA-S11B +	* LPR-MOV-FT-1862A +
14	13	3	1.04E-08	0.95608	IE-S1	* LPI-MDP-MA-S11A +	* LPR-MOV-FT-1862B +
15	15	3	9.00E-09	0.96187	IE-S1	* LPI-MDP-FS-S11A +	* LPR-MOV-FT-1860B +
16	14	3	9.00E-09	0.96766	IE-S1	* LPI-MDP-FS-S11B +	* LPR-MOV-FT-1860A +
17	17	3	9.00E-09	0.97345	IE-S1	* LPR-MOV-FT-1860A +	* LPR-MOV-FT-1860B +
18	16	3	9.00E-09	0.97924	IE-S1	* LPR-MOV-FT-1890A +	* LPR-MOV-FT-1890B +
19	19	3	6.00E-09	0.98310	IE-S1	* LPI-MDP-MA-S11B +	* LPR-MOV-FT-1860A +
20	18	3	6.00E-09	0.98897	IE-S1	* LPI-MDP-MA-S11A +	* LPR-MOV-FT-1860B +
21	21	3	3.28E-09	0.98907	IE-S1	* LPI-MDP-FR-B21HR +	* LPR-MOV-FT-1862A +
22	20	3	3.28E-09	0.99118	IE-S1	* LPI-MDP-FR-A21HR +	* LPR-MOV-FT-1862B +
23	22	3	2.56E-09	0.99283	IE-S1	* RMT-ACT-FA-RMTSA +	* RMT-ACT-FA-RMTSB +
24	26	3	1.89E-09	0.99404	IE-S1	* LPI-MDP-FR-B21HR +	* LPR-MOV-FT-1860A +
25	25	3	1.89E-09	0.99526	IE-S1	* LPI-MDP-FR-A21HR +	* LPI-MDP-FS-S11B +
26	24	3	1.89E-09	0.99648	IE-S1	* LPI-MDP-FR-A21HR +	* LPR-MOV-FT-1860B +
27	23	3	1.89E-09	0.99769	IE-S1	* LPI-MDP-FR-B21HR +	* LPI-MDP-FS-S11A +
28	28	3	1.26E-09	0.99850	IE-S1	* LPI-MDP-FR-A21HR +	* LPI-MDP-MA-S11B +
29	27	3	1.26E-09	0.99931	IE-S1	* LPI-MDP-FR-B21HR +	* LPI-MDP-MA-S11A +
30	30	4	5.32E-10	0.99966	IE-S1	* LPR-MOV-FT-1862A +	* RMT-ACT-FA-RMTSB +
31	29	4	5.32E-10	1.00000	IE-S1	* LPR-MOV-FT-1862B +	* RMT-ACT-FA-RMTSA +

RMT-XHE-FO-MANS1 +
 RMT-XHE-FO-MANS1

SURRY SEQUENCE T7-OD-QS

TOP EVENT T7-OD-QS CONTAINS 16 EVENTS IN 8 CUT SETS

THE FREQUENCY OF TOP EVENT T7-OD-QS IS 1.39E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T7-OD-QS

N	1000
MEAN	1.41E-06
STD DEV	4.48E-06
LOWER 5%	3.44E-08
LOWER 25%	1.45E-07
MEDIAN	3.74E-07
UPPER 25%	1.06E-06
UPPER 5%	5.06E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

5% = 3.44E-08 ***LOG SCALE*** 95% = 5.06E-06
|-----[-----*-----]-----M-----|

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SURRY SEQUENCE T7-OD-QS
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IAS-CCF-LF-INAIR	3	2.70E-05 (14.0)	4.59E-04 (1.0)	5.11E-10	1.35E-07
MSS-XHE-FO-ISAFW	1	6.80E-06 (15.0)	2.10E-04 (2.0)	4.39E-11	7.32E-09
REC-XHE-FO-DPRES	3	1.40E-02 (11.5)	3.15E-05 (3.0)	2.06E-08	4.88E-06
PORV-BLK	2	1.50E-01 (7.5)	2.48E-05 (4.0)	8.15E-09	2.14E-06
MSS-XHE-FO-BLOCK	2	6.40E-02 (9.0)	1.82E-05 (5.0)	3.63E-09	9.14E-07
SGTR-SGSRV-ODMD2	2	1.50E-01 (7.5)	1.82E-05 (6.0)	6.31E-09	2.00E-06
PORV-NOT-BLK	4	8.50E-01 (5.0)	3.30E-06 (7.0)	1.48E-08	3.09E-06
MSS-CKV-FT-SGDHR	1	2.00E-03 (13.0)	2.58E-06 (8.0)	1.24E-10	3.09E-08
RCS-XHE-FO-DPRT7	5	2.90E-02 (10.0)	1.36E-06 (9.0)		
MSS-SRV-OO-ODSRV	4	1.00E+00 (2.5)	1.15E-06 (10.0)		
SGTR-SGSRV-ODMD1	2	1.00E+00 (2.5)	6.21E-07 (11.0)		
MSS-XHE-FO-ISDHR	1	1.40E-02 (11.5)	5.30E-07 (12.0)	1.24E-10	3.09E-08
SGTR-SGADV-ODMD	2	1.00E+00 (2.5)	2.36E-07 (13.5)		
MSS-SOV-OO-ODADV	2	1.00E+00 (2.5)	2.36E-07 (13.5)		
REC-XHE-FO-GAGRV	2	3.00E-01 (6.0)	1.23E-08 (15.0)	1.79E-10	7.97E-08

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T7	8	1.00E-02 (1.0)	5.14E-04 (1.0)	3.49E-08	5.06E-06

SURRY SEQUENCE T7-OD-QS
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
RCS-XHE-FO-DPRT7	5	2.90E-02 (10.0)	4.55E-05 (1.0)		
REC-XHE-FO-DPRES	3	1.40E-02 (11.5)	3.71E-06 (2.0)	1.53E-05	2.62E-04
PORV-NOT-BLK	4	8.50E-01 (5.0)	2.42E-06 (3.0)	6.57E-10	5.52E-07
SGTR-SGSRV-ODMD2	2	1.50E-01 (7.5)	1.51E-06 (4.0)	7.58E-08	9.60E-06
PORV-BLK	2	1.50E-01 (7.5)	1.30E-06 (5.0)	9.64E-08	1.16E-05
MSS-XHE-FO-BLOCK	2	6.40E-02 (9.0)	9.09E-07 (6.0)	1.13E-07	1.09E-05
IAS-CCF-LF-INAIR	3	2.70E-05 (14.0)	6.90E-09 (7.0)	1.59E-04	4.35E-03
MSS-CKV-FT-SGDHR	1	2.00E-03 (13.0)	6.51E-09 (8.5)	1.00E-07	1.67E-05
MSS-XHE-FO-ISDHR	1	1.40E-02 (11.5)	6.51E-09 (8.5)	7.83E-08	1.62E-06
REC-XHE-FO-GAGRV	2	3.00E-01 (6.0)	2.93E-09 (10.0)	6.04E-10	2.04E-07
MSS-XHE-FO-ISAFW	1	6.80E-06 (15.0)	1.08E-10 (11.0)	7.74E-05	6.97E-04
SGTR-SGSRV-ODMD1	2	1.00E+00 (2.5)	0.00E+00 (13.5)		
SGTR-SGADV-ODMD	2	1.00E+00 (2.5)	0.00E+00 (13.5)		
MSS-SOV-OO-ODADV	2	1.00E+00 (2.5)	0.00E+00 (13.5)		
MSS-SRV-OO-ODSRV	4	1.00E+00 (2.5)	0.00E+00 (13.5)		

SURRY SEQUENCE T7-OD-QS
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
REC-XHE-FO-DPRES	3	1.40E-02 (11.5)	63.1 (1.0)	6.72	0.77
PORV-BLK	2	1.50E-01 (7.5)	5.2 (2.0)	1.25	1.07
SGTR-SGSRV-ODMD2	2	1.50E-01 (7.5)	4.4 (3.0)	1.13	0.94
IAS-CCF-LF-INAIR	3	2.70E-05 (14.0)	1.2 (4.0)	1.10	1.00
MSS-XHE-FO-BLOCK	2	6.40E-02 (9.0)	1.0 (5.0)	0.97	1.02
PORV-NOT-BLK	4	8.50E-01 (5.0)	0.9 (6.0)	1.00	0.97
MSS-XHE-FO-ISAFW	1	6.80E-06 (15.0)	0.6 (7.0)	1.02	1.00
MSS-XHE-FO-ISDHR	1	1.40E-02 (11.5)	0.4 (8.0)		
REC-XHE-FO-GAGRV	2	3.00E-01 (6.0)	0.0 (9.5)		
MSS-CKV-FT-SGDHR	1	2.00E-03 (13.0)	0.0 (9.5)		
SGTR-SGSRV-ODMD1	2	1.00E+00 (2.5)			
SGTR-SGADV-ODMD	2	1.00E+00 (2.5)			
MSS-SOV-OO-ODADV	2	1.00E+00 (2.5)			
RCS-XHE-FO-DPRT7	5	2.90E-02 (10.0)			
MSS-SRV-OO-ODSRV	4	1.00E+00 (2.5)			

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T7	8	1.00E-02 (1.0)	20.2 (1.0)	1.74	1.03

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT.

SURRY SEQUENCE T7-OD-QS

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T7-OD-QS WITH TOP EVENT FREQUENCY 1.39E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	6	6.09E-07	0.43663	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	RCS-XHE-FO-DPRT7	*
3					REC-XHE-FO-DPRES	*	SGTR-SGSRV-ODMD1	+				
4	2	6	5.18E-07	0.80777	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	RCS-XHE-FO-DPRT7	*
5					REC-XHE-FO-DPRES	*	SGTR-SGSRV-ODMD2	+				
6	3	7	2.21E-07	0.96612	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
7					RCS-XHE-FO-DPRT7	*	REC-XHE-FO-DPRES	*	SGTR-SGADV ODMD	+		
8	7	6	1.47E-08	0.97865	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*
9					PORV-NOT-BLK	*	SGTR-SGADV-ODMD	+				
10	4	6	1.22E-08	0.98536	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*
11					REC-XHE-FO-GAGRV	*	SGTR-SGSRV-ODMD1	+				
12	5	6	1.03E-08	0.99276	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*
13					REC-XHE-FO-GAGRV	*	SGTR-SGSRV-ODMD2	+				
14	6	4	8.12E-09	0.99859	IE-T7	*	MSS-CKV-FT-SGDHR	*	MSS-XHE-FO-1SDHR	*	RCS-XHE-FO-DPRT7	+
15	8	3	1.97E-09	1.00000	IE-T7	*	MSS-XHE-FO-1SAFW	*	RCS-XHE-FO-DPRT7	+		

SEQUENCE T2-L-D2

TOP EVENT T2-L-D2 CONTAINS 24 EVENTS IN 21 CUT SETS

THE FREQUENCY OF TOP EVENT T2-L-D2 IS 7.16E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T2-L-D2

N	1000
MEAN	9.82E-07
STD DEV	9.62E-08
LOWER 5%	1.44E-08
LOWER 25%	6.99E-08
MEDIAN	1.99E-07
UPPER 25%	5.95E-07
UPPER 5%	2.45E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = $PD \times EV(J)$
= $TEF - TEF(\text{EVALUATED WITH } EV(J) = 0)$

2. FOR BASE EVENTS ONLY:

RISK INCREASE = $PD - \text{RISK REDUCTION}$
= $PD \times (1 - EV(J))$
= $TEF(\text{EVALUATED WITH } EV(J) = 1) - TEF$

SEQUENCE T2-L-D2
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
AFW-XHE-FO-UNIT2	21	3.60E-02	(4.0)	7.16E-07 (1.0)	1.44E-08	2.45E-06
HPI-XHE-FO-FDBLD	14	7.10E-02	(2.0)	7.10E-07 (2.0)	1.42E-08	2.45E-06
AFW-PSF-FC-XCONN	6	1.50E-04	(18.0)	3.65E-07 (3.0)	8.74E-09	1.42E-06
AFW-CCF-LK-STMBD	3	1.00E-04	(20.5)	2.42E-07 (4.0)	1.86E-10	6.11E-07
BETA-AFW	3	5.60E-02	(3.0)	4.32E-08 (5.5)	2.72E-10	1.92E-07
AFW-MDP-FS	3	6.30E-03	(9.0)	4.32E-08 (5.5)	2.72E-10	1.92E-07
AFW-TDP-FS-FW2	3	1.10E-02	(6.0)	3.68E-08 (7.0)	1.62E-10	1.60E-07
AFW-TDP-FR-2P6HR	4	3.00E-02	(5.0)	3.01E-08 (8.0)	7.00E-11	1.09E-07
AFW-CKV-OO-CV142	1	1.00E-03	(16.0)	2.64E-08 (9.0)	9.71E-11	1.15E-07
AFW-MDP-FS-FW3B	5	6.30E-03	(9.0)	2.09E-08 (10.5)	2.68E-10	9.26E-08
AFW-MDP-FS-FW3A	5	6.30E-03	(9.0)	2.09E-08 (10.5)	2.68E-10	9.26E-08
AFW-CKV-OO-CV157	1	1.00E-03	(16.0)	1.51E-08 (12.5)	1.98E-10	5.17E-08
AFW-CKV-OO-CV172	1	1.00E-03	(16.0)	1.51E-08 (12.5)	1.98E-10	5.17E-08
AFW-TDP-MA-FW2	2	1.00E-02	(7.0)	9.43E-09 (14.0)	2.19E-11	3.03E-08
BETA-2MOV	4	8.80E-02	(1.0)	4.47E-09 (15.0)	1.88E-11	1.50E-08
AFW-TNK-VF-CST	1	1.00E-06	(23.0)	2.40E-09 (16.0)	5.44E-11	9.69E-09
HPI-MOV-FT-1867C	2	3.00E-03	(11.5)	2.23E-09 (17.5)	9.41E-12	7.51E-09
HPI-MOV-FT-1115B	2	3.00E-03	(11.5)	2.23E-09 (17.5)	9.41E-12	7.51E-09
AFW-MDP-MA-FW3B	1	2.00E-03	(13.5)	9.08E-10 (19.5)	6.82E-13	2.59E-09
AFW-MDP-MA-FW3A	1	2.00E-03	(13.5)	9.08E-10 (19.5)	6.82E-13	2.59E-09
HPI-CKV-FT-CV410	1	1.00E-04	(20.5)	5.08E-10 (22.0)	1.54E-11	1.83E-09
HPI-CKV-FT-CV25	1	1.00E-04	(20.5)	5.08E-10 (22.0)	1.54E-11	1.83E-09
HPI-CKV-FT-CV225	1	1.00E-04	(20.5)	5.08E-10 (22.0)	1.54E-11	1.83E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T2	21	9.40E-01	(1.0)	7.16E-07 (1.0)	1.44E-08	2.45E-06

SEQUENCE T2-L-D2
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
AFW-PSF-FC-XCONN	6	1.50E-04	(18.0)	2.43E-03	(1.0)	8.75E-05	9.05E-03
AFW-CCF-LK-STMBD	3	1.00E-04	(20.5)	2.42E-03	(2.0)	8.63E-05	9.03E-03
AFW-TNK-VF-CST	1	1.00E-06	(23.0)	2.40E-03	(3.0)	8.40E-05	9.02E-03
AFW-CKV-OO-CV142	1	1.00E-03	(16.0)	2.64E-05	(4.0)	1.22E-07	1.08E-04
AFW-XHE-FO-UNIT2	21	3.60E-02	(4.0)	1.92E-05	(5.0)	9.47E-07	6.25E-05
AFW-CKV-OO-CV172	1	1.00E-03	(16.0)	1.51E-05	(6.5)	3.42E-07	5.67E-05
AFW-CKV-OO-CV157	1	1.00E-03	(16.0)	1.51E-05	(6.5)	3.42E-07	5.67E-05
HPI-XHE-FO-FDBLD	14	7.10E-02	(2.0)	9.29E-06	(8.0)	4.25E-07	2.89E-05
AFW-MDP-FS	3	6.30E-03	(9.0)	6.82E-06	(9.0)	6.78E-08	2.90E-05
HPI-CKV-FT-CV410	1	1.00E-04	(20.5)	5.08E-06	(11.0)	2.64E-07	1.70E-05
HPI-CKV-FT-CV225	1	1.00E-04	(20.5)	5.08E-06	(11.0)	2.64E-07	1.70E-05
HPI-CKV-FT-CV25	1	1.00E-04	(20.5)	5.08E-06	(11.0)	2.64E-07	1.70E-05
AFW-TDP-FS-FW2	3	1.10E-02	(6.0)	3.31E-06	(13.0)	7.97E-08	1.20E-05
AFW-MDP-FS-FW3B	5	6.30E-03	(9.0)	3.30E-06	(14.5)	7.01E-08	1.24E-05
AFW-MDP-FS-FW3A	5	6.30E-03	(9.0)	3.30E-06	(14.5)	7.01E-08	1.24E-05
AFW-TDP-FR-2P6HR	4	3.00E-02	(5.0)	9.73E-07	(16.0)	1.53E-08	4.47E-06
AFW-TDP-MA-FW2	2	1.00E-02	(7.0)	9.34E-07	(17.0)	1.47E-08	4.16E-06
HPI-MOV-FT-1887C	2	3.00E-03	(11.5)	7.42E-07	(18.5)	1.60E-08	2.47E-06
HPI-MOV-FT-1115B	2	3.00E-03	(11.5)	7.42E-07	(18.5)	1.60E-08	2.47E-06
BETA-AFW	3	5.60E-02	(3.0)	7.29E-07	(20.0)	6.36E-09	2.91E-06
AFW-MDP-MA-FW3B	1	2.00E-03	(13.5)	4.53E-07	(21.5)	1.60E-09	1.68E-06
AFW-MDP-MA-FW3A	1	2.00E-03	(13.5)	4.53E-07	(21.5)	1.60E-09	1.68E-06
BETA-2MOV	4	8.80E-02	(1.0)	4.63E-08	(23.0)	2.37E-10	1.71E-07

SEQUENCE T2-L-D2
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
HPI-XHE-FO-FDBLD	14	7.10E-02	(2.0)	32.5	(1.0)
AFW-XHE-FO-UNIT2	21	3.60E-02	(4.0)	32.1	(2.0)
AFW-CCF-LK-STMBD	3	1.00E-04	(20.5)	9.8	(3.0)
AFW-PSF-FC-XCONN	6	1.50E-04	(18.0)	7.4	(4.0)
AFW-TDP-FR-2P6HR	4	3.00E-02	(5.0)	1.6	(5.0)
BETA-AFW	3	5.60E-02	(3.0)	1.2	(6.0)
AFW-TDP-FS-FW2	3	1.10E-02	(6.0)	0.9	(7.0)
AFW-MDP-FS-FW3B	5	6.30E-03	(9.0)	0.8	(9.0)
AFW-MDP-FS-FW3A	5	6.30E-03	(9.0)	0.8	(9.0)
AFW-MDP-FS	3	6.30E-03	(9.0)	0.8	(9.0)
AFW-TDP-MA-FW2	2	1.00E-02	(7.0)	0.7	(11.0)
AFW-CKV-OO-CV157	1	1.00E-03	(16.0)	0.4	(13.0)
AFW-CKV-OO-CV172	1	1.00E-03	(16.0)	0.4	(13.0)
AFW-CKV-OO-CV142	1	1.00E-03	(16.0)	0.4	(13.0)
AFW-TNK-VF-CST	1	1.00E-06	(23.0)	0.0	(19.0)
HPI-MOV-FT-1867C	2	3.00E-03	(11.5)	0.0	(19.0)
HPI-MOV-FT-1115B	2	3.00E-03	(11.5)	0.0	(19.0)
HPI-CKV-FT-CV410	1	1.00E-04	(20.5)	0.0	(19.0)
HPI-CKV-FT-CV25	1	1.00E-04	(20.5)	0.0	(19.0)
HPI-CKV-FT-CV225	1	1.00E-04	(20.5)	0.0	(19.0)
AFW-MDP-MA-FW3B	1	2.00E-03	(13.5)	0.0	(19.0)
BETA-2MOV	4	8.80E-02	(1.0)	0.0	(19.0)
AFW-MDP-MA-FW3A	1	2.00E-03	(13.5)	0.0	(19.0)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
IE-T2	21	9.40E-01	(1.0)	17.9	(1.0)

SEQUENCE T2-L-D2

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T2-L-D2 WITH TOP EVENT FREQUENCY 7.16E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	4	3.60E-07	0.50358	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*	IE-T2	+
3	2	4	2.40E-07	0.83930	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*	IE-T2	+
4	3	5	2.64E-08	0.87623	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*
5					IE-T2	+						
6	4	6	2.54E-08	0.91177	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
7					HPI-XHE-FO-FDBLD	*	IE-T2	+				
8	6	5	1.51E-08	0.93292	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*
9					IE-T2	+						
10	5	5	1.51E-08	0.95407	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*
11					IE-T2	+						
12	7	6	9.32E-09	0.96710	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
13					HPI-XHE-FO-FDBLD	*	IE-T2	+				
14	8	6	8.48E-09	0.97894	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
15					HPI-XHE-FO-FDBLD	*	IE-T2	+				
16	9	6	2.86E-09	0.98294	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*
17					HPI-XHE-FO-FDBLD	*	IE-T2	+				
18	10	4	2.40E-09	0.98629	AFW-TNK-VF-CST	*	AFW-XHE-FO-UNIT2	*	HPI-XHE-FO-FDBLD	*	IE-T2	+
19	12	5	1.34E-09	0.98817	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1867C	*
20					IE-T2	+						
21	11	5	1.34E-09	0.99004	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1115B	*
22					IE-T2	+						
23	13	6	1.05E-09	0.99151	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*
24					HPI-XHE-FO-FDBLD	*	IE-T2	+				
25	14	6	9.54E-10	0.99284	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*
26					HPI-XHE-FO-FDBLD	*	IE-T2	+				
27	15	6	9.08E-10	0.99411	AFW-MDP-FS-FW3B	*	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*
28					HPI-XHE-FO-FDBLD	*	IE-T2	+				
29	16	6	9.08E-10	0.99538	AFW-MDP-FS-FW3A	*	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*
30					HPI-XHE-FO-FDBLD	*	IE-T2	+				
31	18	5	8.93E-10	0.99662	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1867C	*
32					IE-T2	+						
33	17	5	8.93E-10	0.99787	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1115B	*
34					IE-T2	+						
35	21	4	5.08E-10	0.99858	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	HPI-CKV-FT-CV225	*	IE-T2	+
36	20	4	5.08E-10	0.99929	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	HPI-CKV-FT-CV410	*	IE-T2	+
37	19	4	5.08E-10	1.00000	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	HPI-CKV-FT-CV25	*	IE-T2	.

SEQUENCE S1-D1

TOP EVENT S1-D1-CM CONTAINS 21 EVENTS IN 14 CUT SETS

THE FREQUENCY OF TOP EVENT S1-D1-CM IS 8.17E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT S1-D1-CM

N	1000
MEAN	8.59E-07
STD DEV	2.02E-08
LOWER 5%	1.05E-07
LOWER 25%	2.37E-07
MEDIAN	4.55E-07
UPPER 25%	8.89E-07
UPPER 5%	2.38E-08

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE S1-D1
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
HPI-MOV-FT	2	3.00E-03 (7.0)	4.25E-07 (1.5)	5.90E-09	1.33E-06
BETA-2MOV	2	8.80E-02 (3.0)	4.25E-07 (1.5)	5.90E-09	1.33E-06
HPI-XHE-FO-ALT	1	6.10E-01 (1.0)	1.61E-07 (3.0)	1.41E-09	5.50E-07
HPI-CKV-FT-CV410	1	1.00E-04 (15.0)	1.00E-07 (5.0)	1.34E-08	3.03E-07
HPI-CKV-FT-CV25	1	1.00E-04 (15.0)	1.00E-07 (5.0)	1.34E-08	3.03E-07
HPI-CKV-FT-CV225	1	1.00E-04 (15.0)	1.00E-07 (5.0)	1.34E-08	3.03E-07
HPI-XVM-PG-XV24	1	4.00E-05 (19.0)	4.00E-08 (7.0)	5.43E-09	1.17E-07
CPC-STR-PG-3HR	1	9.00E-05 (17.5)	2.37E-08 (8.5)		
BETA-STR	1	2.63E-01 (2.0)	2.37E-08 (8.5)	4.15E-09	7.18E-08
HPI-MOV-FT-1115D	1	3.00E-03 (7.0)	9.00E-09 (11.5)	7.37E-12	1.08E-07
HPI-MOV-FT-1115C	1	3.00E-03 (7.0)	9.00E-09 (11.5)	7.37E-12	1.08E-07
HPI-MOV-FT-1115B	1	3.00E-03 (7.0)	9.00E-09 (11.5)	7.37E-12	1.08E-07
HPI-MOV-FT-1115E	1	3.00E-03 (7.0)	9.00E-09 (11.5)	7.37E-12	1.08E-07
CPC-MDP-FR-SWA3H	2	4.80E-04 (13.0)	4.80E-09 (14.0)	3.38E-10	1.50E-08
CPC-MDP-FS-SW10B	2	8.00E-03 (4.0)	4.56E-09 (15.0)	3.08E-10	1.50E-08
RWT-TNK-LF-RWST	1	2.70E-06 (20.0)	2.70E-09 (16.0)	6.12E-11	1.07E-08
SIS-ACT-FA-SISB	1	1.60E-03 (11.5)	2.56E-09 (17.5)	2.87E-11	2.38E-08
SIS-ACT-FA-SISA	1	1.60E-03 (11.5)	2.56E-09 (17.5)	2.87E-11	2.38E-08
CPC-MDP-MA-SW10B	1	2.00E-03 (10.0)	9.60E-10 (19.0)	1.51E-11	3.61E-09
CPC-STR-PG-2A3HR	1	9.00E-05 (17.5)	7.20E-10 (20.0)	9.84E-12	2.43E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-S1	14	1.00E-03 (1.0)	8.17E-07 (1.0)	1.05E-07	2.38E-06

SEQUENCE S1-D1
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
RWT-TNK-LF-RWST	1	2.70E-06	(20.0)	1.00E-03	(1.0)	2.66E-04	2.40E-03
HPI-XVM-PG-XV24	1	4.00E-05	(19.0)	1.00E-03	(2.0)	2.66E-04	2.40E-03
HPI-CKV-FT-CV25	1	1.00E-04	(15.0)	1.00E-03	(4.0)	2.66E-04	2.40E-03
HPI-CKV-FT-CV410	1	1.00E-04	(15.0)	1.00E-03	(4.0)	2.66E-04	2.40E-03
HPI-CKV-FT-CV225	1	1.00E-04	(15.0)	1.00E-03	(4.0)	2.66E-04	2.40E-03
CPC-STR-PG-3HR	1	9.00E-05	(17.5)	2.63E-04	(6.0)		
HPI-MOV-FT	2	3.00E-03	(7.0)	1.41E-04	(7.0)	1.84E-05	4.29E-04
CPC-MDP-FR-SWA3H	2	4.80E-04	(13.0)	1.00E-05	(8.0)	1.23E-06	3.25E-05
CPC-STR-PG-2A3HR	1	9.00E-05	(17.5)	8.00E-06	(9.0)	9.10E-07	2.73E-05
BETA-2MOV	2	8.80E-02	(3.0)	4.40E-06	(10.0)	9.44E-08	1.69E-05
HPI-MOV-FT-1115D	1	3.00E-03	(7.0)	2.99E-06	(12.5)	6.55E-08	1.10E-05
HPI-MOV-FT-1115C	1	3.00E-03	(7.0)	2.99E-06	(12.5)	6.55E-08	1.10E-05
HPI-MOV-FT-1115B	1	3.00E-03	(7.0)	2.99E-06	(12.5)	6.55E-08	1.10E-05
HPI-MOV-FT-1115E	1	3.00E-03	(7.0)	2.99E-06	(12.5)	6.55E-08	1.10E-05
SIS-ACT-FA-SISB	1	1.60E-03	(11.5)	1.60E-06	(15.5)	1.16E-07	5.25E-06
SIS-ACT-FA-SISA	1	1.60E-03	(11.5)	1.60E-06	(15.5)	1.16E-07	5.25E-06
CPC-MDP-FS-SW10B	2	8.00E-03	(4.0)	5.65E-07	(17.0)	8.64E-08	1.64E-06
CPC-MDP-MA-SW10B	1	2.00E-03	(10.0)	4.79E-07	(18.0)	6.83E-08	1.43E-06
HPI-XHE-FO-ALT	1	6.10E-01	(1.0)	1.03E-07	(19.0)	5.00E-10	3.72E-07
BETA-STR	1	2.63E-01	(2.0)	6.63E-08	(20.0)	1.51E-08	1.59E-07

SEQUENCE S1-D1
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
HPI-MOV-FT-1115C	1	3.00E-03	(15.0)	30.0	(3.5)	1.85	0.80
HPI-MOV-FT-1115D	1	3.00E-03	(15.0)	30.0	(3.5)	1.85	0.80
HPI-MOV-FT-1867D	3	3.00E-03	(15.0)	30.0	(3.5)	1.85	0.80
HPI-MOV-FT-1115B	1	3.00E-03	(15.0)	30.0	(3.5)	1.85	0.80
HPI-MOV-FT	2	3.00E-03	(15.0)	30.0	(3.5)	1.85	0.80
HPI-MOV-FT-1115E	1	3.00E-03	(15.0)	30.0	(3.5)	1.85	0.80
HPI-XHE-FO-UN2S3	13	4.40E-02	(8.0)	19.3	(7.0)	1.52	0.80
BETA-2MOV	2	8.80E-02	(3.0)	4.5	(8.0)	1.05	0.96
HPI-CKV-FT-CV25	1	1.00E-04	(26.0)	3.9	(10.0)	1.18	0.92
HPI-CKV-FT-CV410	1	1.00E-04	(26.0)	3.9	(10.0)	1.18	0.92
HPI-CKV-FT-CV225	1	1.00E-04	(26.0)	3.9	(10.0)	1.18	0.92
HPI-XHE-FO-ALTS3	1	5.50E-02	(5.0)	3.2	(12.0)	1.06	1.00
RWT-TNK-LF-RWST	1	2.70E-06	(32.0)	2.4	(13.0)	1.16	1.02
HPI-MDP-FS	1	4.00E-03	(9.0)	0.9	(14.0)	1.00	1.00
CPC-CKV-OO-CV113	1	1.00E-03	(21.5)	0.6	(15.5)	1.07	1.00
HPI-CKV-OO-CV258	1	1.00E-03	(21.5)	0.6	(15.5)	1.07	1.00
HPI-XHE-FO-ALTN	1	5.70E-03	(8.0)	0.5	(17.0)		
CPC-XHE-FO-REALN	3	7.00E-02	(4.0)	0.5	(18.0)		
CPC-MDP-FS-CC2B	1	3.00E-03	(15.0)	0.5	(19.0)		
CPC-MDP-MA-CC2B	1	2.00E-03	(19.0)	0.4	(20.0)		
ACP-TFM-NO-1H1	1	4.00E-05	(30.5)	0.4	(21.0)		
HPI-MDP-FR-1A24H	2	1.60E-03	(20.0)	0.1	(22.0)		
HPI-XVM-PG-XV24	1	4.00E-05	(30.5)	0.0	(27.0)		
CPC-MDP-FS-SW10B	1	8.00E-03	(7.0)	0.0	(27.0)		
BETA-STR	1	2.63E-01	(1.0)	0.0	(27.0)		
ACP-BAC-ST-1H1	1	9.00E-05	(28.5)	0.0	(27.0)		
CPC-MDP-FR-SWB24	1	3.80E-03	(10.5)	0.0	(27.0)		
BETA-HP1	1	2.10E-01	(2.0)	0.0	(27.0)		
CPC-MDP-FR-SWA24	3	3.80E-03	(10.5)	0.0	(27.0)		
CPC-MDP-FR-CCA24	2	7.20E-04	(23.5)	0.0	(27.0)		
ACP-BAC-ST-4KV1H	1	9.00E-05	(28.5)	0.0	(27.0)		
CPC-STR-PG-24H	1	7.20E-04	(23.5)	0.0	(27.0)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-S3	20	1.30E-02	(1.0)	32.3	(1.0)	1.94	0.89

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE S1-D1

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT S1-D1-CM WITH TOP EVENT FREQUENCY 8.17E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	3	2.64E-07	0.32294	BETA-2MOV	*	HPI-MOV-FT	*	IE-S1	+
3	2	4	1.61E-07	0.51993	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALT	* IE-S1
4	3	2	1.00E-07	0.64226	HPI-CKV-FT-CV25	*	IE-S1	+		
5	5	2	1.00E-07	0.76458	HPI-CKV-FT-CV410	*	IE-S1	+		
6	4	2	1.00E-07	0.88691	HPI-CKV-FT-CV225	*	IE-S1	+		
7	6	2	4.00E-08	0.93584	HPI-XVM-PG-XV24	*	IE-S1	+		
8	7	3	2.37E-08	0.86479	BETA-STR	*	CPC-STR-PG-3HR	*	IE-S1	+
9	9	3	9.00E-09	0.97580	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	IE-S1	+
10	8	3	9.00E-09	0.98681	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	IE-S1	+
11	10	3	3.84E-09	0.99151	CPC-MDP-FR-SWA3H	*	CPC-MDP-FS-SW10B	*	IE-S1	+
12	11	2	2.70E-09	0.99481	IE-S1	*	RWT-TNK-LF-RWST	+		
13	12	3	2.56E-09	0.99795	IE-S1	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+
14	13	3	9.60E-10	0.99912	CPC-MDP-FR-SWA3H	*	CPC-MDP-MA-SW10B	*	IE-S1	+
15	14	3	7.20E-10	1.00000	CPC-MDP-FS-SW10B	*	CPC-STR-PG-2A3HR	*	IE-S1	+

SEQUENCE T-K-R-Z

TOP EVENT T-K-R-Z CONTAINS 4 EVENTS IN 1 CUT SETS

THE FREQUENCY OF TOP EVENT T-K-R-Z IS 8.43E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T-K-R-Z

N	1000
MEAN	8.23E-07
STD DEV	3.39E-08
LOWER 5%	6.29E-09
LOWER 25%	3.79E-08
MEDIAN	1.52E-07
UPPER 25%	5.00E-07
UPPER 5%	3.16E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE T-K-R-Z

RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK		
				REDUCTION (RANK)	LOWER 5%	UPPER 5%
K	1	6.00E-05	(3.0)	8.43E-07 (2.0)	6.29E-09	3.16E-06
Z	1	1.40E-02	(2.0)	8.43E-07 (2.0)	6.29E-09	3.16E-06
R	1	1.70E-01	(1.0)	8.43E-07 (2.0)	6.29E-09	3.16E-06

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ	(RANK)	RISK		
				REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-TN	1	5.90E+00	(1.0)	8.43E-07 (1.0)	6.29E-09	3.16E-06

SEQUENCE T-K-R-Z

RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
K	1	6.00E-05 (3.0)	1.40E-02 (1.0)	2.56E-04	5.21E-02
Z	1	1.40E-02 (2.0)	5.93E-05 (2.0)	1.60E-06	2.16E-04
R	1	1.70E-01 (1.0)	4.11E-06 (3.0)	6.48E-08	1.94E-05

SEQUENCE T-K-R-Z
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
Z	1	1.40E-02 (2.0)	39.5	(1.0)
K	1	6.00E-05 (3.0)	26.8	(2.0)
R	1	1.70E-01 (1.0)	22.5	(3.0)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
IE-TN	1	5.90E+00 (1.0)	13.3	(1.0)

SEQUENCE T-K-R-Z

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
FOR TOP EVENT T-K-R-Z WITH TOP EVENT FREQUENCY 8.43E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	4	8.43E-07	1.00000	IE-TN	* K	* R	* Z
---	---	---	----------	---------	-------	-----	-----	-----

SEQUENCE A-H1

TOP EVENT A-H1-CM CONTAINS 19 EVENTS IN 28 CUT SETS

THE FREQUENCY OF TOP EVENT A-H1-CM IS 7.78E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT A-H1-CM

N	1000
MEAN	8.18E-07
STD DEV	1.70E-08
LOWER 5%	6.34E-08
LOWER 25%	1.68E-07
MEDIAN	3.75E-07
UPPER 25%	8.48E-07
UPPER 5%	2.97E-08

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE A-H1
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
BETA-2MOV	3	8.80E-02 (1.0)	4.93E-07 (1.0)	1.56E-08	1.93E-06
LPR-MOV-FT-1862A	6	5.20E-03 (2.5)	2.65E-07 (2.0)	4.69E-09	1.23E-06
LPR-MOV-FT-1860A	6	3.00E-03 (6.5)	1.53E-07 (3.0)	2.29E-09	6.24E-07
RMT-CCF-FA-MSCAL	1	3.00E-04 (18.0)	1.50E-07 (4.0)	3.25E-09	5.76E-07
LPR-MOV-FT-1890A	2	3.00E-03 (6.5)	1.37E-07 (5.0)	1.84E-09	5.65E-07
LPR-MOV-FT-1862B	5	5.20E-03 (2.5)	3.62E-08 (6.0)	2.81E-10	2.79E-07
LPR-CCF-PG-SUMP	1	5.00E-05 (17.0)	2.50E-08 (7.0)	5.31E-10	8.88E-08
LPR-MOV-FT-1860B	5	3.00E-03 (6.5)	2.09E-08 (8.0)	2.20E-10	1.44E-07
LPR-XHE-FO-HOTLG	1	4.00E-05 (18.0)	2.00E-08 (9.0)	4.72E-10	7.72E-08
LPI-MDP-FS-S11B	3	3.00E-03 (6.5)	1.34E-08 (10.5)	1.20E-10	5.22E-08
LPI-MDP-FS-S11A	3	3.00E-03 (6.5)	1.34E-08 (10.5)	1.20E-10	5.22E-08
LPI-MDP-MA-S11B	3	2.00E-03 (10.5)	8.92E-09 (12.5)	7.22E-11	3.07E-08
LPI-MDP-MA-S11A	3	2.00E-03 (10.5)	8.92E-09 (12.5)	7.22E-11	3.07E-08
LPI-MDP-FR-B24HR	4	7.20E-04 (14.5)	4.75E-09 (14.5)	5.27E-11	1.99E-08
LPI-MDP-FR-A24HR	4	7.20E-04 (14.5)	4.75E-09 (14.5)	5.27E-11	1.99E-08
LPR-MOV-FT-1890B	1	3.00E-03 (6.5)	4.50E-09 (16.0)	4.55E-12	5.85E-08
RMT-ACT-FA-RMTSB	1	1.60E-03 (12.5)	1.28E-09 (17.5)	1.27E-11	1.04E-08
RMT-ACT-FA-RMTSA	1	1.60E-03 (12.5)	1.28E-09 (17.5)	1.27E-11	1.04E-08

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-A	28	5.00E-04 (1.0)	7.78E-07 (1.0)	6.34E-08	2.97E-06

SEQUENCE A-H1
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
LPR-XHE-FO-HOTLG	1	4.00E-05	(18.0)	5.00E-04	(1.5)	1.33E-04	1.20E-03
LPR-CCF-PG-SUMP	1	5.00E-05	(17.0)	5.00E-04	(1.5)	1.33E-04	1.20E-03
RMT-CCF-FA-MSCAL	1	3.00E-04	(16.0)	5.00E-04	(3.0)	1.33E-04	1.20E-03
LPR-MOV-FT-1860A	6	3.00E-03	(6.5)	5.08E-05	(4.0)	7.86E-06	1.51E-04
LPR-MOV-FT-1862A	6	5.20E-03	(2.5)	5.07E-05	(5.0)	7.84E-06	1.50E-04
LPR-MOV-FT-1890A	2	3.00E-03	(6.5)	4.54E-05	(6.0)	6.13E-06	1.34E-04
LPR-MOV-FT-1860B	5	3.00E-03	(6.5)	6.94E-06	(7.0)	7.15E-07	2.19E-05
LPR-MOV-FT-1862B	5	5.20E-03	(2.5)	6.92E-06	(8.0)	7.16E-07	2.19E-05
LPI-MDP-FR-B24HR	4	7.20E-04	(14.5)	6.60E-06	(9.5)	6.52E-07	2.15E-05
LPI-MDP-FR-A24HR	4	7.20E-04	(14.5)	6.60E-06	(9.5)	6.52E-07	2.15E-05
BETA-2MOV	3	8.80E-02	(1.0)	5.11E-06	(11.0)	3.18E-07	1.83E-05
LPI-MDP-MA-SI1B	3	2.00E-03	(10.5)	4.45E-06	(12.5)	3.18E-07	1.55E-05
LPI-MDP-MA-SI1A	3	2.00E-03	(10.5)	4.45E-06	(12.5)	3.18E-07	1.55E-05
LPI-MDP-FS-SI1B	3	3.00E-03	(6.5)	4.45E-06	(14.5)	3.18E-07	1.54E-05
LPI-MDP-FS-SI1A	3	3.00E-03	(6.5)	4.45E-06	(14.5)	3.18E-07	1.54E-05
LPR-MOV-FT-1890B	1	3.00E-03	(6.5)	1.50E-06	(16.0)	3.30E-08	5.83E-06
RMT-ACT-FA-RMTSB	1	1.60E-03	(12.5)	7.99E-07	(17.5)	5.38E-08	2.79E-06
RMT-ACT-FA-RMTSA	1	1.60E-03	(12.5)	7.99E-07	(17.5)	5.38E-08	2.79E-06

SEQUENCE A-H1
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
LPR-MOV-FT-1862B	5	5.20E-03 (2.5)	22.9 (1.5)	1.54	0.87
LPR-MOV-FT-1862A	6	5.20E-03 (2.5)	22.9 (1.5)	1.54	0.87
LPR-MOV-FT-1860A	6	3.00E-03 (6.5)	20.8 (4.5)	1.62	0.84
LPR-MOV-FT-1860B	5	3.00E-03 (6.5)	20.8 (4.5)	1.62	0.84
LPR-MOV-FT-1890A	2	3.00E-03 (6.5)	20.8 (4.5)	1.62	0.84
LPR-MOV-FT-1890B	1	3.00E-03 (6.5)	20.8 (4.5)	1.62	0.84
RMT-CCF-FA-MSCAL	1	3.00E-04 (16.0)	9.5 (7.0)	1.52	0.98
BETA-2MOV	3	8.80E-02 (1.0)	9.1 (8.0)	1.07	0.90
LPR-XHE-FO-HOTLG	1	4.00E-05 (18.0)	1.4 (9.0)	1.04	0.99
LPI-MDP-FS-S11B	3	3.00E-03 (6.5)	1.2 (10.5)	1.01	1.00
LPI-MDP-FS-S11A	3	3.00E-03 (6.5)	1.2 (10.5)	1.01	1.00
LPR-CCF-PG-SUMP	1	5.00E-05 (17.0)	0.8 (12.0)	1.03	1.00
LPI-MDP-MA-S11B	3	2.00E-03 (10.5)	0.4 (13.5)		
LPI-MDP-MA-S11A	3	2.00E-03 (10.5)	0.4 (13.5)		
LPI-MDP-FR-B24HR	4	7.20E-04 (14.5)	0.2 (15.5)		
LPI-MDP-FR-A24HR	4	7.20E-04 (14.5)	0.2 (15.5)		
RMT-ACT-FA-RMTSB	1	1.60E-03 (12.5)	0.1 (17.5)		
RMT-ACT-FA-RMTSA	1	1.60E-03 (12.5)	0.1 (17.5)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-A	28	5.00E-04 (1.0)	30.4 (1.0)	1.71	0.95

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE A-H1

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT A-H1-CM WITH TOP EVENT FREQUENCY 7.78E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	3	3	2.29E-07	0.29420	BETA-2MOV	*	IE-A	*	LPR-MOV-FT-1862A	+
3	1	2	1.50E-07	0.48707	IE-A	*	RMT-CCF-FA-MSCAL	+		
4	4	3	1.32E-07	0.65681	BETA-2MOV	*	IE-A	*	LPR-MOV-FT-1890A	+
5	2	3	1.32E-07	0.82654	BETA-2MOV	*	IE-A	*	LPR-MOV-FT-1860A	+
6	5	2	2.50E-08	0.85868	IE-A	*	LPR-CCF-PG-SUMP	+		
7	6	2	2.00E-08	0.88440	IE-A	*	LPR-XHE-FO-HOTLG	+		
8	7	3	1.35E-08	0.90178	IE-A	*	LPR-MOV-FT-1862A	*	LPR-MOV-FT-1862B	+
9	10	3	7.80E-09	0.91181	IE-A	*	LPI-MDP-FS-S11A	*	LPR-MOV-FT-1862B	+
10	9	3	7.80E-09	0.92184	IE-A	*	LPI-MDP-FS-S11B	*	LPR-MOV-FT-1862A	+
11	11	3	7.80E-09	0.93187	IE-A	*	LPR-MOV-FT-1860B	*	LPR-MOV-FT-1862A	+
12	8	3	7.80E-09	0.94190	IE-A	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1862B	+
13	12	3	5.20E-09	0.94859	IE-A	*	LPI-MDP-MA-S11B	*	LPR-MOV-FT-1862A	+
14	13	3	5.20E-09	0.95527	IE-A	*	LPI-MDP-MA-S11A	*	LPR-MOV-FT-1862B	+
15	15	3	4.50E-09	0.96106	IE-A	*	LPI-MDP-FS-S11A	*	LPR-MOV-FT-1860B	+
16	14	3	4.50E-09	0.96685	IE-A	*	LPI-MDP-FS-S11B	*	LPR-MOV-FT-1860A	+
17	17	3	4.50E-09	0.97263	IE-A	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1860B	+
18	16	3	4.50E-09	0.97842	IE-A	*	LPR-MOV-FT-1890A	*	LPR-MOV-FT-1890B	+
19	19	3	3.00E-09	0.98228	IE-A	*	LPI-MDP-MA-S11B	*	LPR-MOV-FT-1860A	+
20	18	3	3.00E-09	0.98613	IE-A	*	LPI-MDP-MA-S11A	*	LPR-MOV-FT-1860B	+
21	21	3	1.87E-09	0.98854	IE-A	*	LPI-MDP-FR-B24HR	*	LPR-MOV-FT-1862A	+
22	20	3	1.87E-09	0.99095	IE-A	*	LPI-MDP-FR-A24HR	*	LPR-MOV-FT-1862B	+
23	22	3	1.28E-09	0.99259	IE-A	*	RMT-ACT-FA-RMTSA	*	RMT-ACT-FA-RMTSB	+
24	26	3	1.08E-09	0.99398	IE-A	*	LPI-MDP-FR-B24HR	*	LPR-MOV-FT-1860A	+
25	25	3	1.08E-09	0.99537	IE-A	*	LPI-MDP-FR-A24HR	*	LPI-MDP-FS-S11B	+
26	24	3	1.08E-09	0.99676	IE-A	*	LPI-MDP-FR-A24HR	*	LPR-MOV-FT-1860B	+
27	23	3	1.08E-09	0.99815	IE-A	*	LPI-MDP-FR-B24HR	*	LPI-MDP-FS-S11A	+
28	28	3	7.20E-10	0.99907	IE-A	*	LPI-MDP-FR-A24HR	*	LPI-MDP-MA-S11B	+
29	27	3	7.20E-10	1.00000	IE-A	*	LPI-MDP-FR-B24HR	*	LPI-MDP-MA-S11A	+

SEQUENCE T2-L-P

TOP EVENT T2-L-P CONTAINS 29 EVENTS IN 44 CUT SETS

THE FREQUENCY OF TOP EVENT T2-L-P IS 7.69E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T2-L-P

N	1000
MEAN	7.36E-07
STD DEV	1.72E-08
LOWER 5%	2.27E-08
LOWER 25%	9.78E-08
MEDIAN	2.61E-07
UPPER 25%	6.66E-07
UPPER 5%	2.62E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE T2-L-P
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
AFW-XHE-FO-UNIT2	44	3.60E-02	(10.0)	7.69E-07 (1.0)	2.27E-08	2.62E-06
PPS-XHE-FO-PORVS	4	4.40E-02	(6.0)	4.52E-07 (2.0)	8.80E-09	1.66E-06
AFW-PSF-FC-XCONN	7	1.50E-04	(23.0)	3.66E-07 (3.0)	1.21E-08	1.28E-06
AFW-CCF-LK-STMBD	7	1.00E-04	(24.0)	2.44E-07 (4.0)	2.66E-10	6.33E-07
PPS-MOV-FC-1536	15	3.00E-01	(1.5)	1.46E-07 (5.5)	2.72E-09	5.13E-07
PPS-MOV-FC-1535	15	3.00E-01	(1.5)	1.46E-07 (5.5)	2.72E-09	5.13E-07
PPS-MOV-FT-1536	11	4.00E-02	(8.0)	1.34E-07 (7.5)	2.50E-09	4.71E-07
PPS-MOV-FT-1535	11	4.00E-02	(8.0)	1.34E-07 (7.5)	2.50E-09	4.71E-07
AFW-TDP-FR-2P24H	19	1.20E-01	(3.0)	1.17E-07 (9.0)	1.44E-09	4.83E-07
AFW-MDP-FS	11	6.30E-03	(14.0)	1.09E-07 (10.5)	1.08E-09	4.40E-07
BETA-AFW	11	5.60E-02	(5.0)	1.09E-07 (10.5)	1.08E-09	4.40E-07
AFW-TDP-FS-FW2	5	1.10E-02	(11.0)	2.85E-08 (12.0)	1.31E-10	1.39E-07
AFW-CKV-OO-CV142	3	1.00E-03	(20.0)	2.53E-08 (13.0)	1.20E-10	1.19E-07
PPS-MOV-FT	6	4.00E-02	(8.0)	2.09E-08 (14.5)	2.72E-10	6.93E-08
BETA-2MOV	6	8.80E-02	(4.0)	2.09E-08 (14.5)	2.72E-10	6.93E-08
AFW-MDP-FS-FW3B	8	6.30E-03	(14.0)	1.32E-08 (16.5)	1.87E-10	5.70E-08
AFW-MDP-FS-FW3A	8	6.30E-03	(14.0)	1.32E-08 (16.5)	1.87E-10	5.70E-08
PPS-SOV-FT-1455C	3	1.00E-03	(20.0)	9.89E-09 (18.5)	2.54E-10	3.36E-08
PPS-SOV-FT-1456	3	1.00E-03	(20.0)	9.89E-09 (18.5)	2.54E-10	3.36E-08
AFW-CKV-OO-CV172	2	1.00E-03	(20.0)	5.12E-09 (20.5)	7.77E-11	1.85E-08
AFW-CKV-OO-CV157	2	1.00E-03	(20.0)	5.12E-09 (20.5)	7.77E-11	1.85E-08
DCP-BDC-ST-BUS1B	2	9.00E-05	(26.5)	3.03E-09 (22.5)	2.57E-11	1.11E-08
DCP-BDC-ST-BUS1A	2	9.00E-05	(26.5)	3.03E-09 (22.5)	2.57E-11	1.11E-08
AFW-TDP-MA-FW2	2	1.00E-02	(12.0)	2.87E-09 (24.0)	5.72E-12	9.04E-09
AFW-MDP-MA-FW3B	3	2.00E-03	(16.5)	1.96E-09 (25.5)	5.19E-12	6.83E-09
AFW-MDP-MA-FW3A	3	2.00E-03	(16.5)	1.96E-09 (25.5)	5.19E-12	6.83E-09
ACP-BAC-ST-4KV1J	1	9.00E-05	(26.5)	6.91E-10 (27.5)	4.25E-12	3.00E-09
ACP-BAC-ST-4KV1H	1	9.00E-05	(26.5)	6.91E-10 (27.5)	4.25E-12	3.00E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T2	44	9.40E-01	(1.0)	7.69E-07 (1.0)	2.27E-08	2.62E-06

SEQUENCE T2-L-P
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
AFW-CCF-LK-STMBD	7	1.00E-04 (24.0)	2.44E-03 (1.0)	1.29E-04	8.90E-03
AFW-PSF-FC-XCONN	7	1.50E-04 (23.0)	2.44E-03 (2.0)	1.29E-04	8.90E-03
DCP-BDC-ST-BUS1A	2	9.00E-05 (26.5)	3.37E-05 (3.5)	7.77E-07	1.36E-04
DCP-BDC-ST-BUS1B	2	9.00E-05 (26.5)	3.37E-05 (3.5)	7.77E-07	1.36E-04
AFW-CKV-OO-CV142	3	1.00E-03 (20.0)	2.53E-05 (5.0)	1.70E-07	1.02E-04
AFW-XHE-FO-UNIT2	44	3.60E-02 (10.0)	2.06E-05 (6.0)	1.64E-06	6.58E-05
AFW-MDP-FS	11	6.30E-03 (14.0)	1.72E-05 (7.0)	2.52E-07	6.78E-05
PPS-SOV-FT-1455C	3	1.00E-03 (20.0)	9.88E-06 (8.5)	4.21E-07	3.22E-05
PPS-SOV-FT-1456	3	1.00E-03 (20.0)	9.88E-06 (8.5)	4.21E-07	3.22E-05
PPS-XHE-FO-PORVS	4	4.40E-02 (6.0)	9.81E-06 (10.0)	4.28E-07	3.19E-05
ACP-BAC-ST-4KV1H	1	9.00E-05 (26.5)	7.67E-06 (11.5)	1.22E-07	3.09E-05
ACP-BAC-ST-4KV1J	1	9.00E-05 (26.5)	7.67E-06 (11.5)	1.22E-07	3.09E-05
AFW-CKV-OO-CV172	2	1.00E-03 (20.0)	5.11E-06 (13.5)	1.07E-07	1.94E-05
AFW-CKV-OO-CV157	2	1.00E-03 (20.0)	5.11E-06 (13.5)	1.07E-07	1.94E-05
PPS-MOV-FT-1536	11	4.00E-02 (8.0)	3.23E-06 (15.5)	1.03E-07	1.14E-05
PPS-MOV-FT-1535	11	4.00E-02 (8.0)	3.23E-06 (15.5)	1.03E-07	1.14E-05
AFW-TDP-FS-FW2	5	1.10E-02 (11.0)	2.56E-06 (17.0)	8.64E-08	1.04E-05
AFW-MDP-FS-FW3B	8	6.30E-03 (14.0)	2.08E-06 (18.5)	5.72E-08	7.43E-06
AFW-MDP-FS-FW3A	8	6.30E-03 (14.0)	2.08E-06 (18.5)	5.72E-08	7.43E-06
BETA-AFW	11	5.60E-02 (5.0)	1.84E-06 (20.0)	2.99E-08	7.81E-06
AFW-MDP-MA-FW3B	3	2.00E-03 (16.5)	9.78E-07 (21.5)	1.67E-08	3.75E-06
AFW-MDP-MA-FW3A	3	2.00E-03 (16.5)	9.78E-07 (21.5)	1.67E-08	3.75E-06
AFW-TDP-FR-2P24H	19	1.20E-01 (3.0)	8.59E-07 (23.0)	1.88E-08	3.64E-06
PPS-MOV-FT	6	4.00E-02 (8.0)	5.01E-07 (24.0)	1.04E-08	1.80E-06
PPS-MOV-FC-1536	15	3.00E-01 (1.5)	3.40E-07 (25.5)	8.65E-09	1.31E-06
PPS-MOV-FC-1535	15	3.00E-01 (1.5)	3.40E-07 (25.5)	8.65E-09	1.31E-06
AFW-TDP-MA-FW2	2	1.00E-02 (12.0)	2.84E-07 (27.0)	4.01E-09	1.12E-06
BETA-2MOV	6	8.80E-02 (4.0)	2.17E-07 (28.0)	3.72E-09	7.55E-07

SEQUENCE T2-L-P
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
AFW-XHE-FO-UNIT2	44	3.60E-02	(10.0)	38.0	(1.0)	2.63	0.96
PPS-XHE-FO-PORVS	4	4.40E-02	(6.0)	11.9	(2.0)	1.40	0.92
AFW-CCF-LK-STMBD	7	1.00E-04	(24.0)	8.0	(3.0)	1.50	1.07
AFW-PSF-FC-XCONN	7	1.50E-04	(23.0)	7.9	(4.0)	1.21	1.01
PPS-MOV-FT-1535	11	4.00E-02	(8.0)	3.6	(6.0)	1.05	1.04
PPS-MOV-FT-1536	11	4.00E-02	(8.0)	3.6	(6.0)	1.05	1.04
PPS-MOV-FT	6	4.00E-02	(8.0)	3.6	(6.0)	1.05	1.04
PPS-MOV-FC-1535	15	3.00E-01	(1.5)	3.3	(8.5)	1.11	0.96
PPS-MOV-FC-1536	15	3.00E-01	(1.5)	3.3	(8.5)	1.11	0.96
AFW-TDP-FR-2P24H	19	1.20E-01	(3.0)	2.4	(10.0)	1.09	1.01
AFW-TDP-FS-FW2	5	1.10E-02	(11.0)	2.3	(11.0)	1.08	1.00
BETA-AFW	11	5.60E-02	(5.0)	2.2	(12.0)	1.02	1.00
AFW-TDP-MA-FW2	2	1.00E-02	(12.0)	0.9	(13.0)	0.99	1.00
AFW-MDP-FS	11	6.30E-03	(14.0)	0.9	(15.0)	1.02	1.06
AFW-MDP-FS-FW3B	8	6.30E-03	(14.0)	0.9	(15.0)	1.02	1.06
AFW-MDP-FS-FW3A	8	6.30E-03	(14.0)	0.9	(15.0)	1.02	1.06
AFW-MDP-MA-FW3B	3	2.00E-03	(16.5)	0.6	(17.5)	1.00	1.00
AFW-MDP-MA-FW3A	3	2.00E-03	(16.5)	0.6	(17.5)	1.00	1.00
BETA-2MOV	6	8.80E-02	(4.0)	0.5	(19.0)		
PPS-SOV-FT-1456	3	1.00E-03	(20.0)	0.4	(20.5)		
PPS-SOV-FT-1455C	3	1.00E-03	(20.0)	0.4	(20.5)		
DCP-BDC-ST-BUS1B	2	9.00E-05	(26.5)	0.4	(23.5)		
ACP-BAC-ST-4KV1H	1	9.00E-05	(26.5)	0.4	(23.5)		
DCP-BDC-ST-BUS1A	2	9.00E-05	(26.5)	0.4	(23.5)		
ACP-BAC-ST-4KV1J	1	9.00E-05	(26.5)	0.4	(23.5)		
AFW-CKV-OO-CV172	2	1.00E-03	(20.0)	0.0	(27.0)		
AFW-CKV-OO-CV157	2	1.00E-03	(20.0)	0.0	(27.0)		
AFW-CKV-OO-CV142	3	1.00E-03	(20.0)	0.0	(27.0)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T2	44	9.40E-01	(1.0)	22.3	(1.0)	1.71	1.08

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE T2-L-P

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T2-L-P WITH TOP EVENT FREQUENCY 7.69E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	4	2.23E-07	0.29054	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-XHE-FO-PORVS +
3	2	4	1.49E-07	0.48424	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-XHE-FO-PORVS +
4	3	6	6.30E-08	0.56624	AFW-MDP-FS *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	BETA-AFW *
5					IE-T2 *	PPS-XHE-FO-PORVS +		
6	4	5	6.09E-08	0.64548	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-MOV-FC-1535 *
7					PPS-MOV-FT-1535 +			
8	5	5	6.09E-08	0.72472	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-MOV-FC-1536 *
9					PPS-MOV-FT-1536 +			
10	6	5	4.06E-08	0.77754	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-MOV-FC-1536 *
11					PPS-MOV-FT-1536 +			
12	7	5	4.06E-08	0.83037	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-MOV-FC-1535 *
13					PPS-MOV-FT-1535 +			
14	9	7	1.72E-08	0.85273	AFW-MDP-FS *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	BETA-AFW *
15					IE-T2 *	PPS-MOV-FC-1535 *	PPS-MOV-FT-1535 +	
16	8	7	1.72E-08	0.87510	AFW-MDP-FS *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	BETA-AFW *
17					IE-T2 *	PPS-MOV-FC-1536 *	PPS-MOV-FT-1536 +	
18	10	5	1.64E-08	0.89640	AFW-CKV-OO-CV142 *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T2 *
19					PPS-XHE-FO-PORVS +			
20	12	6	5.36E-09	0.90338	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	BETA-2MOV *	IE-T2 *
21					PPS-MOV-FC-1535 *	PPS-MOV-FT +		
22	11	6	5.36E-09	0.91035	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	BETA-2MOV *	IE-T2 *
23					PPS-MOV-FC-1536 *	PPS-MOV-FT +		
24	14	4	5.06E-09	0.91695	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-SOV-FT-1455C +
25	13	4	5.08E-09	0.92356	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-SOV-FT-1456 +
26	15	6	4.47E-09	0.92937	AFW-CKV-OO-CV142 *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T2 *
27					PPS-MOV-FC-1536 *	PPS-MOV-FT-1536 +		
28	16	6	4.47E-09	0.93518	AFW-CKV-OO-CV142 *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T2 *
29					PPS-MOV-FC-1535 *	PPS-MOV-FT-1535 +		
30	18	6	3.57E-09	0.93983	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	BETA-2MOV *	IE-T2 *
31					PPS-MOV-FC-1535 *	PPS-MOV-FT +		
32	17	6	3.57E-09	0.94448	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	BETA-2MOV *	IE-T2 *
33					PPS-MOV-FC-1536 *	PPS-MOV-FT +		
34	20	4	3.38E-09	0.94888	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-SOV-FT-1456 +
35	19	4	3.38E-09	0.95328	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2 *	PPS-SOV-FT-1455C +
36	24	6	2.58E-09	0.95661	AFW-CKV-OO-CV172 *	AFW-MDP-FS-FW3B *	AFW-XHE-FO-UNIT2 *	IE-T2 *
37					PPS-MOV-FC-1535 *	PPS-MOV-FT-1535 +		
38	23	6	2.58E-09	0.95994	AFW-CKV-OO-CV157 *	AFW-MDP-FS-FW3A *	AFW-XHE-FO-UNIT2 *	IE-T2 *
39					PPS-MOV-FC-1536 *	PPS-MOV-FT-1536 +		
40	22	6	2.58E-09	0.96326	AFW-CKV-OO-CV157 *	AFW-MDP-FS-FW3A *	AFW-XHE-FO-UNIT2 *	IE-T2 *
41					PPS-MOV-FC-1535 *	PPS-MOV-FT-1535 +		
42	21	6	2.58E-09	0.96659	AFW-CKV-OO-CV172 *	AFW-MDP-FS-FW3B *	AFW-XHE-FO-UNIT2 *	IE-T2 *
43					PPS-MOV-FC-1536 *	PPS-MOV-FT-1536 +		
44	26	5	2.30E-09	0.96959	AFW-MDP-FS-FW3B *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	DCP-BDC-ST-BUS1A *
45					IE-T2 +			
46	25	5	2.30E-09	0.97258	AFW-MDP-FS-FW3A *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	DCP-BDC-ST-BUS1B *

47					IE-T2	+								
48	28	7	1.93E-09	0.97510	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
49					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+				
50	27	7	1.93E-09	0.97762	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
51					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+				
52	30	7	1.58E-09	0.97967	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*		
53					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+				
54	29	7	1.58E-09	0.98172	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*		
55					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+				
56	31	8	1.51E-09	0.98368	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*		
57					BETA-AFW	*	IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT	+		
58	32	8	1.51E-09	0.98565	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*		
59					BETA-AFW	*	IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT	+		
60	34	6	1.43E-09	0.98752	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*		
61					IE-T2	*	PPS-SOV-FT-1455C	+						
62	33	6	1.43E-09	0.98938	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*		
63					IE-T2	*	PPS-SOV-FT-1456	+						
64	36	7	1.43E-09	0.99124	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*		
65					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+				
66	35	7	1.43E-09	0.99311	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*		
67					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+				
68	38	5	7.31E-10	0.99406	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1B	*		
69					IE-T2	+								
70	37	5	7.31E-10	0.99501	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1A	*		
71					IE-T2	+								
72	40	6	6.91E-10	0.99591	ACP-BAC-ST-4KV1H	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
73					IE-T2	*	PPS-MOV-FC-1535	+						
74	39	6	6.91E-10	0.99681	ACP-BAC-ST-4KV1J	*	AFW-MDP-FS-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
75					IE-T2	*	PPS-MOV-FC-1536	+						
76	44	7	6.14E-10	0.99760	AFW-MDP-FS-FW3A	*	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
77					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+				
78	43	7	6.14E-10	0.99840	AFW-MDP-FS-FW3B	*	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
79					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+				
80	42	7	6.14E-10	0.99920	AFW-MDP-FS-FW3A	*	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
81					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+				
82	41	7	6.14E-10	1.00000	AFW-MDP-FS-FW3B	*	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*		
83					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+				

SEQUENCE S1-D8

TOP EVENT S1-D8-CM CONTAINS 12 EVENTS IN 11 CUT SETS

THE FREQUENCY OF TOP EVENT S1-D8-CM IS 9.33E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT S1-D8-CM

N	1000
MEAN	8.88E-07
STD DEV	2.65E-08
LOWER 5%	4.20E-08
LOWER 25%	1.06E-07
MEDIAN	2.27E-07
UPPER 25%	5.17E-07
UPPER 5%	2.17E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE S1-D8

RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
BETA-LPI	1	1.50E-01 (1.0)	4.50E-07 (1.5)	6.85E-09	1.66E-06
LPI-MDP-FS	1	3.00E-03 (3.0)	4.50E-07 (1.5)	6.85E-09	1.66E-06
LPI-MOV-PG-1890C	1	4.40E-04 (11.0)	4.40E-07 (3.0)	1.34E-08	2.78E-07
LPI-MDP-FS-S11B	4	3.00E-03 (3.0)	2.28E-08 (4.5)	2.48E-10	1.49E-07
LPI-MDP-FS-S11A	4	3.00E-03 (3.0)	2.28E-08 (4.5)	2.48E-10	1.49E-07
LPI-MDP-MA-S11A	2	2.00E-03 (5.5)	9.20E-09 (6.5)	8.45E-11	3.74E-08
LPI-MDP-MA-S11B	2	2.00E-03 (5.5)	9.20E-09 (6.5)	8.45E-11	3.74E-08
SIS-ACT-FA-SISB	2	1.60E-03 (7.5)	8.00E-09 (8.5)	1.65E-10	2.86E-08
SIS-ACT-FA-SISA	2	1.60E-03 (7.5)	8.00E-09 (8.5)	1.65E-10	2.86E-08
LPI-CKV-OO-CV58	1	1.00E-03 (9.5)	3.00E-09 (10.5)	4.70E-11	1.19E-08
LPI-CKV-OO-CV50	1	1.00E-03 (9.5)	3.00E-09 (10.5)	4.70E-11	1.18E-08

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-S1	11	1.00E-03 (1.0)	9.33E-07 (1.0)	4.20E-08	2.17E-06

SEQUENCE S1-D8

RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
LPI-MOV-PG-1890C	1	4.40E-04 (11.0)	1.00E-03 (1.0)	2.66E-04	2.40E-03
LPI-MDP-FS	1	3.00E-03 (3.0)	1.50E-04 (2.0)	2.08E-05	4.85E-04
LPI-MDP-FS-S11B	4	3.00E-03 (3.0)	7.58E-08 (3.5)	9.71E-07	2.48E-05
LPI-MDP-FS-S11A	4	3.00E-03 (3.0)	7.58E-08 (3.5)	9.71E-07	2.48E-05
SIS-ACT-FA-SISA	2	1.60E-03 (7.5)	4.99E-08 (5.5)	2.72E-07	1.83E-05
SIS-ACT-FA-SISB	2	1.60E-03 (7.5)	4.99E-08 (5.5)	2.72E-07	1.83E-05
LPI-MDP-MA-S11A	2	2.00E-03 (5.5)	4.59E-08 (7.5)	3.49E-07	1.55E-05
LPI-MDP-MA-S11B	2	2.00E-03 (5.5)	4.59E-08 (7.5)	3.49E-07	1.55E-05
LPI-CKV-OO-CV58	1	1.00E-03 (9.5)	3.00E-08 (9.5)	7.58E-08	1.20E-05
LPI-CKV-OO-CV50	1	1.00E-03 (9.5)	3.00E-08 (9.5)	7.58E-08	1.20E-05
BETA-LPI	1	1.50E-01 (1.0)	2.55E-08 (11.0)	5.98E-08	1.05E-05

SEQUENCE S1-D8

UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
LPI-MDP-FS-S11B	4	3.00E-03	(3.0)	52.9	(2.0)
LPI-MDP-FS-S11A	4	3.00E-03	(3.0)	52.9	(2.0)
LPI-MDP-FS	1	3.00E-03	(3.0)	52.9	(2.0)
BETA-LPI	1	1.50E-01	(1.0)	7.9	(4.0)
LPI-MOV-PG-1890C	1	4.40E-04	(11.0)	5.2	(5.0)
LPI-MDP-MA-S11A	2	2.00E-03	(5.5)	1.1	(8.5)
LPI-MDP-MA-S11B	2	2.00E-03	(5.5)	1.1	(8.5)
SIS-ACT-FA-SISB	2	1.60E-03	(7.5)	0.7	(8.5)
SIS-ACT-FA-SISA	2	1.60E-03	(7.5)	0.7	(8.5)
LPI-CKV-OO-CV58	1	1.00E-03	(9.5)	0.8	(10.5)
LPI-CKV-OO-CV50	1	1.00E-03	(9.5)	0.8	(10.5)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
IE-S1	11	1.00E-03	(1.0)	30.8	(1.0)

E-160

SEQUENCE S1-D8

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
FOR TOP EVENT S1-D8-CM WITH TOP EVENT FREQUENCY 9.33E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	3	4.50E-07	0.48232	BETA-LPI	*	IE-S1	*	LPI-MDP-FS	+
3	2	2	4.40E-07	0.95391	IE-S1	*	LPI-MOV-PG-1890C	+		
4	3	3	9.00E-09	0.96356	IE-S1	*	LPI-MDP-FS-SI1A	*	LPI-MDP-FS-SI1B	+
5	5	3	6.00E-09	0.96899	IE-S1	*	LPI-MDP-FS-SI1A	*	LPI-MDP-MA-SI1B	+
6	4	3	6.00E-09	0.97642	IE-S1	*	LPI-MDP-FS-SI1B	*	LPI-MDP-MA-SI1A	+
7	7	3	4.80E-09	0.98156	IE-S1	*	LPI-MDP-FS-SI1B	*	SIS-ACT-FA-SISA	+
8	6	3	4.80E-09	0.98671	IE-S1	*	LPI-MDP-FS-SI1A	*	SIS-ACT-FA-SISB	+
9	9	3	3.20E-09	0.99014	IE-S1	*	LPI-MDP-MA-SI1A	*	SIS-ACT-FA-SISB	+
10	8	3	3.20E-09	0.99357	IE-S1	*	LPI-MDP-MA-SI1B	*	SIS-ACT-FA-SISA	+
11	11	3	3.00E-09	0.99678	IE-S1	*	LPI-CKV-OO-CV58	*	LPI-MDP-FS-SI1A	+
12	10	3	3.00E-09	1.00000	IE-S1	*	LPI-CKV-OO-CV50	*	LPI-MDP-FS-SI1B	.

SURRY SEQUENCE SBO-L2
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
REC-XHE-FO-DGEN	61	9.00E-01	(2.0)	6.17E-07 (1.0)	1.74E-08	2.59E-06
NOTQ	57	9.73E-01	(1.0)	6.15E-07 (2.0)		
OEP-DGN-FS	46	2.20E-02	(19.5)	5.94E-07 (3.0)	1.65E-08	2.41E-06
BETA-3DG	31	1.80E-02	(22.0)	5.77E-07 (4.0)	1.55E-08	2.38E-06
QS-SBO	61	2.70E-01	(8.0)	2.85E-07 (5.0)	4.45E-09	1.17E-06
NRAC-HALFHR	40	6.00E-01	(3.0)	2.66E-07 (6.0)	5.60E-09	1.16E-06
NRAC-1HR	11	4.40E-01	(6.0)	2.33E-07 (7.5)	3.13E-09	1.05E-06
AFW-XHE-FO-CST2	11	6.50E-02	(12.0)	2.33E-07 (7.5)	3.13E-09	1.05E-06
UNIT2-LOW-POWER	20	3.50E-01	(7.0)	1.41E-07 (9.0)		
AFW-TDP-FS-FW2	20	1.10E-02	(26.5)	1.35E-07 (10.0)	1.18E-09	5.78E-07
AFW-TDP-MA-FW2	17	1.00E-02	(28.5)	1.22E-07 (11.0)	7.70E-10	4.90E-07
NRAC-6HR-AVG	10	1.94E-01	(9.0)	1.18E-07 (12.0)	4.61E-10	5.64E-07
AFW-TDP-FR-2P6HR	8	3.00E-02	(15.5)	1.15E-07 (13.0)	4.47E-10	5.34E-07
QS-UNIT2	6	1.60E-01	(10.0)	6.04E-08 (14.0)	7.72E-10	1.95E-07
AFW-XHE-FO-U2SBO	4	7.50E-02	(11.0)	2.78E-08 (15.0)	2.33E-10	1.16E-07
OEP-DGN-FS-DG03	12	2.20E-02	(19.5)	1.86E-08 (17.0)	1.28E-10	1.85E-07
OEP-DGN-FS-DG01	12	2.20E-02	(19.5)	1.86E-08 (17.0)	1.28E-10	1.85E-07
OEP-DGN-FS-DG02	12	2.20E-02	(19.5)	1.86E-08 (17.0)	1.28E-10	1.85E-07
NOTDG-CCF	15	5.20E-01	(4.0)	1.76E-08 (19.5)		
BETA-2DG	15	3.80E-02	(13.0)	1.76E-08 (19.5)	1.13E-10	6.89E-08
AFW-CKV-OO-CV172	4	1.00E-03	(33.0)	1.12E-08 (21.0)	4.16E-10	4.04E-08
OEP-DGN-FR-6HDG3	7	1.20E-02	(24.0)	8.79E-09 (23.0)	4.17E-11	3.93E-08
OEP-DGN-FR-6HDG2	7	1.20E-02	(24.0)	8.79E-09 (23.0)	4.17E-11	3.93E-08
OEP-DGN-FR-6HDG1	7	1.20E-02	(24.0)	8.79E-09 (23.0)	4.17E-11	3.93E-08
AFW-TDP-FR-6HRU2	3	3.00E-02	(15.5)	5.79E-09 (25.0)	6.62E-12	4.50E-08
AFW-TDP-FS-U2FW2	3	1.10E-02	(26.5)	3.95E-09 (26.0)	6.44E-12	2.34E-08
AFW-TDP-MA-U2FW2	3	1.00E-02	(28.5)	3.59E-09 (27.0)	6.68E-12	2.44E-08
SBO-PORV-DMD	4	4.50E-01	(5.0)	2.39E-09 (28.0)	5.52E-12	4.94E-09
OEP-DGN-MA-DG03	1	6.00E-03	(31.0)	1.36E-09 (30.0)	3.13E-12	4.34E-09
OEP-DGN-MA-DG02	1	6.00E-03	(31.0)	1.36E-09 (30.0)	3.13E-12	4.34E-09
OEP-DGN-MA-DG01	1	6.00E-03	(31.0)	1.36E-09 (30.0)	3.13E-12	4.34E-09
PPS-SOV-OO-1456	2	3.00E-02	(15.5)	1.19E-09 (32.5)	2.76E-12	2.47E-09
PPS-SOV-OO-1455C	2	3.00E-02	(15.5)	1.19E-09 (32.5)	2.76E-12	2.47E-09
AFW-PSF-FC-XCONN	1	1.50E-04	(34.0)	6.14E-10 (34.0)	1.90E-11	2.50E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	61	7.70E-02	(1.0)	6.17E-07 (1.0)	1.74E-08	2.59E-06

SURRY SEQUENCE SBO-L2
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
BETA-3DG	31	1.80E-02 (22.0)	3.15E-05 (1.0)	1.38E-06	1.13E-04
OEP-DGN-FS	46	2.20E-02 (19.5)	2.64E-05 (2.0)	1.34E-06	1.05E-04
AFW-TDP-FS-FW2	20	1.10E-02 (26.5)	1.22E-05 (3.0)	7.63E-07	4.37E-05
AFW-TDP-MA-FW2	17	1.00E-02 (28.5)	1.20E-05 (4.0)	7.32E-07	4.32E-05
AFW-CKV-OO-CV172	4	1.00E-03 (33.0)	1.12E-05 (5.0)	6.71E-07	3.81E-05
AFW-PSF-FC-XCONN	1	1.50E-04 (34.0)	4.09E-06 (6.0)	1.71E-07	1.54E-05
AFW-TDP-FR-2P6HR	8	3.00E-02 (15.5)	3.73E-06 (7.0)	1.00E-07	1.44E-05
AFW-XHE-FO-CST2	11	6.50E-02 (12.0)	3.35E-06 (8.0)	1.04E-07	1.43E-05
OEP-DGN-FS-DG02	12	2.20E-02 (19.5)	8.27E-07 (10.0)	1.77E-08	4.36E-06
OEP-DGN-FS-DG03	12	2.20E-02 (19.5)	8.27E-07 (10.0)	1.77E-08	4.36E-06
OEP-DGN-FS-DG01	12	2.20E-02 (19.5)	8.27E-07 (10.0)	1.77E-08	4.36E-06
QS-SBO	61	2.70E-01 (8.0)	7.71E-07 (12.0)	1.69E-08	3.12E-06
OEP-DGN-FR-6HDG3	7	1.20E-02 (24.0)	7.24E-07 (14.0)	1.73E-08	3.72E-06
OEP-DGN-FR-6HDG2	7	1.20E-02 (24.0)	7.24E-07 (14.0)	1.73E-08	3.72E-06
OEP-DGN-FR-6HDG1	7	1.20E-02 (24.0)	7.24E-07 (14.0)	1.73E-08	3.72E-06
NRAC-6HR-AVG	10	1.94E-01 (9.0)	4.89E-07 (16.0)	3.68E-09	2.04E-06
BETA-2DG	15	3.80E-02 (13.0)	4.45E-07 (17.0)	3.96E-09	1.66E-06
AFW-TDP-MA-U2FW2	3	1.00E-02 (28.5)	3.55E-07 (18.0)	5.99E-09	1.44E-06
AFW-TDP-FS-U2FW2	3	1.10E-02 (26.5)	3.55E-07 (19.0)	5.98E-09	1.44E-06
AFW-XHE-FO-U2SBO	4	7.50E-02 (11.0)	3.43E-07 (20.0)	6.32E-09	1.40E-06
QS-UNIT2	6	1.60E-01 (10.0)	3.17E-07 (21.0)	5.46E-09	1.41E-06
NRAC-1HR	11	4.40E-01 (6.0)	2.97E-07 (22.0)	4.02E-09	1.36E-06
UNIT2-LOW-POWER	20	3.50E-01 (7.0)	2.61E-07 (23.0)		
OEP-DGN-MA-DG03	1	6.00E-03 (31.0)	2.25E-07 (25.0)	2.91E-09	9.30E-07
OEP-DGN-MA-DG02	1	6.00E-03 (31.0)	2.25E-07 (25.0)	2.91E-09	9.30E-07
OEP-DGN-MA-DG01	1	6.00E-03 (31.0)	2.25E-07 (25.0)	2.91E-09	9.30E-07
AFW-TDP-FR-6HRU2	3	3.00E-02 (15.5)	1.87E-07 (27.0)	1.82E-09	7.72E-07
NRAC-HALFHR	40	6.00E-01 (3.0)	1.78E-07 (28.0)	3.71E-09	7.16E-07
REC-XHE-FO-DGEN	61	9.00E-01 (2.0)	6.86E-08 (29.0)	4.38E-10	2.49E-07
PPS-SOV-OO-1456	2	3.00E-02 (15.5)	3.86E-08 (30.5)	3.05E-10	1.47E-07
PPS-SOV-OO-1455C	2	3.00E-02 (15.5)	3.86E-08 (30.5)	3.05E-10	1.47E-07
NOTQ	57	9.73E-01 (1.0)	1.71E-08 (32.0)		
NOTDG-CCF	15	5.20E-01 (4.0)	1.62E-08 (33.0)		
SBO-PORV-DMD	4	4.50E-01 (5.0)	2.92E-09 (34.0)	5.15E-12	5.41E-09

SURRY SEQUENCE SBO-L2
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
OEP-DGN-FS-DG03	12	2.20E-02	(19.5)	22.6	(2.5)	1.88	0.93
OEP-DGN-FS	46	2.20E-02	(19.5)	22.6	(2.5)	1.88	0.93
OEP-DGN-FS-DG01	12	2.20E-02	(19.5)	22.6	(2.5)	1.88	0.93
OEP-DGN-FS-DG02	12	2.20E-02	(19.5)	22.6	(2.5)	1.88	0.93
BETA-3DG	31	1.80E-02	(22.0)	17.9	(5.0)	1.56	0.91
QS-SBO	61	2.70E-01	(8.0)	7.7	(6.0)	1.29	0.97
QS-UNIT2	6	1.60E-01	(10.0)	7.5	(7.0)	1.08	1.06
PPS-SOV-OO-1455C	2	3.00E-02	(15.5)	7.0	(8.5)	1.00	1.00
PPS-SOV-OO-1456	2	3.00E-02	(15.5)	7.0	(8.5)	1.00	1.00
AFW-XHE-FO-CST2	11	6.50E-02	(12.0)	5.5	(10.0)	1.27	1.00
AFW-TDP-MA-FW2	17	1.00E-02	(28.5)	4.9	(11.5)	1.38	0.98
AFW-TDP-MA-U2FW2	3	1.00E-02	(28.5)	4.9	(11.5)	1.38	0.98
AFW-TDP-FS-U2FW2	3	1.10E-02	(26.5)	4.9	(13.5)	1.29	1.08
AFW-TDP-FS-FW2	20	1.10E-02	(26.5)	4.9	(13.5)	1.29	1.08
AFW-TDP-FR-2P6HR	8	3.00E-02	(15.5)	3.0	(15.5)	1.19	0.93
AFW-TDP-FR-6HRU2	3	3.00E-02	(15.5)	3.0	(15.5)	1.19	0.93
NRAC-6HR-AVG	10	1.94E-01	(9.0)	1.5	(17.0)	1.02	0.98
REC-XHE-FO-DGEN	61	9.00E-01	(2.0)	1.3	(18.0)	1.01	0.94
SBO-PORV-DMD	4	4.50E-01	(5.0)	0.9	(19.0)	1.00	1.00
AFW-PSF-FC-XCONN	1	1.50E-04	(34.0)	0.9	(20.0)	1.00	1.00
AFW-XHE-FO-U2SBO	4	7.50E-02	(11.0)	0.8	(21.0)	0.98	1.02
OEP-DGN-FR-6HDG3	7	1.20E-02	(24.0)	0.7	(23.0)	0.99	1.01
OEP-DGN-FR-6HDG2	7	1.20E-02	(24.0)	0.7	(23.0)	0.99	1.01
OEP-DGN-FR-6HDG1	7	1.20E-02	(24.0)	0.7	(23.0)	0.99	1.01
NRAC-1HR	11	4.40E-01	(6.0)	0.6	(25.0)	0.96	1.01
NRAC-HALFHR	40	6.00E-01	(3.0)	0.5	(26.0)	0.97	1.00
BETA-2DG	15	3.80E-02	(13.0)	0.5	(27.0)	1.00	1.00
AFW-CKV-OO-CV172	4	1.00E-03	(33.0)	0.4	(28.0)		
OEP-DGN-MA-DG03	1	6.00E-03	(31.0)	0.0	(30.0)		
OEP-DGN-MA-DG02	1	6.00E-03	(31.0)	0.0	(30.0)		
OEP-DGN-MA-DG01	1	6.00E-03	(31.0)	0.0	(30.0)		
NOTQ	57	9.73E-01	(1.0)				
NOTDG-CCF	15	5.20E-01	(4.0)				
UNIT2-LOW-POWER	20	3.50E-01	(7.0)				

E-165

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	61	7.70E-02	(1.0)	28.6	(1.0)	1.79	1.05

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SURRY SEQUENCE SBO-L2

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-L2 WITH TOP EVENT FREQUENCY 6.17E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	8	2.06E-07	0.33418	AFW-XHE-FO-CST2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
3					NRAC-1HR	*	OEP-DGN-FS	*	QS-SBO	*	REC-XHE-FO-DGEN	+
4	2	8	4.76E-08	0.41129	AFW-TDP-FS-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
5					NRAC-HALFHR	*	OEP-DGN-FS	*	QS-SBO	*	REC-XHE-FO-DGEN	+
6	3	9	4.50E-08	0.48427	AFW-TDP-FS-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
7					NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
8					UNIT2-LOW-POWER	+						
9	4	8	4.33E-08	0.55438	AFW-TDP-MA-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
10					NRAC-HALFHR	*	OEP-DGN-FS	*	QS-SBO	*	REC-XHE-FO-DGEN	+
11	6	8	4.20E-08	0.62238	AFW-TDP-FR-2P6HR	*	BETA-3DG	*	IE-T1	*	NOTQ	*
12					NRAC-6HR-AVG	*	OEP-DGN-FS	*	QS-SBO	*	REC-XHE-FO-DGEN	+
13	5	9	4.09E-08	0.68872	AFW-TDP-MA-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
14					NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
15					UNIT2-LOW-POWER	+						
16	8	9	3.97E-08	0.75307	AFW-TDP-FR-2P6HR	*	BETA-3DG	*	IE-T1	*	NOTQ	*
17					NRAC-6HR-AVG	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
18					UNIT2-LOW-POWER	+						
19	7	9	2.06E-08	0.78643	AFW-TDP-FS-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
20					NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*	QS-UNIT2	*
21					REC-XHE-FO-DGEN	+						
22	9	9	1.87E-08	0.81676	AFW-TDP-MA-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
23					NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*	QS-UNIT2	*
24					REC-XHE-FO-DGEN	+						
25	11	9	1.82E-08	0.84618	AFW-TDP-FR-2P6HR	*	BETA-3DG	*	IE-T1	*	NOTQ	*
26					NRAC-6HR-AVG	*	OEP-DGN-FS	*	/QS-SBO	*	QS-UNIT2	*
27					REC-XHE-FO-DGEN	+						
28	10	9	9.65E-09	0.86182	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U2SBO	*	BETA-3DG	*	IE-T1	*
29					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*
30					REC-XHE-FO-DGEN	+						
31	12	9	8.77E-09	0.87603	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U2SBO	*	BETA-3DG	*	IE-T1	*
32					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*
33					REC-XHE-FO-DGEN	+						
34	15	9	8.51E-09	0.88982	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-U2SBO	*	BETA-3DG	*	IE-T1	*
35					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*	/QS-SBO	*
36					REC-XHE-FO-DGEN	+						
37	13	9	5.54E-09	0.89881	AFW-XHE-FO-CST2	*	IE-T1	*	NOTQ	*	NRAC-1HR	*
38					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	QS-SBO	*
39					REC-XHE-FO-DGEN	+						
40	14	8	4.33E-09	0.90582	AFW-CKV-OO-CV172	*	BETA-3DG	*	IE-T1	*	NOTQ	*
41					NRAC-HALFHR	*	OEP-DGN-FS	*	QS-SBO	*	REC-XHE-FO-DGEN	+
42	16	9	4.09E-09	0.91245	AFW-CKV-OO-CV172	*	BETA-3DG	*	IE-T1	*	NOTQ	*
43					NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
44					UNIT2-LOW-POWER	+						
45	27	9	3.40E-09	0.91797	AFW-TDP-FR-2P6HR	*	AFW-TDP-FR-6HRU2	*	BETA-3DG	*	IE-T1	*
46					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*	/QS-SBO	*

103				NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FS	*	/QS-SBO	*
104				REC-XHE-FO-DGEN	+						
105	59	9	1.13E-09	0.97539		AFW-TDP-FR-2P8HR	*	IE-T1	*	NOTQ	*
106						OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
107						REC-XHE-FO-DGEN	+				
108	33	10	1.10E-09	0.97717		AFW-TDP-MA-FW2	*	IE-T1	*	NOTQ	*
109						OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
110						REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+		
111	34	9	8.77E-10	0.97859		AFW-CKV-OO-CV172	*	AFW-XHE-FO-U2SBO	*	BETA-3DG	*
112						NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
113						REC-XHE-FO-DGEN	+				
114	37	10	6.60E-10	0.97966		AFW-TDP-FS-FW2	*	IE-T1	*	NOTQ	*
115						OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
116						REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+		
117	36	10	6.60E-10	0.98073		AFW-TDP-FS-FW2	*	IE-T1	*	NOTQ	*
118						OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
119						REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+		
120	35	10	6.60E-10	0.98181		AFW-TDP-FS-FW2	*	IE-T1	*	NOTQ	*
121						OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
122						REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+		
123	42	10	6.27E-10	0.98282		AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*
124						NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*
125						QS-SBO	*	REC-XHE-FO-DGEN	+		
126	41	10	6.27E-10	0.98384		AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*
127						NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*
128						QS-SBO	*	REC-XHE-FO-DGEN	+		
129	40	10	6.27E-10	0.98485		AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*
130						NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*
131						QS-SBO	*	REC-XHE-FO-DGEN	+		
132	39	10	6.25E-10	0.98587		AFW-TDP-FS-FW2	*	BETA-3DG	*	IE-T1	*
133						OEP-DGN-FS	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
134						SBO-PORV-DMD	*	UNIT2-LOW-POWER	+		
135	38	10	6.25E-10	0.98688		AFW-TDP-FS-FW2	*	BETA-3DG	*	IE-T1	*
136						OEP-DGN-FS	*	PPS-SOV-OO-1456	*	/QS-SBO	*
137						SBO-PORV-DMD	*	UNIT2-LOW-POWER	+		
138	45	9	6.14E-10	0.98787		AFW-PSF-FC-XCONN	*	BETA-3DG	*	IE-T1	*
139						NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*
140						UNIT2-LOW-POWER	+				
141	48	10	6.00E-10	0.98885		AFW-TDP-MA-FW2	*	IE-T1	*	NOTQ	*
142						OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
143						REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+		
144	47	10	6.00E-10	0.98982		AFW-TDP-MA-FW2	*	IE-T1	*	NOTQ	*
145						OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
146						REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+		
147	46	10	6.00E-10	0.99079		AFW-TDP-MA-FW2	*	IE-T1	*	NOTQ	*
148						OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
149						REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+		
150	51	11	5.93E-10	0.99175		AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*
151						NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*
152						/QS-SBO	*	REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+
153	50	11	5.93E-10	0.99271		AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*
154						NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*
155						/QS-SBO	*	REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+
156	49	11	5.93E-10	0.99368		AFW-TDP-FS-FW2	*	BETA-2DG	*	IE-T1	*
157						NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*
158						/QS-SBO	*	REC-XHE-FO-DGEN	*	UNIT2-LOW-POWER	+

159	56	10	5.70E-10	0.99460	AFW-TDP-MA-FW2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
160					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*
161					QS-SBO	*	REC-XHE-FO-DGEN	+				
162	55	10	5.70E-10	0.99552	AFW-TDP-MA-FW2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
163					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*
164					QS-SBO	*	REC-XHE-FO-DGEN	+				
165	54	10	5.70E-10	0.99645	AFW-TDP-MA-FW2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
166					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*
167					QS-SBO	*	REC-XHE-FO-DGEN	+				
168	53	10	5.68E-10	0.99737	AFW-TDP-MA-FW2	*	BETA-3DG	*	IE-T1	*	NRAC-HALFHR	*
169					OEP-DGN-FS	*	PPS-SOV-OO-1455C	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
170					SBO-PORV-DMD	*	UNIT2-LOW-POWER	+				
171	52	10	5.68E-10	0.99829	AFW-TDP-MA-FW2	*	BETA-3DG	*	IE-T1	*	NRAC-HALFHR	*
172					OEP-DGN-FS	*	PPS-SOV-OO-1456	*	/QS-SBO	*	REC-XHE-FO-DGEN	*
173					SBO-PORV-DMD	*	UNIT2-LOW-POWER	+				
174	60	10	5.53E-10	0.99918	AFW-TDP-FS-FW2	*	IE-T1	*	NOTQ	*	NRAC-HALFHR	*
175					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	/QS-SBO	*
176					QS-UNIT2	*	REC-XHE-FO-DGEN	+				
177	61	10	5.03E-10	1.00000	AFW-TDP-MA-FW2	*	IE-T1	*	NOTQ	*	NRAC-HALFHR	*
178					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*	/QS-SBO	*
179					QS-UNIT2	*	REC-XHE-FO-DGEN	*				*

SEQUENCE A-D5

TOP EVENT A-D5 CONTAINS 7 EVENTS IN 8 CUT SETS

THE FREQUENCY OF TOP EVENT A-D5 IS 8.50E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT A-D5

N	1000
MEAN	6.37E-07
STD DEV	6.32E-07
LOWER 5%	1.12E-07
LOWER 25%	2.58E-07
MEDIAN	4.58E-07
UPPER 25%	7.90E-07
UPPER 5%	1.77E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

$$\begin{aligned} \text{RISK REDUCTION} &= \text{PD} \times \text{EV}(J) \\ &= \text{TEF} - \text{TEF}(\text{EVALUATED WITH EV}(J) = 0) \end{aligned}$$

2. FOR BASE EVENTS ONLY:

$$\begin{aligned} \text{RISK INCREASE} &= \text{PD} - \text{RISK REDUCTION} \\ &= \text{PD} \times (1 - \text{EV}(J)) \\ &= \text{TEF}(\text{EVALUATED WITH EV}(J) = 1) - \text{TEF} \end{aligned}$$

SEQUENCE A-D5

RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
ACC-MOV-PG-1865B	1	6.50E-04 (1.5)	3.25E-07 (1.5)	3.03E-08	6.51E-07
ACC-MOV-PG-1865C	1	6.50E-04 (1.5)	3.25E-07 (1.5)	3.03E-08	6.51E-07
ACC-CKV-FT-CV145	1	1.00E-04 (4.5)	5.00E-08 (4.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV147	1	1.00E-04 (4.5)	5.00E-08 (4.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV130	1	1.00E-04 (4.5)	5.00E-08 (4.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV128	1	1.00E-04 (4.5)	5.00E-08 (4.5)	6.43E-09	1.63E-07

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-A	6	5.00E-04 (1.0)	6.50E-07 (1.0)	1.12E-07	1.77E-06

SEQUENCE A-D5
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
ACC-CKV-FT-CV128	1	1.00E-04 (4.5)	5.00E-04 (2.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV145	1	1.00E-04 (4.5)	5.00E-04 (2.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV147	1	1.00E-04 (4.5)	5.00E-04 (2.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV130	1	1.00E-04 (4.5)	5.00E-04 (2.5)	1.33E-04	1.20E-03
ACC-MOV-PG-1865C	1	6.50E-04 (1.5)	5.00E-04 (5.5)	1.33E-04	1.20E-03
ACC-MOV-PG-1865B	1	6.50E-04 (1.5)	5.00E-04 (5.5)	1.33E-04	1.20E-03

SEQUENCE A-D5
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
ACC-MOV-PG-1865B	1	6.50E-04	(1.5)	28.0	(1.5)
ACC-MOV-PG-1865C	1	6.50E-04	(1.5)	28.0	(1.5)
ACC-CKV-FT-CV145	1	1.00E-04	(4.5)	9.0	(4.5)
ACC-CKV-FT-CV147	1	1.00E-04	(4.5)	9.0	(4.5)
ACC-CKV-FT-CV130	1	1.00E-04	(4.5)	9.0	(4.5)
ACC-CKV-FT-CV128	1	1.00E-04	(4.5)	9.0	(4.5)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
IE-A	6	5.00E-04	(1.0)	63.6	(1.0)

SEQUENCE A-D5

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
FOR TOP EVENT A-D5 WITH TOP EVENT FREQUENCY 8.50E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	2	3.25E-07	0.38235	ACC-MOV-PG-1865C *	IE-A	+
3	2	2	3.25E-07	0.78471	ACC-MOV-PG-1865B *	IE-A	+
4	3	2	5.00E-08	0.82353	ACC-CKV-FT-CV128 *	IE-A	+
5	5	2	5.00E-08	0.88235	ACC-CKV-FT-CV145 *	IE-A	+
6	6	2	5.00E-08	0.94118	ACC-CKV-FT-CV130 *	IE-A	+
7	4	2	5.00E-08	1.00000	ACC-CKV-FT-CV147 *	IE-A	.

SEQUENCE T-K-R-D4

TOP EVENT T-K-R-D4 CONTAINS 23 EVENTS IN 14 CUT SETS

THE FREQUENCY OF TOP EVENT T-K-R-D4 IS 5.65E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T-K-R-D4

N	1000
MEAN	6.36E-07
STD DEV	1.80E-08
LOWER 5%	9.48E-09
LOWER 25%	4.77E-08
MEDIAN	1.50E-07
UPPER 25%	4.39E-07
UPPER 5%	2.82E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE T-K-R-D4
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
R	14	1.70E-01 (4.0)	5.65E-07 (1.5)	9.48E-09	2.82E-06
K	14	6.00E-05 (18.0)	5.65E-07 (1.5)	9.48E-09	2.82E-06
PPS-MOV-FC-1536	3	3.00E-01 (1.5)	2.64E-07 (3.5)	2.00E-09	1.46E-06
PPS-MOV-FC-1535	3	3.00E-01 (1.5)	2.64E-07 (3.5)	2.00E-09	1.46E-06
PPS-MOV-FT-1535	2	4.00E-02 (8.0)	2.43E-07 (5.0)	1.82E-09	1.29E-06
HPI-MOV-FT-1350	1	3.00E-03 (10.0)	2.02E-07 (6.0)	8.17E-10	7.56E-07
PPS-XHE-FO-EMBOR	1	1.00E-03 (12.5)	6.73E-08 (7.0)	2.58E-10	2.40E-07
BETA-2MOV	1	8.80E-02 (5.0)	2.13E-08 (8.5)	1.11E-10	1.15E-07
PPS-MOV-FT	1	4.00E-02 (8.0)	2.13E-08 (8.5)	1.11E-10	1.15E-07
ACP-BAC-ST-4KV1H	1	9.00E-05 (16.0)	6.06E-09 (11.0)	6.02E-11	2.23E-08
ACP-BAC-ST-1H1-2	1	9.00E-05 (16.0)	6.06E-09 (11.0)	6.02E-11	2.23E-08
ACP-BAC-ST-1H1	1	9.00E-05 (16.0)	6.06E-09 (11.0)	6.02E-11	2.23E-08
BETA-SRV	1	7.00E-02 (6.0)	4.71E-09 (13.5)	5.25E-11	1.74E-08
PPS-SOV-FT	1	1.00E-03 (12.5)	4.71E-09 (13.5)	5.25E-11	1.74E-08
HPI-MOV-PG-1350	1	4.00E-05 (19.5)	2.69E-09 (15.5)	4.77E-11	1.08E-08
ACP-TFM-NO-1H1	1	4.00E-05 (19.5)	2.69E-09 (15.5)	4.79E-11	1.15E-08
CVC-MDP-FR-2A1HR	1	3.00E-05 (21.5)	2.02E-09 (17.0)	8.51E-12	6.51E-09
PPS-SOV-FT-1456	1	1.00E-03 (12.5)	8.08E-10 (19.0)	7.39E-12	3.22E-09
PPS-SOV-FT-1455C	1	1.00E-03 (12.5)	8.08E-10 (19.0)	7.39E-12	3.22E-09
PPS-MOV-FT-1536	1	4.00E-02 (8.0)	8.08E-10 (19.0)	7.39E-12	3.22E-09
BETA-STR	1	2.63E-01 (3.0)	5.31E-10 (21.5)	1.11E-11	1.88E-09
CPC-STR-PG-1HR	1	3.00E-05 (21.5)	5.31E-10 (21.5)		

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T	14	6.60E+00 (1.0)	5.65E-07 (1.0)	9.48E-09	2.82E-06

SEQUENCE T-K-R-D4
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
K	14	6.00E-05 (18.0)	9.42E-03 (1.0)	4.23E-04	4.43E-02
CVC-MDP-FR-2A1HR	1	3.00E-05 (21.5)	6.73E-05 (3.0)	1.80E-06	2.49E-04
HPI-MOV-PG-1350	1	4.00E-05 (19.5)	6.73E-05 (3.0)	1.80E-06	2.49E-04
ACP-TFM-NO-1H1	1	4.00E-05 (19.5)	6.73E-05 (3.0)	1.80E-06	2.49E-04
ACP-BAC-ST-1H1	1	9.00E-05 (16.0)	6.73E-05 (6.0)	1.80E-06	2.49E-04
ACP-BAC-ST-4KV1H	1	9.00E-05 (16.0)	6.73E-05 (6.0)	1.80E-06	2.49E-04
ACP-BAC-ST-1H1-2	1	9.00E-05 (16.0)	6.73E-05 (6.0)	1.80E-06	2.49E-04
PPS-XHE-FO-EMBOR	1	1.00E-03 (12.5)	6.73E-05 (8.0)	1.79E-06	2.48E-04
HPI-MOV-FT-1350	1	3.00E-03 (10.0)	6.71E-05 (9.0)	1.80E-06	2.48E-04
CPC-STR-PG-1HR	1	3.00E-05 (21.5)	1.77E-05 (10.0)		
PPS-MOV-FT-1535	2	4.00E-02 (8.0)	5.84E-06 (11.0)	7.32E-08	3.20E-05
PPS-SOV-FT	1	1.00E-03 (12.5)	4.71E-06 (12.0)	8.54E-08	1.69E-05
R	14	1.70E-01 (4.0)	2.76E-06 (13.0)	8.63E-08	1.21E-05
PPS-SOV-FT-1456	1	1.00E-03 (12.5)	8.07E-07 (14.5)	1.16E-08	3.27E-06
PPS-SOV-FT-1455C	1	1.00E-03 (12.5)	8.07E-07 (14.5)	1.16E-08	3.27E-06
PPS-MOV-FC-1536	3	3.00E-01 (1.5)	6.17E-07 (16.5)	8.65E-09	2.03E-06
PPS-MOV-FC-1535	3	3.00E-01 (1.5)	6.17E-07 (16.5)	8.65E-09	2.03E-06
PPS-MOV-FT	1	4.00E-02 (8.0)	5.12E-07 (18.0)	4.12E-09	2.79E-06
BETA-2MOV	1	8.80E-02 (5.0)	2.21E-07 (19.0)	1.67E-09	1.19E-06
BETA-SRV	1	7.00E-02 (6.0)	6.26E-08 (20.0)	1.12E-09	2.36E-07
PPS-MOV-FT-1536	1	4.00E-02 (8.0)	1.94E-08 (21.0)	2.91E-10	8.88E-08
BETA-STR	1	2.63E-01 (3.0)	1.49E-09 (22.0)	3.74E-11	6.09E-09

E-177

SEQUENCE T-K-R-D4
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
K	14	6.00E-05	(18.0)	31.9	(1.0)
R	14	1.70E-01	(4.0)	26.6	(2.0)
PPS-MOV-FC-1535	3	3.00E-01	(1.5)	11.0	(3.5)
PPS-MOV-FC-1536	3	3.00E-01	(1.5)	11.0	(3.5)
HPI-MOV-FT-1350	1	3.00E-03	(10.0)	8.3	(5.0)
PPS-MOV-FT	1	4.00E-02	(8.0)	3.9	(7.0)
PPS-MOV-FT-1536	1	4.00E-02	(8.0)	3.9	(7.0)
PPS-MOV-FT-1535	2	4.00E-02	(8.0)	3.9	(7.0)
PPS-XHE-FO-EMBOR	1	1.00E-03	(12.5)	1.3	(9.0)
BETA-SRV	1	7.00E-02	(8.0)	0.8	(10.0)
CVC-MDP-FR-2A1HR	1	3.00E-05	(21.5)	0.8	(11.0)
ACP-TFM-NO-1H1	1	4.00E-05	(19.5)	0.5	(12.0)
PPS-SOV-FT-1456	1	1.00E-03	(12.5)	0.4	(14.0)
PPS-SOV-FT-1455C	1	1.00E-03	(12.5)	0.4	(14.0)
PPS-SOV-FT	1	1.00E-03	(12.5)	0.4	(14.0)
BETA-STR	1	2.63E-01	(3.0)	0.3	(16.0)
ACP-BAC-ST-4KV1H	1	9.00E-05	(16.0)	0.0	(19.0)
HPI-MOV-PG-1350	1	4.00E-05	(19.5)	0.0	(19.0)
BETA-2MOV	1	8.80E-02	(5.0)	0.0	(19.0)
ACP-BAC-ST-1H1-2	1	9.00E-05	(16.0)	0.0	(19.0)
ACP-BAC-ST-1H1	1	9.00E-05	(16.0)	0.0	(19.0)
CPC-STR-PG-1HR	1	3.00E-05	(21.5)	0.0	(19.0)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
IE-T	14	6.60E+00	(1.0)	16.1	(1.0)

E-178

SEQUENCE T-K-R-D4

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T-K-R-D4 WITH TOP EVENT FREQUENCY 5.65E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	6	2.42E-07	0.42864	IE-T	*	K	*	PPS-MOV-FC-1535	*	PPS-MOV-FC-1536	*
3					PPS-MOV-FT-1535	*	R	+				
4	2	4	2.02E-07	0.78584	HPI-MOV-FT-1350	*	IE-T	*	K	*	R	+
5	3	4	6.73E-08	0.90490	IE-T	*	K	*	PPS-XHE-FO-EMBOR	*	R	+
6	4	7	2.13E-08	0.94282	BETA-2MOV	*	IE-T	*	K	*	PPS-MOV-FC-1535	*
7					PPS-MOV-FC-1536	*	PPS-MOV-FT	*	R	+		
8	6	4	6.06E-09	0.95334	ACP-BAC-ST-4KV1H	*	IE-T	*	K	*	R	+
9	7	4	6.06E-09	0.96406	ACP-BAC-ST-1H1	*	IE-T	*	K	*	R	+
10	5	4	6.06E-09	0.97477	ACP-BAC-ST-1H1-2	*	IE-T	*	K	*	R	+
11	8	5	4.71E-09	0.98311	BETA-SRV	*	IE-T	*	K	*	PPS-SOV-FT	*
12					R	+						
13	10	4	2.69E-09	0.98787	ACP-TFM-NO-1H1	*	IE-T	*	K	*	R	+
14	9	4	2.69E-09	0.99263	HPI-MOV-PG-1350	*	IE-T	*	K	*	R	+
15	11	4	2.02E-09	0.99620	CVC-MDP-FR-2A1HR	*	IE-T	*	K	*	R	+
16	13	6	8.08E-10	0.99783	IE-T	*	K	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	*
17					PPS-SOV-FT-1456	*	R	+				
18	12	6	8.08E-10	0.99806	IE-T	*	K	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	*
19					PPS-SOV-FT-1455C	*	R	+				
20	14	5	5.31E-10	1.00000	BETA-STR	*	CPC-STR-PG-1HR	*	IE-T	*	K	*
21					R							

SURRY SEQUENCE S3-D1

TOP EVENT S3-D1-CM CONTAINS 33 EVENTS IN 20 CUT SETS

THE FREQUENCY OF TOP EVENT S3-D1-CM IS 6.39E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT S3-D1-CM

N	1000
MEAN	6.25E-07
STD DEV	1.34E-08
LOWER 5%	4.24E-08
LOWER 25%	1.30E-07
MEDIAN	2.70E-07
UPPER 25%	6.16E-07
UPPER 5%	2.35E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

5% = 4.24E-08 ***LOG SCALE*** 95% = 2.35E-06
|-----[-----*-----MN-----|

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

- FOR BASE EVENTS AND INITIATING EVENTS:
RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)
- FOR BASE EVENTS ONLY:
RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SURRY SEQUENCE S3-D1
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
BETA-2MOV	2	8.80E-02 (3.0)	4.05E-07 (1.5)	3.72E-09	1.56E-06
HPI-MOV-FT	2	3.00E-03 (15.0)	4.05E-07 (1.5)	3.72E-09	1.56E-06
HPI-XHE-FO-UN2S3	13	4.40E-02 (6.0)	3.13E-07 (3.0)	1.52E-08	1.29E-06
HPI-XHE-FO-ALTS3	1	7.40E-02 (4.0)	2.54E-07 (4.0)	2.00E-09	9.24E-07
HPI-CKV-FT-CV25	1	1.00E-04 (26.0)	5.72E-08 (5.5)	3.04E-09	2.08E-07
HPI-CKV-FT-CV410	1	1.00E-04 (26.0)	5.72E-08 (5.5)	3.04E-09	2.08E-07
RWT-TNK-LF-RWST	1	2.70E-06 (32.0)	3.51E-08 (7.0)	7.12E-10	1.29E-07
HPI-XVM-PG-XV24	1	4.00E-05 (30.5)	2.29E-08 (8.0)	1.22E-09	8.29E-08
HPI-MDP-FR-1A24H	2	1.60E-03 (20.0)	2.16E-08 (9.0)	1.95E-09	6.93E-08
HPI-CKV-OO-CV258	1	1.00E-03 (21.5)	2.08E-08 (10.0)	1.77E-09	6.71E-08
CPC-XHE-FO-REALN	3	7.00E-02 (5.0)	9.38E-09 (11.0)	2.61E-10	3.62E-08
HPI-MOV-FT-1867D	3	3.00E-03 (15.0)	8.58E-09 (12.0)	1.16E-10	3.33E-08
BETA-STR	1	2.63E-01 (1.0)	7.58E-09 (13.5)	2.00E-10	2.96E-08
CPC-STR-PG-24H	1	7.20E-04 (23.5)	7.58E-09 (13.5)		
HPI-XHE-FO-ALTIN	1	5.70E-03 (8.0)	7.41E-09 (15.5)	9.74E-11	3.25E-08
HPI-CKV-FT-CV225	1	1.00E-04 (26.0)	7.41E-09 (15.5)	9.74E-11	3.25E-08
HPI-MOV-FT-1115E	1	3.00E-03 (15.0)	5.15E-09 (18.5)	2.41E-12	6.23E-08
HPI-MOV-FT-1115D	1	3.00E-03 (15.0)	5.15E-09 (18.5)	2.41E-12	6.23E-08
HPI-MOV-FT-1115C	1	3.00E-03 (15.0)	5.15E-09 (18.5)	2.41E-12	6.23E-08
HPI-MOV-FT-1115B	1	3.00E-03 (15.0)	5.15E-09 (18.5)	2.41E-12	6.23E-08
CPC-MDP-FR-SWA24	3	3.80E-03 (10.5)	3.97E-09 (21.0)	1.35E-10	1.56E-08
ACP-BAC-ST-4KV1H	1	9.00E-05 (28.5)	3.51E-09 (22.5)	3.30E-11	1.33E-08
ACP-BAC-ST-1H1	1	9.00E-05 (28.5)	3.51E-09 (22.5)	3.30E-11	1.33E-08
CPC-CKV-OO-CV113	1	1.00E-03 (21.5)	2.17E-09 (24.0)	7.76E-11	8.77E-09
CPC-MDP-FR-CCA24	2	7.20E-04 (23.5)	2.06E-09 (25.0)	8.97E-12	6.85E-09
ACP-TFM-NO-1H1	1	4.00E-05 (30.5)	1.56E-09 (26.0)	2.60E-11	6.43E-09
CPC-MDP-FS-CC2B	1	3.00E-03 (15.0)	1.24E-09 (27.0)	2.69E-12	4.35E-09
CPC-MDP-FS-SW10B	1	8.00E-03 (7.0)	1.22E-09 (28.0)	1.70E-11	4.86E-09
CPC-MDP-MA-CC2B	1	2.00E-03 (19.0)	8.24E-10 (29.0)	1.35E-12	2.64E-09
BETA-HPI	1	2.10E-01 (2.0)	7.69E-10 (30.5)	1.80E-11	3.14E-09
HPI-MDP-FS	1	4.00E-03 (9.0)	7.69E-10 (30.5)	1.80E-11	3.14E-09
CPC-MDP-FR-SWB24	1	3.80E-03 (10.5)	5.78E-10 (32.0)	5.84E-12	3.57E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-S3	20	1.30E-02 (1.0)	6.39E-07 (1.0)	4.24E-08	2.35E-06

SURRY SEQUENCE S3-D1
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
RWT-TNK-LF-RWST	1	2.70E-06 (32.0)	1.30E-02 (1.0)	3.47E-03	3.12E-02
HPI-XVM-PG-XV24	1	4.00E-05 (30.5)	5.72E-04 (2.0)	4.80E-05	2.01E-03
HPI-CKV-FT-CV410	1	1.00E-04 (26.0)	5.72E-04 (3.5)	4.80E-05	2.01E-03
HPI-CKV-FT-CV25	1	1.00E-04 (26.0)	5.72E-04 (3.5)	4.80E-05	2.01E-03
HPI-MOV-FT	2	3.00E-03 (15.0)	1.35E-04 (5.0)	1.01E-05	4.71E-04
HPI-CKV-FT-CV225	1	1.00E-04 (26.0)	7.41E-05 (6.0)	1.66E-06	3.04E-04
ACP-TFM-NO-1H1	1	4.00E-05 (30.5)	3.90E-05 (7.0)	9.10E-07	1.52E-04
ACP-BAC-ST-1H1	1	9.00E-05 (28.5)	3.90E-05 (8.5)	9.10E-07	1.51E-04
ACP-BAC-ST-4KV1H	1	9.00E-05 (28.5)	3.90E-05 (8.5)	9.10E-07	1.51E-04
HPI-CKV-OO-CV258	1	1.00E-03 (21.5)	2.08E-05 (10.0)	3.16E-06	6.41E-05
HPI-MDP-FR-1A24H	2	1.60E-03 (20.0)	1.35E-05 (11.0)	1.84E-06	3.93E-05
CPC-STR-PG-24H	1	7.20E-04 (23.5)	1.05E-05 (12.0)		
HPI-XHE-FO-UN2S3	13	4.40E-02 (6.0)	6.80E-06 (13.0)	8.38E-07	2.30E-05
BETA-2MOV	2	8.80E-02 (3.0)	4.20E-06 (14.0)	5.65E-08	1.66E-05
HPI-XHE-FO-ALTS3	1	7.40E-02 (4.0)	3.18E-06 (15.0)	4.96E-08	1.22E-05
CPC-MDP-FR-CCA24	2	7.20E-04 (23.5)	2.86E-06 (16.0)	7.55E-08	1.08E-05
HPI-MOV-FT-1867D	3	3.00E-03 (15.0)	2.85E-06 (17.0)	3.31E-07	9.46E-06
CPC-CKV-OO-CV113	1	1.00E-03 (21.5)	2.17E-06 (18.0)	1.18E-07	8.73E-06
HPI-MOV-FT-1115E	1	3.00E-03 (15.0)	1.71E-06 (20.5)	1.76E-08	7.48E-06
HPI-MOV-FT-1115D	1	3.00E-03 (15.0)	1.71E-06 (20.5)	1.76E-08	7.48E-06
HPI-MOV-FT-1115C	1	3.00E-03 (15.0)	1.71E-06 (20.5)	1.76E-08	7.48E-06
HPI-MOV-FT-1115B	1	3.00E-03 (15.0)	1.71E-06 (20.5)	1.76E-08	7.48E-06
HPI-XHE-FO-ALT1N	1	5.70E-03 (8.0)	1.29E-06 (23.0)	1.74E-07	3.90E-06
CPC-MDP-FR-SWA24	3	3.80E-03 (10.5)	1.04E-06 (24.0)	6.32E-08	3.81E-06
CPC-MDP-MA-CC2B	1	2.00E-03 (19.0)	4.11E-07 (25.0)	4.82E-09	1.70E-06
CPC-MDP-FS-CC2B	1	3.00E-03 (15.0)	4.11E-07 (26.0)	4.82E-09	1.70E-06
HPI-MDP-FS	1	4.00E-03 (9.0)	1.91E-07 (27.0)	7.96E-09	7.31E-07
CPC-MDP-FR-SWB24	1	3.80E-03 (10.5)	1.52E-07 (28.0)	3.31E-09	6.45E-07
CPC-MDP-FS-SW10B	1	8.00E-03 (7.0)	1.51E-07 (29.0)	3.29E-09	6.47E-07
CPC-XHE-FO-REALN	3	7.00E-02 (5.0)	1.25E-07 (30.0)	8.10E-09	4.54E-07
BETA-STR	1	2.63E-01 (1.0)	2.12E-08 (31.0)	7.16E-10	8.46E-08
BETA-HPI	1	2.10E-01 (2.0)	2.89E-09 (32.0)	7.81E-11	1.10E-08

SURRY SEQUENCE S3-D1
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y .05/TE .05*	Y .95/TE .95*
HPI-MOV-FT-1115E	1	3.00E-03 (15.0)	32.1 (3.5)	1.90	0.85
HPI-MOV-FT-1115C	1	3.00E-03 (15.0)	32.1 (3.5)	1.90	0.85
HPI-MOV-FT-1115D	1	3.00E-03 (15.0)	32.1 (3.5)	1.90	0.85
HPI-MOV-FT-1867D	3	3.00E-03 (15.0)	32.1 (3.5)	1.90	0.85
HPI-MOV-FT-1115B	1	3.00E-03 (15.0)	32.1 (3.5)	1.90	0.85
HPI-MOV-FT	2	3.00E-03 (15.0)	32.1 (3.5)	1.90	0.85
HPI-XHE-FO-UN2S3	13	4.40E-02 (6.0)	17.0 (7.0)	1.48	0.84
BETA-2MOV	2	8.80E-02 (3.0)	5.4 (8.0)	1.07	0.99
HPI-XHE-FO-ALTS3	1	7.40E-02 (4.0)	4.4 (9.0)	1.08	0.99
HPI-CKV-FT-CV225	1	1.00E-04 (26.0)	3.5 (11.0)	1.16	0.99
HPI-CKV-FT-CV410	1	1.00E-04 (26.0)	3.5 (11.0)	1.16	0.99
HPI-CKV-FT-CV25	1	1.00E-04 (26.0)	3.5 (11.0)	1.16	0.99
RWT-TNK-LF-RWST	1	2.70E-06 (32.0)	2.3 (13.0)	1.16	1.00
HPI-MDP-FS	1	4.00E-03 (9.0)	0.9 (14.0)	1.00	1.00
ACP-TFM-NO-1H1	1	4.00E-05 (30.5)	0.6 (15.0)	1.00	1.00
CPC-CKV-OO-CV113	1	1.00E-03 (21.5)	0.5 (16.5)	1.06	0.98
HPI-CKV-OO-CV258	1	1.00E-03 (21.5)	0.5 (16.5)	1.06	0.98
HPI-XHE-FO-ALTIN	1	5.70E-03 (8.0)	0.5 (18.0)	1.00	1.00
CPC-XHE-FO-REALN	3	7.00E-02 (5.0)	0.5 (19.0)		
CPC-MDP-FS-CC2B	1	3.00E-03 (15.0)	0.4 (20.0)		
CPC-MDP-MA-CC2B	1	2.00E-03 (19.0)	0.4 (21.0)		
HPI-XVM-PG-XV24	1	4.00E-05 (30.5)	0.0 (26.5)		
CPC-MDP-FS-SW10B	1	8.00E-03 (7.0)	0.0 (26.5)		
BETA-STR	1	2.83E-01 (1.0)	0.0 (26.5)		
ACP-BAC-ST-1H1	1	9.00E-05 (28.5)	0.0 (26.5)		
HPI-MDP-FR-1A24H	2	1.80E-03 (20.0)	0.0 (26.5)		
CPC-MDP-FR-SWB24	1	3.80E-03 (10.5)	0.0 (26.5)		
BETA-HPI	1	2.10E-01 (2.0)	0.0 (26.5)		
CPC-MDP-FR-SWA24	3	3.80E-03 (10.5)	0.0 (26.5)		
CPC-MDP-FR-CCA24	2	7.20E-04 (23.5)	0.0 (26.5)		
ACP-BAC-ST-4KV1H	1	9.00E-05 (28.5)	0.0 (26.5)		
CPC-STR-PG-24H	1	7.20E-04 (23.5)			

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y .05/TE .05*	Y .95/TE .95*
IE-S3	20	1.30E-02 (1.0)	31.4 (1.0)	1.93	0.93

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SURRY SEQUENCE S3-D1

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT S3-D1-CM WITH TOP EVENT FREQUENCY 6.39E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	4	2.54E-07	0.39756	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALTS3	*	IE-S3	+
3	2	4	1.51E-07	0.63394	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
4	3	3	5.72E-08	0.72348	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S3	*	IE-S3	+		
5	4	3	5.72E-08	0.81302	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S3	*	IE-S3	+		
6	5	2	3.51E-08	0.86797	IE-S3	+	RWT-TNK-LF-RWST	+				
7	6	3	2.29E-08	0.90378	HPI-XHE-FO-UN2S3	*	HPI-XVM-PG-XV24	*	IE-S3	+		
8	7	3	2.08E-08	0.93634	HPI-CKV-OO-CV258	*	HPI-MDP-FR-1A24H	*	IE-S3	+		
9	8	5	7.58E-09	0.94821	BETA-STR	*	CPC-STR-PG-24H	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S3	*
10					IE-S3	+						
11	9	3	7.41E-09	0.95981	HPI-CKV-FT-CV225	*	HPI-XHE-FO-ALTN	*	IE-S3	+		
12	11	4	5.15E-09	0.96787	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
13	10	4	5.15E-09	0.97593	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
14	13	3	3.51E-09	0.98142	ACP-BAC-ST-1H1	*	HPI-MOV-FT-1867D	*	IE-S3	+		
15	12	3	3.51E-09	0.98692	ACP-BAC-ST-4KV1H	*	HPI-MOV-FT-1867D	*	IE-S3	+		
16	14	4	2.17E-09	0.99032	CPC-CKV-OO-CV113	*	CPC-MDP-FR-SWA24	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
17	15	3	1.56E-09	0.99276	ACP-TFM-NO-1H1	*	HPI-MOV-FT-1867D	*	IE-S3	+		
18	16	4	1.24E-09	0.99470	CPC-MDP-FR-CCA24	*	CPC-MDP-FS-CC2B	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
19	17	5	1.22E-09	0.99660	CPC-MDP-FR-SWA24	*	CPC-MDP-FS-SW10B	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S3	*
20					IE-S3	+						
21	18	4	8.24E-10	0.99789	CPC-MDP-FR-CCA24	*	CPC-MDP-MA-CC2B	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
22	19	5	7.69E-10	0.99909	BETA-HPI	*	HPI-MDP-FR-1A24H	*	HPI-MDP-FS	*	HPI-XHE-FO-UN2S3	*
23					IE-S3	+						
24	20	5	5.78E-10	1.00000	CPC-MDP-FR-SWA24	*	CPC-MDP-FR-SWB24	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S3	*
25					IE-S3	.						

SEQUENCE S2-D1

TOP EVENT S2-D1-CM CONTAINS 19 EVENTS IN 11 CUT SETS

THE FREQUENCY OF TOP EVENT S2-D1-CM IS 4.29E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT S2-D1-CM

N	1000
MEAN	4.37E-07
STD DEV	8.81E-07
LOWER 5%	4.18E-08
LOWER 25%	1.08E-07
MEDIAN	2.27E-07
UPPER 25%	4.46E-07
UPPER 5%	1.38E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE S2-D1
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
BETA-2MOV	2	8.80E-02 (4.0)	2.43E-07 (1.5)	2.96E-09	8.86E-07
HPI-MOV-FT	2	3.00E-03 (8.0)	2.43E-07 (1.5)	2.96E-09	8.86E-07
HPI-XHE-FO-UN2S2	7	3.10E-01 (2.0)	1.63E-07 (3.0)	7.61E-09	6.53E-07
HPI-XHE-FO-ALT	1	6.10E-01 (1.0)	1.61E-07 (4.0)	1.80E-09	5.41E-07
HPI-CKV-FT-CV225	1	1.00E-04 (15.0)	1.00E-07 (5.0)	1.32E-08	3.01E-07
HPI-CKV-FT-CV25	1	1.00E-04 (15.0)	3.10E-08 (6.5)	1.55E-09	1.11E-07
HPI-CKV-FT-CV410	1	1.00E-04 (15.0)	3.10E-08 (6.5)	1.55E-09	1.11E-07
HPI-XVM-PG-XV24	1	4.00E-05 (17.0)	1.24E-08 (8.0)	6.18E-10	4.11E-08
HPI-MOV-FT-1115E	1	3.00E-03 (8.0)	2.79E-09 (10.5)	1.52E-12	3.07E-08
HPI-MOV-FT-1115D	1	3.00E-03 (8.0)	2.79E-09 (10.5)	1.52E-12	3.07E-08
HPI-MOV-FT-1115C	1	3.00E-03 (8.0)	2.79E-09 (10.5)	1.52E-12	3.07E-08
HPI-MOV-FT-1115B	1	3.00E-03 (8.0)	2.79E-09 (10.5)	1.52E-12	3.07E-08
RWT-TNK-LF-RWST	1	2.70E-06 (18.0)	2.70E-09 (13.0)	6.15E-11	1.06E-08
SIS-ACT-FA-SISB	1	1.60E-03 (11.5)	2.56E-09 (14.5)	2.70E-11	2.53E-08
SIS-ACT-FA-SISA	1	1.60E-03 (11.5)	2.56E-09 (14.5)	2.70E-11	2.53E-08
CPC-STR-PG-6HR	1	1.80E-04 (13.0)	1.03E-09 (17.0)		
CPC-XHE-FO-REALN	1	7.00E-02 (5.0)	1.03E-09 (17.0)	2.87E-11	4.34E-09
BETA-STR	1	2.63E-01 (3.0)	1.03E-09 (17.0)	2.87E-11	4.34E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-S2	11	1.00E-03 (1.0)	4.29E-07 (1.0)	4.18E-08	1.38E-06

SEQUENCE S2-D1
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
RWT-TNK-LF-RWST	1	2.70E-06	(18.0)	1.00E-03	(1.0)	2.66E-04	2.40E-03
HPI-CKV-FT-CV225	1	1.00E-04	(15.0)	1.00E-03	(2.0)	2.66E-04	2.40E-03
HPI-XVM-PG-XV24	1	4.00E-05	(17.0)	3.10E-04	(3.0)	2.53E-05	9.25E-04
HPI-CKV-FT-CV410	1	1.00E-04	(15.0)	3.10E-04	(4.5)	2.53E-05	9.25E-04
HPI-CKV-FT-CV25	1	1.00E-04	(15.0)	3.10E-04	(4.5)	2.53E-05	9.25E-04
HPI-MOV-FT	2	3.00E-03	(8.0)	8.07E-05	(6.0)	8.22E-06	2.50E-04
CPC-STR-PG-6HR	1	1.80E-04	(13.0)	5.71E-08	(7.0)		
BETA-2MOV	2	8.80E-02	(4.0)	2.52E-08	(8.0)	4.31E-08	1.00E-05
SIS-ACT-FA-SISB	1	1.60E-03	(11.5)	1.60E-06	(9.5)	1.14E-07	5.59E-06
SIS-ACT-FA-SISA	1	1.60E-03	(11.5)	1.60E-06	(9.5)	1.14E-07	5.59E-06
HPI-MOV-FT-1115E	1	3.00E-03	(8.0)	9.27E-07	(12.5)	1.16E-08	3.62E-06
HPI-MOV-FT-1115D	1	3.00E-03	(8.0)	9.27E-07	(12.5)	1.16E-08	3.62E-06
HPI-MOV-FT-1115C	1	3.00E-03	(8.0)	9.27E-07	(12.5)	1.16E-08	3.62E-06
HPI-MOV-FT-1115B	1	3.00E-03	(8.0)	9.27E-07	(12.5)	1.16E-08	3.62E-06
HPI-XHE-FO-UN2S2	7	3.10E-01	(2.0)	3.62E-07	(15.0)	2.74E-08	1.25E-06
HPI-XHE-FO-ALT	1	6.10E-01	(1.0)	1.03E-07	(16.0)	4.60E-10	3.88E-07
CPC-XHE-FO-REALN	1	7.00E-02	(5.0)	1.36E-08	(17.0)	8.42E-10	4.66E-08
BETA-STR	1	2.63E-01	(3.0)	2.88E-09	(18.0)	9.75E-11	1.21E-08

SEQUENCE S2-D1
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
HPI-MOV-FT	2	3.00E-03 (8.0)	31.8 (3.0)	1.60	0.87
HPI-MOV-FT-1115E	1	3.00E-03 (8.0)	31.8 (3.0)	1.60	0.87
HPI-MOV-FT-1115C	1	3.00E-03 (8.0)	31.8 (3.0)	1.60	0.87
HPI-MOV-FT-1115B	1	3.00E-03 (8.0)	31.8 (3.0)	1.60	0.87
HPI-MOV-FT-1115D	1	3.00E-03 (8.0)	31.8 (3.0)	1.60	0.87
HPI-CKV-FT-CV25	1	1.00E-04 (15.0)	11.7 (7.0)	1.37	0.91
HPI-CKV-FT-CV225	1	1.00E-04 (15.0)	11.7 (7.0)	1.37	0.91
HPI-CKV-FT-CV410	1	1.00E-04 (15.0)	11.7 (7.0)	1.37	0.91
HPI-XHE-FO-UN2S2	7	3.10E-01 (2.0)	7.2 (9.0)	1.09	1.00
BETA-2MOV	2	8.80E-02 (4.0)	5.0 (10.0)	1.07	1.12
HPI-XHE-FO-ALT	1	8.10E-01 (1.0)	2.1 (11.0)	1.03	1.01
RWT-TNK-LF-RWST	1	2.70E-06 (18.0)	0.6 (12.0)	0.98	1.01
CPC-XHE-FO-REALN	1	7.00E-02 (5.0)	0.3 (13.0)		
SIS-ACT-FA-SISB	1	1.60E-03 (11.5)	0.3 (14.5)		
SIS-ACT-FA-SISA	1	1.60E-03 (11.5)	0.3 (14.5)		
HPI-XVM-PG-XV24	1	4.00E-05 (17.0)	0.0 (16.5)		
BETA-STR	1	2.63E-01 (3.0)	0.0 (16.5)		
CPC-STR-PG-6HR	1	1.80E-04 (13.0)			

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-S2	11	1.00E-03 (1.0)	39.1 (1.0)	1.98	0.90

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE S2-D1

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT S2-D1-CM. WITH TOP EVENT FREQUENCY 4.29E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMAGSETS.DNF)

2	1	4	1.61E-07	0.37528	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALT	*	IE-S2	+
3	2	2	1.00E-07	0.60828	HPI-CKV-FT-CV225	*	IE-S2	+				
4	3	4	8.18E-08	0.79898	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
5	5	3	3.10E-08	0.87122	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S2	*	IE-S2	+		
6	4	3	3.10E-08	0.94345	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S2	*	IE-S2	+		
7	6	3	1.24E-08	0.97235	HPI-XHE-FO-UN2S2	*	HPI-XVM-PG-XV24	*	IE-S2	+		
8	7	4	2.79E-09	0.97885	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
9	8	4	2.79E-09	0.98535	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
10	9	2	2.70E-09	0.99164	IE-S2	*	RWT-TNK-LF-RWST	+				
11	10	3	2.56E-09	0.99761	IE-S2	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+		
12	11	5	1.03E-09	1.00000	BETA-STR	*	CPC-STR-PG-6HR	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S2	*
13					IE-S2							

SEQUENCE SBO-BATT2

TOP EVENT SBO-BATT2 CONTAINS 24 EVENTS IN 40 CUT SETS

THE FREQUENCY OF TOP EVENT SBO-BATT2 IS 2.97E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SBO-BATT2

N	1000
MEAN	4.33E-07
STD DEV	1.98E-08
LOWER 5%	0.00E+00
LOWER 25%	0.00E+00
MEDIAN	0.00E+00
UPPER 25%	1.03E-07
UPPER 5%	1.70E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE SBO-BATT2
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NRAC-7HR	40	5.00E-02 (7.0)	2.97E-07 (2.5)	0.00E+00	1.70E-06
NOTL-SBOU1U2	40	9.68E-01 (2.0)	2.97E-07 (2.5)		
NOTQ	40	9.73E-01 (1.0)	2.97E-07 (2.5)		
NSLOCA	40	2.70E-01 (5.5)	2.97E-07 (2.5)	0.00E+00	1.70E-06
REC-XHE-FO-DGHWB	39	6.00E-01 (3.0)	2.96E-07 (5.0)	0.00E+00	1.63E-06
OEP-DGN-FS	12	2.20E-02 (11.5)	2.45E-07 (6.0)	0.00E+00	1.19E-06
BETA-3DG	3	1.80E-02 (14.0)	2.33E-07 (7.0)	0.00E+00	1.14E-06
OEP-DGN-FS-DG03	15	2.20E-02 (11.5)	4.02E-08 (8.0)	0.00E+00	2.68E-07
OEP-DGN-MA-DG01	5	6.00E-03 (19.0)	2.45E-08 (9.0)	0.00E+00	8.83E-08
OEP-DGN-FS-DG02	14	2.20E-02 (11.5)	1.93E-08 (10.5)	0.00E+00	1.48E-07
OEP-DGN-FS-DG01	14	2.20E-02 (11.5)	1.93E-08 (10.5)	0.00E+00	1.48E-07
QS-SBO	40	2.70E-01 (5.5)	1.63E-08 (12.0)	0.00E+00	5.48E-08
OEP-DGN-FR-6HDG3	11	1.20E-02 (16.0)	1.23E-08 (14.0)	0.00E+00	5.79E-08
OEP-DGN-FR-6HDG2	11	1.20E-02 (16.0)	1.23E-08 (14.0)	0.00E+00	5.79E-08
OEP-DGN-FR-6HDG1	11	1.20E-02 (16.0)	1.23E-08 (14.0)	0.00E+00	5.79E-08
NOTDG-CCF	9	5.20E-01 (4.0)	1.21E-08 (16.5)		
BETA-2DG	9	3.80E-02 (9.0)	1.21E-08 (16.5)	0.00E+00	4.23E-08
OEP-DGN-MA-DG03	4	6.00E-03 (19.0)	3.54E-09 (18.5)	0.00E+00	1.20E-08
OEP-DGN-MA-DG02	4	6.00E-03 (19.0)	3.54E-09 (18.5)	0.00E+00	1.20E-08
OEP-CRB-FT-25H3	1	3.00E-03 (22.0)	5.92E-10 (21.0)	0.00E+00	2.22E-09
OEP-CRB-FT-15J3	1	3.00E-03 (22.0)	5.92E-10 (21.0)	0.00E+00	2.22E-09
OEP-CRB-FT-15H3	1	3.00E-03 (22.0)	5.92E-10 (21.0)	0.00E+00	2.22E-09
O	28	4.90E-02 (8.0)	-1.82E-09 (23.0)	-1.16E-08	0.00E+00

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	40	7.70E-02 (1.0)	2.97E-07 (1.0)	0.00E+00	1.70E-06

SEQUENCE SBO-BATT2
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
BETA-3DG	3	1.80E-02 (14.0)	1.27E-05 (1.0)	0.00E+00	7.34E-05
OEP-DGN-FS	12	2.20E-02 (11.5)	1.09E-05 (2.0)	0.00E+00	6.18E-05
NRAC-7HR	40	5.00E-02 (7.0)	5.65E-06 (3.0)	0.00E+00	3.86E-05
OEP-DGN-MA-DG01	5	8.00E-03 (19.0)	4.05E-06 (4.0)	0.00E+00	2.21E-05
OEP-DGN-FS-DG03	15	2.20E-02 (11.5)	1.79E-06 (5.0)	0.00E+00	9.83E-06
OEP-DGN-FR-6HDG2	11	1.20E-02 (16.0)	1.01E-06 (7.0)	0.00E+00	6.36E-06
OEP-DGN-FR-6HDG1	11	1.20E-02 (16.0)	1.01E-06 (7.0)	0.00E+00	6.36E-06
OEP-DGN-FR-6HDG3	11	1.20E-02 (16.0)	1.01E-06 (7.0)	0.00E+00	6.36E-06
OEP-DGN-FS-DG02	14	2.20E-02 (11.5)	8.56E-07 (9.5)	0.00E+00	5.14E-06
OEP-DGN-FS-DG01	14	2.20E-02 (11.5)	8.56E-07 (9.5)	0.00E+00	5.14E-06
NSLOCA	40	2.70E-01 (5.5)	8.04E-07 (11.0)	0.00E+00	4.05E-06
OEP-DGN-MA-DG03	4	6.00E-03 (19.0)	5.86E-07 (12.5)	0.00E+00	3.19E-06
OEP-DGN-MA-DG02	4	6.00E-03 (19.0)	5.86E-07 (12.5)	0.00E+00	3.19E-06
BETA-2DG	9	3.80E-02 (9.0)	3.05E-07 (14.0)	0.00E+00	1.30E-06
REC-XHE-FO-DGHWB	39	6.00E-01 (3.0)	1.97E-07 (15.0)	0.00E+00	1.02E-06
OEP-CRB-FT-25H3	1	3.00E-03 (22.0)	1.97E-07 (17.0)	0.00E+00	1.17E-06
OEP-CRB-FT-15J3	1	3.00E-03 (22.0)	1.97E-07 (17.0)	0.00E+00	1.17E-06
OEP-CRB-FT-15H3	1	3.00E-03 (22.0)	1.97E-07 (17.0)	0.00E+00	1.17E-06
QS-SBO	40	2.70E-01 (5.5)	4.42E-08 (19.0)	0.00E+00	1.48E-07
NOTDG-CCF	9	5.20E-01 (4.0)	1.11E-08 (20.0)		
NOTL-SBOU1U2	40	9.68E-01 (2.0)	9.83E-09 (21.0)		
NOTQ	40	9.73E-01 (1.0)	8.25E-09 (22.0)		
O	28	4.90E-02 (8.0)	-3.53E-08 (23.0)	-2.59E-07	0.00E+00

SEQUENCE SBO-BATT2
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
NSLOCA	40	2.70E-01	(5.5)	95.5	(1.0)	NA	0.91
OEP-DGN-FS-DG02	14	2.20E-02	(11.5)	1.3	(3.5)	NA	1.05
OEP-DGN-FS-DG01	14	2.20E-02	(11.5)	1.3	(3.5)	NA	1.05
OEP-DGN-FS	12	2.20E-02	(11.5)	1.3	(3.5)	NA	1.05
OEP-DGN-FS-DG03	15	2.20E-02	(11.5)	1.3	(3.5)	NA	1.05
BETA-3DG	3	1.80E-02	(14.0)	1.2	(6.0)	NA	1.12
OEP-DGN-FR-6HDG3	11	1.20E-02	(16.0)	1.1	(8.0)	NA	0.93
OEP-DGN-FR-6HDG2	11	1.20E-02	(16.0)	1.1	(8.0)	NA	0.93
OEP-DGN-FR-6HDG1	11	1.20E-02	(16.0)	1.1	(8.0)	NA	0.93
OEP-DGN-MA-DG02	4	6.00E-03	(19.0)	0.6	(11.0)	NA	0.98
OEP-DGN-MA-DG01	5	6.00E-03	(19.0)	0.6	(11.0)	NA	0.98
OEP-DGN-MA-DG03	4	6.00E-03	(19.0)	0.6	(11.0)	NA	0.98
NRAC-7HR	40	5.00E-02	(7.0)	0.5	(13.0)	NA	1.16
OEP-CRB-FT-25H3	1	3.00E-03	(22.0)	0.4	(15.0)		
OEP-CRB-FT-15J3	1	3.00E-03	(22.0)	0.4	(15.0)		
OEP-CRB-FT-15H3	1	3.00E-03	(22.0)	0.4	(15.0)		
QS-SBO	40	2.70E-01	(5.5)	0.0	(18.5)		
BETA-2DG	9	3.80E-02	(9.0)	0.0	(18.5)		
O	28	4.90E-02	(8.0)	0.0	(18.5)		
REC-XHE-FO-DGHWB	39	6.00E-01	(3.0)	0.0	(18.5)		
NOTDG-CCF	9	5.20E-01	(4.0)				
NOTQ	40	9.73E-01	(1.0)				
NOTL-SBOU1U2	40	9.68E-01	(2.0)				

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	40	7.70E-02	(1.0)	0.3	(1.0)		

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE SBO-BATT2

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-BATT2 WITH TOP EVENT FREQUENCY 2.97E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	10	1.61E-07	0.54324	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	* *
3					NRAC-7HR	* NSLOCA	* /O	* OEP-DGN-FS	* *
4					/QS-SBO	* REC-XHE-FO-DGHWB	+		
5	2	9	6.28E-08	0.75452	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	* *
6					NRAC-7HR	* NSLOCA	* OEP-DGN-FS	* QS-SBO	* *
7					REC-XHE-FO-DGHWB	+			
8	3	9	2.09E-08	0.82495	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
9					NSLOCA	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* QS-SBO	* *
10					REC-XHE-FO-DGHWB	+			
11	4	10	8.32E-09	0.85294	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	* *
12					NRAC-7HR	* NSLOCA	* O	* OEP-DGN-FS	* *
13					/QS-SBO	* REC-XHE-FO-DGHWB	+		
14	5	11	4.34E-09	0.86754	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
15					NSLOCA	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* *
16					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
17	7	11	2.37E-09	0.87551	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
18					NSLOCA	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* *
19					OEP-DGN-FS-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
20	6	11	2.37E-09	0.88348	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
21					NSLOCA	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* *
22					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
23	8	11	2.37E-09	0.89145	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
24					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* *
25					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
26	11	12	2.13E-09	0.89860	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	* *
27					NOTQ	* NRAC-7HR	* NSLOCA	* /O	* *
28					OEP-DGN-FR-6HDG1	* OEP-DGN-FS	* /QS-SBO	* REC-XHE-FO-DGHWB	+
29	10	12	2.13E-09	0.90578	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	* *
30					NOTQ	* NRAC-7HR	* NSLOCA	* /O	* *
31					OEP-DGN-FR-6HDG3	* OEP-DGN-FS	* /QS-SBO	* REC-XHE-FO-DGHWB	+
32	9	12	2.13E-09	0.91291	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	* *
33					NOTQ	* NRAC-7HR	* NSLOCA	* /O	* *
34					OEP-DGN-FR-6HDG2	* OEP-DGN-FS	* /QS-SBO	* REC-XHE-FO-DGHWB	+
35	12	10	1.69E-09	0.91860	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
36					NSLOCA	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* *
37					QS-SBO	* REC-XHE-FO-DGHWB	+		
38	15	11	1.29E-09	0.92294	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
39					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	* *
40					OEP-DGN-FS-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
41	14	11	1.29E-09	0.92729	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
42					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	* *
43					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	
44	13	11	1.29E-09	0.93163	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	* *
45					NSLOCA	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FR-6HDG3	* *
46					OEP-DGN-FS-DG01	* /QS-SBO	* REC-XHE-FO-DGHWB	+	

47	18	11	1.18E-09	0.93562	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
48					NSLOCA	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
49					OEP-DGN-MA-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
50	17	11	1.18E-09	0.93960	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
51					NSLOCA	* /O	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*
52					OEP-DGN-MA-DG01	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
53	16	11	1.18E-09	0.94358	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
54					NSLOCA	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
55					OEP-DGN-MA-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
56	19	10	1.17E-09	0.94754	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
57					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
58					OEP-DGN-FR-6HDG3	* /QS-SBO	+		*
59	22	12	1.06E-09	0.95111	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
60					NOTQ	* NRAC-7HR	* NSLOCA	* /O	*
61					OEP-DGN-FS	* OEP-DGN-MA-DG01	* /QS-SBO	* REC-XHE-FO-DGHWB	+
62	21	12	1.06E-09	0.95469	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
63					NOTQ	* NRAC-7HR	* NSLOCA	* /O	*
64					OEP-DGN-FS	* OEP-DGN-MA-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+
65	20	12	1.06E-09	0.95827	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
66					NOTQ	* NRAC-7HR	* NSLOCA	* /O	*
67					OEP-DGN-FS	* OEP-DGN-MA-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+
68	25	10	9.21E-10	0.96137	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
69					NSLOCA	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
70					QS-SBO	* REC-XHE-FO-DGHWB	+		*
71	24	10	9.21E-10	0.96447	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
72					NSLOCA	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
73					QS-SBO	* REC-XHE-FO-DGHWB	+		*
74	23	10	9.21E-10	0.96757	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
75					NSLOCA	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	*
76					QS-SBO	* REC-XHE-FO-DGHWB	+		*
77	28	11	8.27E-10	0.97035	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
78					NOTQ	* NRAC-7HR	* NSLOCA	* OEP-DGN-FR-6HDG3	*
79					OEP-DGN-FS	* QS-SBO	* REC-XHE-FO-DGHWB	+	*
80	27	11	8.27E-10	0.97313	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
81					NOTQ	* NRAC-7HR	* NSLOCA	* OEP-DGN-FR-6HDG1	*
82					OEP-DGN-FS	* QS-SBO	* REC-XHE-FO-DGHWB	+	*
83	26	11	8.27E-10	0.97592	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2	*
84					NOTQ	* NRAC-7HR	* NSLOCA	* OEP-DGN-FR-6HDG2	*
85					OEP-DGN-FS	* QS-SBO	* REC-XHE-FO-DGHWB	+	*
86	31	11	6.46E-10	0.97809	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
87					NSLOCA	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG03	*
88					OEP-DGN-MA-DG01	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
89	30	11	6.46E-10	0.98026	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
90					NSLOCA	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
91					OEP-DGN-MA-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
92	29	11	6.46E-10	0.98243	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
93					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
94					OEP-DGN-MA-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
95	34	11	6.46E-10	0.98461	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
96					NSLOCA	* /O	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
97					OEP-DGN-MA-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
98	33	11	6.46E-10	0.98678	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
99					NSLOCA	* /O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
100					OEP-DGN-MA-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+	*
101	32	11	6.46E-10	0.98895	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
102					NSLOCA	* /O	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG02	*

103					OEP-DGN-MA-DG01	* /QS-SBO	* REC-XHE-FO-DGHWB	+		
104	37	11	5.92E-10	0.99095	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
105					NSLOCA	* /O	* OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
106					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+		
107	36	11	5.92E-10	0.99294	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
108					NSLOCA	* /O	* OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
109					OEP-DGN-FS-DG02	* /QS-SBO	* REC-XHE-FO-DGHWB	+		
110	35	11	5.92E-10	0.99493	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
111					NSLOCA	* /O	* OEP-CRB-FT-25H3	*	OEP-DGN-FS-DG01	*
112					OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWB	+		
113	40	10	5.02E-10	0.99662	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
114					NSLOCA	* OEP-DGN-FR-6HDG2	* OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
115					QS-SBO	* REC-XHE-FO-DGHWB	+			
116	39	10	5.02E-10	0.99831	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
117					NSLOCA	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*
118					QS-SBO	* REC-XHE-FO-DGHWB	+			
119	38	10	5.02E-10	1.00000	IE-T1	* NOTL-SBOU1U2	* NOTQ	*	NRAC-7HR	*
120					NSLOCA	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*
121					QS-SBO	* REC-XHE-FO-DGHWB	.			

SEQUENCE SBO-Q2

TOP EVENT SBO-Q2 CONTAINS 21 EVENTS IN 32 CUT SETS

THE FREQUENCY OF TOP EVENT SBO-Q2 IS 3.48E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT SBO-Q2

N	1000
MEAN	3.23E-07
STD DEV	1.10E-08
LOWER 5%	1.83E-09
LOWER 25%	1.44E-08
MEDIAN	5.91E-08
UPPER 25%	2.21E-07
UPPER 5%	1.25E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE SBO-Q2
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NOTL-SBOU1U2	32	9.68E-01 (1.0)	3.46E-07 (2.5)		
NRAC-1HR	32	4.40E-01 (5.0)	3.46E-07 (2.5)	1.83E-09	1.25E-06
SBO-PORV-DMD	32	4.50E-01 (4.0)	3.46E-07 (2.5)	1.83E-09	1.25E-06
REC-XHE-FO-DGEN	32	9.00E-01 (2.0)	3.46E-07 (2.5)	1.83E-09	1.25E-06
OEP-DGN-FS	22	2.20E-02 (11.5)	3.33E-07 (5.0)	1.70E-09	1.20E-06
BETA-3DG	4	1.80E-02 (14.0)	3.16E-07 (6.0)	1.61E-09	1.15E-06
PPS-SOV-OO-1456	16	3.00E-02 (8.5)	1.73E-07 (7.5)	9.13E-10	6.26E-07
PPS-SOV-OO-1455C	16	3.00E-02 (8.5)	1.73E-07 (7.5)	9.13E-10	6.26E-07
NOTDG-CCF	18	5.20E-01 (3.0)	1.70E-08 (9.5)		
BETA-2DG	18	3.80E-02 (7.0)	1.70E-08 (9.5)	3.47E-11	4.38E-08
OEP-DGN-FS-DG03	8	2.20E-02 (11.5)	1.19E-08 (12.0)	1.87E-11	1.01E-07
OEP-DGN-FS-DG02	8	2.20E-02 (11.5)	1.19E-08 (12.0)	1.87E-11	1.01E-07
OEP-DGN-FS-DG01	8	2.20E-02 (11.5)	1.19E-08 (12.0)	1.87E-11	1.01E-07
OEP-DGN-FR-6HDG2	4	1.20E-02 (16.0)	4.16E-09 (15.0)	4.32E-12	1.17E-08
OEP-DGN-FR-6HDG1	4	1.20E-02 (16.0)	4.16E-09 (15.0)	4.32E-12	1.17E-08
OEP-DGN-FR-6HDG3	4	1.20E-02 (16.0)	4.16E-09 (15.0)	4.32E-12	1.17E-08
OEP-DGN-MA-DG03	4	6.00E-03 (19.0)	3.21E-09 (18.0)	3.13E-12	9.44E-09
OEP-DGN-MA-DG02	4	6.00E-03 (19.0)	3.21E-09 (18.0)	3.13E-12	9.44E-09
OEP-DGN-MA-DG01	4	6.00E-03 (19.0)	3.21E-09 (18.0)	3.13E-12	9.44E-09
QS-SBO	32	2.70E-01 (6.0)	-3.56E-09 (20.0)	-2.37E-08	-6.73E-13

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	32	7.70E-02 (1.0)	3.46E-07 (1.0)	1.83E-09	1.25E-06

SEQUENCE SBO-Q2
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
BETA-3DG	4	1.80E-02 (14.0)	1.72E-05 (1.0)	1.25E-07	6.31E-05
OEP-DGN-FS	22	2.20E-02 (11.5)	1.48E-05 (2.0)	1.14E-07	5.38E-05
PPS-SOV-OO-1455C	16	3.00E-02 (8.5)	5.60E-06 (3.5)	1.82E-07	2.51E-05
PPS-SOV-OO-1458	16	3.00E-02 (8.5)	5.60E-06 (3.5)	1.82E-07	2.51E-05
OEP-DGN-MA-DG03	4	6.00E-03 (19.0)	5.31E-07 (6.0)	2.90E-09	1.42E-06
OEP-DGN-MA-DG02	4	6.00E-03 (19.0)	5.31E-07 (6.0)	2.90E-09	1.42E-06
OEP-DGN-MA-DG01	4	6.00E-03 (19.0)	5.31E-07 (6.0)	2.90E-09	1.42E-06
OEP-DGN-FS-DG03	8	2.20E-02 (11.5)	5.27E-07 (9.0)	1.85E-09	2.03E-06
OEP-DGN-FS-DG02	8	2.20E-02 (11.5)	5.27E-07 (9.0)	1.85E-09	2.03E-06
OEP-DGN-FS-DG01	8	2.20E-02 (11.5)	5.27E-07 (9.0)	1.85E-09	2.03E-06
NRAC-1HR	32	4.40E-01 (5.0)	4.41E-07 (11.0)	2.58E-09	1.64E-08
BETA-2DG	18	3.80E-02 (7.0)	4.31E-07 (12.0)	1.23E-09	1.32E-06
SBO-PORV-DMD	32	4.50E-01 (4.0)	4.23E-07 (13.0)	2.03E-09	1.81E-06
OEP-DGN-FR-6HDG2	4	1.20E-02 (16.0)	3.42E-07 (15.0)	1.61E-09	1.38E-06
OEP-DGN-FR-6HDG1	4	1.20E-02 (16.0)	3.42E-07 (15.0)	1.61E-09	1.38E-06
OEP-DGN-FR-6HDG3	4	1.20E-02 (16.0)	3.42E-07 (15.0)	1.61E-09	1.38E-06
REC-XHE-FO-DGEN	32	9.00E-01 (2.0)	3.85E-08 (17.0)	4.56E-11	1.32E-07
NOTDG-CCF	18	5.20E-01 (3.0)	1.57E-08 (18.0)		
NOTL-SBOU1U2	32	9.68E-01 (1.0)	1.14E-08 (19.0)		
QS-SBO	32	2.70E-01 (6.0)	-9.62E-09 (20.0)	-2.83E-08	-9.38E-12

SEQUENCE SBO-Q2
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
PPS-SOV-OO-1456	16	3.00E-02	(8.5)	46.1	(1.5)	6.23	1.21
PPS-SOV-OO-1455C	16	3.00E-02	(8.5)	46.1	(1.5)	6.23	1.21
QS-SBO	32	2.70E-01	(6.0)	45.2	(3.0)	1.00	1.02
SBO-PORV-DMD	32	4.50E-01	(4.0)	15.3	(4.0)	1.69	1.14
OEP-DGN-FS-DG03	8	2.20E-02	(11.5)	13.9	(6.5)	1.51	0.99
OEP-DGN-FS	22	2.20E-02	(11.5)	13.9	(6.5)	1.51	0.99
OEP-DGN-FS-DG01	8	2.20E-02	(11.5)	13.9	(6.5)	1.51	0.99
OEP-DGN-FS-DG02	8	2.20E-02	(11.5)	13.9	(6.5)	1.51	0.99
BETA-3DG	4	1.80E-02	(14.0)	9.3	(9.0)	1.39	1.04
REC-XHE-FO-DGEN	32	9.00E-01	(2.0)	1.1	(10.0)	1.01	1.03
NRAC-1HR	32	4.40E-01	(5.0)	0.7	(11.0)	1.12	1.02
BETA-2DG	18	3.80E-02	(7.0)	0.6	(12.0)	0.97	1.00
OEP-DGN-FR-6HDG2	4	1.20E-02	(16.0)	0.5	(14.0)		
OEP-DGN-FR-6HDG1	4	1.20E-02	(16.0)	0.5	(14.0)		
OEP-DGN-FR-6HDG3	4	1.20E-02	(16.0)	0.5	(14.0)		
OEP-DGN-MA-DG03	4	6.00E-03	(19.0)	0.0	(17.0)		
OEP-DGN-MA-DG02	4	6.00E-03	(19.0)	0.0	(17.0)		
OEP-DGN-MA-DG01	4	6.00E-03	(19.0)	0.0	(17.0)		
NOTDG-CCF	18	5.20E-01	(3.0)				
NOTL-SBOU1U2	32	9.68E-01	(1.0)				

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	32	7.70E-02	(1.0)	17.0	(1.0)	1.52	1.10

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE SBO-Q2

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT SBO-Q2 WITH TOP EVENT FREQUENCY 3.46E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	2	9	1.15E-07	0.33276	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR
3					OEP-DGN-FS	* PPS-SOV-OO-1456	* /QS-SBO	* REC-XHE-FO-DGEN
4					SBO-PORV-DMD	+		
5	1	9	1.15E-07	0.66552	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR
6					OEP-DGN-FS	* PPS-SOV-OO-1455C	* /QS-SBO	* REC-XHE-FO-DGEN
7					SBO-PORV-DMD	+		
8	3	9	4.26E-08	0.78859	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR
9					OEP-DGN-FS	* PPS-SOV-OO-1455C	* QS-SBO	* REC-XHE-FO-DGEN
10					SBO-PORV-DMD	+		
11	4	9	4.26E-08	0.91167	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR
12					OEP-DGN-FS	* PPS-SOV-OO-1456	* QS-SBO	* REC-XHE-FO-DGEN
13					SBO-PORV-DMD	+		
14	5	10	3.10E-09	0.92061	IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	* OEP-DGN-FS-DG01
15					OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* /QS-SBO
16					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+	
17	6	10	3.10E-09	0.92956	IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	* OEP-DGN-FS-DG01
18					OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1456	* /QS-SBO
19					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+	
20	11	11	1.52E-09	0.93394	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2
21					NRAC-1HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS	* PPS-SOV-OO-1456
22					/QS-SBO	* REC-XHE-FO-DGEN	* SBO-PORV-DMD	+
23	12	11	1.52E-09	0.93833	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2
24					NRAC-1HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS	* PPS-SOV-OO-1456
25					/QS-SBO	* REC-XHE-FO-DGEN	* SBO-PORV-DMD	+
26	10	11	1.52E-09	0.94271	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2
27					NRAC-1HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS	* PPS-SOV-OO-1456
28					/QS-SBO	* REC-XHE-FO-DGEN	* SBO-PORV-DMD	+
29	9	11	1.52E-09	0.94709	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2
30					NRAC-1HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS	* PPS-SOV-OO-1455C
31					/QS-SBO	* REC-XHE-FO-DGEN	* SBO-PORV-DMD	+
32	8	11	1.52E-09	0.95148	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2
33					NRAC-1HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS	* PPS-SOV-OO-1455C
34					/QS-SBO	* REC-XHE-FO-DGEN	* SBO-PORV-DMD	+
35	7	11	1.52E-09	0.95586	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1U2
36					NRAC-1HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS	* PPS-SOV-OO-1455C
37					/QS-SBO	* REC-XHE-FO-DGEN	* SBO-PORV-DMD	+
38	14	10	1.15E-09	0.95917	IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	* OEP-DGN-FS-DG01
39					OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1456	* QS-SBO
40					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+	
41	13	10	1.15E-09	0.96248	IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	* OEP-DGN-FS-DG01
42					OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* QS-SBO
43					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+	
44	15	10	8.45E-10	0.96492	IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	* OEP-DGN-FS-DG01
45					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1455C	* /QS-SBO
46					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+	

47	20	10	8.45E-10	0.96736	IE-T1	*	NOTL-SBOU1U2	*	NRAC-1HR	*	OEP-DGN-FS-DG01	*
48					OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*	/QS-SBO	*
49					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
50	19	10	8.45E-10	0.96980	IE-T1	*	NOTL-SBOU1U2	*	NRAC-1HR	*	OEP-DGN-FS-DG02	*
51					OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*	/QS-SBO	*
52					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
53	18	10	8.45E-10	0.97224	IE-T1	*	NOTL-SBOU1U2	*	NRAC-1HR	*	OEP-DGN-FS-DG02	*
54					OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
55					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
56	17	10	8.45E-10	0.97468	IE-T1	*	NOTL-SBOU1U2	*	NRAC-1HR	*	OEP-DGN-FS-DG01	*
57					OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
58					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
59	16	10	8.45E-10	0.97712	IE-T1	*	NOTL-SBOU1U2	*	NRAC-1HR	*	OEP-DGN-FS-DG01	*
60					OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	/QS-SBO	*
61					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
62	26	11	7.59E-10	0.97931	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
63					NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*
64					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
65	25	11	7.59E-10	0.98150	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
66					NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1456	*
67					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
68	24	11	7.59E-10	0.98370	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
69					NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*
70					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
71	23	11	7.59E-10	0.98589	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
72					NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*
73					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
74	22	11	7.59E-10	0.98808	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
75					NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*
76					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
77	21	11	7.59E-10	0.99027	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
78					NRAC-1HR	*	OEP-DGN-FS	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*
79					/QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
80	30	11	5.61E-10	0.99189	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
81					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*	PPS-SOV-OO-1456	*
82					QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
83	29	11	5.61E-10	0.99351	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
84					NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*
85					QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
86	28	11	5.61E-10	0.99514	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
87					NRAC-1HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*
88					QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
89	31	11	5.61E-10	0.99676	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
90					NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS	*	PPS-SOV-OO-1456	*
91					QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
92	27	11	5.61E-10	0.99838	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
93					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS	*	PPS-SOV-OO-1455C	*
94					QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		
95	32	11	5.61E-10	1.00000	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1U2	*
96					NRAC-1HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS	*	PPS-SOV-OO-1456	*
97					QS-SBO	*	REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+		

SEQUENCE A-D8

TOP EVENT A-D8-CM CONTAINS 13 EVENTS IN 13 CUT SETS

THE FREQUENCY OF TOP EVENT A-D8-CM IS 4.69E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT A-D8-CM

N	1000
MEAN	3.10E-07
STD DEV	7.26E-07
LOWER 5%	2.10E-08
LOWER 25%	5.79E-08
MEDIAN	1.20E-07
UPPER 25%	2.63E-07
UPPER 5%	1.13E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE A-D8
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
BETA-LPI	1	1.50E-01 (1.0)	2.25E-07 (1.5)	3.50E-09	8.63E-07
LPI-MDP-FS	1	3.00E-03 (3.0)	2.25E-07 (1.5)	3.50E-09	8.63E-07
LPI-MOV-PG-1890C	1	4.40E-04 (11.0)	2.20E-07 (3.0)	6.87E-09	1.48E-07
LPI-MDP-FS-SI1A	4	3.00E-03 (3.0)	1.14E-08 (4.5)	1.10E-10	8.82E-08
LPI-MDP-FS-SI1B	4	3.00E-03 (3.0)	1.14E-08 (4.5)	1.10E-10	8.82E-08
SIS-ACT-FA-SISB	3	1.60E-03 (7.5)	5.28E-09 (6.5)	1.20E-10	2.78E-08
SIS-ACT-FA-SISA	3	1.60E-03 (7.5)	5.28E-09 (6.5)	1.20E-10	2.78E-08
LPI-MDP-MA-SI1A	2	2.00E-03 (5.5)	4.60E-09 (8.5)	4.45E-11	1.69E-08
LPI-MDP-MA-SI1B	2	2.00E-03 (5.5)	4.60E-09 (8.5)	4.45E-11	1.69E-08
LPI-CKV-OO-CV58	1	1.00E-03 (9.5)	1.50E-09 (10.5)	2.51E-11	6.31E-09
LPI-CKV-OO-CV50	1	1.00E-03 (9.5)	1.50E-09 (10.5)	2.51E-11	6.31E-09
RWT-TNK-LF-RWST	1	2.70E-06 (12.0)	1.35E-09 (12.0)	2.77E-11	5.10E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-A	13	5.00E-04 (1.0)	4.69E-07 (1.0)	2.10E-08	1.13E-06

SEQUENCE A-D8
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
RWT-TNK-LF-RWST	1	2.70E-06 (12.0)	5.00E-04 (1.0)	1.33E-04	1.20E-03
LPI-MOV-PG-1890C	1	4.40E-04 (11.0)	5.00E-04 (2.0)	1.33E-04	1.20E-03
LPI-MDP-FS	1	3.00E-03 (3.0)	7.48E-05 (3.0)	9.95E-06	2.12E-04
LPI-MDP-FS-S11A	4	3.00E-03 (3.0)	3.79E-06 (4.5)	5.09E-07	1.17E-05
LPI-MDP-FS-S11B	4	3.00E-03 (3.0)	3.79E-06 (4.5)	5.09E-07	1.17E-05
SIS-ACT-FA-SISB	3	1.60E-03 (7.5)	3.29E-06 (6.5)	3.25E-07	1.12E-05
SIS-ACT-FA-SISA	3	1.60E-03 (7.5)	3.29E-06 (6.5)	3.25E-07	1.12E-05
LPI-MDP-MA-S11A	2	2.00E-03 (5.5)	2.30E-06 (8.5)	1.65E-07	7.64E-06
LPI-MDP-MA-S11B	2	2.00E-03 (5.5)	2.30E-06 (8.5)	1.65E-07	7.64E-06
LPI-CKV-OO-CV58	1	1.00E-03 (9.5)	1.50E-06 (10.5)	3.32E-08	5.90E-06
LPI-CKV-OO-CV50	1	1.00E-03 (9.5)	1.50E-06 (10.5)	3.32E-08	5.90E-06
BETA-LPI	1	1.50E-01 (1.0)	1.28E-06 (12.0)	2.85E-08	4.90E-06

SEQUENCE A-D8
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
LPI-MDP-FS-S11B	4	3.00E-03	(3.0)	52.9	(2.0)	2.47	0.73
LPI-MDP-FS-S11A	4	3.00E-03	(3.0)	52.9	(2.0)	2.47	0.73
LPI-MDP-FS	1	3.00E-03	(3.0)	52.9	(2.0)	2.47	0.73
BETA-LPI	1	1.50E-01	(1.0)	8.0	(4.0)	1.11	1.03
LPI-MOV-PG-1890C	1	4.40E-04	(11.0)	4.9	(5.0)	3.75	1.25
LPI-MDP-MA-S11A	2	2.00E-03	(5.5)	1.2	(6.5)	1.02	1.02
LPI-MDP-MA-S11B	2	2.00E-03	(5.5)	1.2	(6.5)	1.02	1.02
SIS-ACT-FA-SISB	3	1.80E-03	(7.5)	0.6	(8.5)	0.97	1.02
SIS-ACT-FA-SISA	3	1.80E-03	(7.5)	0.6	(8.5)	0.97	1.02
LPI-CKV-OO-CV58	1	1.00E-03	(9.5)	0.4	(10.5)		
LPI-CKV-OO-CV50	1	1.00E-03	(9.5)	0.4	(10.5)		
RWT-TNK-LF-RWST	1	2.70E-06	(12.0)	0.0	(12.0)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-A	13	5.00E-04	(1.0)	30.7	(1.0)	1.98	0.91

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SEQUENCE A-D6

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT A-D6-CM WITH TOP EVENT FREQUENCY 4.69E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	3	2.25E-07	0.47961	BETA-LPI	*	IE-A	*	LPI-MDP-FS	+
3	2	2	2.20E-07	0.94856	IE-A	*	LPI-MOV-PG-1890C	+		
4	3	3	4.50E-09	0.95816	IE-A	*	LPI-MDP-FS-SI1A	*	LPI-MDP-FS-SI1B	+
5	5	3	3.00E-09	0.96455	IE-A	*	LPI-MDP-FS-SI1A	*	LPI-MDP-MA-SI1B	+
6	4	3	3.00E-09	0.97095	IE-A	*	LPI-MDP-FS-SI1B	*	LPI-MDP-MA-SI1A	+
7	7	3	2.40E-09	0.97606	IE-A	*	LPI-MDP-FS-SI1B	*	SIS-ACT-FA-SISA	+
8	6	3	2.40E-09	0.98118	IE-A	*	LPI-MDP-FS-SI1A	*	SIS-ACT-FA-SISB	+
9	9	3	1.60E-09	0.98459	IE-A	*	LPI-MDP-MA-SI1A	*	SIS-ACT-FA-SISB	+
10	8	3	1.60E-09	0.98800	IE-A	*	LPI-MDP-MA-SI1B	*	SIS-ACT-FA-SISA	+
11	11	3	1.50E-09	0.99120	IE-A	*	LPI-CKV-OO-CV58	*	LPI-MDP-FS-SI1A	+
12	10	3	1.50E-09	0.99439	IE-A	*	LPI-CKV-OO-CV50	*	LPI-MDP-FS-SI1B	+
13	12	2	1.35E-09	0.99727	IE-A	*	RWT-TNK-LF-RWST	+		
14	13	3	1.28E-09	1.00000	IE-A	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	

SURRY STEAM GENERATOR TUBE RUPTURE SEQUENCE T7-D1-OD

TOP EVENT T7-D1-OD CONTAINS 22 EVENTS IN 12 CUT SETS

THE FREQUENCY OF TOP EVENT T7-D1-OD IS 1.95E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T7-D1-OD

N	1000
MEAN	2.13E-07
STD DEV	8.64E-07
LOWER 5%	6.57E-09
LOWER 25%	2.76E-08
MEDIAN	7.03E-08
UPPER 25%	1.91E-07
UPPER 5%	7.72E-07

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

5% = 6.57E-09 ***LOG SCALE*** 95% = 7.72E-07
|-----[-----*-----]NM-----|

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SURRY STEAM GENERATOR TUBE RUPTURE SEQUENCE T7-D1-OD
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
RCS-XHE-FO-DPT7D	12	4.00E-01 (1.0)	1.95E-07 (1.0)	6.57E-09	7.72E-07
BETA-2MOV	2	8.80E-02 (3.0)	1.25E-07 (2.5)	5.68E-10	4.34E-07
HPI-MOV-FT	2	3.00E-03 (8.5)	1.25E-07 (2.5)	5.68E-10	4.34E-07
HPI-XHE-FO-UN2S3	5	4.40E-02 (6.0)	8.93E-08 (4.0)	2.29E-09	3.46E-07
HPI-XHE-FO-ALTS3	1	7.40E-02 (4.0)	7.81E-08 (5.0)	3.04E-10	2.88E-07
HPI-CKV-FT-CV410	1	1.00E-04 (16.0)	1.76E-08 (6.5)	4.92E-10	7.05E-08
HPI-CKV-FT-CV25	1	1.00E-04 (16.0)	1.76E-08 (6.5)	4.92E-10	7.05E-08
RWT-TNK-LF-RWST	1	2.70E-06 (21.0)	1.08E-08 (8.0)	1.23E-10	3.98E-08
SIS-ACT-FA-SISA	1	1.60E-03 (10.5)	1.02E-08 (9.5)	5.74E-11	1.06E-07
SIS-ACT-FA-SISB	1	1.60E-03 (10.5)	1.02E-08 (9.5)	5.74E-11	1.06E-07
HPI-XVM-PG-XV24	1	4.00E-05 (20.0)	7.04E-09 (11.0)	1.70E-10	2.77E-08
HPI-XHE-FO-ALTIN	1	5.70E-03 (7.0)	2.28E-09 (12.5)	1.94E-11	8.89E-09
HPI-CKV-FT-CV225	1	1.00E-04 (16.0)	2.28E-09 (12.5)	1.94E-11	8.89E-09
HPI-MOV-FT-1867D	2	3.00E-03 (8.5)	2.16E-09 (14.0)	9.64E-12	7.91E-09
HPI-MDP-FR-1A6HR	1	4.00E-04 (13.0)	1.60E-09 (15.5)	5.94E-11	5.71E-09
HPI-CKV-OO-CV258	1	1.00E-03 (12.0)	1.60E-09 (15.5)	5.94E-11	5.71E-09
ACP-BAC-ST-1H1	1	9.00E-05 (18.5)	1.08E-09 (17.5)	4.82E-12	3.96E-09
ACP-BAC-ST-4KV1H	1	9.00E-05 (18.5)	1.08E-09 (17.5)	4.82E-12	3.96E-09
CPC-XHE-FO-REALN	1	7.00E-02 (5.0)	5.83E-10 (20.0)	6.47E-12	2.27E-09
CPC-STR-PG-6HR	1	1.80E-04 (14.0)	5.83E-10 (20.0)	6.47E-12	2.27E-09
BETA-STR	1	2.63E-01 (2.0)	5.83E-10 (20.0)	6.47E-12	2.27E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T7	12	1.00E-02 (1.0)	1.95E-07 (1.0)	6.57E-09	7.72E-07

SURRY STEAM GENERATOR TUBE RUPTURE SEQUENCE T7-D1-OD
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
RWT-TNK-LF-RWST	1	2.70E-06 (21.0)	4.00E-03 (1.0)	3.87E-04	1.20E-02
HPI-XVM-PG-XV24	1	4.00E-05 (20.0)	1.76E-04 (2.0)	7.23E-06	6.23E-04
HPI-CKV-FT-CV410	1	1.00E-04 (16.0)	1.76E-04 (3.5)	7.23E-06	6.23E-04
HPI-CKV-FT-CV25	1	1.00E-04 (16.0)	1.76E-04 (3.5)	7.23E-06	6.23E-04
HPI-MOV-FT	2	3.00E-03 (8.5)	4.14E-05 (5.0)	1.28E-06	1.62E-04
HPI-CKV-FT-CV225	1	1.00E-04 (16.0)	2.28E-05 (6.0)	3.25E-07	9.25E-05
ACP-BAC-ST-4KV1H	1	9.00E-05 (18.5)	1.20E-05 (7.5)	1.38E-07	4.21E-05
ACP-BAC-ST-1H1	1	9.00E-05 (18.5)	1.20E-05 (7.5)	1.38E-07	4.21E-05
SIS-ACT-FA-SISB	1	1.60E-03 (10.5)	6.39E-06 (9.5)	2.14E-07	2.60E-05
SIS-ACT-FA-SISA	1	1.60E-03 (10.5)	6.39E-06 (9.5)	2.14E-07	2.60E-05
HPI-MDP-FR-1A6HR	1	4.00E-04 (13.0)	4.00E-06 (11.0)	2.30E-07	1.29E-05
CPC-STR-PG-6HR	1	1.80E-04 (14.0)	3.24E-06 (12.0)		
HPI-XHE-FO-UN2S3	5	4.40E-02 (6.0)	1.94E-06 (13.0)	1.05E-07	6.54E-06
HPI-CKV-OO-CV258	1	1.00E-03 (12.0)	1.60E-06 (14.0)	9.92E-08	5.32E-06
BETA-2MOV	2	8.80E-02 (3.0)	1.29E-06 (15.0)	1.12E-08	4.95E-06
HPI-XHE-FO-ALTS3	1	7.40E-02 (4.0)	9.78E-07 (16.0)	8.92E-09	3.75E-06
HPI-MOV-FT-1867D	2	3.00E-03 (8.5)	7.18E-07 (17.0)	2.51E-08	2.63E-06
HPI-XHE-FO-ALTIN	1	5.70E-03 (7.0)	3.98E-07 (18.0)	2.31E-08	1.41E-06
RCS-XHE-FO-DPT7D	12	4.00E-01 (1.0)	2.92E-07 (19.0)	1.07E-08	1.08E-06
CPC-XHE-FO-REALN	1	7.00E-02 (5.0)	7.75E-09 (20.0)	2.31E-10	2.70E-08
BETA-STR	1	2.63E-01 (2.0)	1.63E-09 (21.0)	2.37E-11	6.76E-09

SURRY STEAM GENERATOR TUBE RUPTURE SEQUENCE T7-D1-OD
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
RCS-XHE-FO-DPT7D	12	4.00E-01	(1.0)	32.9	(1.0)	2.01	0.82
HPI-MOV-FT-1867D	2	3.00E-03	(8.5)	19.2	(2.5)	1.61	1.00
HPI-MOV-FT	2	3.00E-03	(8.5)	19.2	(2.5)	1.61	1.00
HPI-XHE-FO-UN2S3	5	4.40E-02	(6.0)	8.7	(4.0)	1.31	0.97
SIS-ACT-FA-SISA	1	1.60E-03	(10.5)	6.3	(5.5)	1.11	0.90
SIS-ACT-FA-SISB	1	1.60E-03	(10.5)	6.3	(5.5)	1.11	0.90
BETA-2MOV	2	8.80E-02	(3.0)	4.8	(7.0)	1.03	0.95
HPI-XHE-FO-ALTS3	1	7.40E-02	(4.0)	3.1	(8.0)	1.09	1.02
HPI-CKV-FT-CV225	1	1.00E-04	(16.0)	2.2	(10.0)	1.12	0.97
HPI-CKV-FT-CV410	1	1.00E-04	(16.0)	2.2	(10.0)	1.12	0.97
HPI-CKV-FT-CV25	1	1.00E-04	(16.0)	2.2	(10.0)	1.12	0.97
RWT-TNK-LF-RWST	1	2.70E-06	(21.0)	1.7	(12.0)	1.05	1.01
ACP-BAC-ST-4KV1H	1	9.00E-05	(18.5)	0.8	(13.5)	1.00	1.00
ACP-BAC-ST-1H1	1	9.00E-05	(18.5)	0.8	(13.5)	1.00	1.00
HPI-CKV-OO-CV258	1	1.00E-03	(12.0)	0.6	(15.0)	1.01	1.00
HPI-XHE-FO-ALTIN	1	5.70E-03	(7.0)	0.6	(16.0)	1.00	1.01
HPI-MDP-FR-1A6HR	1	4.00E-04	(13.0)	0.5	(17.0)		
CPC-XHE-FO-REALN	1	7.00E-02	(5.0)	0.0	(19.0)		
HPI-XVM-PG-XV24	1	4.00E-05	(20.0)	0.0	(19.0)		
BETA-STR	1	2.63E-01	(2.0)	0.0	(19.0)		
CPC-STR-PG-6HR	1	1.80E-04	(14.0)				

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T7	12	1.00E-02	(1.0)	23.4	(1.0)	1.73	0.87

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SURRY STEAM GENERATOR TUBE RUPTURE SEQUENCE T7-D1-OD

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T7-D1-OD WITH TOP EVENT FREQUENCY 1.95E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	5	7.81E-08	0.40175	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALTS3	*	IE-T7	*
3					RCS-XHE-FO-DPT7D	+						
4	2	5	4.65E-08	0.64062	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-UN2S3	*	IE-T7	*
5					RCS-XHE-FO-DPT7D	+						
6	3	4	1.76E-08	0.73110	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S3	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
7	4	4	1.76E-08	0.82159	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S3	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
8	5	3	1.08E-08	0.87711	IE-T7	*	RCS-XHE-FO-DPT7D	*	RWT-TNK-LF-RWST	+		
9	6	4	1.02E-08	0.92976	IE-T7	*	RCS-XHE-FO-DPT7D	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+
10	7	4	7.04E-09	0.96595	HPI-XHE-FO-UN2S3	*	HPI-XVM-PG-XV24	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
11	8	4	2.28E-09	0.97767	HPI-CKV-FT-CV225	*	HPI-XHE-FO-ALT1N	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
12	9	4	1.60E-09	0.98590	HPI-CKV-OO-CV258	*	HPI-MDP-FR-1A6HR	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
13	11	4	1.08E-09	0.99145	ACP-BAC-ST-4KV1H	*	HPI-MOV-FT-1867D	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
14	10	4	1.08E-09	0.99700	ACP-BAC-ST-1H1	*	HPI-MOV-FT-1867D	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
15	12	6	5.83E-10	1.00000	BETA-STR	*	CPC-STR-PG-6HR	*	CPC-XHE-FC-REALN	*	HPI-XHE-FO-UN2S3	*
16					IE-T7	*	RCS-XHE-FO-DPT7D	.				

SEQUENCE T5A-L-P

TOP EVENT T5A-L-P CONTAINS 22 EVENTS IN 25 CUT SETS

THE FREQUENCY OF TOP EVENT T5A-L-P IS 1.38E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T5A-L-P

N	1000
MEAN	1.31E-07
STD DEV	5.85E-07
LOWER 5%	1.12E-09
LOWER 25%	7.40E-09
MEDIAN	2.62E-08
UPPER 25%	8.85E-08
UPPER 5%	4.52E-07

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE T5A-L-P
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
AFW-CCF-LK-STMBD	1	1.00E-04 (16.5)	5.14E-05 (2.0)	8.01E-12	3.45E-08
AFW-PSF-FC-XCONN	1	1.50E-04 (15.0)	5.14E-05 (2.0)	2.85E-10	9.44E-08
AFW-TNK-VF-CST	1	1.00E-08 (21.0)	5.14E-05 (2.0)	1.60E-12	6.54E-10
AFW-MDP-FS-FW3B	4	6.30E-03 (7.0)	3.42E-06 (4.0)	2.43E-10	1.78E-07
AFW-MDP-MA-FW3B	3	2.00E-03 (9.0)	3.36E-06 (6.0)	2.60E-11	5.29E-08
AFW-MDP-FR-3B6HR	3	1.80E-04 (14.0)	3.36E-06 (6.0)	1.83E-12	4.44E-09
AFW-ACT-FA-PMP3B	3	6.00E-04 (13.0)	3.36E-06 (6.0)	1.69E-11	1.60E-08
AFW-XHE-FO-UNIT2	25	3.60E-02 (2.0)	2.34E-06 (8.0)	1.20E-09	4.52E-07
AFW-CKV-OO-CV142	1	1.00E-03 (11.0)	1.65E-06 (9.0)	3.34E-12	6.10E-09
AFW-TDP-FS-FW2	6	1.10E-02 (4.0)	8.91E-07 (10.0)	4.50E-11	6.70E-08
DCP-BDC-ST-BUS1B	1	9.00E-05 (18.5)	8.88E-07 (12.5)	5.67E-13	1.45E-09
ACP-BAC-ST-4KV1J	1	9.00E-05 (18.5)	8.88E-07 (12.5)	5.67E-13	1.45E-09
AFW-XVM-PG-XV183	1	4.00E-05 (20.0)	8.88E-07 (12.5)	4.05E-13	6.29E-10
AFW-CKV-FT-CV172	1	1.00E-04 (18.5)	8.88E-07 (12.5)	1.01E-12	1.80E-09
AFW-TDP-FR-2P6HR	9	3.00E-02 (3.0)	8.40E-07 (15.0)	9.46E-11	1.59E-07
AFW-TDP-MA-FW2	5	1.00E-02 (5.0)	8.27E-07 (16.0)	3.59E-11	5.68E-08
AFW-CKV-OO-CV172	1	1.00E-03 (11.0)	7.55E-07 (17.5)	6.59E-12	4.29E-09
AFW-CKV-OO-CV157	1	1.00E-03 (11.0)	7.55E-07 (17.5)	6.59E-12	4.29E-09
AFW-MDP-FS	3	6.30E-03 (7.0)	1.42E-07 (19.0)	8.28E-12	1.02E-08
AFW-MDP-FS-FW3A	1	6.30E-03 (7.0)	6.40E-08 (20.0)	6.59E-12	4.29E-09
BETA-AFW	3	5.80E-02 (1.0)	4.93E-08 (21.0)	8.28E-12	1.02E-08

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T5A	25	5.00E-03 (1.0)	4.08E-05 (1.0)	1.20E-09	4.52E-07

SEQUENCE T5A-L-P
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
AFW-XHE-FO-UNIT2	25	3.60E-02	(2.0)	7.01E-08	(1.0)	6.18E-08	1.17E-05
AFW-MDP-FS-FW3B	4	6.30E-03	(7.0)	5.02E-08	(2.0)	6.88E-08	2.96E-05
AFW-TDP-FS-FW2	6	1.10E-02	(4.0)	2.86E-08	(3.0)	2.42E-08	6.48E-06
AFW-TDP-FR-2P6HR	9	3.00E-02	(3.0)	1.45E-08	(4.0)	2.03E-08	5.78E-06
AFW-TDP-MA-FW2	5	1.00E-02	(5.0)	1.32E-08	(5.0)	1.88E-08	5.94E-06
AFW-PSF-FC-XCONN	1	1.50E-04	(15.0)	1.08E-08	(6.0)	2.78E-06	6.24E-04
BETA-AFW	3	5.60E-02	(1.0)	2.09E-09	(7.5)	2.10E-10	1.60E-07
AFW-MDP-FS	3	6.30E-03	(7.0)	2.09E-09	(7.5)	2.44E-09	1.51E-08
AFW-MDP-MA-FW3B	3	2.00E-03	(9.0)	2.06E-09	(9.0)	6.31E-08	2.95E-05
AFW-CKV-OO-CV142	1	1.00E-03	(11.0)	2.06E-09	(10.0)	4.97E-09	6.31E-06
AFW-CCF-LK-STMBD	1	1.00E-04	(16.5)	1.07E-09	(11.0)	2.78E-06	6.24E-04
AFW-CKV-OO-CV172	1	1.00E-03	(11.0)	9.40E-10	(13.0)	1.14E-08	4.10E-06
AFW-CKV-OO-CV157	1	1.00E-03	(11.0)	9.40E-10	(13.0)	1.14E-08	4.10E-06
AFW-MDP-FS-FW3A	1	6.30E-03	(7.0)	9.40E-10	(13.0)	1.83E-09	6.71E-07
AFW-MDP-FR-3B6HR	3	1.80E-04	(14.0)	4.30E-10	(15.0)	6.33E-08	2.95E-05
AFW-ACT-FA-PMP3B	3	6.00E-04	(13.0)	1.75E-10	(16.0)	6.33E-08	2.95E-05
AFW-CKV-FT-CV172	1	1.00E-04	(16.5)	1.69E-10	(17.0)	1.45E-08	1.81E-05
AFW-XVM-PG-XV183	1	4.00E-05	(20.0)	3.84E-11	(18.0)	1.45E-08	1.81E-05
AFW-TNK-VF-CST	1	1.00E-06	(21.0)	1.86E-11	(19.0)	2.78E-06	6.24E-04
DCP-BDC-ST-BUS1B	1	9.00E-05	(18.5)	2.98E-12	(20.5)	1.45E-08	1.81E-05
ACP-BAC-ST-4KV1J	1	9.00E-05	(18.5)	2.98E-12	(20.5)	1.45E-08	1.81E-05

SEQUENCE T5A-L-P
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
AFW-XHE-FO-UNIT2	25	3.60E-02 (2.0)	25.3 (1.0)	2.02	0.95
AFW-TDP-FR-2P6HR	9	3.00E-02 (3.0)	7.3 (2.0)	1.35	1.04
AFW-MDP-FS-FW3B	4	6.30E-03 (7.0)	2.5 (4.0)	1.20	1.10
AFW-MDP-FS	3	6.30E-03 (7.0)	2.5 (4.0)	1.20	1.10
AFW-MDP-FS-FW3A	1	6.30E-03 (7.0)	2.5 (4.0)	1.20	1.10
AFW-TDP-FS-FW2	6	1.10E-02 (4.0)	2.5 (6.0)	1.06	0.98
AFW-PSF-FC-XCONN	1	1.50E-04 (15.0)	2.4 (7.0)	1.13	0.93
AFW-CCF-LK-STMBD	1	1.00E-04 (16.5)	1.8 (8.0)	1.28	1.00
AFW-TDP-MA-FW2	5	1.00E-02 (5.0)	1.5 (9.0)	1.13	0.99
AFW-MDP-MA-FW3B	3	2.00E-03 (9.0)	1.0 (10.0)	1.04	1.06
AFW-CKV-FT-CV172	1	1.00E-04 (16.5)	0.9 (11.0)	1.07	1.00
AFW-MDP-FR-3B6HR	3	1.80E-04 (14.0)	0.4 (12.0)		
AFW-CKV-OO-CV172	1	1.00E-03 (11.0)	0.4 (14.0)		
AFW-CKV-OO-CV157	1	1.00E-03 (11.0)	0.4 (14.0)		
AFW-CKV-OO-CV142	1	1.00E-03 (11.0)	0.4 (14.0)		
AFW-ACT-FA-PMP3B	3	6.00E-04 (13.0)	0.2 (16.0)		
DCP-BDC-ST-BUS1B	1	9.00E-05 (18.5)	0.0 (19.0)		
BETA-AFW	3	5.60E-02 (1.0)	0.0 (19.0)		
AFW-XVM-PG-XV183	1	4.00E-05 (20.0)	0.0 (19.0)		
AFW-TNK-VF-CST	1	1.00E-06 (21.0)	0.0 (19.0)		
ACP-BAC-ST-4KV1J	1	9.00E-05 (18.5)	0.0 (19.0)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T5A	25	5.00E-03 (1.0)	57.0 (1.0)	7.86	0.96

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS
 HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT
 IS NOT HELD CONSTANT

SURRY SEQUENCE T5A-L-P

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T5A-L-P WITH TOP EVENT FREQUENCY 1.38E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	4	3.40E-08	0.24697	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
3	2	3	2.70E-08	0.44298	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+		
4	3	3	1.80E-08	0.57365	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+		
5	4	4	1.25E-08	0.66421	AFW-MDP-FS-FW3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
6	5	4	1.13E-08	0.74653	AFW-MDP-FS-FW3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
7	6	4	1.08E-08	0.82493	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
8	7	4	3.96E-09	0.85368	AFW-MDP-MA-FW3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
9	8	4	3.60E-09	0.87982	AFW-MDP-MA-FW3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
10	9	4	3.24E-09	0.90334	AFW-ACT-FA-PMP3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
11	10	4	1.98E-09	0.91771	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
12	11	5	1.91E-09	0.93154	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
13					IE-T5A	+						
14	12	4	1.19E-09	0.94017	AFW-ACT-FA-PMP3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
15	14	4	1.13E-09	0.94840	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
16	13	4	1.13E-09	0.95663	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
17	15	4	1.08E-09	0.96447	AFW-ACT-FA-PMP3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
18	16	4	9.72E-10	0.97153	AFW-MDP-FR-3B6HR	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
19	17	5	6.99E-10	0.97660	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
20					IE-T5A	+						
21	18	5	6.35E-10	0.98121	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
22					IE-T5A	+						
23	19	4	5.40E-10	0.98513	AFW-CKV-FT-CV172	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
24	20	4	4.86E-10	0.98868	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1B	*	IE-T5A	+
25	21	4	4.86E-10	0.99219	ACP-BAC-ST-4KV1J	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
26	22	4	3.56E-10	0.99477	AFW-MDP-FR-3B6HR	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
27	23	4	3.24E-10	0.99713	AFW-MDP-FR-3B6HR	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
28	24	4	2.16E-10	0.99869	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	AFW-XVM-PG-XV183	*	IE-T5A	+
29	25	3	1.80E-10	1.00000	AFW-TNK-VF-CST	*	AFW-XHE-FO-UNIT2	*	IE-T5A			

SEQUENCE T5B-L-P

TOP EVENT T5B-L-P CONTAINS 22 EVENTS IN 25 CUT SETS

THE FREQUENCY OF TOP EVENT T5B-L-P IS 1.38E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T5B-L-P

N	1000
MEAN	1.31E-07
STD DEV	5.85E-07
LOWER 5%	1.12E-09
LOWER 25%	7.40E-09
MEDIAN	2.62E-08
UPPER 25%	8.85E-08
UPPER 5%	4.52E-07

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE T5B-L-P

RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
AFW-CCF-LK-STMBD	1	1.00E-04 (16.5)	5.14E-05 (2.0)	8.01E-12	3.45E-08
AFW-TNK-VF-CST	1	1.00E-06 (21.0)	5.14E-05 (2.0)	1.60E-12	6.54E-10
AFW-PSF-FC-XCONN	1	1.50E-04 (15.0)	5.14E-05 (2.0)	2.85E-10	9.44E-08
AFW-MDP-FS-FW3A	4	6.30E-03 (7.0)	3.42E-08 (4.0)	2.43E-10	1.78E-07
AFW-MDP-MA-FW3A	3	2.00E-03 (9.0)	3.36E-06 (6.0)	2.60E-11	5.29E-08
AFW-ACT-FA-PMP3A	3	6.00E-04 (13.0)	3.36E-06 (6.0)	1.69E-11	1.60E-08
AFW-MDP-FR-3A6HR	3	1.80E-04 (14.0)	3.36E-06 (6.0)	1.83E-12	4.44E-09
AFW-XHE-FO-UNIT2	25	3.60E-02 (2.0)	2.34E-06 (8.0)	1.20E-09	4.52E-07
AFW-CKV-OO-CV142	1	1.00E-03 (11.0)	1.65E-06 (9.0)	3.34E-12	6.10E-09
AFW-TDP-FS-FW2	6	1.10E-02 (4.0)	8.91E-07 (10.0)	4.50E-11	6.70E-08
DCP-BDC-ST-BUS1A	1	9.00E-05 (18.5)	8.88E-07 (12.5)	5.67E-13	1.45E-09
ACP-BAC-ST-4KV1H	1	9.00E-05 (18.5)	8.88E-07 (12.5)	5.67E-13	1.45E-09
AFW-XVM-PG-XV168	1	4.00E-05 (20.0)	8.88E-07 (12.5)	4.05E-13	6.29E-10
AFW-CKV-FT-CV157	1	1.00E-04 (16.5)	8.88E-07 (12.5)	1.01E-12	1.80E-09
AFW-TDP-FR-2P6HR	9	3.00E-02 (3.0)	8.40E-07 (15.0)	9.46E-11	1.59E-07
AFW-TDP-MA-FW2	5	1.00E-02 (5.0)	8.27E-07 (16.0)	3.59E-11	5.68E-08
AFW-CKV-OO-CV172	1	1.00E-03 (11.0)	7.55E-07 (17.5)	6.59E-12	4.29E-09
AFW-CKV-OO-CV157	1	1.00E-03 (11.0)	7.55E-07 (17.5)	6.59E-12	4.29E-09
AFW-MDP-FS	3	6.30E-03 (7.0)	1.42E-07 (19.0)	8.28E-12	1.02E-08
AFW-MDP-FS-FW3B	1	6.30E-03 (7.0)	6.40E-08 (20.0)	6.59E-12	4.29E-09
BETA-AFW	3	5.60E-02 (1.0)	4.93E-08 (21.0)	8.28E-12	1.02E-08

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T5B	25	5.00E-03 (1.0)	4.08E-05 (1.0)	1.20E-09	4.52E-07

SEQUENCE T5B-L-P
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
AFW-XHE-FO-UNIT2	25	3.80E-02 (2.0)	7.01E-08 (1.0)	6.18E-08	1.17E-05
AFW-MDP-FS-FW3A	4	6.30E-03 (7.0)	5.02E-08 (2.0)	6.88E-08	2.96E-05
AFW-TDP-FS-FW2	6	1.10E-02 (4.0)	2.86E-08 (3.0)	2.42E-08	6.48E-06
AFW-TDP-FR-2P6HR	9	3.00E-02 (3.0)	1.45E-08 (4.0)	2.03E-08	5.78E-06
AFW-TDP-MA-FW2	5	1.00E-02 (5.0)	1.32E-08 (5.0)	1.88E-08	5.94E-06
AFW-PSF-FC-XCONN	1	1.50E-04 (15.0)	1.08E-08 (6.0)	2.78E-06	6.24E-04
BETA-AFW	3	5.60E-02 (1.0)	2.09E-09 (7.5)	2.10E-10	1.60E-07
AFW-MDP-FS	3	6.30E-03 (7.0)	2.09E-09 (7.5)	2.44E-09	1.51E-06
AFW-MDP-MA-FW3A	3	2.00E-03 (9.0)	2.06E-09 (9.0)	6.31E-08	2.95E-05
AFW-CKV-OO-CV142	1	1.00E-03 (11.0)	2.06E-09 (10.0)	4.97E-09	6.31E-06
AFW-CCF-LK-STMBD	1	1.00E-04 (16.5)	1.07E-09 (11.0)	2.78E-06	6.24E-04
AFW-CKV-OO-CV172	1	1.00E-03 (11.0)	9.40E-10 (13.0)	1.14E-08	4.10E-06
AFW-CKV-OO-CV157	1	1.00E-03 (11.0)	9.40E-10 (13.0)	1.14E-08	4.10E-06
AFW-MDP-FS-FW3B	1	6.30E-03 (7.0)	9.40E-10 (13.0)	1.63E-09	6.71E-07
AFW-MDP-FR-3A6HR	3	1.80E-04 (14.0)	4.30E-10 (15.0)	6.33E-08	2.95E-05
AFW-ACT-FA-PMP3A	3	6.00E-04 (13.0)	1.75E-10 (16.0)	6.33E-08	2.95E-05
AFW-CKV-FT-CV157	1	1.00E-04 (16.5)	1.89E-10 (17.0)	1.45E-08	1.81E-05
AFW-XVM-PG-XV168	1	4.00E-05 (20.0)	3.84E-11 (18.0)	1.45E-08	1.81E-05
AFW-TNK-VF-CST	1	1.00E-06 (21.0)	1.86E-11 (19.0)	2.78E-06	6.24E-04
DCP-BDC-ST-BUS1A	1	9.00E-05 (18.5)	2.96E-12 (20.5)	1.45E-08	1.81E-05
ACP-BAC-ST-4KV1H	1	9.00E-05 (18.5)	2.96E-12 (20.5)	1.45E-08	1.81E-05

SEQUENCE T5B-L-P
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
AFW-XHE-FO-UNIT2	25	3.60E-02 (2.0)	25.3 (1.0)	2.02	0.95
AFW-TDP-FR-2P6HR	9	3.00E-02 (3.0)	7.3 (2.0)	1.35	1.04
AFW-MDP-FS-FW3B	1	6.30E-03 (7.0)	2.5 (4.0)	1.20	1.10
AFW-MDP-FS	3	6.30E-03 (7.0)	2.5 (4.0)	1.20	1.10
AFW-MDP-FS-FW3A	4	6.30E-03 (7.0)	2.5 (4.0)	1.20	1.10
AFW-TDP-FS-FW2	6	1.10E-02 (4.0)	2.5 (4.0)	1.06	0.98
AFW-PSF-FC-XCONN	1	1.50E-04 (15.0)	2.4 (7.0)	1.13	0.93
AFW-CCF-LK-STMBD	1	1.00E-04 (16.5)	1.8 (8.0)	1.28	1.00
AFW-TDP-MA-FW2	5	1.00E-02 (5.0)	1.5 (9.0)	1.13	0.99
AFW-MDP-MA-FW3A	3	2.00E-03 (9.0)	1.0 (10.0)	1.04	1.06
AFW-CKV-FT-CV157	1	1.00E-04 (16.5)	0.9 (11.0)	1.07	1.00
AFW-MDP-FR-3A6HR	3	1.80E-04 (14.0)	0.4 (12.0)		
AFW-CKV-OO-CV172	1	1.00E-03 (11.0)	0.4 (14.0)		
AFW-CKV-OO-CV157	1	1.00E-03 (11.0)	0.4 (14.0)		
AFW-CKV-OO-CV142	1	1.00E-03 (11.0)	0.4 (14.0)		
AFW-ACT-FA-PMP3A	3	6.00E-04 (13.0)	0.2 (16.0)		
DCP-BDC-ST-BUS1A	1	9.00E-05 (18.5)	0.0 (19.0)		
BETA-AFW	3	5.60E-02 (1.0)	0.0 (19.0)		
AFW-XVM-PG-XV168	1	4.00E-05 (20.0)	0.0 (19.0)		
AFW-TNK-VF-CST	1	1.00E-06 (21.0)	0.0 (19.0)		
ACP-BAC-ST-4KV1H	1	9.00E-05 (18.5)	0.0 (19.0)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T5B	25	5.00E-03 (1.0)	57.0 (1.0)	7.86	0.96

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SURRY SEQUENCE T5B-L-P

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T5B-L-P WITH TOP EVENT FREQUENCY 1.38E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	4	3.40E-08	0.24697	AFW-MDP-FS-FW3A	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
3	2	3	2.70E-08	0.44298	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+		
4	3	3	1.80E-08	0.57365	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+		
5	4	4	1.25E-08	0.66421	AFW-MDP-FS-FW3A	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
6	5	4	1.13E-08	0.74653	AFW-MDP-FS-FW3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
7	6	4	1.08E-08	0.82493	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
8	7	4	3.96E-09	0.85368	AFW-MDP-MA-FW3A	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
9	8	4	3.60E-09	0.87982	AFW-MDP-MA-FW3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
10	9	4	3.24E-09	0.90334	AFW-ACT-FA-PMP3A	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
11	10	4	1.98E-09	0.91771	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
12	11	5	1.91E-09	0.93154	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
13					IE-T5B	+						
14	12	4	1.19E-09	0.94017	AFW-ACT-FA-PMP3A	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
15	14	4	1.13E-09	0.94840	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
16	13	4	1.13E-09	0.95663	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
17	15	4	1.08E-09	0.96447	AFW-ACT-FA-PMP3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
18	16	4	9.72E-10	0.97153	AFW-MDP-FR-3A6HR	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
19	17	5	6.99E-10	0.97660	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
20					IE-T5B	+						
21	18	5	6.35E-10	0.98121	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
22					IE-T5B	+						
23	19	4	5.40E-10	0.98513	AFW-CKV-FT-CV157	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
24	20	4	4.86E-10	0.98868	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1A	*	IE-T5B	+
25	21	4	4.86E-10	0.99219	ACP-BAC-ST-4KV1H	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
26	22	4	3.58E-10	0.99477	AFW-MDP-FR-3A6HR	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
27	23	4	3.24E-10	0.99713	AFW-MDP-FR-3A6HR	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
28	24	4	2.16E-10	0.99869	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	AFW-XVM-PG-XV168	*	IE-T5B	+
29	25	3	1.80E-10	1.00000	AFW-TNK-VF-CST	*	AFW-XHE-FO-UNIT2	*	IE-T5B			

SEQUENCE T7-L3

TOP EVENT T7-L3 CONTAINS 14 EVENTS IN 8 CUT SETS

THE FREQUENCY OF TOP EVENT T7-L3 IS 1.05E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T7-L3

N	1000
MEAN	1.06E-07
STD DEV	2.83E-07
LOWER 5%	4.81E-09
LOWER 25%	1.74E-08
MEDIAN	4.06E-08
UPPER 25%	1.01E-07
UPPER 5%	3.42E-07

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

$$\begin{aligned} \text{RISK REDUCTION} &= \text{PD} \times \text{EV}(\text{J}) \\ &= \text{TEF} - \text{TEF}(\text{EVALUATED WITH EV}(\text{J}) = 0) \end{aligned}$$

2. FOR BASE EVENTS ONLY:

$$\begin{aligned} \text{RISK INCREASE} &= \text{PD} - \text{RISK REDUCTION} \\ &= \text{PD} \times (1 - \text{EV}(\text{J})) \\ &= \text{TEF}(\text{EVALUATED WITH EV}(\text{J}) = 1) - \text{TEF} \end{aligned}$$

SEQUENCE T7-L3
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
AFW-XHE-FO-UNIT2	8	3.80E-02 (2.0)	1.05E-07 (1.0)	4.81E-09	3.42E-07
AFW-PSF-FC-XCONN	1	1.50E-04 (12.0)	5.40E-08 (2.0)	2.87E-09	2.07E-07
AFW-CCF-LK-STMBD	1	1.00E-04 (13.0)	3.60E-08 (3.0)	4.42E-11	9.33E-08
AFW-MDP-FS	3	6.30E-03 (7.0)	6.48E-09 (4.5)	6.09E-11	2.37E-08
BETA-AFW	3	5.60E-02 (1.0)	6.48E-09 (4.5)	8.09E-11	2.37E-08
AFW-TDP-FS-FW2	2	1.10E-02 (4.0)	5.36E-09 (6.0)	4.32E-11	2.05E-08
AFW-CKV-OO-CV142	1	1.00E-03 (10.0)	3.96E-09 (7.0)	3.02E-11	1.54E-08
AFW-TDP-FR-2P6HR	1	3.00E-02 (3.0)	3.81E-09 (8.0)	1.87E-11	1.30E-08
AFW-MDP-FS-FW3B	1	6.30E-03 (7.0)	2.27E-09 (10.5)	7.15E-11	8.22E-09
AFW-MDP-FS-FW3A	1	6.30E-03 (7.0)	2.27E-09 (10.5)	7.15E-11	8.22E-09
AFW-CKV-OO-CV157	1	1.00E-03 (10.0)	2.27E-09 (10.5)	7.15E-11	8.22E-09
AFW-CKV-OO-CV172	1	1.00E-03 (10.0)	2.27E-09 (10.5)	7.15E-11	8.22E-09
AFW-TDP-MA-FW2	1	1.00E-02 (5.0)	1.27E-09 (13.0)	5.11E-12	4.90E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T7	8	1.00E-02 (1.0)	1.05E-07 (1.0)	4.81E-09	3.42E-07

SEQUENCE T7-L3

RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
AFW-CCF-LK-STMBD	1	1.00E-04 (13.0)	3.60E-04 (1.0)	2.98E-05	1.16E-03
AFW-PSF-FC-XCONN	1	1.50E-04 (12.0)	3.60E-04 (2.0)	2.98E-05	1.16E-03
AFW-CKV-OO-CV142	1	1.00E-03 (10.0)	3.96E-06 (3.0)	4.48E-08	1.58E-05
AFW-XHE-FO-UNIT2	8	3.60E-02 (2.0)	2.81E-06 (4.0)	3.32E-07	7.86E-06
AFW-CKV-OO-CV157	1	1.00E-03 (10.0)	2.27E-06 (5.5)	1.13E-07	7.66E-06
AFW-CKV-OO-CV172	1	1.00E-03 (10.0)	2.27E-06 (5.5)	1.13E-07	7.66E-06
AFW-MDP-FS	3	6.30E-03 (7.0)	1.02E-06 (7.0)	1.70E-08	3.80E-06
AFW-TDP-FS-FW2	2	1.10E-02 (4.0)	4.82E-07 (8.0)	2.88E-08	1.61E-06
AFW-MDP-FS-FW3B	1	6.30E-03 (7.0)	3.58E-07 (9.5)	1.71E-08	1.34E-06
AFW-MDP-FS-FW3A	1	6.30E-03 (7.0)	3.58E-07 (9.5)	1.71E-08	1.34E-06
AFW-TDP-MA-FW2	1	1.00E-02 (5.0)	1.26E-07 (11.0)	3.94E-09	4.85E-07
AFW-TDP-FR-2P6HR	1	3.00E-02 (3.0)	1.23E-07 (12.0)	3.91E-09	4.71E-07
BETA-AFW	3	5.60E-02 (1.0)	1.09E-07 (13.0)	2.09E-09	4.25E-07

SEQUENCE T7-L3
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
AFW-XHE-FO-UNIT2	8	3.60E-02	(2.0)	48.9	(1.0)
AFW-PSF-FC-XCONN	1	1.50E-04	(12.0)	12.1	(2.0)
AFW-CCF-LK-STMBD	1	1.00E-04	(13.0)	11.1	(3.0)
AFW-TDP-FS-FW2	2	1.10E-02	(4.0)	1.7	(4.0)
AFW-TDP-FR-2P6HR	1	3.00E-02	(3.0)	1.5	(5.0)
BETA-AFW	3	5.60E-02	(1.0)	1.1	(6.0)
AFW-MDP-FS-FW3B	1	6.30E-03	(7.0)	0.9	(8.0)
AFW-MDP-FS-FW3A	1	6.30E-03	(7.0)	0.9	(8.0)
AFW-MDP-FS	3	6.30E-03	(7.0)	0.9	(8.0)
AFW-TDP-MA-FW2	1	1.00E-02	(5.0)	0.4	(10.0)
AFW-CKV-OO-CV157	1	1.00E-03	(10.0)	0.3	(12.0)
AFW-CKV-OO-CV172	1	1.00E-03	(10.0)	0.3	(12.0)
AFW-CKV-OO-CV142	1	1.00E-03	(10.0)	0.3	(12.0)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)
IE-T7	8	1.00E-02	(1.0)	25.5	(1.0)

SEQUENCE T7-L3

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T7-L WITH TOP EVENT FREQUENCY 1.05E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	3	5.40E-08	0.51442	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T7	+		
3	2	3	3.60E-08	0.85738	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T7	+		
4	3	4	3.96E-09	0.89508	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T7	+
5	4	5	3.81E-09	0.93138	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
6					IE-T7	+						
7	6	4	2.27E-09	0.95299	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T7	+
8	5	4	2.27E-09	0.97459	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T7	+
9	7	5	1.40E-09	0.98790	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
10					IE-T7	+						
11	8	5	1.27E-09	1.00000	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
12					IE-T7	.						

SURRY SEQUENCE T7-OD-Q-QS
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
PPS-SOV-OO-1455C	5	3.00E-02 (12.5)	2.14E-07 (1.5)	4.39E-10	2.52E-07
PPS-SOV-OO-1456	5	3.00E-02 (12.5)	2.14E-07 (1.5)	4.39E-10	2.52E-07
RCS-XHE-FO-DPRT7	10	2.90E-02 (14.0)	1.22E-07 (3.0)		
MSS-SRV-OO-ODSRV	8	1.00E+00 (2.5)	1.03E-07 (4.0)		
SGTR-SGSRV-ODMD1	4	1.00E+00 (2.5)	5.57E-08 (5.0)		
PPS-MOV-FC-OPER	4	2.70E-03 (15.0)	5.19E-08 (6.0)	1.33E-11	2.76E-08
PPS-MOV-OO-1536	3	4.00E-02 (10.5)	3.43E-08 (7.5)	4.23E-10	2.43E-07
PPS-MOV-OO-1535	3	4.00E-02 (10.5)	3.43E-08 (7.5)	4.23E-10	2.43E-07
SGTR-SGADV-ODMD	2	1.00E+00 (2.5)	1.89E-08 (9.5)		
MSS-SOV-OO-ODADV	2	1.00E+00 (2.5)	1.89E-08 (9.5)		
PORV-BLK	4	1.50E-01 (7.5)	1.33E-08 (11.0)	2.72E-10	2.41E-07
SGTR-SGSRV-ODMD2	4	1.50E-01 (7.5)	9.71E-09 (12.0)	1.90E-10	1.70E-07
MSS-XHE-FO-BLOCK	2	6.40E-02 (9.0)	8.82E-09 (13.0)	8.60E-11	7.18E-08
RCS-PORV-ODMD	10	5.00E-01 (8.0)	8.08E-09 (14.0)	8.79E-10	5.04E-07
PORV-NOT-BLK	6	8.50E-01 (5.0)	1.70E-09 (15.0)	3.70E-10	2.57E-07

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T7	10	1.00E-02 (1.0)	2.68E-07 (1.0)	8.79E-10	5.04E-07

SURRY SEQUENCE T7-OD-Q-QS
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
RCS-XHE-FO-DPRT7	10	2.90E-02 (14.0)	4.09E-06 (1.0)		
RCS-PORV-ODMD	10	5.00E-01 (6.0)	1.94E-09 (2.0)	7.02E-10	4.79E-07
PORV-NOT-BLK	6	8.50E-01 (5.0)	1.24E-09 (3.0)	2.04E-11	4.22E-08
PPS-SOV-OO-1456	5	3.00E-02 (12.5)	9.71E-10 (4.5)	8.85E-08	7.16E-06
PPS-SOV-OO-1455C	5	3.00E-02 (12.5)	9.71E-10 (4.5)	8.85E-08	7.16E-06
PPS-MOV-OO-1535	3	4.00E-02 (10.5)	9.01E-10 (6.5)	1.51E-08	5.96E-06
PPS-MOV-OO-1536	3	4.00E-02 (10.5)	9.01E-10 (6.5)	1.51E-08	5.96E-06
SGTR-SGSRV-ODMD2	4	1.50E-01 (7.5)	8.05E-10 (8.0)	2.56E-09	1.10E-06
PORV-BLK	4	1.50E-01 (7.5)	6.96E-10 (9.0)	2.79E-09	1.23E-06
MSS-XHE-FO-BLOCK	2	6.40E-02 (9.0)	4.40E-10 (10.0)	2.45E-09	1.10E-06
PPS-MOV-FC-OPER	4	2.70E-03 (15.0)	1.38E-10 (11.0)	2.51E-08	1.03E-05
SGTR-SGSRV-ODMD1	4	1.00E+00 (2.5)	0.00E+00 (13.5)		
SGTR-SGADV-ODMD	2	1.00E+00 (2.5)	0.00E+00 (13.5)		
MSS-SRV-OO-ODSRV	8	1.00E+00 (2.5)	0.00E+00 (13.5)		
MSS-SOV-OO-ODADV	2	1.00E+00 (2.5)	0.00E+00 (13.5)		

SURRY SEQUENCE T7-OD-Q-QS
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
PPS-SOV-OO-1456	5	3.00E-02	(12.5)	53.0	(1.5)	6.34	0.85
PPS-SOV-OO-1455C	5	3.00E-02	(12.5)	53.0	(1.5)	6.34	0.85
RCS-PORV-ODMD	10	5.00E-01	(6.0)	14.0	(3.0)	1.81	0.94
PPS-MOV-OO-1535	3	4.00E-02	(10.5)	11.3	(4.5)	1.46	1.01
PPS-MOV-OO-1536	3	4.00E-02	(10.5)	11.3	(4.5)	1.46	1.01
PORV-BLK	4	1.50E-01	(7.5)	4.5	(6.0)	1.13	0.94
SGTR-SGSRV-ODMD2	4	1.50E-01	(7.5)	4.0	(7.0)	1.16	1.00
PORV-NOT-BLK	6	8.50E-01	(5.0)	1.0	(8.0)	1.07	0.99
MSS-XHE-FO-BLOCK	2	6.40E-02	(9.0)	1.0	(9.0)	1.04	1.01
PPS-MOV-FC-OPER	4	2.70E-03	(15.0)	0.6	(10.0)	1.05	1.01
SGTR-SGSRV-ODMD1	4	1.00E+00	(2.5)				
SGTR-SGADV-ODMD	2	1.00E+00	(2.5)				
RCS-XHE-FO-DPRT7	10	2.90E-02	(14.0)				
MSS-SRV-OO-ODSRV	8	1.00E+00	(2.5)				
MSS-SOV-OO-ODADV	2	1.00E+00	(2.5)				

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T7	10	1.00E-02	(1.0)	13.0	(1.0)	1.62	0.99

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SURRY SEQUENCE T7-OD-Q-QS

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT T7-OD-Q-QS WITH TOP EVENT FREQUENCY 1.22E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	8	2.61E-08	0.21390	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-OO-1535	*
3					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
4	2	8	2.61E-08	0.42780	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-OO-1536	*
5					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
6	4	8	2.22E-08	0.60961	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-OO-1536	*
7					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
8	3	8	2.22E-08	0.79143	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-OO-1535	*
9					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
10	6	9	9.47E-09	0.86900	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
11					PPS-MOV-OO-1536	*	PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*
12					SGTR-SGADV-ODMD	+						
13	5	9	9.47E-09	0.94658	IE-T7	*	MSS SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
14					PPS-MOV-OO-1535	*	PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*
15					SGTR-SGADV-ODMD	+						
16	7	8	1.76E-09	0.96102	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-FC-OPER	*
17					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
18	8	8	1.76E-09	0.97546	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-FC-OPER	*
19					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
20	10	8	1.50E-09	0.98773	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-FC-OPER	*
21					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
22	9	8	1.50E-09	1.00000	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-FC-OPER	*
23					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	.

SEQUENCE T7-K-R

TOP EVENT T7-K-R CONTAINS 3 EVENTS IN 1 CUT SETS

THE FREQUENCY OF TOP EVENT T7-K-R IS 1.02E-07

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT T7-K-R

N	1000
MEAN	1.04E-07
STD DEV	2.50E-07
LOWER 5%	3.24E-09
LOWER 25%	1.29E-08
MEDIAN	3.41E-08
UPPER 25%	9.12E-08
UPPER 5%	4.04E-07

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SEQUENCE T7-K-R
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
K	1	6.00E-05 (2.0)	1.02E-07 (1.5)	3.24E-09	4.04E-07
R	1	1.70E-01 (1.0)	1.02E-07 (1.5)	3.24E-09	4.04E-07

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T7	1	1.00E-02 (1.0)	1.02E-07 (1.0)	3.24E-09	4.04E-07

SEQUENCE T7-K-R
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
K	1	8.00E-05 (2.0)	1.70E-03 (1.0)	1.41E-04	5.83E-03
R	1	1.70E-01 (1.0)	4.98E-07 (2.0)	3.53E-08	1.85E-06

SEQUENCE T7-K-R
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)
K	1	6.00E-05 (2.0)	43.6 (1.0)
R	1	1.70E-01 (1.0)	38.0 (2.0)

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)
IE-T7	1	1.00E-02 (1.0)	21.4 (1.0)

SEQUENCE T7-K-R

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
FOR TOP EVENT T7-K-R WITH TOP EVENT FREQUENCY 1.02E-07

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	3	1.02E-07	1.00000	1E-17	* K	* R
---	---	---	----------	---------	-------	-----	-----

PLANT DAMAGE STATE GROUP PDS1

TOP EVENT PDS1 CONTAINS 53 EVENTS IN 2148 CUT SETS

THE FREQUENCY OF TOP EVENT PDS1 IS 1.66E-05

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT PDS1

N	1000
MEAN	2.21E-05
STD DEV	4.54E-05
LOWER 5%	6.10E-07
LOWER 25%	3.20E-06
MEDIAN	8.21E-08
UPPER 25%	2.04E-05
UPPER 5%	9.47E-05

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

PLANT DAMAGE STATE GROUP PDS1
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NOTQ	2021	9.73E-01	(2.0)	1.43E-05 (1.0)		
NOTL-SBOU1	1304	9.83E-01	(1.0)	1.33E-05 (2.0)		
NRAC-7HR	974	5.00E-02	(25.0)	8.02E-06 (3.0)	2.64E-07	4.22E-05
NOTW2	54	8.15E-01	(5.0)	7.15E-06 (4.0)		
REC-XHE-FO-DGHWB	148	6.00E-01	(8.0)	6.88E-06 (5.0)	2.16E-07	3.66E-05
OEP-DGN-FS-DG01	617	2.20E-02	(32.5)	6.49E-06 (6.0)	1.62E-07	3.70E-05
REC-XHE-FO-DGHWS	1407	8.00E-01	(8.0)	5.98E-06 (7.0)	0.00E+00	2.97E-05
RCP-LOCA-750-90M	262	5.30E-01	(9.0)	5.20E-06 (8.0)	0.00E+00	3.16E-05
NRAC-216M	200	1.38E-01	(18.0)	5.00E-06 (9.0)	0.00E+00	2.99E-05
OEP-DGN-FS	232	2.20E-02	(32.5)	4.41E-06 (10.0)	1.55E-07	1.64E-05
OEP-DGN-FS-DG03	462	2.20E-02	(32.5)	3.51E-06 (11.0)	8.59E-08	1.94E-05
OEP-DGN-FS-DG02	461	2.20E-02	(32.5)	3.49E-06 (12.0)	8.54E-08	1.94E-05
NOTL-SBOU1U2	841	9.68E-01	(3.0)	3.23E-06 (13.0)		
OEP-DGN-FR-6HDG1	588	1.20E-02	(40.0)	3.21E-06 (14.0)	1.92E-08	2.37E-05
REC-XHE-FO-SCOOL	589	1.25E-01	(20.0)	2.88E-06 (15.0)	3.67E-08	1.61E-05
BETA-3DG	27	1.80E-02	(35.0)	2.63E-06 (16.0)	6.96E-08	1.07E-05
NRAC-1HR	124	4.40E-01	(13.0)	2.27E-06 (17.5)	1.17E-08	9.56E-06
SBO-PORV-DMD	124	4.50E-01	(12.0)	2.27E-06 (17.5)	1.17E-08	9.56E-06
REC-XHE-FO-DGEN	118	9.00E-01	(4.0)	2.26E-06 (19.0)	1.17E-08	9.38E-06
OEP-DGN-FR-6HDG3	424	1.20E-02	(40.0)	1.85E-06 (20.0)	1.10E-08	1.40E-05
BETA-2DG	205	3.80E-02	(27.0)	1.78E-06 (21.5)	6.15E-08	6.88E-06
NOTDG-CCF	205	5.20E-01	(10.0)	1.78E-06 (21.5)		
OEP-DGN-FR-6HDG2	416	1.20E-02	(40.0)	1.61E-06 (23.0)	9.44E-09	1.14E-05
OEP-DGN-MA-DG01	362	8.00E-03	(43.0)	1.48E-06 (24.0)	1.08E-08	6.09E-06
MCW-CCF-VF-SBO	570	6.00E-02	(24.0)	1.38E-06 (25.0)	1.51E-08	7.82E-06
PPS-SOV-OO-1456	62	3.00E-02	(29.5)	1.13E-06 (26.5)	5.86E-09	4.78E-06
PPS-SOV-OO-1455C	62	3.00E-02	(29.5)	1.13E-06 (26.5)	5.86E-09	4.78E-06
RCP-LOCA-467-150	262	1.27E-01	(19.0)	9.74E-07 (28.0)	0.00E+00	6.42E-06
NRAC-258M	200	1.08E-01	(23.0)	9.38E-07 (29.0)	0.00E+00	6.18E-06
OEP-CRB-FT-15H3	396	3.00E-03	(48.0)	9.19E-07 (30.0)	6.84E-09	3.42E-06
OEP-DGN-MA-DG02	259	6.00E-03	(43.0)	8.14E-07 (31.0)	5.86E-09	3.30E-06
OEP-DGN-MA-DG03	257	6.00E-03	(43.0)	7.72E-07 (32.0)	5.62E-09	3.12E-06
NSLOCA	134	2.70E-01	(14.5)	7.08E-07 (33.0)	0.00E+00	3.86E-06
OEP-CRB-FT-15J3	265	3.00E-03	(48.0)	5.11E-07 (34.0)	3.64E-09	2.12E-06
REC-XHE-FO-DGTMB	18	5.00E-01	(11.0)	2.78E-07 (35.0)	6.63E-10	9.35E-07
NRAC-201M	62	1.50E-01	(17.0)	1.95E-07 (36.0)	0.00E+00	1.00E-06
REC-XHE-FO-DGTMS	217	7.00E-01	(7.0)	1.68E-07 (37.0)	0.00E+00	6.86E-07
OEP-DGN-FR-DG01	22	2.00E-03	(51.0)	9.72E-08 (38.0)	1.49E-10	3.39E-07
NRAC-246M	262	1.15E-01	(22.0)	6.74E-08 (39.0)	0.00E+00	1.60E-07
RCP-LOCA-1440-90	262	4.30E-03	(45.0)	6.40E-08 (40.5)	0.00E+00	0.00E+00
NRAC-150M	262	2.10E-01	(18.0)	6.40E-08 (40.5)	0.00E+00	0.00E+00
RCP-LOCA-183-210	262	1.61E-02	(36.5)	5.70E-08 (42.5)	0.00E+00	0.00E+00
RCP-LOCA-183-150	262	1.61E-02	(36.5)	5.70E-08 (42.5)	0.00E+00	0.00E+00
OEP-DGN-FR-DG02	14	2.00E-03	(51.0)	5.13E-08 (44.0)	8.00E-11	1.78E-07
OEP-DGN-FR-DG03	12	2.00E-03	(51.0)	5.06E-08 (45.0)	8.06E-11	1.76E-07
RCP-LOCA-183-90	262	1.40E-02	(38.0)	4.97E-08 (46.0)	0.00E+00	0.00E+00
RCP-LOCA-561-150	262	4.00E-03	(46.0)	3.27E-08 (47.0)	0.00E+00	0.00E+00

E-239

OEP-CRB-FT-25H3	106	3.00E-03 (48.0)	2.46E-08 (48.0)	2.20E-11	1.45E-07
NRAC-234M	62	1.23E-01 (21.0)	1.21E-09 (49.0)	0.00E+00	0.00E+00
QS-SBO	2145	2.70E-01 (14.5)	-5.62E-09 (50.0)	-2.33E-07	7.23E-08
O	1288	4.80E-02 (26.0)	-1.55E-08 (51.0)	-2.20E-07	8.02E-08
DGN-FTO	1252	3.39E-02 (28.0)	-4.11E-07 (52.0)	-2.29E-08	-5.65E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T1	2146	7.70E-02 (1.0)	1.66E-05 (1.0)	6.10E-07	9.47E-05

PLANT DAMAGE STATE GROUP PDS1
RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
OEP-CRB-FT-15H3	398	3.00E-03	(48.0)	3.05E-04	(1.0)	1.86E-05	1.00E-03
OEP-DGN-FS-DG01	617	2.20E-02	(32.5)	2.89E-04	(2.0)	1.48E-05	9.30E-04
OEP-DGN-FR-8HDG1	568	1.20E-02	(40.0)	2.64E-04	(3.0)	1.43E-05	8.47E-04
OEP-DGN-MA-DG01	362	6.00E-03	(43.0)	2.48E-04	(4.0)	1.25E-05	8.55E-04
OEP-DGN-FS	232	2.20E-02	(32.5)	1.96E-04	(5.0)	1.23E-05	5.96E-04
OEP-CRB-FT-15J3	265	3.00E-03	(48.0)	1.70E-04	(6.0)	1.13E-05	5.71E-04
OEP-DGN-FS-DG03	462	2.20E-02	(32.5)	1.56E-04	(7.0)	7.85E-06	5.15E-04
OEP-DGN-FS-DG02	461	2.20E-02	(32.5)	1.55E-04	(8.0)	7.84E-06	5.15E-04
OEP-DGN-FR-8HDG3	424	1.20E-02	(40.0)	1.52E-04	(9.0)	9.13E-06	4.95E-04
NRAC-7HR	974	5.00E-02	(25.0)	1.52E-04	(10.0)	6.19E-06	8.40E-04
BETA-3DG	27	1.80E-02	(35.0)	1.43E-04	(11.0)	5.93E-06	4.91E-04
OEP-DGN-MA-DG02	259	6.00E-03	(43.0)	1.35E-04	(12.0)	7.02E-06	4.80E-04
OEP-DGN-FR-8HDG2	418	1.20E-02	(40.0)	1.33E-04	(13.0)	6.68E-06	4.28E-04
OEP-DGN-MA-DG03	257	6.00E-03	(43.0)	1.28E-04	(14.0)	6.55E-06	4.63E-04
OEP-DGN-FR-DG01	22	2.00E-03	(51.0)	4.85E-05	(15.0)	3.58E-07	1.79E-04
BETA-2DG	205	3.80E-02	(27.0)	4.51E-05	(16.0)	2.17E-06	1.53E-04
PPS-SOV-OO-1455C	62	3.00E-02	(29.5)	3.67E-05	(17.5)	1.37E-06	1.77E-04
PPS-SOV-OO-1456	62	3.00E-02	(29.5)	3.67E-05	(17.5)	1.37E-06	1.77E-04
NRAC-216M	200	1.38E-01	(18.0)	3.13E-05	(18.0)	0.00E+00	1.96E-04
OEP-DGN-FR-DG02	14	2.00E-03	(51.0)	2.56E-05	(20.0)	1.82E-07	9.71E-05
OEP-DGN-FR-DG03	12	2.00E-03	(51.0)	2.53E-05	(21.0)	1.83E-07	9.02E-05
MCW-CCF-VF-SBO	570	6.00E-02	(24.0)	2.16E-05	(22.0)	4.43E-07	1.26E-04
REC-XHE-FO-SCOO	589	1.25E-01	(20.0)	2.02E-05	(23.0)	3.86E-07	1.10E-04
RCP-LOCA-1440-90	282	4.30E-03	(45.0)	1.48E-05	(24.0)	5.15E-07	7.58E-05
OEP-CRB-FT-25H3	106	3.00E-03	(48.0)	8.19E-06	(25.0)	3.00E-08	4.93E-05
RCP-LOCA-561-150	262	4.00E-03	(46.0)	8.14E-06	(26.0)	3.59E-07	4.29E-05
NRAC-259M	200	1.08E-01	(23.0)	7.75E-06	(27.0)	0.00E+00	5.03E-05
RCP-LOCA-487-150	262	1.27E-01	(19.0)	6.70E-06	(28.0)	0.00E+00	3.68E-05
RCP-LOCA-750-90M	262	5.30E-01	(9.0)	4.61E-06	(29.0)	0.00E+00	2.89E-05
REC-XHE-FO-DGHWB	148	6.00E-01	(8.0)	4.59E-06	(30.0)	6.18E-08	2.27E-05
RCP-LOCA-183-90	262	1.40E-02	(38.0)	3.50E-06	(31.0)	1.28E-07	2.03E-05
RCP-LOCA-183-210	262	1.61E-02	(36.5)	3.49E-06	(32.5)	8.75E-08	1.99E-05
RCP-LOCA-183-150	262	1.61E-02	(36.5)	3.49E-06	(32.5)	9.22E-08	2.03E-05
NRAC-1HR	124	4.40E-01	(13.0)	2.89E-06	(34.0)	1.46E-08	1.12E-05
SBO-PORV-DMD	124	4.50E-01	(12.0)	2.77E-06	(35.0)	1.31E-08	1.29E-05
NSLOCA	134	2.70E-01	(14.5)	1.91E-06	(36.0)	0.00E+00	1.03E-05
NOTDG-CCF	205	5.20E-01	(10.0)	1.84E-06	(37.0)		
NOTW2	54	8.15E-01	(5.0)	1.62E-06	(38.0)		
REC-XHE-FO-DGHWS	1407	8.00E-01	(6.0)	1.49E-06	(39.0)	0.00E+00	7.99E-06
NRAC-201M	62	1.50E-01	(17.0)	1.11E-06	(40.0)	0.00E+00	6.36E-06
NRAC-246M	262	1.15E-01	(22.0)	5.18E-07	(41.0)	0.00E+00	1.30E-06
NOTQ	2021	9.73E-01	(2.0)	3.96E-07	(42.0)		
REC-XHE-FO-DGTMB	18	5.00E-01	(11.0)	2.78E-07	(43.0)	5.61E-10	1.14E-06
REC-XHE-FO-DGEN	118	9.00E-01	(4.0)	2.51E-07	(44.0)	3.10E-10	1.01E-06
NRAC-150M	262	2.10E-01	(16.0)	2.41E-07	(45.0)	0.00E+00	0.00E+00
NOTL-SBOU1U2	841	9.68E-01	(3.0)	1.07E-07	(46.0)		
NOTL-SBOU1	1304	9.93E-01	(1.0)	9.40E-08	(47.0)		

REC-XHE-FO-DGTMS	217	7.00E-01	(7.0)	7.11E-08	(48.0)	0.00E+00	2.45E-07
NRAC-234M	62	1.23E-01	(21.0)	8.62E-08	(49.0)	0.00E+00	0.00E+00
QS-SBO	2145	2.70E-01	(14.5)	-1.52E-08	(50.0)	-3.73E-07	2.44E-07
O	1268	4.90E-02	(26.0)	-3.01E-07	(51.0)	-4.11E-06	1.42E-06
DGN-FTO	1252	3.39E-02	(28.0)	-1.17E-05	(52.0)	-7.11E-05	-3.16E-07

PLANT DAMAGE STATE GROUP PDS1
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y. 05/TE. 05*	Y. 95/TE. 95*
OEP-DGN-FS-DG01	617	2.20E-02	(32.5)	24.2	(2.5)	1.79	0.64
OEP-DGN-FS-DG02	461	2.20E-02	(32.5)	24.2	(2.5)	1.79	0.64
OEP-DGN-FS-DG03	462	2.20E-02	(32.5)	24.2	(2.5)	1.79	0.64
OEP-DGN-FS	232	2.20E-02	(32.5)	24.2	(2.5)	1.79	0.64
OEP-DGN-FR-6HDG3	424	1.20E-02	(40.0)	17.1	(6.0)	1.55	0.72
OEP-DGN-FR-6HDG1	588	1.20E-02	(40.0)	17.1	(6.0)	1.55	0.72
OEP-DGN-FR-6HDG2	418	1.20E-02	(40.0)	17.1	(6.0)	1.55	0.72
OEP-DGN-FR-DG02	14	2.00E-03	(51.0)	16.7	(9.0)	1.03	1.00
OEP-DGN-FR-DG03	12	2.00E-03	(51.0)	16.7	(9.0)	1.03	1.00
OEP-DGN-FR-DG01	22	2.00E-03	(51.0)	16.7	(9.0)	1.03	1.00
REC-XHE-FO-DGTMB	18	5.00E-01	(11.0)	8.8	(11.0)	0.99	1.00
REC-XHE-FO-DGHWS1407	1407	8.00E-01	(6.0)	8.8	(12.0)	1.11	0.98
REC-XHE-FO-DGEN	119	9.00E-01	(4.0)	8.8	(13.0)	0.99	1.00
REC-XHE-FO-DGHWB	148	8.00E-01	(8.0)	8.8	(14.0)	1.20	0.99
NRAC-7HR	974	5.00E-02	(25.0)	8.4	(15.0)	1.26	1.00
REC-XHE-FO-DGTMS	217	7.00E-01	(7.0)	8.4	(16.0)	1.00	1.00
NRAC-258M	200	1.08E-01	(23.0)	8.2	(17.0)	1.06	1.00
NRAC-201M	62	1.50E-01	(17.0)	8.2	(18.0)	1.00	1.01
NRAC-234M	62	1.23E-01	(21.0)	8.1	(19.0)	1.00	1.00
NRAC-1HR	124	4.40E-01	(13.0)	8.1	(20.0)	1.02	1.00
NRAC-218M	200	1.38E-01	(18.0)	8.0	(21.0)	1.03	0.98
NRAC-150M	262	2.10E-01	(16.0)	8.0	(22.0)	1.00	1.00
NRAC-248M	262	1.15E-01	(22.0)	7.9	(23.0)	1.01	1.00
NSLOCA	134	2.70E-01	(14.5)	3.8	(24.0)	0.98	1.03
OEP-DGN-MA-DG03	257	6.00E-03	(43.0)	3.3	(26.0)	1.12	0.89
OEP-DGN-MA-DG02	259	6.00E-03	(43.0)	3.3	(26.0)	1.12	0.89
OEP-DGN-MA-DG01	362	6.00E-03	(43.0)	3.3	(26.0)	1.12	0.89
RCP-LOCA-750-90M	262	5.30E-01	(9.0)	2.2	(28.0)	1.15	0.93
PPS-SOV-OO-1456	62	3.00E-02	(29.5)	2.0	(29.5)	1.24	0.89
PPS-SOV-OO-1455C	62	3.00E-02	(29.5)	2.0	(29.5)	1.24	0.89
QS-SBO	2145	2.70E-01	(14.5)	1.9	(31.0)	1.00	1.00
OEP-CRB-FT-25H3	106	3.00E-03	(48.0)	1.5	(33.0)	1.02	0.96
OEP-CRB-FT-15J3	265	3.00E-03	(48.0)	1.5	(33.0)	1.02	0.96
OEP-CRB-FT-15H3	396	3.00E-03	(48.0)	1.5	(33.0)	1.02	0.96
REC-XHE-FO-SCOOL	589	1.25E-01	(20.0)	1.2	(35.0)	1.06	0.97
BETA-3DG	27	1.80E-02	(35.0)	1.2	(36.0)	1.06	0.98
BETA-2DG	205	3.80E-02	(27.0)	1.1	(37.0)	1.01	1.01
O	1288	4.90E-02	(26.0)	1.0	(38.0)	1.00	1.00
SBO-PORV-DMD	124	4.50E-01	(12.0)	0.9	(39.0)	0.99	0.92
RCP-LOCA-183-150	262	1.61E-02	(36.5)	0.3	(40.0)		
RCP-LOCA-467-150	262	1.27E-01	(19.0)	0.2	(41.0)		
RCP-LOCA-1440-90	262	4.30E-03	(45.0)	0.2	(42.0)		
RCP-LOCA-561-150	262	4.00E-03	(46.0)	0.1	(43.0)		
RCP-LOCA-183-90	262	1.40E-02	(38.0)	0.0	(44.0)		
RCP-LOCA-183-210	262	1.61E-02	(36.5)	0.0	(45.0)		
DGN-FTO	1252	3.39E-02	(28.0)	0.0	(46.5)		
MCW-CCF-VF-SBO	570	6.00E-02	(24.0)	0.0	(46.5)		

NOTL-SBOU1U2	841	9.68E-01	(3.0)
NOTL-SBOU1	1304	9.93E-01	(1.0)
NOTDG-CCF	205	5.20E-01	(10.0)
NOTW2	54	8.15E-01	(5.0)
NOTQ	2021	9.73E-01	(2.0)

 UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T1	2146	7.70E-02 (1.0)	30.0 (1.0)	2.03	0.88

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS
 HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT
 IS NOT HELD CONSTANT

PLANT DAMAGE STATE GROUP PDS1

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT PDS1 WITH TOP EVENT FREQUENCY 1.66E-05

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	55	10	1.17E-06	0.07046	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
3					NRAC-216M	* /O	* OEP-DGN-FS	* /QS-SBO	*
4					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		*
5	2	10	6.21E-07	0.10796	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
6					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
7					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
8	1	10	6.21E-07	0.14546	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
9					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
10					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
11	3	10	5.77E-07	0.18033	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
12					NOTQ	* NOTW2	* NRAC-7HR	* OEP-DGN-FS	*
13					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
14	56	9	4.54E-07	0.20773	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
15					NRAC-216M	* OEP-DGN-FS	* QS-SBO	* RCP-LOCA-750-90M	*
16					REC-XHE-FO-DGHWS	+			*
17	7	10	3.39E-07	0.22818	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
18					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
19					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
20	5	10	3.39E-07	0.24864	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
21					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
22					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
23	4	10	3.39E-07	0.26909	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
24					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
25					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
26	6	10	3.39E-07	0.28955	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
27					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
28					/QS-SBO	* REC-XHE-FO-DGHWB	+		*
29	8	9	3.08E-07	0.30814	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
30					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
31					/QS-SBO	+			*
32	9	10	2.30E-07	0.32201	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
33					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
34					QS-SBO	* REC-XHE-FO-DGHWB	+		*
35	10	10	2.30E-07	0.33589	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
36					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
37					QS-SBO	* REC-XHE-FO-DGHWB	+		*
38	255	10	2.19E-07	0.34910	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
39					NRAC-258M	* /O	* OEP-DGN-FS	* /QS-SBO	*
40					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+		*
41	11	10	2.14E-07	0.36199	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
42					NOTQ	* NOTW2	* NRAC-7HR	* OEP-DGN-FS	*
43					QS-SBO	* REC-XHE-FO-DGHWB	+		*
44	12	10	1.85E-07	0.37315	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
45					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG2	*
46					/QS-SBO	* REC-XHE-FO-DGHWB	+		*

47	57	12	1.77E-07	0.38382	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
48					NRAC-218M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	*
49					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
50	58	12	1.77E-07	0.39449	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	+
51					NRAC-218M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	*
52					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
53	13	10	1.89E-07	0.40472	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	+
54					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
55					/QS-SBO	* REC-XHE-FO-DGHWB	+		
56	15	10	1.89E-07	0.41494	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
57					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	*
58					/QS-SBO	* REC-XHE-FO-DGHWB	+		
59	18	10	1.89E-07	0.42517	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
60					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
61					/QS-SBO	* REC-XHE-FO-DGHWB	+		
62	14	10	1.89E-07	0.43540	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
63					NOTW2	* NRAC-7HR	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	*
64					/QS-SBO	* REC-XHE-FO-DGHWB	+		
65	58	12	1.64E-07	0.44532	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
66					NOTQ	* NRAC-218M	* /O	* OEP-DGN-FS	*
67					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
68	1579	10	1.61E-07	0.45507	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
69					NRAC-7HR	* NSLOCA	* /O	* OEP-DGN-FS	*
70					/QS-SBO	* REC-XHE-FO-DGHWB	+		
71	1458	10	1.40E-07	0.46350	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
72					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*
73					REC-XHE-FO-DGEN	+			
74	1457	10	1.40E-07	0.47192	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
75					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
76					REC-XHE-FO-DGEN	+			
77	1456	10	1.40E-07	0.48035	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
78					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1456	* /QS-SBO	*
79					REC-XHE-FO-DGEN	+			
80	1455	10	1.40E-07	0.48878	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
81					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1456	* /QS-SBO	*
82					REC-XHE-FO-DGEN	+			
83	1460	10	1.30E-07	0.49861	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
84					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1456	* /QS-SBO	*
85					REC-XHE-FO-DGEN	+			
86	1459	10	1.30E-07	0.50445	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
87					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1455C	* /QS-SBO	*
88					REC-XHE-FO-DGEN	+			
89	20	10	1.25E-07	0.51201	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
90					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG02	*
91					QS-SBO	* REC-XHE-FO-DGHWB	+		
92	18	10	1.25E-07	0.51958	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
93					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG2	* OEP-DGN-FS-DG01	*
94					QS-SBO	* REC-XHE-FO-DGHWB	+		
95	17	10	1.25E-07	0.52714	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
96					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG1	* OEP-DGN-FS-DG03	*
97					QS-SBO	* REC-XHE-FO-DGHWB	+		
98	19	10	1.25E-07	0.53471	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
99					NOTW2	* NRAC-7HR	* OEP-DGN-FR-6HDG3	* OEP-DGN-FS-DG01	*
100					QS-SBO	* REC-XHE-FO-DGHWB	+		
101	1462	9	1.15E-07	0.54187	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	*
102					OEP-DGN-FS	* PPS-SOV-OO-1455C	* /QS-SBO	* REC-XHE-FO-DGEN	*

103					SBO-PORV-DMD	+							
104	1461	9	1.15E-07	0.54862	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NRAC-1HR	*	
105					OEP-DGN-FS	*	PPS-SOV-OO-1458	*	/QS-SBO	*	REC-XHE-FO-DGEN	*	
106					SBO-PORV-DMD	+							
107	21	9	1.14E-07	0.55550	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
108					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	
109					QS-SBO	+							
110	61	12	9.63E-08	0.56132	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
111					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	
112					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
113	60	12	9.63E-08	0.56714	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
114					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	
115					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
116	62	12	9.63E-08	0.57296	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
117					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	
118					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
119	63	12	9.63E-08	0.57878	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
120					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	
121					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+	
122	22	10	9.24E-08	0.58436	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
123					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	
124					/QS-SBO	*	REC-XHE-FO-DGHWB	+					
125	23	10	9.24E-08	0.58994	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
126					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	
127					/QS-SBO	*	REC-XHE-FO-DGHWB	+					
128	256	9	8.51E-08	0.59507	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	
129					NRAC-258M	*	OEP-DGN-FS	*	QS-SBO	*	RCP-LOCA-467-150	*	
130					REC-XHE-FO-DGHWS	+							
131	65	12	8.48E-08	0.60020	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*	
132					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*	
133					OEP-DGN-FS-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	
134	64	12	8.48E-08	0.60532	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*	
135					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*	
136					OEP-DGN-FS-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	
137	25	10	8.47E-08	0.61043	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
138					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	
139					/QS-SBO	*	REC-XHE-FO-DGHWB	+					
140	26	10	8.47E-08	0.61554	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
141					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	
142					/QS-SBO	*	REC-XHE-FO-DGHWB	+					
143	24	10	8.47E-08	0.62068	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
144					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	
145					/QS-SBO	*	REC-XHE-FO-DGHWB	+					
146	66	12	7.88E-08	0.62542	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*	
147					NOTL-SBOU1	*	NOTQ	*	NRAC-216M	*	/O	*	
148					OEP-DGN-FS	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	
149	27	10	7.70E-08	0.63007	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
150					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	
151					/QS-SBO	*	REC-XHE-FO-DGTMB	+					
152	28	10	7.70E-08	0.63472	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
153					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	
154					/QS-SBO	*	REC-XHE-FO-DGTMB	+					
155	29	9	7.70E-08	0.63936	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	
156					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3	*	
157					/QS-SBO	+							
158	30	9	7.70E-08	0.64401	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*	

159					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-8HDG1	*
160					/QS-SBO	+						
161	68	11	6.87E-08	0.64816	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
162					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
163					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		*
164	67	11	6.87E-08	0.65231	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
165					NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
166					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		*
167	31	10	6.83E-08	0.65644	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
168					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-8HDG1	*	OEP-DGN-FR-8HDG2	*
169					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
170	69	11	6.57E-08	0.66041	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
171					NRAC-216M	*	/O	*	OEP-DGN-FR-8HDG1	*	OEP-DGN-FR-8HDG3	*
172					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOL	+		*
173	1713	10	6.53E-08	0.66435	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
174					NRAC-201M	*	O	*	OEP-DGN-FS	*	/QS-SBO	*
175					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+				*
176	70	11	6.39E-08	0.66821	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
177					NOTQ	*	NRAC-216M	*	OEP-DGN-FS	*	QS-SBO	*
178					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		*
179	1580	9	6.28E-08	0.67200	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
180					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS	*	QS-SBO	*
181					REC-XHE-FO-DGHWB	+						*
182	32	10	6.26E-08	0.67579	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
183					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*
184					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
185	33	10	6.26E-08	0.67957	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
186					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*
187					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
188	34	10	6.26E-08	0.68335	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
189					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*
190					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
191	35	10	6.26E-08	0.68713	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
192					NOTW2	*	NRAC-7HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
193					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
194	71	12	5.26E-08	0.69031	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
195					NRAC-216M	*	/O	*	OEP-DGN-FR-8HDG1	*	OEP-DGN-FR-8HDG2	*
196					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
197	1528	10	5.16E-08	0.69343	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
198					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1458	*	QS-SBO	*
199					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				*
200	1530	10	5.16E-08	0.69654	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
201					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
202					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				*
203	1532	10	5.16E-08	0.69986	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
204					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1455C	*	QS-SBO	*
205					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				*
206	1531	10	5.16E-08	0.70278	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
207					OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	PPS-SOV-OO-1458	*	QS-SBO	*
208					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				*
209	75	12	4.82E-08	0.70569	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
210					NRAC-216M	*	/O	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*
211					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
212	72	12	4.82E-08	0.70859	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
213					NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*
214					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+

215	73	12	4.82E-08	0.71150	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
216					NRAC-216M	* /O	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	*
217					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
218	74	12	4.82E-08	0.71441	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
219					NRAC-216M	* /O	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	*
220					/QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+
221	1534	10	4.80E-08	0.71731	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
222					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1456	* QS-SBO	*
223					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
224	1533	10	4.80E-08	0.72021	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
225					NRAC-1HR	* OEP-DGN-FS	* PPS-SOV-OO-1455C	* QS-SBO	*
226					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
227	76	12	4.82E-08	0.72300	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
228					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG2	*
229					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
230	78	12	4.82E-08	0.72580	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
231					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
232					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
233	77	12	4.82E-08	0.72859	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
234					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG3	*
235					OEP-DGN-FS-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
236	79	12	4.82E-08	0.73138	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
237					NOTQ	* NRAC-216M	* /O	* OEP-DGN-FR-6HDG1	*
238					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
239	36	10	4.82E-08	0.73417	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
240					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-FR-6HDG2	*
241					/QS-SBO	* REC-XHE-FO-DGHWS			+
242	1535	9	4.26E-08	0.73674	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	*
243					OEP-DGN-FS	* PPS-SOV-OO-1455C	* QS-SBO	* REC-XHE-FO-DGEN	*
244					SBO-PORV-DMD				+
245	1536	9	4.26E-08	0.73932	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NRAC-1HR	*
246					OEP-DGN-FS	* PPS-SOV-OO-1456	* QS-SBO	* REC-XHE-FO-DGEN	*
247					SBO-PORV-DMD				+
248	1465	10	3.81E-08	0.74162	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
249					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1456	* /QS-SBO	*
250					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
251	1467	10	3.81E-08	0.74391	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
252					OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1456	* /QS-SBO	*
253					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
254	1470	10	3.81E-08	0.74621	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
255					OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
256					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
257	1468	10	3.81E-08	0.74851	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
258					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
259					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
260	1483	10	3.81E-08	0.75081	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
261					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
262					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
263	1466	10	3.81E-08	0.75311	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
264					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1456	* /QS-SBO	*
265					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
266	1469	10	3.81E-08	0.75541	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
267					OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* PPS-SOV-OO-1456	* /QS-SBO	*
268					REC-XHE-FO-DGEN	* SBO-PORV-DMD			+
269	1484	10	3.81E-08	0.75770	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
270					OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*

271					REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
272	81	11	3.75E-08	0.75997	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
273					NRAC-216M	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
274					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		*
275	80	11	3.75E-08	0.76223	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
276					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
277					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		*
278	82	11	3.75E-08	0.76449	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
279					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
280					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		*
281	83	11	3.75E-08	0.76676	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
282					NRAC-216M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
283					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+		*
284	37	10	3.42E-08	0.76882	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
285					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
286					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
287	38	10	3.42E-08	0.77088	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
288					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
289					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
290	257	12	3.31E-08	0.77288	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
291					NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
292					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
293	258	12	3.31E-08	0.77489	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
294					NRAC-258M	*	/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
295					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
296	84	11	3.30E-08	0.77688	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
297					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
298					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		*
299	85	11	3.30E-08	0.77887	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
300					NOTQ	*	NRAC-216M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
301					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		*
302	86	11	3.15E-08	0.78077	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
303					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
304					OEP-DGN-FR-6HDG3	*	/QS-SBO	*	RCP-LOCA-750-90M	+		*
305	87	11	3.14E-08	0.78267	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
306					/O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	OEP-DGN-FS-DG03	*
307					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		*
308	41	10	3.13E-08	0.78456	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
309					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
310					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
311	40	10	3.13E-08	0.78645	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
312					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
313					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
314	38	10	3.13E-08	0.78834	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
315					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
316					QS-SBO	*	REC-XHE-FO-DGHWB	+				*
317	259	12	3.08E-08	0.79020	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*
318					NOTQ	*	NRAC-258M	*	/O	*	OEP-DGN-FS	*
319					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOO1	+
320	88	11	3.07E-08	0.79205	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
321					NOTL-SBOU1	*	NOTQ	*	NRAC-216M	*	OEP-DGN-FS	*
322					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		*
323	42	10	2.85E-08	0.79377	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
324					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*
325					QS-SBO	*	REC-XHE-FO-DGTMB	+				*
326	45	9	2.85E-08	0.79549	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*

327					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG3	*
328					QS-SBO	+						
329	43	10	2.85E-08	0.79721	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
330					NOTW2	*	NRAC-7HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
331					QS-SBO	*	REC-XHE-FO-DGTMB	+				
332	44	9	2.85E-08	0.79893	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
333					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FR-6HDG1	*
334					QS-SBO	+						
335	90	12	2.63E-08	0.80052	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
336					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*
337					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
338	89	12	2.63E-08	0.80210	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
339					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*
340					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
341	91	10	2.55E-08	0.80365	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
342					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	*
343					RCP-LOCA-750-90M	*	REC-XHE-FO-SCOOOL	+				
344	92	12	2.52E-08	0.80517	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
345					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
346					OEP-DGN-FR-6HDG2	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
347	1581	12	2.45E-08	0.80665	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
348					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FS-DG01	*
349					OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOOL	+
350	1582	12	2.45E-08	0.80813	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
351					NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FS-DG01	*
352					OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOOL	+
353	95	12	2.41E-08	0.80958	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
354					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*
355					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
356	94	12	2.41E-08	0.81103	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
357					NRAC-216M	*	/O	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*
358					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
359	93	12	2.41E-08	0.81249	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
360					NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*
361					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOOL	+
362	99	12	2.31E-08	0.81389	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
363					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG02	*
364					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
365	96	12	2.31E-08	0.81528	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
366					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
367					OEP-DGN-MA-DG02	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
368	98	12	2.31E-08	0.81668	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
369					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG03	*
370					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
371	97	12	2.31E-08	0.81808	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
372					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FS-DG01	*
373					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
374	46	10	2.31E-08	0.81947	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
375					NOTW2	*	NRAC-7HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-MA-DG02	*
376					/QS-SBO	*	REC-XHE-FO-DGHWB	+				
377	101	12	2.30E-08	0.82088	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
378					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*
379					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOOL	+
380	100	12	2.30E-08	0.82225	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
381					NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*
382					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	*	REC-XHE-FO-SCOOOL	+

383	1583	12	2.27E-08	0.82362	.BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
384					NOTQ	* NRAC-7HR	* NSLOCA	* /O	*
385					OEP-DGN-FS	* /QS-SBO	* REC-XHE-FO-DGHWB	* REC-XHE-FO-SCOO	+
386	1584	9	2.09E-08	0.82489	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-7HR	*
387					NSLOCA	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* QS-SBO	*
388					REC-XHE-FO-DGHWB	+			
389	102	11	2.04E-08	0.82812	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
390					NRAC-216M	* OEP-DGN-FR-8HDG1	* OEP-DGN-FR-8HDG2	* QS-SBO	*
391					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
392	49	9	1.92E-08	0.82728	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
393					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-CRB-FT-15J3	*
394					/QS-SBO	+			
395	48	10	1.92E-08	0.82844	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
396					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15H3	* OEP-DGN-MA-DG03	*
397					/QS-SBO	* REC-XHE-FO-DGTMB	+		
398	47	10	1.92E-08	0.82961	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
399					NOTW2	* NRAC-7HR	* OEP-CRB-FT-15J3	* OEP-DGN-MA-DG01	*
400					/QS-SBO	* REC-XHE-FO-DGTMB	+		
401	1473	10	1.90E-08	0.83076	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
402					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1458	* /QS-SBO	*
403					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
404	1476	10	1.90E-08	0.83190	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
405					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*
406					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
407	1471	10	1.90E-08	0.83305	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
408					OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1458	* /QS-SBO	*
409					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
410	1475	10	1.90E-08	0.83420	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
411					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1455C	* /QS-SBO	*
412					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
413	1474	10	1.90E-08	0.83535	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
414					OEP-CRB-FT-15H3	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1458	* /QS-SBO	*
415					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
416	1472	10	1.90E-08	0.83650	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
417					OEP-CRB-FT-15J3	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
418					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
419	104	11	1.87E-08	0.83763	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
420					NRAC-216M	* OEP-DGN-FS-DG03	* OEP-DGN-MA-DG01	* QS-SBO	*
421					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
422	105	11	1.87E-08	0.83876	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
423					NRAC-216M	* OEP-DGN-FS-DG02	* OEP-DGN-MA-DG01	* QS-SBO	*
424					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
425	103	11	1.87E-08	0.83990	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
426					NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG03	* QS-SBO	*
427					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
428	108	11	1.87E-08	0.84103	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
429					NRAC-216M	* OEP-DGN-FS-DG01	* OEP-DGN-MA-DG02	* QS-SBO	*
430					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+	
431	260	12	1.81E-08	0.84212	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
432					NRAC-258M	* /O	* OEP-DGN-FR-8HDG1	* OEP-DGN-FS-DG03	*
433					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
434	282	12	1.81E-08	0.84321	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
435					NRAC-258M	* /O	* OEP-DGN-FR-8HDG3	* OEP-DGN-FS-DG01	*
436					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOO	+
437	283	12	1.81E-08	0.84430	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
438					NRAC-258M	* /O	* OEP-DGN-FR-8HDG1	* OEP-DGN-FS-DG02	*

439					/QS-SBO	* RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS *	REC-XHE-FO-SCOOL +
440	261	12	1.81E-08	0.84539	/DGN-FTO	* IE-T1 *	NOTL-SBOU1 *	NOTQ *
441					NRAC-258M	* /O *	OEP-DGN-FR-6HDG2 *	OEP-DGN-FS-DG01 *
442					/QS-SBO	* RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS *	REC-XHE-FO-SCOOL +
443	109	11	1.80E-08	0.84648	/DGN-FTO	* IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
444					NOTQ	* NRAC-216M *	OEP-DGN-FR-6HDG3 *	OEP-DGN-FS-DG01 *
445					QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +	
446	108	11	1.80E-08	0.84757	/DGN-FTO	* IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
447					NOTQ	* NRAC-216M *	OEP-DGN-FR-6HDG2 *	OEP-DGN-FS-DG01 *
448					QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +	
449	107	11	1.80E-08	0.84865	/DGN-FTO	* IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
450					NOTQ	* NRAC-216M *	OEP-DGN-FR-6HDG1 *	OEP-DGN-FS-DG03 *
451					QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +	
452	110	11	1.80E-08	0.84974	/DGN-FTO	* IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
453					NOTQ	* NRAC-216M *	OEP-DGN-FR-6HDG1 *	OEP-DGN-FS-DG02 *
454					QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +	
455	113	11	1.71E-08	0.85077	IE-T1	* NOTL-SBOU1U2 *	NOTQ *	NRAC-216M *
456					/O	* OEP-DGN-FR-6HDG1 *	OEP-DGN-FS-DG02 *	OEP-DGN-FS-DG03 *
457					/QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +	
458	111	11	1.71E-08	0.85180	IE-T1	* NOTL-SBOU1U2 *	NOTQ *	NRAC-216M *
459					/O	* OEP-DGN-FR-6HDG3 *	OEP-DGN-FS-DG01 *	OEP-DGN-FS-DG02 *
460					/QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +	
461	112	11	1.71E-08	0.85284	IE-T1	* NOTL-SBOU1U2 *	NOTQ *	NRAC-216M *
462					/O	* OEP-DGN-FR-6HDG2 *	OEP-DGN-FS-DG01 *	OEP-DGN-FS-DG03 *
463					/QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +	
464	50	10	1.71E-08	0.85387	/DGN-FTO	* IE-T1 *	NOTL-SBOU1 *	NOTQ *
465					NOTW2	* NRAC-7HR *	OEP-CRB-FT-15H3 *	OEP-DGN-FR-6HDG2 *
466					QS-SBO	* REC-XHE-FO-DGHWS +		
467	114	11	1.64E-08	0.85486	/DGN-FTO	* IE-T1 *	NOTL-SBOU1 *	NOTQ *
468					NRAC-216M	* /O *	OEP-CRB-FT-15J3 *	OEP-DGN-FR-6HDG1 *
469					/QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-SCOOL +	
470	115	11	1.64E-08	0.85585	/DGN-FTO	* IE-T1 *	NOTL-SBOU1 *	NOTQ *
471					NRAC-216M	* /O *	OEP-CRB-FT-15H3 *	OEP-DGN-FR-6HDG3 *
472					/QS-SBO	* RCP-LOCA-750-90M *	REC-XHE-FO-SCOOL +	
473	264	12	1.59E-08	0.85681	/DGN-FTO	* IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
474					NOTQ	* NRAC-258M *	OEP-DGN-FS-DG01 *	OEP-DGN-FS-DG01 *
475					OEP-DGN-FS-DG02	* /QS-SBO *	RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS +
476					/DGN-FTO	* IE-T1 *	MCW-CCF-VF-SBO *	NOTL-SBOU1 *
477					NOTQ	* NRAC-258M *	OEP-DGN-FS-DG01 *	OEP-DGN-FS-DG01 *
478					OEP-DGN-FS-DG03	* /QS-SBO *	RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS +
479	117	12	1.54E-08	0.85870	BETA-2DG	* IE-T1 *	NOTDG-CCF *	NOTL-SBOU1U2 *
480					NOTQ	* NRAC-216M *	OEP-DGN-FR-6HDG2 *	OEP-DGN-FR-6HDG2 *
481					OEP-DGN-FS	* /QS-SBO *	RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +
482	116	12	1.54E-08	0.85963	BETA-2DG	* IE-T1 *	NOTDG-CCF *	NOTL-SBOU1U2 *
483					NOTQ	* NRAC-216M *	OEP-DGN-FR-6HDG3 *	OEP-DGN-FR-6HDG3 *
484					OEP-DGN-FS	* /QS-SBO *	RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +
485	118	12	1.54E-08	0.86056	BETA-2DG	* IE-T1 *	NOTDG-CCF *	NOTL-SBOU1U2 *
486					NOTQ	* NRAC-216M *	OEP-DGN-FR-6HDG1 *	OEP-DGN-FR-6HDG1 *
487					OEP-DGN-FS	* /QS-SBO *	RCP-LOCA-750-90M *	REC-XHE-FO-DGHWS +
488	266	12	1.48E-08	0.86145	BETA-2DG	* IE-T1 *	MCW-CCF-VF-SBO *	NOTDG-CCF *
489					NOTL-SBOU1	* NOTQ *	NRAC-258M *	/O *
490					OEP-DGN-FS	* /QS-SBO *	RCP-LOCA-467-150 *	REC-XHE-FO-DGHWS +
491	855	10	1.44E-08	0.86232	BETA-3DG	* IE-T1 *	NOTL-SBOU1U2 *	NOTQ *
492					NRAC-150M	* /O *	OEP-DGN-FS *	/QS-SBO *
493					RCP-LOCA-1440-90	* REC-XHE-FO-DGHWS +		
494	1542	10	1.41E-08	0.86317	/DGN-FTO	* IE-T1 *	NOTL-SBOU1 *	NRAC-1HR *

495				OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1455C	*	QS-SBO	*
496				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
497	1544	10	1.41E-08	0.86402	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
498				OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1456	*	QS-SBO	*
499				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
500	1539	10	1.41E-08	0.86487	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
501				OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1458	*	QS-SBO	*
502				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
503	1543	10	1.41E-08	0.86572	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
504				OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	PPS-SOV-OO-1455C	*	QS-SBO	*
505				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
506	1538	10	1.41E-08	0.86657	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
507				OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	QS-SBO	*
508				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
509	1537	10	1.41E-08	0.86742	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
510				OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1455C	*	QS-SBO	*
511				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
512	1541	10	1.41E-08	0.86827	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
513				OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	PPS-SOV-OO-1456	*	QS-SBO	*
514				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
515	1540	10	1.41E-08	0.86912	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
516				OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	PPS-SOV-OO-1458	*	QS-SBO	*
517				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
518	1587	12	1.33E-08	0.86993	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
519				NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG3	*
520				OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
521	1588	12	1.33E-08	0.87073	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
522				NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG1	*
523				OEP-DGN-FS-DG03	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
524	1586	12	1.33E-08	0.87154	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
525				NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG2	*
526				OEP-DGN-FS-DG01	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
527	1585	12	1.33E-08	0.87234	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
528				NRAC-7HR	*	NSLOCA	*	/O	*	OEP-DGN-FR-6HDG1	*
529				OEP-DGN-FS-DG02	*	/QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+
530	119	12	1.31E-08	0.87314	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
531				NRAC-216M	*	/O	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*
532				/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
533	267	11	1.29E-08	0.87392	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
534				NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
535				RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
536	268	11	1.29E-08	0.87469	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
537				NRAC-258M	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
538				RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
539	655	10	1.28E-08	0.87547	BETA-3DG	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
540				NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
541				RCP-LOCA-183-210	*	REC-XHE-FO-DGHWS	+				
542	455	10	1.28E-08	0.87625	BETA-3DG	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
543				NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
544				RCP-LOCA-183-150	*	REC-XHE-FO-DGHWS	+				
545	1477	10	1.27E-08	0.87701	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
546				OEP-DGN-FR-DG01	*	OEP-DGN-FS-DG02	*	PPS-SOV-OO-1455C	*	/QS-SBO	*
547				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				
548	1479	10	1.27E-08	0.87778	/DGN-FTO	IE-T1	*	NOTL-SBOU1	*	NRAC-1HR	*
549				OEP-DGN-FR-DG02	*	OEP-DGN-FS-DG01	*	PPS-SOV-OO-1458	*	/QS-SBO	*
550				REC-XHE-FO-DGEN	*	SBO-PORV-DMD	+				

551	1481	10	1.27E-08	0.87854	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
552					OEP-DGN-FR-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1458	* /QS-SBO	*
553					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
554	1484	10	1.27E-08	0.87931	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
555					OEP-DGN-FR-DG01	* OEP-DGN-FS-DG02	* PPS-SOV-OO-1458	* /QS-SBO	*
556					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
557	1480	10	1.27E-08	0.88008	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
558					OEP-DGN-FR-DG03	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
559					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
560	1482	10	1.27E-08	0.88084	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
561					OEP-DGN-FR-DG03	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1458	* /QS-SBO	*
562					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
563	1483	10	1.27E-08	0.88161	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
564					OEP-DGN-FR-DG02	* OEP-DGN-FS-DG01	* PPS-SOV-OO-1455C	* /QS-SBO	*
565					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
566	1478	10	1.27E-08	0.88237	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NRAC-1HR	*
567					OEP-DGN-FR-DG01	* OEP-DGN-FS-DG03	* PPS-SOV-OO-1455C	* /QS-SBO	*
568					REC-XHE-FO-DGEN	* SBO-PORV-DMD	+		
569	121	12	1.26E-08	0.88314	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
570					NOTQ	* NRAC-218M	*/O	* OEP-DGN-FR-6HDG1	*
571					OEP-DGN-MA-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
572	120	12	1.26E-08	0.88390	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
573					NOTQ	* NRAC-218M	*/O	* OEP-DGN-FR-6HDG2	*
574					OEP-DGN-MA-DG01	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
575	269	11	1.23E-08	0.88464	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
576					NRAC-258M	*/O	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
577					/QS-SBO	* RCP-LOCA-467-150	* REC-XHE-FO-SCOOL	+	
578	122	10	1.23E-08	0.88538	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
579					NOTQ	* NRAC-218M	* OEP-DGN-FR-6HDG1	* OEP-DGN-FR-6HDG3	*
580					QS-SBO	* RCP-LOCA-750-90M	+		
581	123	10	1.22E-08	0.88612	IE-T1	* NOTL-SBOU1U2	* NOTQ	* NRAC-218M	*
582					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* OEP-DGN-FS-DG03	* QS-SBO	*
583					RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+		
584	1589	11	1.21E-08	0.88685	/DGN-FTO	* IE-T1	* NOTL-SBOU1	* NOTQ	*
585					NRAC-7HR	* NSLOCA	*/O	* OEP-DGN-FR-6HDG1	*
586					OEP-DGN-FR-6HDG3	* /QS-SBO	* REC-XHE-FO-SCOOL	+	
587	1775	10	1.20E-08	0.88758	BETA-3DG	* IE-T1	* NOTL-SBOU1U2	* NOTQ	*
588					NRAC-246M	* O	* OEP-DGN-FS	* /QS-SBO	*
589					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	+		
590	270	11	1.20E-08	0.88830	BETA-2DG	* IE-T1	* NOTDG-CCF	* NOTL-SBOU1	*
591					NOTQ	* NRAC-258M	* OEP-DGN-FS	* QS-SBO	*
592					RCP-LOCA-467-150	* REC-XHE-FO-DGHWS	* REC-XHE-FO-SCOOL	+	
593	1591	12	1.17E-08	0.88901	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
594					NOTQ	* NRAC-7HR	* NSLOCA	*/O	*
595					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG03	* /QS-SBO	* REC-XHE-FO-DGHWS	+
596	1590	12	1.17E-08	0.88972	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
597					NOTQ	* NRAC-7HR	* NSLOCA	*/O	*
598					OEP-DGN-FS-DG01	* OEP-DGN-FS-DG02	* /QS-SBO	* REC-XHE-FO-DGHWS	+
599	125	12	1.16E-08	0.89042	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
600					NOTQ	* NRAC-218M	*/O	* OEP-CRB-FT-15H3	*
601					OEP-DGN-FS-DG02	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
602	126	12	1.16E-08	0.89111	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
603					NOTQ	* NRAC-218M	*/O	* OEP-CRB-FT-15H3	*
604					OEP-DGN-FS-DG03	* /QS-SBO	* RCP-LOCA-750-90M	* REC-XHE-FO-DGHWS	+
605	124	12	1.16E-08	0.89181	/DGN-FTO	* IE-T1	* MCW-CCF-VF-SBO	* NOTL-SBOU1	*
606					NOTQ	* NRAC-218M	*/O	* OEP-CRB-FT-15J3	*

607					OEP-DGN-FS-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+
608	1055	10	1.12E-08	0.89249	BETA-3DG	*	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*
609					NRAC-7HR	*	/O	*	OEP-DGN-FS	*	/QS-SBO	*
610					RCP-LOCA-183-90	*	REC-XHE-FO-DGHWS	+				
611	128	12	1.10E-08	0.89315	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
612					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG3	*
613					OEP-DGN-MA-DG01	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+
614	127	12	1.10E-08	0.89382	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
615					NOTQ	*	NRAC-216M	*	/O	*	OEP-DGN-FR-6HDG1	*
616					OEP-DGN-MA-DG03	*	/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGTMS	+
617	1592	12	1.09E-08	0.89448	BETA-2DG	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTDG-CCF	*
618					NOTL-SBOU1	*	NOTQ	*	NRAC-7HR	*	NSLOCA	*
619					/O	*	OEP-DGN-FS	*	/QS-SBO	*	REC-XHE-FO-DGHWB	+
620	129	11	1.02E-08	0.89510	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
621					NRAC-216M	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-MA-DG01	*	QS-SBO	*
622					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	REC-XHE-FO-SCOOL	+		
623	130	11	1.02E-08	0.89571	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
624					NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG02	*	QS-SBO	*
625					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+	REC-XHE-FO-SCOOL	+		
626	1715	12	9.89E-09	0.89631	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
627					NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
628					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
629	1714	12	9.89E-09	0.89691	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
630					NRAC-201M	*	O	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
631					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
632	271	12	9.86E-09	0.89750	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
633					NRAC-258M	*	/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
634					/QS-SBO	*	RCP-LOCA-467-150	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+
635	131	11	9.81E-09	0.89810	/DGN-FTO	*	IE-T1	*	MCW-CCF-VF-SBO	*	NOTL-SBOU1	*
636					NOTQ	*	NRAC-216M	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*
637					QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
638	1594	11	9.51E-09	0.89867	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
639					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
640					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
641	1593	11	9.51E-09	0.89924	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
642					NRAC-7HR	*	NSLOCA	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
643					QS-SBO	*	REC-XHE-FO-DGHWB	*	REC-XHE-FO-SCOOL	+		
644	134	11	9.37E-09	0.89981	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
645					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
646					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
647	132	11	9.37E-09	0.90038	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
648					NRAC-216M	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
649					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
650	133	11	9.37E-09	0.90094	/DGN-FTO	*	IE-T1	*	NOTL-SBOU1	*	NOTQ	*
651					NRAC-216M	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
652					RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	*	REC-XHE-FO-SCOOL	+		
653	136	11	9.33E-09	0.90151	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
654					/O	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
655					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
656	137	11	9.33E-09	0.90207	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
657					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG03	*
658					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
659	135	11	9.33E-09	0.90263	IE-T1	*	NOTL-SBOU1U2	*	NOTQ	*	NRAC-216M	*
660					/O	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG02	*
661					/QS-SBO	*	RCP-LOCA-750-90M	*	REC-XHE-FO-DGHWS	+		
662	1716	12	9.20E-09	0.90319	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*	NOTL-SBOU1	*

PLANT DAMAGE STATE GROUP PDS2

TOP EVENT PDS2 CONTAINS 74 EVENTS IN 127 CUT SETS

THE FREQUENCY OF TOP EVENT PDS2 IS 6.35E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT PDS2

N	1000
MEAN	5.97E-06
STD DEV	8.89E-06
LOWER 5%	1.21E-06
LOWER 25%	2.28E-06
MEDIAN	3.79E-06
UPPER 25%	6.48E-06
UPPER 5%	1.63E-05

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

PLANT DAMAGE STATE GROUP PDS2
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK		
				REDUCTION (RANK)	LOWER 5%	UPPER 5%
BETA-2MOV	12	8.80E-02	(6.0)	2.55E-06 (1.0)	9.60E-08	8.47E-06
HPI-MOV-FT	6	3.00E-03	(24.5)	1.07E-06 (2.0)	1.76E-08	3.62E-06
LPR-MOV-FT-1862A	13	5.20E-03	(13.5)	7.95E-07 (3.0)	1.60E-08	3.59E-06
LPI-MDP-FS	2	3.00E-03	(24.5)	6.75E-07 (4.5)	1.26E-08	2.53E-06
BETA-LPI	2	1.50E-01	(5.0)	6.75E-07 (4.5)	1.26E-08	2.53E-06
LPI-MOV-PG-1890C	2	4.40E-04	(54.0)	6.60E-07 (6.0)	2.56E-08	3.97E-07
LPR-MOV-FT-1860A	12	3.00E-03	(24.5)	4.58E-07 (7.0)	8.90E-09	1.63E-06
RMT-CCF-FA-MSCAL	2	3.00E-04	(55.0)	4.50E-07 (8.0)	1.41E-08	1.86E-06
LPR-MOV-FT-1890A	4	3.00E-03	(24.5)	4.10E-07 (9.0)	7.30E-09	1.52E-06
ACC-MOV-PG-1865C	1	6.50E-04	(49.5)	3.25E-07 (10.5)	3.03E-08	6.51E-07
ACC-MOV-PG-1865B	1	6.50E-04	(49.5)	3.25E-07 (10.5)	3.03E-08	6.51E-07
HPI-XHE-FO-ALT	2	6.10E-01	(1.0)	3.22E-07 (12.0)	3.64E-09	1.07E-06
HPI-XHE-FO-UN2S3	13	4.40E-02	(10.0)	3.13E-07 (13.0)	1.52E-08	1.29E-06
HPI-XHE-FO-ALTS3	1	7.40E-02	(7.0)	2.54E-07 (14.0)	2.00E-09	9.24E-07
HPI-CKV-FT-CV225	3	1.00E-04	(60.0)	2.07E-07 (15.0)	3.71E-08	5.80E-07
HPI-CKV-FT-CV410	3	1.00E-04	(60.0)	1.88E-07 (16.5)	3.23E-08	5.52E-07
HPI-CKV-FT-CV25	3	1.00E-04	(60.0)	1.88E-07 (16.5)	3.23E-08	5.52E-07
HPI-XHE-FO-UN2S2	7	3.10E-01	(2.0)	1.63E-07 (18.0)	7.61E-09	6.53E-07
LPR-MOV-FT-1862B	11	5.20E-03	(13.5)	1.09E-07 (19.0)	1.02E-09	8.24E-07
HPI-XVM-PG-XV24	3	4.00E-05	(69.0)	7.53E-08 (20.0)	1.27E-08	2.12E-07
LPI-MDP-FS-SI1B	14	3.00E-03	(24.5)	7.41E-08 (21.5)	1.12E-09	3.67E-07
LPI-MDP-FS-SI1A	14	3.00E-03	(24.5)	7.41E-08 (21.5)	1.12E-09	3.67E-07
LPR-MOV-FT-1860B	10	3.00E-03	(24.5)	6.24E-08 (23.0)	6.67E-10	4.25E-07
LPR-XHE-FO-HOTLG	2	4.00E-05	(69.0)	6.00E-08 (24.0)	1.78E-09	2.16E-07
ACC-CKV-FT-CV145	1	1.00E-04	(60.0)	5.00E-08 (26.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV130	1	1.00E-04	(60.0)	5.00E-08 (26.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV147	1	1.00E-04	(60.0)	5.00E-08 (26.5)	6.43E-09	1.63E-07
ACC-CKV-FT-CV128	1	1.00E-04	(60.0)	5.00E-08 (26.5)	6.43E-09	1.63E-07
LPI-MDP-MA-SI1B	10	2.00E-03	(33.5)	4.04E-08 (29.5)	6.04E-10	1.58E-07
LPI-MDP-MA-SI1A	10	2.00E-03	(33.5)	4.04E-08 (29.5)	6.04E-10	1.58E-07
BETA-STR	3	2.63E-01	(3.0)	3.23E-08 (31.0)	6.08E-09	9.70E-08
CPC-STR-PG-3HR	1	9.00E-05	(65.5)	2.37E-08 (32.0)		
HPI-MDP-FR-1A24H	2	1.60E-03	(38.0)	2.16E-08 (33.0)	1.95E-09	6.93E-08
HPI-CKV-OO-CV258	1	1.00E-03	(42.5)	2.08E-08 (34.0)	1.77E-09	6.71E-08
SIS-ACT-FA-SISB	7	1.60E-03	(38.0)	1.84E-08 (35.5)	5.68E-10	1.02E-07
SIS-ACT-FA-SISA	7	1.60E-03	(38.0)	1.84E-08 (35.5)	5.68E-10	1.02E-07
HPI-MOV-FT-1115E	3	3.00E-03	(24.5)	1.69E-08 (38.5)	1.47E-11	2.20E-07
HPI-MOV-FT-1115D	3	3.00E-03	(24.5)	1.69E-08 (38.5)	1.47E-11	2.20E-07
HPI-MOV-FT-1115C	3	3.00E-03	(24.5)	1.69E-08 (38.5)	1.47E-11	2.20E-07
HPI-MOV-FT-1115B	3	3.00E-03	(24.5)	1.69E-08 (38.5)	1.47E-11	2.20E-07
LPR-MOV-FT-1890B	2	3.00E-03	(24.5)	1.35E-08 (41.0)	1.23E-11	1.59E-07
CPC-XHE-FO-REALN	4	7.00E-02	(8.0)	1.04E-08 (42.0)	4.61E-10	4.17E-08
HPI-MOV-FT-1867D	3	3.00E-03	(24.5)	8.58E-09 (43.0)	1.16E-10	3.33E-08
LPI-MDP-FR-B21HR	4	6.30E-04	(51.5)	8.32E-09 (44.5)	9.43E-11	2.93E-08
LPI-MDP-FR-A21HR	4	6.30E-04	(51.5)	8.32E-09 (44.5)	9.43E-11	2.93E-08
CPC-STR-PG-24H	1	7.20E-04	(46.5)	7.58E-09 (46.0)		
HPI-XHE-FO-ALTN	1	5.70E-03	(12.0)	7.41E-09 (47.0)	9.74E-11	3.25E-08

E-258

CPC-MDP-FS-SW10B	3	8.00E-03	(11.0)	5.78E-09	(48.0)	4.30E-10	1.96E-08
CPC-MDP-FR-SWA3H	2	4.80E-04	(53.0)	4.80E-09	(49.0)	3.38E-10	1.50E-08
LPI-MDP-FR-B24HR	4	7.20E-04	(46.5)	4.75E-09	(50.5)	5.27E-11	1.99E-08
LPI-MDP-FR-A24HR	4	7.20E-04	(46.5)	4.75E-09	(50.5)	5.27E-11	1.99E-08
LPI-CKV-OO-CV58	2	1.00E-03	(42.5)	4.50E-09	(52.5)	8.17E-11	1.91E-08
LPI-CKV-OO-CV50	2	1.00E-03	(42.5)	4.50E-09	(52.5)	8.17E-11	1.91E-08
RMT-ACT-FA-RMTSB	3	1.60E-03	(38.0)	4.37E-09	(54.5)	7.13E-11	3.79E-08
RMT-ACT-FA-RMTSA	3	1.60E-03	(38.0)	4.37E-09	(54.5)	7.13E-11	3.79E-08
CPC-MDP-FR-SWA24	3	3.80E-03	(16.5)	3.97E-09	(56.0)	1.35E-10	1.56E-08
ACP-BAC-ST-1H1	1	9.00E-05	(65.5)	3.51E-09	(57.5)	3.30E-11	1.33E-08
ACP-BAC-ST-4KV1H	1	9.00E-05	(65.5)	3.51E-09	(57.5)	3.30E-11	1.33E-08
CPC-CKV-OO-CV113	1	1.00E-03	(42.5)	2.17E-09	(59.0)	7.76E-11	8.77E-09
CPC-MDP-FR-CCA24	2	7.20E-04	(46.5)	2.06E-09	(60.0)	8.97E-12	6.85E-09
ACP-TFM-NO-1H1	1	4.00E-05	(69.0)	1.56E-09	(61.0)	2.60E-11	6.43E-09
CPC-MDP-FS-CC2B	1	3.00E-03	(24.5)	1.24E-09	(62.0)	2.69E-12	4.35E-09
RMT-XHE-FO-MANS1	2	6.40E-02	(9.0)	1.06E-09	(63.0)	5.10E-12	3.57E-09
CPC-STR-PG-6HR	1	1.80E-04	(56.0)	1.03E-09	(64.0)		
CPC-MDP-MA-SW10B	1	2.00E-03	(33.5)	9.60E-10	(65.0)	1.51E-11	3.61E-09
CPC-MDP-MA-CC2B	1	2.00E-03	(33.5)	8.24E-10	(66.0)	1.35E-12	2.64E-09
BETA-HPI	1	2.10E-01	(4.0)	7.69E-10	(67.5)	1.80E-11	3.14E-09
HPI-MDP-FS	1	4.00E-03	(15.0)	7.69E-10	(67.5)	1.80E-11	3.14E-09
CPC-STR-PG-2A3HR	1	9.00E-05	(65.5)	7.20E-10	(69.0)	9.84E-12	2.43E-09
CPC-MDP-FR-SWB24	1	3.80E-03	(16.5)	5.78E-10	(70.0)	5.84E-12	3.57E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ	(RANK)	RISK REDUCTION	(RANK)	LOWER 5%	UPPER 5%
IE-S1	53	1.00E-03	(2.5)	3.25E-06	(1.0)	3.47E-07	9.66E-06
IE-A	45	5.00E-04	(4.0)	2.07E-06	(2.0)	2.74E-07	5.44E-06
IE-S3	19	1.30E-02	(1.0)	6.04E-07	(3.0)	3.41E-08	2.29E-06
IE-S2	10	1.00E-03	(2.5)	4.26E-07	(4.0)	3.98E-08	1.38E-06

PLANT DAMAGE STATE GROUP PDS2
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
HPI-CKV-FT-CV225	3	1.00E-04	(60.0)	2.07E-03	(1.0)	8.52E-04	4.07E-03
HPI-XVM-PG-XV24	3	4.00E-05	(69.0)	1.88E-03	(2.0)	6.57E-04	3.94E-03
HPI-CKV-FT-CV410	3	1.00E-04	(60.0)	1.88E-03	(3.5)	6.57E-04	3.94E-03
HPI-CKV-FT-CV25	3	1.00E-04	(60.0)	1.88E-03	(3.5)	6.57E-04	3.94E-03
LPR-XHE-FO-HOTLG	2	4.00E-05	(69.0)	1.50E-03	(5.0)	5.89E-04	2.98E-03
RMT-CCF-FA-MSCAL	2	3.00E-04	(55.0)	1.50E-03	(6.0)	5.89E-04	2.98E-03
LPI-MOV-PG-1890C	2	4.40E-04	(54.0)	1.50E-03	(7.0)	5.89E-04	2.98E-03
ACC-CKV-FT-CV130	1	1.00E-04	(60.0)	5.00E-04	(9.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV145	1	1.00E-04	(60.0)	5.00E-04	(9.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV147	1	1.00E-04	(60.0)	5.00E-04	(9.5)	1.33E-04	1.20E-03
ACC-CKV-FT-CV128	1	1.00E-04	(60.0)	5.00E-04	(9.5)	1.33E-04	1.20E-03
ACC-MOV-PG-1865B	1	6.50E-04	(49.5)	5.00E-04	(12.5)	1.33E-04	1.20E-03
ACC-MOV-PG-1865C	1	6.50E-04	(49.5)	5.00E-04	(12.5)	1.33E-04	1.20E-03
HPI-MOV-FT	6	3.00E-03	(24.5)	3.57E-04	(14.0)	6.44E-05	9.84E-04
CPC-STR-PG-3HR	1	9.00E-05	(65.5)	2.63E-04	(15.0)		
LPI-MDP-FS	2	3.00E-03	(24.5)	2.24E-04	(16.0)	3.90E-05	6.03E-04
LPR-MOV-FT-1860A	12	3.00E-03	(24.5)	1.52E-04	(17.0)	3.23E-05	3.92E-04
LPR-MOV-FT-1862A	13	5.20E-03	(13.5)	1.52E-04	(18.0)	3.22E-05	3.92E-04
LPR-MOV-FT-1890A	4	3.00E-03	(24.5)	1.36E-04	(19.0)	2.41E-05	3.66E-04
ACP-TFM-NO-1H1	1	4.00E-05	(69.0)	3.90E-05	(20.0)	9.10E-07	1.52E-04
ACP-BAC-ST-1H1	1	9.00E-05	(65.5)	3.90E-05	(21.5)	9.10E-07	1.51E-04
ACP-BAC-ST-4KV1H	1	9.00E-05	(65.5)	3.90E-05	(21.5)	9.10E-07	1.51E-04
BETA-2MOV	12	8.80E-02	(6.0)	2.64E-05	(23.0)	1.80E-06	9.43E-05
LPI-MDP-FS-S11A	14	3.00E-03	(24.5)	2.46E-05	(24.5)	4.22E-06	6.98E-05
LPI-MDP-FS-S11B	14	3.00E-03	(24.5)	2.46E-05	(24.5)	4.22E-06	6.98E-05
LPR-MOV-FT-1862B	11	5.20E-03	(13.5)	2.08E-05	(26.0)	2.79E-06	6.36E-05
HPI-CKV-OO-CV258	1	1.00E-03	(42.5)	2.08E-05	(27.0)	3.16E-06	6.41E-05
LPR-MOV-FT-1860B	10	3.00E-03	(24.5)	2.07E-05	(28.0)	2.74E-06	6.46E-05
LPI-MDP-MA-S11B	10	2.00E-03	(33.5)	2.01E-05	(29.5)	2.81E-06	5.71E-05
LPI-MDP-MA-S11A	10	2.00E-03	(33.5)	2.01E-05	(29.5)	2.81E-06	5.71E-05
HPI-MDP-FR-1A24H	2	1.60E-03	(38.0)	1.35E-05	(31.0)	1.84E-06	3.93E-05
LPI-MDP-FR-B21HR	4	6.30E-04	(51.5)	1.32E-05	(32.5)	1.30E-06	4.11E-05
LPI-MDP-FR-A21HR	4	6.30E-04	(51.5)	1.32E-05	(32.5)	1.30E-06	4.11E-05
SIS-ACT-FA-S1SA	7	1.60E-03	(38.0)	1.15E-05	(34.5)	1.80E-06	3.46E-05
SIS-ACT-FA-S1SB	7	1.60E-03	(38.0)	1.15E-05	(34.5)	1.80E-06	3.46E-05
CPC-STR-PG-24H	1	7.20E-04	(46.5)	1.05E-05	(36.0)		
CPC-MDP-FR-SWA3H	2	4.80E-04	(53.0)	1.00E-05	(37.0)	1.23E-06	3.25E-05
CPC-STR-PG-2A3HR	1	9.00E-05	(65.5)	8.00E-06	(38.0)	9.10E-07	2.73E-05
HPI-XHE-FO-UN2S3	13	4.40E-02	(10.0)	6.80E-06	(39.0)	8.38E-07	2.30E-05
LPI-MDP-FR-B24HR	4	7.20E-04	(46.5)	6.60E-06	(40.5)	6.52E-07	2.15E-05
LPI-MDP-FR-A24HR	4	7.20E-04	(46.5)	6.60E-06	(40.5)	6.52E-07	2.15E-05
CPC-STR-PG-6HR	1	1.80E-04	(56.0)	5.71E-06	(42.0)		
HPI-MOV-FT-1115E	3	3.00E-03	(24.5)	5.63E-06	(44.5)	1.25E-07	2.09E-05
HPI-MOV-FT-1115D	3	3.00E-03	(24.5)	5.63E-06	(44.5)	1.25E-07	2.09E-05
HPI-MOV-FT-1115C	3	3.00E-03	(24.5)	5.63E-06	(44.5)	1.25E-07	2.09E-05
HPI-MOV-FT-1115B	3	3.00E-03	(24.5)	5.63E-06	(44.5)	1.25E-07	2.09E-05
LPI-CKV-OO-CV58	2	1.00E-03	(42.5)	4.50E-06	(47.5)	1.45E-07	1.69E-05

LPI-CKV-OO-CV50	2	1.00E-03	(42.5)	4.50E-06	(47.5)	1.45E-07	1.69E-05
LPR-MOV-FT-1890B	2	3.00E-03	(24.5)	4.49E-06	(49.0)	1.12E-07	1.72E-05
BETA-LPI	2	1.50E-01	(5.0)	3.83E-06	(50.0)	1.11E-07	1.49E-05
HPI-XHE-FO-ALTS3	1	7.40E-02	(7.0)	3.18E-06	(51.0)	4.96E-08	1.22E-05
CPC-MDP-FR-CCA24	2	7.20E-04	(46.5)	2.86E-06	(52.0)	7.55E-08	1.08E-05
HPI-MOV-FT-1867D	3	3.00E-03	(24.5)	2.85E-06	(53.0)	3.31E-07	9.46E-06
RMT-ACT-FA-RMTSB	3	1.60E-03	(38.0)	2.73E-06	(54.5)	2.79E-07	8.82E-06
RMT-ACT-FA-RMTSA	3	1.60E-03	(38.0)	2.73E-06	(54.5)	2.79E-07	8.82E-06
CPC-CKV-OO-CV113	1	1.00E-03	(42.5)	2.17E-06	(56.0)	1.18E-07	8.73E-06
HPI-XHE-FO-ALTIN	1	5.70E-03	(12.0)	1.29E-06	(57.0)	1.74E-07	3.90E-06
CPC-MDP-FR-SWA24	3	3.80E-03	(16.5)	1.04E-06	(58.0)	6.32E-08	3.81E-06
CPC-MDP-FS-SW10B	3	8.00E-03	(11.0)	7.16E-07	(59.0)	1.11E-07	2.09E-06
CPC-MDP-MA-SW10B	1	2.00E-03	(33.5)	4.79E-07	(60.0)	6.83E-08	1.43E-06
CPC-MDP-MA-CC2B	1	2.00E-03	(33.5)	4.11E-07	(61.0)	4.82E-09	1.70E-06
CPC-MDP-FS-CC2B	1	3.00E-03	(24.5)	4.11E-07	(62.0)	4.82E-09	1.70E-06
HPI-XHE-FO-UN2S2	7	3.10E-01	(2.0)	3.62E-07	(63.0)	2.74E-08	1.25E-06
HPI-XHE-FO-ALT	2	6.10E-01	(1.0)	2.08E-07	(64.0)	1.18E-09	7.78E-07
HPI-MDP-FS	1	4.00E-03	(15.0)	1.91E-07	(65.0)	7.96E-09	7.31E-07
CPC-MDP-FR-SWB24	1	3.80E-03	(16.5)	1.52E-07	(66.0)	3.31E-09	6.45E-07
CPC-XHE-FO-REALN	4	7.00E-02	(8.0)	1.38E-07	(67.0)	1.43E-08	4.95E-07
BETA-STR	3	2.63E-01	(3.0)	9.05E-08	(68.0)	2.41E-08	2.16E-07
RMT-XHE-FO-MANS1	2	6.40E-02	(9.0)	1.56E-08	(69.0)	1.46E-10	6.27E-08
BETA-HPI	1	2.10E-01	(4.0)	2.89E-09	(70.0)	7.81E-11	1.10E-08

PLANT DAMAGE STATE GROUP PDS2
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
HPI-MOV-FT-1115C	3	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
LPR-MOV-FT-1860B	10	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
HPI-MOV-FT-1115E	3	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
LPR-MOV-FT-1890B	2	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
LPR-MOV-FT-1860A	12	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
HPI-MOV-FT-1867D	3	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
HPI-MOV-FT-1115D	3	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
LPR-MOV-FT-1890A	4	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
HPI-MOV-FT-1115B	3	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
HPI-MOV-FT	6	3.00E-03	(24.5)	28.0	(5.5)	1.35	0.90
LPR-MOV-FT-1862A	13	5.20E-03	(13.5)	13.2	(11.5)	1.09	0.91
LPR-MOV-FT-1862B	11	5.20E-03	(13.5)	13.2	(11.5)	1.09	0.91
LPI-MDP-FS-SI1A	14	3.00E-03	(24.5)	9.5	(14.5)	1.09	0.91
LPI-MDP-FS	2	3.00E-03	(24.5)	9.5	(14.5)	1.09	0.91
CPC-MDP-FS-CC2B	1	3.00E-03	(24.5)	9.5	(14.5)	1.09	0.91
LPI-MDP-FS-SI1B	14	3.00E-03	(24.5)	9.5	(14.5)	1.09	0.91
BETA-2MOV	12	8.80E-02	(6.0)	7.6	(17.0)	1.06	1.00
RMT-CCF-FA-MSCAL	2	3.00E-04	(55.0)	4.5	(18.0)	1.09	1.00
HPI-CKV-FT-CV410	3	1.00E-04	(60.0)	3.2	(22.0)	1.10	1.01
HPI-CKV-FT-CV25	3	1.00E-04	(60.0)	3.2	(22.0)	1.10	1.01
HPI-CKV-FT-CV225	3	1.00E-04	(60.0)	3.2	(22.0)	1.10	1.01
ACC-CKV-FT-CV145	1	1.00E-04	(60.0)	3.2	(22.0)	1.10	1.01
ACC-CKV-FT-CV130	1	1.00E-04	(60.0)	3.2	(22.0)	1.10	1.01
ACC-CKV-FT-CV128	1	1.00E-04	(60.0)	3.2	(22.0)	1.10	1.01
ACC-CKV-FT-CV147	1	1.00E-04	(60.0)	3.2	(22.0)	1.10	1.01
HPI-XVM-PG-XV24	3	4.00E-05	(69.0)	2.7	(26.0)	1.01	1.00
LPI-MOV-PG-1890C	2	4.40E-04	(54.0)	2.6	(27.0)	1.26	1.03
ACC-MOV-PG-1865C	1	6.50E-04	(49.5)	2.5	(28.5)	1.17	1.01
ACC-MOV-PG-1865B	1	6.50E-04	(49.5)	2.5	(28.5)	1.17	1.01
BETA-LPI	2	1.50E-01	(5.0)	1.0	(30.0)	1.04	0.97
HPI-XHE-FO-UN2S3	13	4.40E-02	(10.0)	0.9	(31.0)	1.03	1.01
CPC-STR-PG-2A3HR	1	9.00E-05	(65.5)	0.9	(32.0)	1.00	1.00
LPR-XHE-FO-HOTLG	2	4.00E-05	(69.0)	0.7	(33.0)	0.99	1.00
HPI-XHE-FO-ALTIN	1	5.70E-03	(12.0)	0.7	(34.0)	1.00	1.00
HPI-MDP-FS	1	4.00E-03	(15.0)	0.7	(35.0)	1.00	1.00
LPI-MDP-MA-SI1B	10	2.00E-03	(33.5)	0.6	(37.5)	1.01	1.00
LPI-MDP-MA-SI1A	10	2.00E-03	(33.5)	0.6	(37.5)	1.01	1.00
CPC-MDP-MA-SW10B	1	2.00E-03	(33.5)	0.6	(37.5)	1.01	1.00
CPC-MDP-MA-CC2B	1	2.00E-03	(33.5)	0.6	(37.5)	1.01	1.00
HPI-CKV-OO-CV258	1	1.00E-03	(42.5)	0.5	(41.5)	1.00	1.00
CPC-CKV-OO-CV113	1	1.00E-03	(42.5)	0.5	(41.5)	1.00	1.00
LPI-CKV-OO-CV58	2	1.00E-03	(42.5)	0.5	(41.5)	1.00	1.00
LPI-CKV-OO-CV50	2	1.00E-03	(42.5)	0.5	(41.5)	1.00	1.00
BETA-STR	3	2.63E-01	(3.0)	0.5	(44.0)		
CPC-MDP-FR-CCA24	2	7.20E-04	(46.5)	0.4	(46.0)		
LPI-MDP-FR-B24HR	4	7.20E-04	(46.5)	0.4	(46.0)		
LPI-MDP-FR-A24HR	4	7.20E-04	(46.5)	0.4	(46.0)		

BETA-HPI	1	2.10E-01	(4.0)	0.4	(48.0)
HPI-XHE-FO-UN2S2	7	3.10E-01	(2.0)	0.4	(49.0)
ACP-TFM-NO-1H1	1	4.00E-05	(89.0)	0.4	(50.0)
ACP-BAC-ST-1H1	1	9.00E-05	(65.5)	0.0	(59.0)
CPC-XHE-FO-REALN	4	7.00E-02	(8.0)	0.0	(59.0)
LPI-MDP-FR-B21HR	4	6.30E-04	(51.5)	0.0	(59.0)
LPI-MDP-FR-A21HR	4	6.30E-04	(51.5)	0.0	(59.0)
SIS-ACT-FA-SISA	7	1.60E-03	(38.0)	0.0	(59.0)
HPI-XHE-FO-ALTS3	1	7.40E-02	(7.0)	0.0	(59.0)
HPI-XHE-FO-ALT	2	6.10E-01	(1.0)	0.0	(59.0)
CPC-MDP-FS-SW10B	3	8.00E-03	(11.0)	0.0	(59.0)
CPC-MDP-FR-SWB24	1	3.80E-03	(16.5)	0.0	(59.0)
SIS-ACT-FA-SISB	7	1.60E-03	(38.0)	0.0	(59.0)
RMT-XHE-FO-MANS1	2	6.40E-02	(9.0)	0.0	(59.0)
CPC-MDP-FR-SWA3H	2	4.80E-04	(53.0)	0.0	(59.0)
RMT-ACT-FA-RMTSB	3	1.60E-03	(38.0)	0.0	(59.0)
RMT-ACT-FA-RMTSA	3	1.60E-03	(38.0)	0.0	(59.0)
HPI-MDP-FR-1A24H	2	1.60E-03	(38.0)	0.0	(59.0)
CPC-MDP-FR-SWA24	3	3.80E-03	(16.5)	0.0	(59.0)
ACP-BAC-ST-4KV1H	1	9.00E-05	(65.5)	0.0	(59.0)
CPC-STR-PG-6HR	1	1.80E-04	(56.0)		
CPC-STR-PG-3HR	1	9.00E-05	(65.5)		
CPC-STR-PG-24H	1	7.20E-04	(46.5)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-S1	53	1.00E-03 (2.5)	17.3 (1.0)	1.24	0.99
IE-A	45	5.00E-04 (4.0)	7.1 (2.0)	1.14	0.96
IE-S3	19	1.30E-02 (1.0)	1.4 (3.0)	1.01	1.01
IE-S2	10	1.00E-03 (2.5)	0.6 (4.0)	1.00	1.01

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

PLANT DAMAGE STATE GROUP PDS2

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT PDS2 WITH TOP EVENT FREQUENCY 6.35E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	3	3	4.58E-07	0.07203	BETA-2MOV	*	IE-S1	*	LPR-MOV-FT-1862A	+
3	43	3	4.50E-07	0.14287	BETA-LPI	*	IE-S1	*	LPI-MDP-FS	+
4	44	2	4.40E-07	0.21214	IE-S1	*	LPI-MOV-PG-1890C	*		
5	81	2	3.25E-07	0.26330	ACC-MOV-PG-1865C	*	IE-A	+		
6	82	2	3.25E-07	0.31446	ACC-MOV-PG-1865B	*	IE-A	+		
7	1	2	3.00E-07	0.36168	IE-S1	*	RMT-CCF-FA-MSCAL	+		
8	30	3	2.64E-07	0.40324	BETA-2MOV	*	HPI-MOV-FT	*	IE-S1	+
9	4	3	2.64E-07	0.44480	BETA-2MOV	*	IE-S1	*	LPR-MOV-FT-1890A	+
10	2	3	2.64E-07	0.48636	BETA-2MOV	*	IE-S1	*	LPR-MOV-FT-1860A	+
11	87	4	2.54E-07	0.52634	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALTS3	* IE-S3
12	56	3	2.29E-07	0.56235	BETA-2MOV	*	IE-A	*	LPR-MOV-FT-1862A	+
13	116	3	2.25E-07	0.59777	BETA-LPI	*	IE-A	*	LPI-MDP-FS	+
14	117	2	2.20E-07	0.63240	IE-A	*	LPI-MOV-PG-1890C	+		
15	106	4	1.61E-07	0.65775	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALT	* IE-S2
16	31	4	1.61E-07	0.68310	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALT	* IE-S1
17	88	4	1.51E-07	0.70688	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-UN2S3	* IE-S3
18	54	2	1.50E-07	0.73049	IE-A	*	RMT-CCF-FA-MSCAL	+		
19	55	3	1.32E-07	0.75127	BETA-2MOV	*	IE-A	*	LPR-MOV-FT-1860A	+
20	57	3	1.32E-07	0.77205	BETA-2MOV	*	IE-A	*	LPR-MOV-FT-1890A	+
21	107	2	1.00E-07	0.78779	HPI-CKV-FT-CV225	*	IE-S2	+		
22	34	2	1.00E-07	0.80353	HPI-CKV-FT-CV410	*	IE-S1	+		
23	33	2	1.00E-07	0.81927	HPI-CKV-FT-CV225	*	IE-S1	+		
24	32	2	1.00E-07	0.83501	HPI-CKV-FT-CV25	*	IE-S1	+		
25	108	4	8.18E-08	0.84790	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-UN2S2	* IE-S2
26	90	3	5.72E-08	0.85690	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
27	89	3	5.72E-08	0.86590	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S3	*	IE-S3	+
28	85	2	5.00E-08	0.87378	ACC-CKV-FT-CV145	*	IE-A	+		
29	83	2	5.00E-08	0.88165	ACC-CKV-FT-CV128	*	IE-A	+		
30	84	2	5.00E-08	0.88952	ACC-CKV-FT-CV147	*	IE-A	+		
31	86	2	5.00E-08	0.89739	ACC-CKV-FT-CV130	*	IE-A	+		
32	35	2	4.00E-08	0.90368	HPI-XVM-PG-XV24	*	IE-S1	+		
33	5	2	4.00E-08	0.90998	IE-S1	*	LPR-XHE-FO-HOTLG	+		
34	110	3	3.10E-08	0.91486	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
35	109	3	3.10E-08	0.91974	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S2	*	IE-S2	+
36	6	3	2.70E-08	0.92400	IE-S1	*	LPR-MOV-FT-1862A	*	LPR-MOV-FT-1862B	+
37	36	3	2.37E-08	0.92772	BETA-STR	*	CPC-STR-PG-3HR	*	IE-S1	+
38	91	3	2.29E-08	0.93133	HPI-XHE-FO-UN2S3	*	HPI-XVM-PG-XV24	*	IE-S3	+
39	92	3	2.08E-08	0.93460	HPI-CKV-OO-CV258	*	HPI-MDP-FR-1A24H	*	IE-S3	+
40	58	2	2.00E-08	0.93775	IE-A	*	LPR-XHE-FO-HOTLG	+		
41	7	3	1.56E-08	0.94020	IE-S1	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1862B	+
42	10	3	1.56E-08	0.94266	IE-S1	*	LPR-MOV-FT-1860B	*	LPR-MOV-FT-1862A	+
43	9	3	1.56E-08	0.94512	IE-S1	*	LPI-MDP-FS-SI1A	*	LPR-MOV-FT-1862B	+
44	8	3	1.56E-08	0.94757	IE-S1	*	LPI-MDP-FS-SI1B	*	LPR-MOV-FT-1862A	+
45	59	3	1.35E-08	0.94970	IE-A	*	LPR-MOV-FT-1862A	*	LPR-MOV-FT-1862B	+
46	111	3	1.24E-08	0.95165	HPI-XHE-FO-UN2S2	*	HPI-XVM-PG-XV24	*	IE-S2	+

47	11	3	1.04E-08	0.95329	IE-S1	*	LPI-MDP-MA-S11B	*	LPR-MOV-FT-1862A	+
48	12	3	1.04E-08	0.95493	IE-S1	*	LPI-MDP-MA-S11A	*	LPR-MOV-FT-1862B	+
49	13	3	9.00E-09	0.95634	IE-S1	*	LPI-MDP-FS-S11B	*	LPR-MOV-FT-1860A	+
50	14	3	9.00E-09	0.95776	IE-S1	*	LPI-MDP-FS-S11A	*	LPR-MOV-FT-1860B	+
51	45	3	9.00E-09	0.95918	IE-S1	*	LPI-MDP-FS-S11A	*	LPI-MDP-FS-S11B	+
52	15	3	9.00E-09	0.96059	IE-S1	*	LPR-MOV-FT-1890A	*	LPR-MOV-FT-1890B	+
53	38	3	9.00E-09	0.96201	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	IE-S1	+
54	37	3	9.00E-09	0.96343	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	IE-S1	+
55	16	3	9.00E-09	0.96484	IE-S1	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1860B	+
56	60	3	7.80E-09	0.96607	IE-A	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1862B	+
57	61	3	7.80E-09	0.96730	IE-A	*	LPI-MDP-FS-S11B	*	LPR-MOV-FT-1862A	+
58	63	3	7.80E-09	0.96853	IE-A	*	LPR-MOV-FT-1860B	*	LPR-MOV-FT-1862A	+
59	62	3	7.80E-09	0.96975	IE-A	*	LPI-MDP-FS-S11A	*	LPR-MOV-FT-1862B	+
60	93	5	7.58E-09	0.97095	BETA-STR	*	CPC-STR-PG-24H	*	CPC-XHE-FO-REALN	*
61					IE-S3	+			HPI-XHE-FO-UN2S3	*
62	94	3	7.41E-09	0.97211	HPI-CKV-FT-CV225	*	HPI-XHE-FO-ALTIN	*	IE-S3	+
63	18	3	6.00E-09	0.97306	IE-S1	*	LPI-MDP-MA-S11B	*	LPR-MOV-FT-1860A	+
64	17	3	6.00E-09	0.97400	IE-S1	*	LPI-MDP-MA-S11A	*	LPR-MOV-FT-1860B	+
65	47	3	6.00E-09	0.97495	IE-S1	*	LPI-MDP-FS-S11A	*	LPI-MDP-MA-S11B	+
66	46	3	6.00E-09	0.97589	IE-S1	*	LPI-MDP-FS-S11B	*	LPI-MDP-MA-S11A	+
67	65	3	5.20E-09	0.97671	IE-A	*	LPI-MDP-MA-S11A	*	LPR-MOV-FT-1862B	+
68	64	3	5.20E-09	0.97753	IE-A	*	LPI-MDP-MA-S11B	*	LPR-MOV-FT-1862A	+
69	96	4	5.15E-09	0.97834	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	HPI-XHE-FO-UN2S3	*
70	95	4	5.15E-09	0.97915	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	HPI-XHE-FO-UN2S3	*
71	49	3	4.80E-09	0.97991	IE-S1	*	LPI-MDP-FS-S11B	*	SIS-ACT-FA-SISA	+
72	48	3	4.80E-09	0.98066	IE-S1	*	LPI-MDP-FS-S11A	*	SIS-ACT-FA-SISB	+
73	118	3	4.50E-09	0.98137	IE-A	*	LPI-MDP-FS-S11A	*	LPI-MDP-FS-S11B	+
74	69	3	4.50E-09	0.98208	IE-A	*	LPR-MOV-FT-1860A	*	LPR-MOV-FT-1860B	+
75	68	3	4.50E-09	0.98279	IE-A	*	LPR-MOV-FT-1890A	*	LPR-MOV-FT-1890B	+
76	67	3	4.50E-09	0.98350	IE-A	*	LPI-MDP-FS-S11A	*	LPR-MOV-FT-1860B	+
77	66	3	4.50E-09	0.98420	IE-A	*	LPI-MDP-FS-S11B	*	LPR-MOV-FT-1860A	+
78	39	3	3.84E-09	0.98481	CPC-MDP-FR-SWA3H	*	CPC-MDP-FS-SW10B	*	IE-S1	+
79	98	3	3.51E-09	0.98536	ACP-BAC-ST-1H1	*	HPI-MOV-FT-1867D	*	IE-S3	+
80	97	3	3.51E-09	0.98591	ACP-BAC-ST-4KV1H	*	HPI-MOV-FT-1867D	*	IE-S3	+
81	20	3	3.28E-09	0.98643	IE-S1	*	LPI-MDP-FR-B21HR	*	LPR-MOV-FT-1862A	+
82	19	3	3.28E-09	0.98694	IE-S1	*	LPI-MDP-FR-A21HR	*	LPR-MOV-FT-1862B	+
83	51	3	3.20E-09	0.98745	IE-S1	*	LPI-MDP-MA-S11A	*	SIS-ACT-FA-SISB	+
84	50	3	3.20E-09	0.98795	IE-S1	*	LPI-MDP-MA-S11B	*	SIS-ACT-FA-SISA	+
85	53	3	3.00E-09	0.98842	IE-S1	*	LPI-CKV-OO-CV58	*	LPI-MDP-FS-S11A	+
86	52	3	3.00E-09	0.98890	IE-S1	*	LPI-CKV-OO-CV50	*	LPI-MDP-FS-S11B	+
87	71	3	3.00E-09	0.98937	IE-A	*	LPI-MDP-MA-S11B	*	LPR-MOV-FT-1860A	+
88	70	3	3.00E-09	0.98984	IE-A	*	LPI-MDP-MA-S11A	*	LPR-MOV-FT-1860B	+
89	119	3	3.00E-09	0.99031	IE-A	*	LPI-MDP-FS-S11B	*	LPI-MDP-MA-S11A	+
90	120	3	3.00E-09	0.99079	IE-A	*	LPI-MDP-FS-S11A	*	LPI-MDP-MA-S11B	+
91	113	4	2.79E-09	0.99122	HPI-MOV-FT-1115B	*	HPI-MOV-FT-1115D	*	HPI-XHE-FO-UN2S2	*
92	112	4	2.79E-09	0.99166	HPI-MOV-FT-1115C	*	HPI-MOV-FT-1115E	*	HPI-XHE-FO-UN2S2	*
93	114	3	2.56E-09	0.99207	IE-S2	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+
94	21	3	2.56E-09	0.99247	IE-S1	*	RMT-ACT-FA-RMTSA	*	RMT-ACT-FA-RMTSB	+
95	40	3	2.56E-09	0.99287	IE-S1	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+
96	122	3	2.40E-09	0.99325	IE-A	*	LPI-MDP-FS-S11B	*	SIS-ACT-FA-SISA	+
97	121	3	2.40E-09	0.99363	IE-A	*	LPI-MDP-FS-S11A	*	SIS-ACT-FA-SISB	+
98	99	4	2.17E-09	0.99397	CPC-CKV-OO-CV113	*	CPC-MDP-FR-SWA24	*	HPI-XHE-FO-UN2S3	*
99	25	3	1.89E-09	0.99427	IE-S1	*	LPI-MDP-FR-A21HR	*	LPI-MDP-FS-S11B	+
100	24	3	1.89E-09	0.99457	IE-S1	*	LPI-MDP-FR-B21HR	*	LPR-MOV-FT-1860A	+
101	23	3	1.89E-09	0.99486	IE-S1	*	LPI-MDP-FR-A21HR	*	LPR-MOV-FT-1860B	+
102	22	3	1.89E-09	0.99516	IE-S1	*	LPI-MDP-FR-B21HR	*	LPI-MDP-FS-S11A	+

103	73	3	1.87E-09	0.99546	IE-A	*	LPI-MDP-FR-B24HR	*	LPR-MOV-FT-1862A	+
104	72	3	1.87E-09	0.99575	IE-A	*	LPI-MDP-FR-A24HR	*	LPR-MOV-FT-1862B	+
105	124	3	1.60E-09	0.99600	IE-A	*	LPI-MDP-MA-S11A	*	SIS-ACT-FA-S1SB	+
106	123	3	1.60E-09	0.99625	IE-A	*	LPI-MDP-MA-S11B	*	SIS-ACT-FA-S1SA	+
107	100	3	1.56E-09	0.99650	ACP-TFM-NO-1H1	*	HPI-MOV-FT-1867D	*	IE-S3	+
108	126	3	1.50E-09	0.99674	IE-A	*	LPI-CKV-OO-CV58	*	LPI-MDP-FS-S11A	+
109	125	3	1.50E-09	0.99697	IE-A	*	LPI-CKV-OO-CV50	*	LPI-MDP-FS-S11B	+
110	127	3	1.28E-09	0.99717	IE-A	*	SIS-ACT-FA-S1SA	*	SIS-ACT-FA-S1SB	+
111	74	3	1.28E-09	0.99737	IE-A	*	RMT-ACT-FA-RMTSA	*	RMT-ACT-FA-RMTSB	+
112	27	3	1.26E-09	0.99757	IE-S1	*	LPI-MDP-FR-A21HR	*	LPI-MDP-MA-S11B	+
113	26	3	1.26E-09	0.99777	IE-S1	*	LPI-MDP-FR-B21HR	*	LPI-MDP-MA-S11A	+
114	101	4	1.24E-09	0.99797	CPC-MDP-FR-CCA24	*	CPC-MDP-FS-CC2B	*	HPI-XHE-FO-UN2S3	*
115	102	5	1.22E-09	0.99816	CPC-MDP-FR-SWA24	*	CPC-MDP-FS-SW10B	*	CPC-XHE-FO-REALN	*
116					IE-S3	+			IE-S3	+
117	78	3	1.08E-09	0.99833	IE-A	*	LPI-MDP-FR-A24HR	*	LPI-MDP-FS-S11B	+
118	77	3	1.08E-09	0.99850	IE-A	*	LPI-MDP-FR-B24HR	*	LPR-MOV-FT-1860A	+
119	76	3	1.08E-09	0.99867	IE-A	*	LPI-MDP-FR-A24HR	*	LPR-MOV-FT-1860B	+
120	75	3	1.08E-09	0.99884	IE-A	*	LPI-MDP-FR-B24HR	*	LPI-MDP-FS-S11A	+
121	115	5	1.03E-09	0.99900	BETA-STR	*	CPC-STR-PG-6HR	*	CPC-XHE-FO-REALN	*
122					IE-S2	+			HPI-XHE-FO-UN2S2	*
123	41	3	9.60E-10	0.99915	CPC-MDP-FR-SWA3H	*	CPC-MDP-MA-SW10B	*	IE-S1	+
124	103	4	8.24E-10	0.99928	CPC-MDP-FR-CCA24	*	CPC-MDP-MA-CC2B	*	HPI-XHE-FO-UN2S3	*
125	104	5	7.69E-10	0.99940	BETA-HPI	*	HPI-MDP-FR-1A24H	*	HPI-MDP-FS	*
126					IE-S3	+			IE-S3	+
127	42	3	7.20E-10	0.99951	CPC-MDP-FS-SW10B	*	CPC-STR-PG-2A3HR	*	IE-S1	+
128	80	3	7.20E-10	0.99963	IE-A	*	LPI-MDP-FR-A24HR	*	LPI-MDP-MA-S11B	+
129	79	3	7.20E-10	0.99974	IE-A	*	LPI-MDP-FR-B24HR	*	LPI-MDP-MA-S11A	+
130	105	5	5.78E-10	0.99983	CPC-MDP-FR-SWA24	*	CPC-MDP-FR-SWB24	*	CPC-XHE-FO-REALN	*
131					IE-S3	+			HPI-XHE-FO-UN2S3	*
132	29	4	5.32E-10	0.99992	IE-S1	*	LPR-MOV-FT-1862A	*	RMT-ACT-FA-RMTSB	*
133	28	4	5.32E-10	1.00000	IE-S1	*	LPR-MOV-FT-1862B	*	RMT-ACT-FA-RMTSA	*
									RMT-XHE-FO-MANS1	+
									RMT-XHE-FO-MANS1	.

SURRY PLANT DAMAGE STATE PDS3
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
NOTQ	277	9.73E-01 (1.0)	4.12E-06 (1.0)		
REC-XHE-FO-DGEN	268	9.00E-01 (2.0)	3.98E-06 (2.0)	1.00E-07	2.12E-05
QS-SBO	281	2.70E-01 (8.0)	3.30E-06 (3.0)	6.60E-08	1.85E-05
NRAC-1HR	33	4.40E-01 (6.0)	2.17E-06 (4.5)	2.82E-08	1.23E-05
AFW-XHE-FO-CST2	33	6.50E-02 (13.0)	2.17E-06 (4.5)	2.82E-08	1.23E-05
OEP-DGN-FS-DG01	99	2.20E-02 (21.5)	1.72E-06 (6.0)	3.12E-08	9.11E-06
NRAC-HALFHR	170	6.00E-01 (3.0)	1.31E-06 (7.0)	2.42E-08	6.51E-06
OEP-DGN-FS	67	2.20E-02 (21.5)	1.02E-06 (8.0)	3.34E-08	3.89E-06
OEP-DGN-FS-DG02	58	2.20E-02 (21.5)	8.92E-07 (9.0)	1.67E-08	4.83E-06
OEP-DGN-FR-6HDG1	67	1.20E-02 (26.0)	8.74E-07 (10.0)	4.48E-09	5.59E-06
OEP-DGN-FS-DG03	58	2.20E-02 (21.5)	8.66E-07 (11.0)	1.62E-08	4.69E-06
AFW-TDP-FS-FW2	78	1.10E-02 (28.5)	6.49E-07 (12.0)	4.34E-09	3.32E-06
NRAC-6HR-AVG	78	1.94E-01 (9.0)	6.42E-07 (13.0)	2.33E-09	3.28E-06
AFW-TDP-MA-FW2	83	1.00E-02 (30.5)	6.40E-07 (14.0)	3.45E-09	3.23E-06
AFW-TDP-FR-2P6HR	70	3.00E-02 (17.5)	6.32E-07 (15.0)	2.17E-09	3.27E-06
BETA-3DG	31	1.80E-02 (24.0)	5.77E-07 (16.0)	1.55E-08	2.38E-06
OEP-DGN-FR-6HDG2	42	1.20E-02 (26.0)	4.78E-07 (17.0)	2.53E-09	2.99E-06
OEP-DGN-FR-6HDG3	40	1.20E-02 (26.0)	4.68E-07 (18.0)	2.39E-09	3.06E-06
BETA-2DG	36	3.80E-02 (14.0)	4.44E-07 (19.5)	9.61E-09	1.72E-06
NOTDG-CCF	36	5.20E-01 (4.0)	4.44E-07 (19.5)		
OEP-DGN-MA-DG01	31	6.00E-03 (33.0)	3.70E-07 (21.0)	1.89E-09	1.43E-06
AFW-XHE-FO-U1SBO	73	8.20E-02 (11.0)	2.84E-07 (22.0)	2.62E-09	1.58E-06
OEP-DGN-MA-DG02	20	6.00E-03 (33.0)	2.00E-07 (23.0)	1.09E-09	7.90E-07
OEP-DGN-MA-DG03	16	6.00E-03 (33.0)	1.86E-07 (24.0)	9.52E-10	7.19E-07
OEP-CRB-FT-15H3	22	3.00E-03 (35.5)	1.45E-07 (25.0)	7.36E-10	5.51E-07
UNIT2-LOW-POWER	24	3.50E-01 (7.0)	1.43E-07 (26.0)		
QS-UNIT2	6	1.60E-01 (10.0)	6.04E-08 (27.0)	7.72E-10	1.95E-07
OEP-CRB-FT-15J3	8	3.00E-03 (35.5)	5.36E-08 (28.0)	3.09E-10	2.11E-07
AFW-TDP-FR-6HRU2	22	3.00E-02 (17.5)	4.13E-08 (29.0)	3.85E-11	3.69E-07
AFW-CKV-OO-CV172	16	1.00E-03 (38.0)	3.61E-08 (30.0)	1.37E-09	1.46E-07
AFW-XHE-FO-U2SBO	4	7.50E-02 (12.0)	2.78E-08 (31.0)	2.33E-10	1.16E-07
AFW-TDP-FS-U2FW2	22	1.10E-02 (28.5)	2.56E-08 (32.0)	4.49E-11	2.13E-07
AFW-TDP-MA-U2FW2	20	1.00E-02 (30.5)	2.23E-08 (33.0)	4.09E-11	1.49E-07
OEP-DGN-FR-DG01	1	2.00E-03 (37.0)	5.11E-09 (34.0)	6.69E-12	1.41E-08
SBO-PORV-DMD	4	4.50E-01 (5.0)	2.39E-09 (35.0)	5.52E-12	4.94E-09
PPS-SOV-OO-1456	2	3.00E-02 (17.5)	1.19E-09 (36.5)	2.76E-12	2.47E-09
PPS-SOV-OO-1455C	2	3.00E-02 (17.5)	1.19E-09 (36.5)	2.76E-12	2.47E-09
AFW-PSF-FC-XCONN	1	1.50E-04 (39.0)	6.14E-10 (38.0)	1.90E-11	2.50E-09
DGN-FTO	198	3.39E-02 (15.0)	-1.08E-07 (39.0)	-6.13E-07	-8.91E-10

E-268

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
------------	-------	-------------	-----------------------	----------	----------

IE-T1

281 7.70E-02 (1.0)

4.12E-06 (1.0) 1.10E-07 2.28E-05

E-269

SURRY PLANT DAMAGE STATE PDS3
RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
OEP-DGN-FS-DG01	99	2.20E-02	(21.5)	7.63E-05	(1.0)	2.86E-06	2.89E-04
OEP-DGN-FR-6HDG1	67	1.20E-02	(26.0)	7.19E-05	(2.0)	2.68E-06	2.64E-04
AFW-TDP-MA-FW2	83	1.00E-02	(30.5)	6.33E-05	(3.0)	3.60E-06	2.84E-04
OEP-DGN-MA-DG01	31	6.00E-03	(33.0)	6.13E-05	(4.0)	2.06E-06	2.30E-04
AFW-TDP-FS-FW2	78	1.10E-02	(28.5)	5.83E-05	(5.0)	3.34E-06	2.61E-04
OEP-CRB-FT-15H3	22	3.00E-03	(35.5)	4.83E-05	(6.0)	1.71E-06	1.69E-04
OEP-DGN-FS	67	2.20E-02	(21.5)	4.54E-05	(7.0)	2.40E-06	1.70E-04
OEP-DGN-FS-DG02	58	2.20E-02	(21.5)	3.96E-05	(8.0)	1.51E-06	1.48E-04
OEP-DGN-FR-6HDG2	42	1.20E-02	(26.0)	3.94E-05	(9.0)	1.51E-06	1.45E-04
OEP-DGN-FS-DG03	58	2.20E-02	(21.5)	3.85E-05	(10.0)	1.44E-06	1.44E-04
OEP-DGN-FR-6HDG3	40	1.20E-02	(26.0)	3.83E-05	(11.0)	1.49E-06	1.39E-04
AFW-CKV-OO-CV172	16	1.00E-03	(38.0)	3.61E-05	(12.0)	2.01E-06	1.58E-04
OEP-DGN-MA-DG02	20	6.00E-03	(33.0)	3.31E-05	(13.0)	1.17E-06	1.24E-04
BETA-3DG	31	1.80E-02	(24.0)	3.15E-05	(14.0)	1.38E-06	1.13E-04
AFW-XHE-FO-CST2	33	6.50E-02	(13.0)	3.12E-05	(15.0)	9.92E-07	1.49E-04
OEP-DGN-MA-DG03	16	6.00E-03	(33.0)	3.08E-05	(16.0)	1.03E-06	1.15E-04
AFW-TDP-FR-2P6HR	70	3.00E-02	(17.5)	2.04E-05	(17.0)	4.69E-07	1.02E-04
OEP-CRB-FT-15J3	8	3.00E-03	(35.5)	1.78E-05	(18.0)	5.95E-07	6.65E-05
BETA-2DG	36	3.80E-02	(14.0)	1.12E-05	(19.0)	3.60E-07	4.46E-05
QS-SBO	281	2.70E-01	(8.0)	8.91E-06	(20.0)	2.62E-07	4.26E-05
AFW-PSF-FC-XCONN	1	1.50E-04	(39.0)	4.09E-06	(21.0)	1.71E-07	1.54E-05
AFW-XHE-FO-U1SBO	73	8.20E-02	(11.0)	3.18E-06	(22.0)	5.48E-08	1.67E-05
NRAC-1HR	33	4.40E-01	(6.0)	2.76E-06	(23.0)	3.60E-08	1.54E-05
NRAC-6HR-AVG	78	1.94E-01	(9.0)	2.67E-06	(24.0)	1.77E-08	1.15E-05
OEP-DGN-FR-DG01	1	2.00E-03	(37.0)	2.55E-06	(25.0)	1.74E-08	9.69E-06
AFW-TDP-FS-U2FW2	22	1.10E-02	(28.5)	2.30E-06	(26.0)	4.31E-08	1.14E-05
AFW-TDP-MA-U2FW2	20	1.00E-02	(30.5)	2.21E-06	(27.0)	3.71E-08	1.03E-05
AFW-TDP-FR-6HRU2	22	3.00E-02	(17.5)	1.34E-06	(28.0)	1.17E-08	7.19E-06
NRAC-HALFHR	170	6.00E-01	(3.0)	8.76E-07	(29.0)	1.62E-08	4.26E-06
REC-XHE-FO-DGEN	268	9.00E-01	(2.0)	4.42E-07	(30.0)	2.50E-09	1.82E-06
NOTDG-CCF	36	5.20E-01	(4.0)	4.10E-07	(31.0)		
AFW-XHE-FO-U2SBO	4	7.50E-02	(12.0)	3.43E-07	(32.0)	6.32E-09	1.40E-06
QS-UNIT2	6	1.60E-01	(10.0)	3.17E-07	(33.0)	5.46E-09	1.41E-06
UNIT2-LOW-POWER	24	3.50E-01	(7.0)	2.66E-07	(34.0)		
NOTQ	277	9.73E-01	(1.0)	1.14E-07	(35.0)		
PPS-SOV-OO-1456	2	3.00E-02	(17.5)	3.86E-08	(36.5)	3.05E-10	1.47E-07
PPS-SOV-OO-1455C	2	3.00E-02	(17.5)	3.86E-08	(36.5)	3.05E-10	1.47E-07
SBO-PORV-DMD	4	4.50E-01	(5.0)	2.92E-09	(38.0)	5.15E-12	5.41E-09
DGN-FTO	198	3.39E-02	(15.0)	-3.08E-06	(39.0)	-1.90E-05	-5.73E-08

SURRY PLANT DAMAGE STATE PDS3
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
OEP-DGN-FS-DG02	58	2.20E-02	(21.5)	20.9	(2.5)	1.74	0.75
OEP-DGN-FS-DG03	58	2.20E-02	(21.5)	20.9	(2.5)	1.74	0.75
OEP-DGN-FS-DG01	99	2.20E-02	(21.5)	20.9	(2.5)	1.74	0.75
OEP-DGN-FS	67	2.20E-02	(21.5)	20.9	(2.5)	1.74	0.75
OEP-DGN-FR-6HDG1	67	1.20E-02	(26.0)	14.7	(6.0)	1.25	0.79
OEP-DGN-FR-6HDG2	42	1.20E-02	(26.0)	14.7	(6.0)	1.25	0.79
OEP-DGN-FR-6HDG3	40	1.20E-02	(26.0)	14.7	(6.0)	1.25	0.79
OEP-DGN-FR-DG01	1	2.00E-03	(37.0)	14.2	(8.0)	1.00	1.00
QS-SBO	281	2.70E-01	(8.0)	13.8	(9.0)	1.61	0.95
QS-UNIT2	6	1.60E-01	(10.0)	13.5	(10.0)	1.02	1.00
PPS-SOV-OO-1455C	2	3.00E-02	(17.5)	13.3	(11.5)	1.00	1.00
PPS-SOV-OO-1456	2	3.00E-02	(17.5)	13.3	(11.5)	1.00	1.00
AFW-XHE-FO-CST2	33	6.50E-02	(13.0)	7.7	(13.0)	1.34	0.88
AFW-TDP-MA-FW2	83	1.00E-02	(30.5)	3.1	(14.5)	1.30	1.07
AFW-TDP-MA-U2FW2	20	1.00E-02	(30.5)	3.1	(14.5)	1.30	1.07
AFW-TDP-FS-U2FW2	22	1.10E-02	(28.5)	2.6	(16.5)	1.20	0.95
AFW-TDP-FS-FW2	78	1.10E-02	(28.5)	2.6	(16.5)	1.20	0.95
OEP-DGN-MA-DG01	31	6.00E-03	(33.0)	2.4	(19.0)	1.16	0.96
OEP-DGN-MA-DG02	20	6.00E-03	(33.0)	2.4	(19.0)	1.16	0.96
OEP-DGN-MA-DG03	16	6.00E-03	(33.0)	2.4	(19.0)	1.16	0.96
AFW-TDP-FR-2P6HR	70	3.00E-02	(17.5)	1.9	(21.5)	1.12	1.00
AFW-TDP-FR-6HRU2	22	3.00E-02	(17.5)	1.9	(21.5)	1.12	1.00
NRAC-6HR-AVG	78	1.94E-01	(9.0)	1.7	(23.0)	1.01	0.97
REC-XHE-FO-DGEN	268	9.00E-01	(2.0)	1.4	(24.0)	1.07	0.97
BETA-3DG	31	1.80E-02	(24.0)	1.2	(25.0)	1.07	0.99
SBO-PORV-DMD	4	4.50E-01	(5.0)	0.9	(26.0)	1.00	1.00
AFW-CKV-OO-CV172	16	1.00E-03	(38.0)	0.7	(27.0)	1.00	0.99
AFW-PSF-FC-XCONN	1	1.50E-04	(39.0)	0.7	(28.0)	1.00	1.00
BETA-2DG	36	3.80E-02	(14.0)	0.6	(29.0)	1.02	1.01
OEP-CRB-FT-15J3	8	3.00E-03	(35.5)	0.5	(30.5)		
OEP-CRB-FT-15H3	22	3.00E-03	(35.5)	0.5	(30.5)		
NRAC-1HR	33	4.40E-01	(6.0)	0.4	(32.0)		
AFW-XHE-FO-U2SBO	4	7.50E-02	(12.0)	0.4	(33.0)		
NRAC-HALFHR	170	6.00E-01	(3.0)	0.4	(34.0)		
DGN-FTO	198	3.39E-02	(15.0)	0.4	(35.0)		
AFW-XHE-FO-U1SBO	73	8.20E-02	(11.0)	0.0	(36.0)		
NOTDG-CCF	36	5.20E-01	(4.0)				
UNIT2-LOW-POWER	24	3.50E-01	(7.0)				
NOTQ	277	9.73E-01	(1.0)				

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
------------	-------	------	--------	--	--------	-------------	-------------

IE-T1 281 7.70E-02 (1.0) 25.4 (1.0) 1.72 0.93
* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS
HELD CONSTANT AT ITS MEAN VALUE
TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT
IS NOT HELD CONSTANT

E-272

SURRY PLANT DAMAGE STATE PDS3

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT TRRR-RSYR WITH TOP EVENT FREQUENCY 4.12E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	9	2.43E-07	0.05903	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
3					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*
4					REC-XHE-FO-DGEN	+						
5	2	9	2.43E-07	0.11806	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
6					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
7					REC-XHE-FO-DGEN	+						
8	3	9	2.26E-07	0.17294	AFW-XHE-FO-CST2	*	BETA-2DG	*	IE-T1	*	NOTDG-CCF	*
9					NOTQ	*	NRAC-1HR	*	OEP-DGN-FS	*	QS-SBO	*
10					REC-XHE-FO-DGEN	+						
11	4	8	2.06E-07	0.22293	AFW-XHE-FO-CST2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
12					NRAC-1HR	*	OEP-DGN-FS	*	QS-SBO	*	REC-XHE-FO-DGEN	+
13	8	9	1.33E-07	0.25513	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
14					NRAC-1HR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
15					REC-XHE-FO-DGEN	+						
16	6	9	1.33E-07	0.28732	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
17					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
18					REC-XHE-FO-DGEN	+						
19	5	9	1.33E-07	0.31952	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
20					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
21					REC-XHE-FO-DGEN	+						
22	7	9	1.33E-07	0.35172	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
23					NRAC-1HR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
24					REC-XHE-FO-DGEN	+						
25	9	8	8.05E-08	0.37123	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
26					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
27	10	9	7.24E-08	0.38879	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
28					NRAC-1HR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
29					REC-XHE-FO-DGEN	+						
30	11	9	6.64E-08	0.40489	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
31					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
32					REC-XHE-FO-DGEN	+						
33	14	9	6.64E-08	0.42099	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
34					NRAC-1HR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
35					REC-XHE-FO-DGEN	+						
36	12	9	6.64E-08	0.43709	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
37					NRAC-1HR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
38					REC-XHE-FO-DGEN	+						
39	13	9	6.64E-08	0.45319	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
40					NRAC-1HR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
41					REC-XHE-FO-DGEN	+						
42	16	9	5.62E-08	0.46681	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
43					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*	QS-SBO	*
44					REC-XHE-FO-DGEN	+						
45	15	9	5.62E-08	0.48043	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
46					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*	QS-SBO	*

103					NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
104					REC-XHE-FO-DGEN	+						
105	34	9	3.06E-08	0.69394	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
106					NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
107					REC-XHE-FO-DGEN	+						
108	33	9	3.06E-08	0.70137	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
109					NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
110					REC-XHE-FO-DGEN	+						
111	32	9	3.06E-08	0.70880	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
112					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
113					REC-XHE-FO-DGEN	+						
114	35	9	2.79E-08	0.71555	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
115					NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
116					REC-XHE-FO-DGEN	+						
117	36	9	2.79E-08	0.72231	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
118					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
119					REC-XHE-FO-DGEN	+						
120	38	9	2.79E-08	0.72906	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
121					NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
122					REC-XHE-FO-DGEN	+						
123	37	9	2.79E-08	0.73582	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
124					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
125					REC-XHE-FO-DGEN	+						
126	62	9	2.70E-08	0.74237	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
127					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
128					REC-XHE-FO-DGEN	+						
129	59	9	2.70E-08	0.74892	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
130					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*	QS-SBO	*
131					REC-XHE-FO-DGEN	+						
132	60	9	2.70E-08	0.75547	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
133					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*	QS-SBO	*
134					REC-XHE-FO-DGEN	+						
135	61	9	2.70E-08	0.76203	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
136					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*	QS-SBO	*
137					REC-XHE-FO-DGEN	+						
138	44	9	2.06E-08	0.76702	AFW-TDP-FS-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
139					NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*	QS-UNIT2	*
140					REC-XHE-FO-DGEN	+						
141	46	9	1.87E-08	0.77155	AFW-TDP-MA-FW2	*	BETA-3DG	*	IE-T1	*	NOTQ	*
142					NRAC-HALFHR	*	OEP-DGN-FS	*	/QS-SBO	*	QS-UNIT2	*
143					REC-XHE-FO-DGEN	+						
144	47	8	1.86E-08	0.77606	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
145					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
146	71	9	1.82E-08	0.78046	AFW-TDP-FR-2P6HR	*	BETA-3DG	*	IE-T1	*	NOTQ	*
147					NRAC-6HR-AVG	*	OEP-DGN-FS	*	/QS-SBO	*	QS-UNIT2	*
148					REC-XHE-FO-DGEN	+						
149	39	9	1.81E-08	0.78485	AFW-XHE-FO-CST2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
150					NRAC-1HR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
151					REC-XHE-FO-DGEN	+						
152	48	8	1.69E-08	0.78894	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
153					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+
154	49	9	1.67E-08	0.79299	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
155					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
156					REC-XHE-FO-DGEN	+						
157	77	8	1.64E-08	0.79696	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
158					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG3	*	QS-SBO	+

159	53	9	1.53E-08	0.80068	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
160					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
161					REC-XHE-FO-DGEN	+						
162	52	9	1.53E-08	0.80439	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
163					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
164					REC-XHE-FO-DGEN	+						
165	50	9	1.53E-08	0.80811	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
166					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
167					REC-XHE-FO-DGEN	+						
168	51	9	1.53E-08	0.81183	AFW-TDP-FS-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
169					NRAC-HALFHR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
170					REC-XHE-FO-DGEN	+						
171	54	9	1.52E-08	0.81551	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
172					NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
173					REC-XHE-FO-DGEN	+						
174	83	9	1.47E-08	0.81908	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
175					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FR-6HDG2	*	QS-SBO	*
176					REC-XHE-FO-DGEN	+						
177	58	9	1.39E-08	0.82246	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
178					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
179					REC-XHE-FO-DGEN	+						
180	55	9	1.39E-08	0.82584	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
181					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
182					REC-XHE-FO-DGEN	+						
183	57	9	1.39E-08	0.82922	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
184					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
185					REC-XHE-FO-DGEN	+						
186	56	9	1.39E-08	0.83259	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
187					NRAC-HALFHR	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
188					REC-XHE-FO-DGEN	+						
189	94	9	1.35E-08	0.83587	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
190					NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG03	*	QS-SBO	*
191					REC-XHE-FO-DGEN	+						
192	93	9	1.35E-08	0.83915	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
193					NRAC-6HR-AVG	*	OEP-DGN-FS-DG01	*	OEP-DGN-MA-DG02	*	QS-SBO	*
194					REC-XHE-FO-DGEN	+						
195	92	9	1.35E-08	0.84242	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
196					NRAC-6HR-AVG	*	OEP-DGN-FS-DG03	*	OEP-DGN-MA-DG01	*	QS-SBO	*
197					REC-XHE-FO-DGEN	+						
198	91	9	1.35E-08	0.84570	AFW-TDP-FR-2P6HR	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
199					NRAC-6HR-AVG	*	OEP-DGN-FS-DG02	*	OEP-DGN-MA-DG01	*	QS-SBO	*
200					REC-XHE-FO-DGEN	+						
201	63	10	1.25E-08	0.84872	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
202					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*
203					/QS-SBO	*	REC-XHE-FO-DGEN	+				
204	64	10	1.25E-08	0.85174	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
205					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
206					/QS-SBO	*	REC-XHE-FO-DGEN	+				
207	66	10	1.16E-08	0.85454	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	BETA-2DG	*	IE-T1	*
208					NOTDG-CCF	*	NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS	*
209					/QS-SBO	*	REC-XHE-FO-DGEN	+				
210	68	10	1.13E-08	0.85729	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
211					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG03	*
212					/QS-SBO	*	REC-XHE-FO-DGEN	+				
213	67	10	1.13E-08	0.86004	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
214					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	OEP-DGN-FS-DG02	*

271				NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-MA-DG01	*	QS-SBO	*	
272				REC-XHE-FO-DGEN	+							
273	119	9	7.37E-09	0.90174	AFW-TDP-FR-2P6HR	+	/DGN-FTO	*	IE-T1	*	NOTQ	*
274					NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-MA-DG03	*	QS-SBO	*
275					REC-XHE-FO-DGEN	+						
276	86	9	6.97E-09	0.90343	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
277					NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
278					REC-XHE-FO-DGEN	+						
279	85	9	6.97E-09	0.90511	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
280					NRAC-HALFHR	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
281					REC-XHE-FO-DGEN	+						
282	84	9	6.97E-09	0.90680	AFW-TDP-MA-FW2	*	/DGN-FTO	*	IE-T1	*	NOTQ	*
283					NRAC-HALFHR	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
284					REC-XHE-FO-DGEN	+						
285	87	10	6.79E-09	0.90845	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
286					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
287					/QS-SBO	*	REC-XHE-FO-DGEN	+				
288	90	10	6.79E-09	0.91010	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
289					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
290					/QS-SBO	*	REC-XHE-FO-DGEN	+				
291	89	10	6.79E-09	0.91174	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
292					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
293					/QS-SBO	*	REC-XHE-FO-DGEN	+				
294	88	10	6.79E-09	0.91339	AFW-TDP-FS-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
295					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
296					/QS-SBO	*	REC-XHE-FO-DGEN	+				
297	130	9	6.76E-09	0.91503	AFW-TDP-FR-2P6HR	+	/DGN-FTO	*	IE-T1	*	NOTQ	*
298					NRAC-6HR-AVG	*	OEP-CRB-FT-15J3	*	OEP-DGN-FS-DG01	*	QS-SBO	*
299					REC-XHE-FO-DGEN	+						
300	129	9	6.76E-09	0.91667	AFW-TDP-FR-2P6HR	+	/DGN-FTO	*	IE-T1	*	NOTQ	*
301					NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG03	*	QS-SBO	*
302					REC-XHE-FO-DGEN	+						
303	128	9	6.76E-09	0.91831	AFW-TDP-FR-2P6HR	+	/DGN-FTO	*	IE-T1	*	NOTQ	*
304					NRAC-6HR-AVG	*	OEP-CRB-FT-15H3	*	OEP-DGN-FS-DG02	*	QS-SBO	*
305					REC-XHE-FO-DGEN	+						
306	98	10	6.18E-09	0.91980	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
307					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG03	*
308					/QS-SBO	*	REC-XHE-FO-DGEN	+				
309	95	10	6.18E-09	0.92130	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
310					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
311					/QS-SBO	*	REC-XHE-FO-DGEN	+				
312	97	10	6.18E-09	0.92280	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
313					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
314					/QS-SBO	*	REC-XHE-FO-DGEN	+				
315	96	10	6.18E-09	0.92430	AFW-TDP-MA-FW2	*	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
316					NOTQ	*	NRAC-HALFHR	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
317					/QS-SBO	*	REC-XHE-FO-DGEN	+				
318	138	10	5.99E-09	0.92575	AFW-TDP-FR-2P6HR	+	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
319					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG1	*	OEP-DGN-FS-DG02	*
320					/QS-SBO	*	REC-XHE-FO-DGEN	+				
321	136	10	5.99E-09	0.92720	AFW-TDP-FR-2P6HR	+	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
322					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG2	*	OEP-DGN-FS-DG01	*
323					/QS-SBO	*	REC-XHE-FO-DGEN	+				
324	135	10	5.99E-09	0.92865	AFW-TDP-FR-2P6HR	+	AFW-XHE-FO-U1SBO	*	/DGN-FTO	*	IE-T1	*
325					NOTQ	*	NRAC-6HR-AVG	*	OEP-DGN-FR-6HDG3	*	OEP-DGN-FS-DG01	*
326					/QS-SBO	*	REC-XHE-FO-DGEN	+				

PLANT DAMAGE STATE PDS4

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-V-TRAIN-2	1	4.00E-07 (2.0)	4.00E-07 (2.0)	1.26E-11	1.75E-06
IE-V-TRAIN-3	1	4.00E-07 (2.0)	4.00E-07 (2.0)	1.26E-11	1.75E-06
IE-V-TRAIN-1	1	4.00E-07 (2.0)	4.00E-07 (2.0)	1.26E-11	1.75E-06

PLANT DAMAGE STATE PDS4

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)
IE-V-TRAIN-2	1	4.00E-07 (2.0)	100.0 (2.0)
IE-V-TRAIN-3	1	4.00E-07 (2.0)	100.0 (2.0)
IE-V-TRAIN-1	1	4.00E-07 (2.0)	100.0 (2.0)

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

PLANT DAMAGE STATE PDS4

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
FOR TOP EVENT PDS4 WITH TOP EVENT FREQUENCY 1.20E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	2	1	4.00E-07	0.33333	IE-V-TRAIN-2	+
3	3	1	4.00E-07	0.66667	IE-V-TRAIN-3	+
4	1	1	4.00E-07	1.00000	IE-V-TRAIN-1	.

PLANT DAMAGE STATE GROUP PDSS

TOP EVENT TLYY-YNV CONTAINS 54 EVENTS IN 143 CUT SETS

THE FREQUENCY OF TOP EVENT TLYY-YNV IS 1.84E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT TLYY-YNV

N	1000
MEAN	2.05E-06
STD DEV	1.05E-05
LOWER 5%	7.15E-08
LOWER 25%	2.72E-07
MEDIAN	6.91E-07
UPPER 25%	1.75E-06
UPPER 5%	6.00E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

PLANT DAMAGE STATE GROUP PDS5
RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
AFW-XHE-FO-UNIT2	143	3.60E-02	(12.0)	1.84E-08 (1.0)	7.15E-08	6.00E-08
AFW-PSF-FC-XCONN	23	1.50E-04	(37.0)	8.21E-07 (2.0)	3.32E-08	2.98E-08
HPI-XHE-FO-FDBLD	14	7.10E-02	(6.0)	7.10E-07 (3.0)	1.42E-08	2.45E-08
AFW-CCF-LK-STMBD	20	1.00E-04	(40.5)	5.48E-07 (4.0)	6.60E-10	1.40E-08
PPS-XHE-FO-PORVS	11	4.40E-02	(8.0)	4.91E-07 (5.0)	1.09E-08	1.84E-08
BETA-AFW	23	5.60E-02	(7.0)	1.87E-07 (6.5)	2.38E-09	6.88E-07
AFW-MDP-FS	23	6.30E-03	(22.0)	1.67E-07 (6.5)	2.38E-09	6.88E-07
PPS-MOV-FC-1536	27	3.00E-01	(2.5)	1.68E-07 (8.0)	3.91E-09	5.80E-07
PPS-MOV-FC-1535	24	3.00E-01	(2.5)	1.61E-07 (9.0)	3.54E-09	5.72E-07
PPS-MOV-FT-1536	14	4.00E-02	(10.0)	1.44E-07 (10.5)	2.99E-09	5.02E-07
PPS-MOV-FT-1535	14	4.00E-02	(10.0)	1.44E-07 (10.5)	2.99E-09	5.02E-07
AFW-TDP-FR-2P6HR	22	3.00E-02	(14.0)	1.35E-07 (12.0)	5.14E-10	4.89E-07
AFW-TDP-FR-2P24H	23	1.20E-01	(4.0)	1.26E-07 (13.0)	1.57E-09	5.07E-07
AFW-TDP-FS-FW2	24	1.10E-02	(19.0)	1.11E-07 (14.0)	8.63E-10	4.50E-07
AFW-MDP-FS-FW3A	23	6.30E-03	(22.0)	9.82E-08 (15.0)	2.13E-09	3.29E-07
AFW-MDP-FS-FW3B	22	6.30E-03	(22.0)	9.70E-08 (16.0)	2.04E-09	3.28E-07
AFW-CKV-OO-CV142	7	1.00E-03	(30.0)	5.70E-08 (17.0)	3.77E-10	2.40E-07
AFW-TDP-MA-FW2	16	1.00E-02	(20.0)	4.76E-08 (18.0)	2.00E-10	1.58E-07
BETA-2MOV	10	8.80E-02	(5.0)	2.54E-08 (19.0)	3.62E-10	8.48E-08
AFW-CKV-OO-CV172	6	1.00E-03	(30.0)	2.33E-08 (20.5)	5.44E-10	7.64E-08
AFW-CKV-OO-CV157	6	1.00E-03	(30.0)	2.33E-08 (20.5)	5.44E-10	7.64E-08
AFW-MDP-MA-FW3B	7	2.00E-03	(26.5)	2.12E-08 (22.5)	4.79E-11	6.59E-08
AFW-MDP-MA-FW3A	7	2.00E-03	(26.5)	2.12E-08 (22.5)	4.78E-11	6.59E-08
PPS-MOV-FT	6	4.00E-02	(10.0)	2.09E-08 (24.0)	2.72E-10	6.93E-08
NRAC-HALFHR	15	6.00E-01	(1.0)	1.88E-08 (25.0)	3.94E-10	6.30E-08
PPS-SOV-FT-1455C	3	1.00E-03	(30.0)	9.89E-09 (26.5)	2.54E-10	3.36E-08
PPS-SOV-FT-1456	3	1.00E-03	(30.0)	9.89E-09 (26.5)	2.54E-10	3.36E-08
AFW-ACT-FA-PMP3A	3	6.00E-04	(33.5)	5.51E-09 (28.5)	1.69E-11	1.60E-08
AFW-ACT-FA-PMP3B	3	6.00E-04	(33.5)	5.51E-09 (28.5)	1.69E-11	1.60E-08
OEP-DGN-FC-DG3U2	3	3.40E-02	(13.0)	5.42E-09 (30.0)	8.97E-11	1.95E-08
OEP-DGN-FS-DG03	4	2.20E-02	(15.5)	4.20E-09 (31.5)	6.28E-11	1.50E-08
OEP-DGN-FS-DG01	4	2.20E-02	(15.5)	4.20E-09 (31.5)	6.28E-11	1.50E-08
DCP-BDC-ST-BUS1B	3	9.00E-05	(45.5)	3.52E-09 (33.5)	3.33E-11	1.35E-08
DCP-BDC-ST-BUS1A	3	9.00E-05	(45.5)	3.52E-09 (33.5)	3.33E-11	1.35E-08
AFW-TNK-VF-CST	3	1.00E-06	(50.0)	2.76E-09 (35.0)	8.44E-11	1.05E-08
HPI-MOV-FT-1867C	2	3.00E-03	(24.5)	2.23E-09 (36.5)	9.41E-12	7.51E-09
HPI-MOV-FT-1115B	2	3.00E-03	(24.5)	2.23E-09 (36.5)	9.41E-12	7.51E-09
AFW-MDP-FR-3B6HR	3	1.80E-04	(35.5)	1.85E-09 (38.5)	1.83E-12	4.44E-09
AFW-MDP-FR-3A6HR	3	1.80E-04	(35.5)	1.85E-09 (38.5)	1.83E-12	4.44E-09
OEP-DGN-FR-6HDG3	2	1.20E-02	(17.5)	1.50E-09 (40.5)	7.36E-12	5.51E-09
OEP-DGN-FR-6HDG1	2	1.20E-02	(17.5)	1.50E-09 (40.5)	7.36E-12	5.51E-09
ACP-BAC-ST-4KV1H	2	9.00E-05	(45.5)	1.18E-09 (42.5)	9.07E-12	3.83E-09
ACP-BAC-ST-4KV1J	2	9.00E-05	(45.5)	1.18E-09 (42.5)	9.07E-12	3.83E-09
AFW-CKV-FT-CV172	1	1.00E-04	(40.5)	5.40E-10 (44.5)	1.01E-12	1.80E-09
AFW-CKV-FT-CV157	1	1.00E-04	(40.5)	5.40E-10 (44.5)	1.01E-12	1.80E-09
HPI-CKV-FT-CV225	1	1.00E-04	(40.5)	5.08E-10 (47.0)	1.54E-11	1.83E-09
HPI-CKV-FT-CV410	1	1.00E-04	(40.5)	5.08E-10 (47.0)	1.54E-11	1.83E-09

HPI-CKV-FT-CV25	1	1.00E-04 (40.5)	5.08E-10 (47.0)	1.54E-11	1.83E-09
AFW-XVM-PG-XV183	1	4.00E-05 (48.5)	2.18E-10 (49.5)	4.05E-13	6.29E-10
AFW-XVM-PG-XV188	1	4.00E-05 (48.5)	2.18E-10 (49.5)	4.05E-13	6.29E-10

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK		
			REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T2	65	9.40E-01 (1.0)	1.48E-08 (1.0)	4.82E-08	4.88E-08
IE-T5A	25	5.00E-03 (3.5)	1.38E-07 (2.5)	1.20E-09	4.52E-07
IE-T5B	25	5.00E-03 (3.5)	1.38E-07 (2.5)	1.20E-09	4.52E-07
IE-T1	28	7.70E-02 (2.0)	7.54E-08 (4.0)	2.08E-09	2.85E-07

PLANT DAMAGE STATE GROUP PDSS
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
AFW-PSF-FC-XCONN	23	1.50E-04	(37.0)	5.47E-03	(1.0)	3.81E-04	1.78E-02
AFW-CCF-LK-STMBD	20	1.00E-04	(40.5)	5.46E-03	(2.0)	3.81E-04	1.77E-02
AFW-TNK-VF-CST	3	1.00E-06	(50.0)	2.76E-03	(3.0)	1.45E-04	1.00E-02
AFW-CKV-OO-CV142	7	1.00E-03	(30.0)	5.70E-05	(4.0)	5.37E-07	2.31E-04
AFW-XHE-FO-UNIT2	143	3.60E-02	(12.0)	4.91E-05	(5.0)	5.40E-08	1.55E-04
DCP-BDC-ST-BUS1B	3	9.00E-05	(45.5)	3.91E-05	(6.5)	1.05E-08	1.49E-04
DCP-BDC-ST-BUS1A	3	9.00E-05	(45.5)	3.91E-05	(6.5)	1.05E-08	1.49E-04
AFW-MDP-FS	23	8.30E-03	(22.0)	2.63E-05	(8.0)	5.53E-07	1.04E-04
AFW-CKV-OO-CV172	6	1.00E-03	(30.0)	2.33E-05	(9.5)	9.45E-07	8.49E-05
AFW-CKV-OO-CV157	6	1.00E-03	(30.0)	2.33E-05	(9.5)	9.45E-07	8.49E-05
AFW-MDP-FS-FW3A	23	8.30E-03	(22.0)	1.55E-05	(11.0)	6.47E-07	4.95E-05
AFW-MDP-FS-FW3B	22	8.30E-03	(22.0)	1.53E-05	(12.0)	5.94E-07	4.91E-05
ACP-BAC-ST-4KV1J	2	9.00E-05	(45.5)	1.31E-05	(13.5)	3.06E-07	4.46E-05
ACP-BAC-ST-4KV1H	2	9.00E-05	(45.5)	1.31E-05	(13.5)	3.06E-07	4.46E-05
PPS-XHE-FO-PORVS	11	4.40E-02	(8.0)	1.07E-05	(15.0)	5.15E-07	3.47E-05
AFW-MDP-MA-FW3B	7	2.00E-03	(26.5)	1.06E-05	(16.5)	1.63E-07	3.36E-05
AFW-MDP-MA-FW3A	7	2.00E-03	(26.5)	1.06E-05	(16.5)	1.63E-07	3.36E-05
AFW-TDP-FS-FW2	24	1.10E-02	(19.0)	9.95E-08	(18.0)	4.98E-07	3.11E-05
PPS-SOV-FT-1455C	3	1.00E-03	(30.0)	9.88E-08	(19.5)	4.21E-07	3.22E-05
PPS-SOV-FT-1456	3	1.00E-03	(30.0)	9.88E-08	(19.5)	4.21E-07	3.22E-05
HPI-XHE-FO-FDBLD	14	7.10E-02	(6.0)	9.29E-08	(21.0)	4.25E-07	2.89E-05
AFW-MDP-FR-3A6HR	3	1.80E-04	(35.5)	9.18E-08	(22.5)	6.33E-08	2.95E-05
AFW-MDP-FR-3B6HR	3	1.80E-04	(35.5)	9.18E-08	(22.5)	6.33E-08	2.95E-05
AFW-ACT-FA-PMP3A	3	6.00E-04	(33.5)	9.17E-08	(24.5)	6.33E-08	2.95E-05
AFW-ACT-FA-PMP3B	3	6.00E-04	(33.5)	9.17E-08	(24.5)	6.33E-08	2.95E-05
AFW-XVM-PG-XV183	1	4.00E-05	(48.5)	5.40E-08	(26.5)	1.45E-08	1.81E-05
AFW-XVM-PG-XV168	1	4.00E-05	(48.5)	5.40E-08	(26.5)	1.45E-08	1.81E-05
AFW-CKV-FT-CV172	1	1.00E-04	(40.5)	5.40E-08	(28.5)	1.45E-08	1.81E-05
AFW-CKV-FT-CV157	1	1.00E-04	(40.5)	5.40E-08	(28.5)	1.45E-08	1.81E-05
HPI-CKV-FT-CV225	1	1.00E-04	(40.5)	5.08E-08	(31.0)	2.64E-07	1.70E-05
HPI-CKV-FT-CV410	1	1.00E-04	(40.5)	5.08E-08	(31.0)	2.64E-07	1.70E-05
HPI-CKV-FT-CV25	1	1.00E-04	(40.5)	5.08E-08	(31.0)	2.64E-07	1.70E-05
AFW-TDP-MA-FW2	16	1.00E-02	(20.0)	4.72E-08	(33.0)	1.27E-07	1.60E-05
AFW-TDP-FR-2P8HR	22	3.00E-02	(14.0)	4.38E-08	(34.0)	9.67E-08	1.48E-05
PPS-MOV-FT-1535	14	4.00E-02	(10.0)	3.46E-08	(35.5)	1.17E-07	1.17E-05
PPS-MOV-FT-1536	14	4.00E-02	(10.0)	3.46E-08	(35.5)	1.17E-07	1.17E-05
BETA-AFW	23	5.60E-02	(7.0)	2.82E-08	(37.0)	6.55E-08	1.17E-05
AFW-TDP-FR-2P24H	23	1.20E-01	(4.0)	9.21E-07	(38.0)	2.09E-08	3.91E-06
HPI-MOV-FT-1867C	2	3.00E-03	(24.5)	7.42E-07	(39.5)	1.60E-08	2.47E-06
HPI-MOV-FT-1115B	2	3.00E-03	(24.5)	7.42E-07	(39.5)	1.60E-08	2.47E-06
PPS-MOV-FT	6	4.00E-02	(10.0)	5.01E-07	(41.0)	1.04E-08	1.80E-06
PPS-MOV-FC-1536	27	3.00E-01	(2.5)	3.88E-07	(42.0)	1.37E-08	1.48E-06
PPS-MOV-FC-1535	24	3.00E-01	(2.5)	3.76E-07	(43.0)	1.23E-08	1.45E-06
BETA-2MOV	10	8.80E-02	(5.0)	2.63E-07	(44.0)	4.98E-09	8.96E-07
OEP-DGN-FS-DG03	4	2.20E-02	(15.5)	1.87E-07	(45.5)	5.07E-09	6.33E-07
OEP-DGN-FS-DG01	4	2.20E-02	(15.5)	1.87E-07	(45.5)	5.07E-09	6.33E-07
OEP-DGN-FC-DG3U2	3	3.40E-02	(13.0)	1.54E-07	(47.0)	4.12E-09	5.61E-07

OEP-DGN-FR-6HDG3	2	1.20E-02 (17.5)	1.23E-07 (48.5)	2.99E-09	4.18E-07
OEP-DGN-FR-6HDG1	2	1.20E-02 (17.5)	1.23E-07 (48.5)	2.99E-09	4.18E-07
NRAC-HALFHR	15	6.00E-01 (1.0)	1.12E-08 (50.0)	2.30E-10	4.20E-08

PLANT DAMAGE STATE GROUP PDS5
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK	(RANK)	Y.05/TE.05*	Y.95/TE.95*
AFW-XHE-FO-UNIT2	143	3.80E-02	(12.0)	43.5	(1.0)	2.83	0.94
AFW-CCF-LK-STMBD	20	1.00E-04	(40.5)	10.2	(2.0)	1.61	1.01
AFW-PSF-FC-XCONN	23	1.50E-04	(37.0)	7.9	(3.0)	1.38	0.88
HPI-XHE-FO-FDBLD	14	7.10E-02	(6.0)	7.2	(4.0)	1.23	0.98
PPS-XHE-FO-PORVS	11	4.40E-02	(8.0)	3.8	(5.0)	1.13	0.92
AFW-TDP-FR-2P6HR	22	3.00E-02	(14.0)	3.3	(6.0)	1.07	0.99
AFW-TDP-FR-2P24H	23	1.20E-01	(4.0)	1.9	(7.0)	1.05	0.94
AFW-TDP-FS-FW2	24	1.10E-02	(19.0)	1.9	(8.0)	1.08	1.00
BETA-AFW	23	5.60E-02	(7.0)	1.7	(9.0)	1.02	0.95
AFW-MDP-FS-FW3A	23	6.30E-03	(22.0)	1.4	(11.0)	1.05	0.98
AFW-MDP-FS	23	6.30E-03	(22.0)	1.4	(11.0)	1.05	0.98
AFW-MDP-FS-FW3B	22	6.30E-03	(22.0)	1.4	(11.0)	1.05	0.98
PPS-MOV-FT-1536	14	4.00E-02	(10.0)	1.3	(14.0)	1.05	1.01
PPS-MOV-FT-1535	14	4.00E-02	(10.0)	1.3	(14.0)	1.05	1.01
PPS-MOV-FT	6	4.00E-02	(10.0)	1.3	(14.0)	1.05	1.01
PPS-MOV-FC-1535	24	3.00E-01	(2.5)	1.1	(16.5)	1.03	0.99
PPS-MOV-FC-1536	27	3.00E-01	(2.5)	1.1	(16.5)	1.03	0.99
AFW-TDP-MA-FW2	16	1.00E-02	(20.0)	1.0	(18.0)	1.04	1.01
HPI-MOV-FT-1867C	2	3.00E-03	(24.5)	0.5	(19.5)		
HPI-MOV-FT-1115B	2	3.00E-03	(24.5)	0.5	(19.5)		
AFW-MDP-FR-3B6HR	3	1.80E-04	(35.5)	0.5	(21.5)		
AFW-MDP-FR-3A6HR	3	1.80E-04	(35.5)	0.5	(21.5)		
BETA-2MOV	10	8.80E-02	(5.0)	0.5	(23.0)		
PPS-SOV-FT-1455C	3	1.00E-03	(30.0)	0.4	(24.5)		
PPS-SOV-FT-1456	3	1.00E-03	(30.0)	0.4	(24.5)		
DCP-BDC-ST-BUS1B	3	9.00E-05	(45.5)	0.4	(27.5)		
DCP-BDC-ST-BUS1A	3	9.00E-05	(45.5)	0.4	(27.5)		
ACP-BAC-ST-4KV1J	2	9.00E-05	(45.5)	0.4	(27.5)		
ACP-BAC-ST-4KV1H	2	9.00E-05	(45.5)	0.4	(27.5)		
OEP-DGN-FS-DG03	4	2.20E-02	(15.5)	0.3	(30.5)		
OEP-DGN-FS-DG01	4	2.20E-02	(15.5)	0.3	(30.5)		
AFW-MDP-MA-FW3B	7	2.00E-03	(26.5)	0.2	(32.5)		
AFW-MDP-MA-FW3A	7	2.00E-03	(26.5)	0.2	(32.5)		
HPI-CKV-FT-CV225	1	1.00E-04	(40.5)	0.0	(42.0)		
AFW-CKV-FT-CV172	1	1.00E-04	(40.5)	0.0	(42.0)		
AFW-XVM-PG-XV183	1	4.00E-05	(48.5)	0.0	(42.0)		
AFW-XVM-PG-XV168	1	4.00E-05	(48.5)	0.0	(42.0)		
AFW-CKV-FT-CV157	1	1.00E-04	(40.5)	0.0	(42.0)		
AFW-ACT-FA-PMP3A	3	6.00E-04	(33.5)	0.0	(42.0)		
AFW-TNK-VF-CST	3	1.00E-06	(50.0)	0.0	(42.0)		
OEP-DGN-FR-6HDG3	2	1.20E-02	(17.5)	0.0	(42.0)		
AFW-CKV-OO-CV172	6	1.00E-03	(30.0)	0.0	(42.0)		
OEP-DGN-FR-6HDG1	2	1.20E-02	(17.5)	0.0	(42.0)		
OEP-DGN-FC-DG3U2	3	3.40E-02	(13.0)	0.0	(42.0)		
NRAC-HALFHR	15	6.00E-01	(1.0)	0.0	(42.0)		
AFW-CKV-OO-CV157	6	1.00E-03	(30.0)	0.0	(42.0)		
HPI-CKV-FT-CV410	1	1.00E-04	(40.5)	0.0	(42.0)		

HPI-CKV-FT-CV25	1	1.00E-04	(40.5)	0.0	(42.0)
AFW-CKV-OO-CV142	7	1.00E-03	(30.0)	0.0	(42.0)
AFW-ACT-FA-PMP3B	3	6.00E-04	(33.5)	0.0	(42.0)

 UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T2	65	9.40E-01 (1.0)	15.4 (1.0)	1.48	0.95
IE-T5A	25	5.00E-03 (3.5)	3.4 (2.5)	1.14	0.95
IE-T5B	25	5.00E-03 (3.5)	3.4 (2.5)	1.14	0.95
IE-T1	28	7.70E-02 (2.0)	0.3 (4.0)		

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS
 HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT
 IS NOT HELD CONSTANT

PLANT DAMAGE STATE GROUP PDS5

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT TLYY-YNV WITH TOP EVENT FREQUENCY 1.84E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	4	3.60E-07	0.19637	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	HPI-XHE-FO-FDBLD *	IE-T2	+
3	2	4	2.40E-07	0.32729	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	HPI-XHE-FO-FDBLD *	IE-T2	+
4	50	4	2.23E-07	0.44899	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2	PPS-XHE-FO-PORVS	+
5	51	4	1.49E-07	0.53012	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2	PPS-XHE-FO-PORVS	+
6	52	6	6.30E-08	0.56447	AFW-MDP-FS *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	BETA-AFW	*
7					IE-T2	PPS-XHE-FO-PORVS			+
8	53	5	6.09E-08	0.59766	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2	PPS-MOV-FC-1535	*
9					PPS-MOV-FT-1535				+
10	54	5	6.09E-08	0.63085	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T2	PPS-MOV-FC-1536	*
11					PPS-MOV-FT-1536				+
12	56	5	4.06E-08	0.65297	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2	PPS-MOV-FC-1535	*
13					PPS-MOV-FT-1535				+
14	55	5	4.06E-08	0.67510	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T2	PPS-MOV-FC-1536	*
15					PPS-MOV-FT-1536				+
16	94	4	3.40E-08	0.69364	AFW-MDP-FS-FW3B *	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	IE-T5A	+
17	119	4	3.40E-08	0.71218	AFW-MDP-FS-FW3A *	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	IE-T5B	+
18	95	3	2.70E-08	0.72689	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T5A		+
19	120	3	2.70E-08	0.74180	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T5B		+
20	3	5	2.64E-08	0.75600	AFW-CKV-OO-CV142 *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	HPI-XHE-FO-FDBLD	*
21					IE-T2				+
22	4	6	2.54E-08	0.76986	AFW-MDP-FS *	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	BETA-AFW	*
23					HPI-XHE-FO-FDBLD	IE-T2			+
24	22	4	1.83E-08	0.77983	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	IE-T1	PPS-XHE-FO-PORVS	+
25	96	3	1.80E-08	0.78983	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T5A		+
26	121	3	1.80E-08	0.79944	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T5B		+
27	58	7	1.72E-08	0.80891	AFW-MDP-FS *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	BETA-AFW	*
28					IE-T2	PPS-MOV-FC-1535	PPS-MOV-FT-1535		+
29	57	7	1.72E-08	0.81816	AFW-MDP-FS *	AFW-TDP-FR-2P24H *	AFW-XHE-FO-UNIT2 *	BETA-AFW	*
30					IE-T2	PPS-MOV-FC-1536	PPS-MOV-FT-1536		+
31	59	5	1.64E-08	0.82710	AFW-CKV-OO-CV142 *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T2	*
32					PPS-XHE-FO-PORVS				+
33	6	5	1.51E-08	0.83535	AFW-CKV-OO-CV172 *	AFW-MDP-FS-FW3B *	AFW-XHE-FO-UNIT2 *	HPI-XHE-FO-FDBLD	*
34					IE-T2				+
35	5	5	1.51E-08	0.84360	AFW-CKV-OO-CV157 *	AFW-MDP-FS-FW3A *	AFW-XHE-FO-UNIT2 *	HPI-XHE-FO-FDBLD	*
36					IE-T2				+
37	97	4	1.25E-08	0.85039	AFW-MDP-FS-FW3B *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5A	+
38	122	4	1.25E-08	0.85719	AFW-MDP-FS-FW3A *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5B	+
39	23	4	1.22E-08	0.86384	AFW-CCF-LK-STMBD *	AFW-XHE-FO-UNIT2 *	IE-T1	PPS-XHE-FO-PORVS	+
40	98	4	1.13E-08	0.87002	AFW-MDP-FS-FW3B *	AFW-TDP-MA-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5A	+
41	123	4	1.13E-08	0.87619	AFW-MDP-FS-FW3A *	AFW-TDP-MA-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5B	+
42	124	4	1.08E-08	0.88208	AFW-MDP-MA-FW3A *	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	IE-T5B	+
43	99	4	1.08E-08	0.88796	AFW-MDP-MA-FW3B *	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	IE-T5A	+
44	7	6	9.32E-09	0.89304	AFW-MDP-FS *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	BETA-AFW	*
45					HPI-XHE-FO-FDBLD	IE-T2			+
46	8	6	8.48E-09	0.89766	AFW-MDP-FS *	AFW-TDP-MA-FW2 *	AFW-XHE-FO-UNIT2 *	BET	*

47					HPI - XHE - FO - FDBLD	*	IE - T2	+				
48	60	6	5.36E-09	0.90058	AFW - PSF - FC - XCONN	*	AFW - XHE - FO - UNIT2	*	BETA - 2MOV	*	IE - T2	*
49					PPS - MOV - FC - 1536	*	PPS - MOV - FT	+				
50	61	6	5.36E-09	0.90350	AFW - PSF - FC - XCONN	*	AFW - XHE - FO - UNIT2	*	BETA - 2MOV	*	IE - T2	*
51					PPS - MOV - FC - 1535	*	PPS - MOV - FT	+				
52	24	6	5.16E-09	0.90632	AFW - MDP - FS	*	AFW - TDP - FR - 2P24H	*	AFW - XHE - FO - UNIT2	*	BETA - AFW	*
53					IE - T1	*	PPS - XHE - FO - PORV8	+				
54	63	4	5.08E-09	0.90908	AFW - PSF - FC - XCONN	*	AFW - XHE - FO - UNIT2	*	IE - T2	*	PPS - SOV - FT - 1455C	+
55	62	4	5.08E-09	0.91185	AFW - PSF - FC - XCONN	*	AFW - XHE - FO - UNIT2	*	IE - T2	*	PPS - SOV - FT - 1456	+
56	26	5	4.99E-09	0.91457	AFW - PSF - FC - XCONN	*	AFW - XHE - FO - UNIT2	*	IE - T1	*	PPS - MOV - FC - 1535	*
57					PPS - MOV - FT - 1535	+						
58	25	5	4.99E-09	0.91729	AFW - PSF - FC - XCONN	*	AFW - XHE - FO - UNIT2	*	IE - T1	*	PPS - MOV - FC - 1536	*
59					PPS - MOV - FT - 1536	+						
60	65	6	4.47E-09	0.91972	AFW - CKV - OO - CV142	*	AFW - TDP - FS - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T2	*
61					PPS - MOV - FC - 1535	*	PPS - MOV - FT - 1535	+				
62	64	6	4.47E-09	0.92216	AFW - CKV - OO - CV142	*	AFW - TDP - FS - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T2	*
63					PPS - MOV - FC - 1536	*	PPS - MOV - FT - 1536	+				
64	100	4	3.98E-09	0.92431	AFW - MDP - MA - FW3B	*	AFW - TDP - FS - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T5A	+
65	125	4	3.96E-09	0.92647	AFW - MDP - MA - FW3A	*	AFW - TDP - FS - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T5B	+
66	101	4	3.60E-09	0.92643	AFW - MDP - MA - FW3B	*	AFW - TDP - MA - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T5A	+
67	126	4	3.60E-09	0.93039	AFW - MDP - MA - FW3A	*	AFW - TDP - MA - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T5B	+
68	66	6	3.57E-09	0.93234	AFW - CCF - LK - STMBD	*	AFW - XHE - FO - UNIT2	*	BETA - 2MOV	*	IE - T2	*
69					PPS - MOV - FC - 1536	*	PPS - MOV - FT	+				
70	67	6	3.57E-09	0.93429	AFW - CCF - LK - STMBD	*	AFW - XHE - FO - UNIT2	*	BETA - 2MOV	*	IE - T2	*
71					PPS - MOV - FC - 1535	*	PPS - MOV - FT	+				
72	69	4	3.38E-09	0.93613	AFW - CCF - LK - STMBD	*	AFW - XHE - FO - UNIT2	*	IE - T2	*	PPS - SOV - FT - 1456	+
73	68	4	3.38E-09	0.93798	AFW - CCF - LK - STMBD	*	AFW - XHE - FO - UNIT2	*	IE - T2	*	PPS - SOV - FT - 1455C	+
74	28	5	3.33E-09	0.93979	AFW - CCF - LK - STMBD	*	AFW - XHE - FO - UNIT2	*	IE - T1	*	PPS - MOV - FC - 1536	*
75					PPS - MOV - FT - 1536	+						
76	27	5	3.33E-09	0.94160	AFW - CCF - LK - STMBD	*	AFW - XHE - FO - UNIT2	*	IE - T1	*	PPS - MOV - FC - 1535	*
77					PPS - MOV - FT - 1535	+						
78	127	4	3.24E-09	0.94337	AFW - ACT - FA - PMP3A	*	AFW - TDP - FR - 2P6HR	*	AFW - XHE - FO - UNIT2	*	IE - T5B	+
79	102	4	3.24E-09	0.94513	AFW - ACT - FA - PMP3B	*	AFW - TDP - FR - 2P6HR	*	AFW - XHE - FO - UNIT2	*	IE - T5A	+
80	9	6	2.86E-09	0.94669	AFW - MDP - FS - FW3A	*	AFW - MDP - FS - FW3B	*	AFW - TDP - FR - 2P6HR	*	AFW - XHE - FO - UNIT2	*
81					HPI - XHE - FO - FDBLD	*	IE - T2	+				
82	71	6	2.56E-09	0.94808	AFW - CKV - OO - CV157	*	AFW - MDP - FS - FW3A	*	AFW - XHE - FO - UNIT2	*	IE - T2	*
83					PPS - MOV - FC - 1535	*	PPS - MOV - FT - 1535	+				
84	72	6	2.56E-09	0.94948	AFW - CKV - OO - CV157	*	AFW - MOV - FS - FW3A	*	AFW - XHE - FO - UNIT2	*	IE - T2	*
85					PPS - MOV - FC - 1536	*	PPS - MOV - FT - 1536	+				
86	70	6	2.56E-09	0.95067	AFW - CKV - OO - CV172	*	AFW - MDP - FS - FW3B	*	AFW - XHE - FO - UNIT2	*	IE - T2	*
87					PPS - MOV - FC - 1536	*	PPS - MOV - FT - 1536	+				
88	73	6	2.56E-09	0.95227	AFW - CKV - OO - CV172	*	AFW - MDP - FS - FW3B	*	AFW - XHE - FO - UNIT2	*	IE - T2	*
89					PPS - MOV - FC - 1535	*	PPS - MOV - FT - 1535	+				
90	29	6	2.54E-09	0.95365	AFW - PSF - FC - XCONN	*	AFW - XHE - FO - UNIT2	*	IE - T1	*	NRAC - HALFHR	*
91					OEP - DGN - FC - DG3U2	*	PPS - MOV - FC - 1536	+				
92	10	4	2.40E-09	0.95496	AFW - TNK - VF - CST	*	AFW - XHE - FO - UNIT2	*	HP1 - XHE - FO - FDBLD	*	IE - T2	+
93	75	5	2.30E-09	0.95622	AFW - MDP - FS - FW3B	*	AFW - TDP - FR - 2P24H	*	AFW - XHE - FO - UNIT2	*	DCP - BDC - ST - BUS1A	*
94					IE - T2	+						
95	74	5	2.30E-09	0.95747	AFW - MDP - FS - FW3A	*	AFW - TDP - FR - 2P24H	*	AFW - XHE - FO - UNIT2	*	DCP - BDC - ST - BUS1B	*
96					IE - T2	+						
97	103	4	1.98E-09	0.95855	AFW - CKV - OO - CV142	*	AFW - TDP - FS - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T5A	+
98	126	4	1.98E-09	0.95963	AFW - CKV - OO - CV142	*	AFW - TDP - FS - FW2	*	AFW - XHE - FO - UNIT2	*	IE - T5B	+
99	77	7	1.93E-09	0.96066	AFW - MDP - FS - FW3A	*	AFW - MDP - FS - FW3B	*	AFW - TDP - FR - 2P24H	*	AFW - XHE - FO - UNIT2	*
100					IE - T2	*	PPS - MOV - FC - 1536	*	PPS - MOV - FT - 1536	+		
101	76	7	1.93E-09	0.96174	AFW - MDP - FS - FW3A	*	AFW - MDP - FS - FW3B	*	AFW - TDP - FR - 2P24H	*	AFW - XHE - FO - UNIT2	*
102					IE - T2	*	PPS - MOV - FC - 1535	*	PPS - MOV - FT - 1535	+		

103					AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
104					IE-T5A	+						
105	129	5	1.91E-09	0.96381	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
106					IE-T5B	+						
107	30	6	1.70E-09	0.96474	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
108					OEP-DGN-FC-DG3U2	*	PPS-MOV-FC-1536	+				
109	31	6	1.65E-09	0.96563	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
110					OEP-DGN-FS-DG03	*	PPS-MOV-FC-1536	+				
111	32	6	1.65E-09	0.96653	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
112					OEP-DGN-FS-DG01	*	PPS-MOV-FC-1535	+				
113	79	7	1.58E-09	0.96739	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
114					IE-T2	*	PPS-MOV-FC-1536	+	PPS-MOV-FT-1536	+		
115	76	7	1.58E-09	0.96825	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
116					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+		
117	81	8	1.51E-09	0.96907	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*
118					BETA-AFW	*	IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT	+
119	80	8	1.51E-09	0.96990	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*
120					BETA-AFW	*	IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT	+
121	83	6	1.43E-09	0.97068	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
122					IE-T2	*	PPS-SOV-FT-1455C	+				
123	82	6	1.43E-09	0.97146	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
124					IE-T2	*	PPS-SOV-FT-1456	+				
125	85	7	1.43E-09	0.97224	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
126					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+		
127	84	7	1.43E-09	0.97302	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
128					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+		
129	33	7	1.41E-09	0.97379	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
130					IE-T1	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+		
131	34	7	1.41E-09	0.97456	AFW-MDP-FS	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
132					IE-T1	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+		
133	35	5	1.34E-09	0.97529	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
134					PPS-XHE-FO-PORVS	+						
135	12	5	1.34E-09	0.97602	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1667C	*
136					IE-T2	+						
137	11	5	1.34E-09	0.97675	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1115B	*
138					IE-T2	+						
139	105	4	1.19E-09	0.97739	AFW-ACT-FA-PMP3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
140	130	4	1.19E-09	0.97804	AFW-ACT-FA-PMP3A	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
141	36	7	1.18E-09	0.97868	AFW-MDP-FS-FW3A	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
142					NRAC-HALFHR	*	OEP-DGN-FC-DG3U2	*	PPS-MOV-FC-1536	+		
143	107	4	1.13E-09	0.97930	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
144	106	4	1.13E-09	0.97992	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
145	132	4	1.13E-09	0.98054	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
146	131	4	1.13E-09	0.98115	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
147	38	6	1.10E-09	0.98175	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
148					OEP-DGN-FS-DG03	*	PPS-MOV-FC-1536	+				
149	37	6	1.10E-09	0.98235	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
150					OEP-DGN-FS-DG01	*	PPS-MOV-FC-1535	+				
151	108	4	1.08E-09	0.98294	AFW-ACT-FA-PMP3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
152	133	4	1.08E-09	0.98353	AFW-ACT-FA-PMP3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
153	13	6	1.05E-09	0.98410	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*
154					HPI-XHE-FO-FDBLD	*	IE-T2	+				
155	109	4	9.72E-10	0.98463	AFW-MDP-FR-3B6HR	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
156	134	4	9.72E-10	0.98516	AFW-MDP-FR-3A6HR	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+
157	14	6	9.54E-10	0.98568	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*
158					HPI-XHE-FO-FDBLD	*	IE-T2	+				

159	15	6	9.08E-10	0.98617	AFW-MDP-FS-FW3B	*	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*
160					HPI-XHE-FO-FDBLD	*	IE-T2	+				
161	16	6	9.08E-10	0.98667	AFW-MDP-FS-FW3A	*	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*
162					HPI-XHE-FO-FDBLD	*	IE-T2	+				
163	40	6	8.98E-10	0.98716	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
164					OEP-DGN-FR-8HDG1	*	PPS-MOV-FC-1535	+				
165	39	6	8.98E-10	0.98765	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
166					OEP-DGN-FR-8HDG3	*	PPS-MOV-FC-1536	+				
167	18	5	8.93E-10	0.98813	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1867C	*
168					IE-T2	+						
169	17	5	8.93E-10	0.98862	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	BETA-2MOV	*	HPI-MOV-FT-1115B	*
170					IE-T2	+						
171	42	5	7.68E-10	0.98904	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
172					PPS-XHE-FO-PORVS	+						
173	41	5	7.68E-10	0.98946	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
174					PPS-XHE-FO-PORVS	+						
175	44	7	7.61E-10	0.98987	AFW-MDP-FS-FW3B	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
176					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	PPS-MOV-FC-1535	+		
177	43	7	7.61E-10	0.99029	AFW-MDP-FS-FW3A	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
178					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	PPS-MOV-FC-1536	+		
179	87	5	7.31E-10	0.99068	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1B	*
180					IE-T2	+						
181	86	5	7.31E-10	0.99108	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*	DCP-BDC-ST-BUS1A	*
182					IE-T2	+						
183	110	5	6.99E-10	0.99146	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
184					IE-T5A	+						
185	135	5	6.99E-10	0.99184	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
186					IE-T5B	+						
187	46	7	6.92E-10	0.99222	AFW-MDP-FS-FW3B	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
188					NRAC-HALFHR	*	OEP-DGN-FS-DG01	*	PPS-MOV-FC-1535	+		
189	45	7	6.92E-10	0.99260	AFW-MDP-FS-FW3A	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T1	*
190					NRAC-HALFHR	*	OEP-DGN-FS-DG03	*	PPS-MOV-FC-1536	+		
191	89	6	6.91E-10	0.99297	ACP-BAC-ST-4KV1H	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
192					IE-T2	*	PPS-MOV-FC-1535	+				
193	88	6	6.91E-10	0.99335	ACP-BAC-ST-4KV1J	*	AFW-MDP-FS-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
194					IE-T2	*	PPS-MOV-FC-1536	+				
195	111	5	6.35E-10	0.99370	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
196					IE-T5A	+						
197	136	5	6.35E-10	0.99404	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
198					IE-T5B	+						
199	93	7	6.14E-10	0.99438	AFW-MDP-FS-FW3A	*	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
200					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+		
201	92	7	6.14E-10	0.99471	AFW-MDP-FS-FW3B	*	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
202					IE-T2	*	PPS-MOV-FC-1535	*	PPS-MOV-FT-1535	+		
203	91	7	6.14E-10	0.99505	AFW-MDP-FS-FW3A	*	AFW-MDP-MA-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
204					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+		
205	90	7	6.14E-10	0.99538	AFW-MDP-FS-FW3B	*	AFW-MDP-MA-FW3A	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
206					IE-T2	*	PPS-MOV-FC-1536	*	PPS-MOV-FT-1536	+		
207	48	6	5.99E-10	0.99571	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
208					OEP-DGN-FR-8HDG1	*	PPS-MOV-FC-1535	+				
209	47	6	5.99E-10	0.99603	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T1	*	NRAC-HALFHR	*
210					OEP-DGN-FR-8HDG3	*	PPS-MOV-FC-1536	+				
211	49	6	5.81E-10	0.99635	AFW-MDP-FS-FW3A	*	AFW-MDP-FS-FW3B	*	AFW-TDP-FR-2P24H	*	AFW-XHE-FO-UNIT2	*
212					IE-T1	*	PPS-XHE-FO-PORVS	+				
213	112	4	5.40E-10	0.99664	AFW-CKV-FT-CV172	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5A	+
214	137	4	5.40E-10	0.99694	AFW-CKV-FT-CV157	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	IE-T5B	+

215	21	4	5.08E-10	0.99721	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	HPI-CKV-FT-CV225 *	IE-T2	+
216	20	4	5.08E-10	0.99749	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	HPI-CKV-FT-CV410 *	IE-T2	+
217	19	4	5.08E-10	0.99777	AFW-PSF-FC-XCONN *	AFW-XHE-FO-UNIT2 *	HPI-CKV-FT-CV25 *	IE-T2	+
218	113	4	4.86E-10	0.99803	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	DCP-BDC-ST-BUS1B *	IE-T5A	+
219	138	4	4.86E-10	0.99830	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	DCP-BDC-ST-BUS1A *	IE-T5B	+
220	114	4	4.86E-10	0.99858	ACP-BAC-ST-4KV1J *	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	IE-T5A	+
221	139	4	4.86E-10	0.99883	ACP-BAC-ST-4KV1H *	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	IE-T5B	+
222	115	4	3.56E-10	0.99902	AFW-MDP-FR-3B6HR *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5A	+
223	140	4	3.56E-10	0.99921	AFW-MDP-FR-3A6HR *	AFW-TDP-FS-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5B	+
224	116	4	3.24E-10	0.99939	AFW-MDP-FR-3B6HR *	AFW-TDP-MA-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5A	+
225	141	4	3.24E-10	0.99957	AFW-MDP-FR-3A6HR *	AFW-TDP-MA-FW2 *	AFW-XHE-FO-UNIT2 *	IE-T5B	+
226	117	4	2.16E-10	0.99969	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	AFW-XVM-PG-XV183 *	IE-T5A	+
227	142	4	2.16E-10	0.99980	AFW-TDP-FR-2P6HR *	AFW-XHE-FO-UNIT2 *	AFW-XVM-PG-XV188 *	IE-T5B	+
228	118	3	1.80E-10	0.99990	AFW-TNK-VF-CST *	AFW-XHE-FO-UNIT2 *	IE-T5A	+	
229	143	3	1.80E-10	1.00000	AFW-TNK-VF-CST *	AFW-XHE-FO-UNIT2 *	IE-T5B	.	

PLANT DAMAGE STATE GROUP PDS6

TOP EVENT PDS6 CONTAINS 28 EVENTS IN 18 CUT SETS

THE FREQUENCY OF TOP EVENT PDS6 IS 1.51E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT PDS6

N	1000
MEAN	1.56E-06
STD DEV	4.49E-06
LOWER 5%	3.23E-06
LOWER 25%	1.36E-07
MEDIAN	4.24E-07
UPPER 25%	1.31E-06
UPPER 5%	5.87E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

NOMENCLATURE:

PD = PARTIAL DERIVATIVE

TEF = FREQUENCY OF THE TOP EVENT

EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

1. FOR BASE EVENTS AND INITIATING EVENTS:

RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)

2. FOR BASE EVENTS ONLY:

RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

PLANT DAMAGE STATE GROUP PDS6
 RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
K	16	6.00E-05 (19.0)	1.51E-08 (1.5)	3.23E-08	5.87E-08
R	16	1.70E-01 (4.0)	1.51E-08 (1.5)	3.23E-08	5.87E-08
Z	1	1.40E-02 (10.0)	8.43E-07 (3.0)	6.29E-09	3.16E-06
PPS-MOV-FC-1535	3	3.00E-01 (1.5)	2.64E-07 (4.5)	2.00E-09	1.46E-06
PPS-MOV-FC-1536	3	3.00E-01 (1.5)	2.64E-07 (4.5)	2.00E-09	1.46E-06
PPS-MOV-FT-1535	2	4.00E-02 (8.0)	2.43E-07 (6.0)	1.82E-09	1.29E-06
HPI-MOV-FT-1350	1	3.00E-03 (11.0)	2.02E-07 (7.0)	8.17E-10	7.58E-07
PPS-XHE-FO-EMBOR	1	1.00E-03 (13.5)	6.73E-08 (8.0)	2.58E-10	2.40E-07
PPS-MOV-FT	1	4.00E-02 (8.0)	2.13E-08 (9.5)	1.11E-10	1.15E-07
BETA-2MOV	1	6.80E-02 (5.0)	2.13E-08 (9.5)	1.11E-10	1.15E-07
ACP-BAC-ST-4KV1H	1	9.00E-05 (17.0)	6.06E-09 (12.0)	6.02E-11	2.23E-08
ACP-BAC-ST-1H1	1	9.00E-05 (17.0)	6.06E-09 (12.0)	6.02E-11	2.23E-08
ACP-BAC-ST-1H1-2	1	9.00E-05 (17.0)	6.06E-09 (12.0)	6.02E-11	2.23E-08
BETA-SRV	1	7.00E-02 (6.0)	4.71E-09 (14.5)	5.25E-11	1.74E-08
PPS-SOV-FT	1	1.00E-03 (13.5)	4.71E-09 (14.5)	5.25E-11	1.74E-08
HPI-MOV-PG-1350	1	4.00E-05 (20.5)	2.69E-09 (16.5)	4.77E-11	1.08E-08
ACP-TFM-NO-1H1	1	4.00E-05 (20.5)	2.69E-09 (16.5)	4.79E-11	1.15E-08
CVC-MDP-FR-2A1HR	1	3.00E-05 (22.5)	2.02E-09 (18.0)	8.51E-12	6.51E-09
PPS-SOV-FT-1456	1	1.00E-03 (13.5)	8.08E-10 (20.0)	7.39E-12	3.22E-09
PPS-SOV-FT-1455C	1	1.00E-03 (13.5)	8.08E-10 (20.0)	7.39E-12	3.22E-09
PPS-MOV-FT-1536	1	4.00E-02 (8.0)	8.08E-10 (20.0)	7.39E-12	3.22E-09
BETA-STR	1	2.63E-01 (3.0)	5.31E-10 (22.5)	1.11E-11	1.88E-09
CPC-STR-PG-1HR	1	3.00E-05 (22.5)	5.31E-10 (22.5)		

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-TN	1	5.90E+00 (2.0)	8.43E-07 (1.0)	6.29E-09	3.16E-06
IE-T	14	6.60E+00 (1.0)	5.65E-07 (2.0)	9.48E-09	2.82E-06
IE-T7	1	1.00E-02 (3.0)	1.02E-07 (3.0)	3.24E-09	4.04E-07

PLANT DAMAGE STATE GROUP PDS6
 RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB (RANK)	RISK INCREASE (RANK)	LOWER 5%	UPPER 5%
K	16	8.00E-05 (19.0)	2.52E-02 (1.0)	1.45E-03	9.58E-02
CVC-MDP-FR-2A1HR	1	3.00E-05 (22.5)	6.73E-05 (3.0)	1.80E-06	2.49E-04
HPI-MOV-PG-1350	1	4.00E-05 (20.5)	6.73E-05 (3.0)	1.80E-06	2.49E-04
ACP-TFM-NO-1H1	1	4.00E-05 (20.5)	6.73E-05 (3.0)	1.80E-06	2.49E-04
ACP-BAC-ST-1H1-2	1	9.00E-05 (17.0)	6.73E-05 (6.0)	1.80E-06	2.49E-04
ACP-BAC-ST-4KV1H	1	9.00E-05 (17.0)	6.73E-05 (6.0)	1.80E-06	2.49E-04
ACP-BAC-ST-1H1	1	9.00E-05 (17.0)	6.73E-05 (6.0)	1.80E-06	2.49E-04
PPS-XHE-FO-EMBOR	1	1.00E-03 (13.5)	6.73E-05 (8.0)	1.79E-06	2.48E-04
HPI-MOV-FT-1350	1	3.00E-03 (11.0)	6.71E-05 (9.0)	1.80E-06	2.48E-04
Z	1	1.40E-02 (10.0)	5.93E-05 (10.0)	1.60E-06	2.16E-04
CPC-STR-PG-1HR	1	3.00E-05 (22.5)	1.77E-05 (11.0)		
R	16	1.70E-01 (4.0)	7.37E-06 (12.0)	3.46E-07	3.12E-05
PPS-MOV-FT-1535	2	4.00E-02 (8.0)	5.84E-06 (13.0)	7.32E-08	3.20E-05
PPS-SOV-FT	1	1.00E-03 (13.5)	4.71E-06 (14.0)	8.54E-08	1.69E-05
PPS-SOV-FT-1456	1	1.00E-03 (13.5)	8.07E-07 (15.5)	1.16E-08	3.27E-06
PPS-SOV-FT-1455C	1	1.00E-03 (13.5)	8.07E-07 (15.5)	1.16E-08	3.27E-06
PPS-MOV-FC-1536	3	3.00E-01 (1.5)	6.17E-07 (17.5)	8.65E-09	2.03E-06
PPS-MOV-FC-1535	3	3.00E-01 (1.5)	6.17E-07 (17.5)	8.65E-09	2.03E-06
PPS-MOV-FT	1	4.00E-02 (8.0)	5.12E-07 (19.0)	4.12E-09	2.79E-06
BETA-2MOV	1	8.80E-02 (5.0)	2.21E-07 (20.0)	1.67E-09	1.19E-06
BETA-SRV	1	7.00E-02 (6.0)	6.26E-08 (21.0)	1.12E-09	2.36E-07
PPS-MOV-FT-1536	1	4.00E-02 (8.0)	1.94E-08 (22.0)	2.91E-10	8.66E-08
BETA-STR	1	2.63E-01 (3.0)	1.49E-09 (23.0)	3.74E-11	6.09E-09

PLANT DAMAGE STATE GROUP PDS8
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB	(RANK)	% REDUCTION IN THE UNCERTAINTY		Y.05/TE.05*	Y.95/TE.95*
				OF LOG RISK	(RANK)		
K	16	6.00E-05	(19.0)	36.6	(1.0)	2.70	0.98
R	16	1.70E-01	(4.0)	30.7	(2.0)	2.24	1.12
Z	1	1.40E-02	(10.0)	13.5	(3.0)	1.33	1.11
PPS-MOV-FC-1536	3	3.00E-01	(1.5)	3.3	(4.5)	0.92	0.92
PPS-MOV-FC-1535	3	3.00E-01	(1.5)	3.3	(4.5)	0.92	0.92
HPI-MOV-FT-1350	1	3.00E-03	(11.0)	2.5	(6.0)	1.10	0.98
PPS-MOV-FT	1	4.00E-02	(8.0)	1.2	(8.0)	0.98	1.03
PPS-MOV-FT-1536	1	4.00E-02	(8.0)	1.2	(8.0)	0.98	1.03
PPS-MOV-FT-1535	2	4.00E-02	(8.0)	1.2	(8.0)	0.98	1.03
ACP-TFM-NO-1H1	1	4.00E-05	(20.5)	0.8	(10.0)	1.00	1.00
CVC-MDP-FR-2A1HR	1	3.00E-05	(22.5)	0.7	(11.0)	1.00	1.00
PPS-SOV-FT-1456	1	1.00E-03	(13.5)	0.6	(13.0)	1.00	1.00
PPS-SOV-FT-1455C	1	1.00E-03	(13.5)	0.6	(13.0)	1.00	1.00
PPS-SOV-FT	1	1.00E-03	(13.5)	0.6	(13.0)	1.00	1.00
BETA-SRV	1	7.00E-02	(6.0)	0.5	(15.0)	1.00	1.00
BETA-STR	1	2.63E-01	(3.0)	0.0	(19.0)		
ACP-BAC-ST-4KV1H	1	9.00E-05	(17.0)	0.0	(19.0)		
HPI-MOV-PG-1350	1	4.00E-05	(20.5)	0.0	(19.0)		
PPS-XHE-FO-EMBOR	1	1.00E-03	(13.5)	0.0	(19.0)		
BETA-2MOV	1	8.80E-02	(5.0)	0.0	(19.0)		
ACP-BAC-ST-1H1-2	1	9.00E-05	(17.0)	0.0	(19.0)		
ACP-BAC-ST-1H1	1	9.00E-05	(17.0)	0.0	(19.0)		
CPC-STR-PG-1HR	1	3.00E-05	(22.5)	0.0	(19.0)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ	(RANK)	% REDUCTION IN THE UNCERTAINTY		Y.05/TE.05*	Y.95/TE.95*
				OF LOG RISK	(RANK)		
IE-T	14	6.60E+00	(1.0)	13.9	(1.0)	1.15	1.07
IE-TN	1	5.90E+00	(2.0)	13.9	(2.0)	1.26	1.08
IE-T7	1	1.00E-02	(3.0)	1.5	(3.0)	0.94	1.01

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

PLANT DAMAGE STATE GROUP PDS6

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT PDS6 WITH TOP EVENT FREQUENCY 1.51E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSET'S.DNF)

2	1	4	8.43E-07	0.55799	IE-TN	* K	* R	* Z	+
3	2	6	2.42E-07	0.71850	IE-T	* K	* PPS-MOV-FC-1535	* PPS-MOV-FC-1536	*
4					PPS-MOV-FT-1535	* R	+		
5	3	4	2.02E-07	0.85225	HPI-MOV-FT-1350	* IE-T	* K	* R	+
6	16	3	1.02E-07	0.91981	IE-T7	* K	* R	+	
7	4	4	6.73E-08	0.96439	IE-T	* K	* PPS-XHE-FO-EMBOR	* R	+
8	5	7	2.13E-08	0.97851	BETA-2MOV	* IE-T	* K	* PPS-MOV-FC-1535	*
9					PPS-MOV-FC-1536	* PPS-MOV-FT	* R	+	
10	7	4	6.06E-09	0.98253	ACP-BAC-ST-4KV1H	* IE-T	* K	* R	+
11	6	4	6.06E-09	0.98654	ACP-BAC-ST-1H1-2	* IE-T	* K	* R	+
12	8	4	6.06E-09	0.99055	ACP-BAC-ST-1H1	* IE-T	* K	* R	+
13	9	5	4.71E-09	0.99367	BETA-SRV	* IE-T	* K	* PPS-SOV-FT	*
14					R	+			
15	11	4	2.69E-09	0.99546	ACP-TFM-NO-1H1	* IE-T	* K	* R	+
16	10	4	2.69E-09	0.99724	HPI-MOV-PG-1350	* IE-T	* K	* R	+
17	12	4	2.02E-09	0.99858	CVC-MDP-FR-2A1HR	* IE-T	* K	* R	+
18	14	6	8.08E-10	0.99911	IE-T	* K	* PPS-MOV-FC-1536	* PPS-MOV-FT-1536	*
19					PPS-SOV-FT-1456	* R	+		
20	13	6	8.08E-10	0.99965	IE-T	* K	* PPS-MOV-FC-1535	* PPS-MOV-FT-1535	*
21					PPS-SOV-FT-1455C	* R	+		
22	15	5	5.31E-10	1.00000	BETA-STR	* CPC-STR-PG-1HR	* IE-T	* K	*
23					R	.			

SURRY PLANT DAMAGE STATE PDS7

TOP EVENT PDS7 CONTAINS 56 EVENTS IN 38 CUT SETS

THE FREQUENCY OF TOP EVENT PDS7 IS 1.82E-06

DESCRIPTIVE STATISTICS FOR THE FREQUENCY OF TOP EVENT PDS7

N	1000
MEAN	1.84E-06
STD DEV	4.87E-06
LOWER 5%	1.23E-07
LOWER 25%	3.60E-07
MEDIAN	7.36E-07
UPPER 25%	1.68E-06
UPPER 5%	5.95E-06

90% UNCERTAINTY INTERVAL FOR TOP EVENT FREQUENCY (INNERMOST BRACKETS DENOTE INTERQUARTILE RANGE, ASTERISK DENOTES MEDIAN, N DENOTES NOMINAL VALUE AND M DENOTES MEAN)

5% = 1.23E-07 ***LOG SCALE*** 95% = 5.95E-06
|-----[-----*-----]-M-----|

NOMENCLATURE:

PD = PARTIAL DERIVATIVE
TEF = FREQUENCY OF THE TOP EVENT
EV(J) = PROBABILITY OF EVENT J FOR BASE EVENTS
= FREQUENCY OF EVENT J FOR INITIATING EVENTS

MEASURES:

- FOR BASE EVENTS AND INITIATING EVENTS:
RISK REDUCTION = PD x EV(J)
= TEF - TEF(EVALUATED WITH EV(J) = 0)
- FOR BASE EVENTS ONLY:
RISK INCREASE = PD - RISK REDUCTION
= PD x (1 - EV(J))
= TEF(EVALUATED WITH EV(J) = 1) - TEF

SURRY PLANT DAMAGE STATE PDS7
RISK REDUCTION BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
RCS-XHE-FO-DPRT7	15	2.90E-02	(24.0)	1.48E-06 (1.0)		
REC-XHE-FO-DPRES	3	1.40E-02	(25.5)	1.35E-06 (2.0)	2.06E-08	4.88E-06
MSS-SRV-OO-ODSRV	12	1.00E+00	(2.5)	1.25E-06 (3.0)		
PORV-NOT-BLK	10	8.50E-01	(5.0)	8.30E-07 (4.0)	2.21E-08	3.30E-06
PORV-BLK	6	1.50E-01	(10.5)	6.77E-07 (5.5)	1.15E-08	2.35E-06
SGTR-SGSRV-ODMD1	6	1.00E+00	(2.5)	6.77E-07 (5.5)		
SGTR-SGSRV-ODMD2	6	1.50E-01	(10.5)	5.75E-07 (7.0)	9.88E-09	2.10E-06
MSS-XHE-FO-BLOCK	4	6.40E-02	(15.0)	2.54E-07 (9.0)	5.03E-09	9.31E-07
SGTR-SGADV-ODMD	4	1.00E+00	(2.5)	2.54E-07 (9.0)		
MSS-SOV-OO-ODADV	4	1.00E+00	(2.5)	2.54E-07 (9.0)		
RCS-XHE-FO-DPT7D	12	4.00E-01	(7.0)	1.95E-07 (11.0)	6.57E-09	7.72E-07
BETA-2MOV	2	8.80E-02	(12.0)	1.25E-07 (12.5)	5.68E-10	4.34E-07
HPI-MOV-FT	2	3.00E-03	(33.5)	1.25E-07 (12.5)	5.68E-10	4.34E-07
RCS-PORV-ODMD	10	5.00E-01	(6.0)	1.22E-07 (14.0)	8.79E-10	5.04E-07
AFW-XHE-FO-UNIT2	8	3.60E-02	(20.0)	1.05E-07 (15.0)	4.81E-09	3.42E-07
HPI-XHE-FO-UN2S3	5	4.40E-02	(17.0)	8.93E-08 (16.0)	2.29E-09	3.46E-07
HPI-XHE-FO-ALTS3	1	7.40E-02	(13.0)	7.81E-08 (17.0)	3.04E-10	2.88E-07
PPS-SOV-OO-1455C	5	3.00E-02	(22.0)	6.10E-08 (18.5)	4.39E-10	2.52E-07
PPS-SOV-OO-1456	5	3.00E-02	(22.0)	6.10E-08 (18.5)	4.39E-10	2.52E-07
PPS-MOV-OO-1535	3	4.00E-02	(18.5)	5.78E-08 (20.5)	4.23E-10	2.43E-07
PPS-MOV-OO-1536	3	4.00E-02	(18.5)	5.78E-08 (20.5)	4.23E-10	2.43E-07
AFW-PSF-FC-XCONN	1	1.50E-04	(45.0)	5.40E-08 (22.0)	2.87E-09	2.07E-07
IAS-CCF-LF-INAIR	3	2.70E-05	(53.0)	3.72E-08 (23.0)	5.11E-10	1.35E-07
AFW-CCF-LK-STMBD	1	1.00E-04	(47.5)	3.80E-08 (24.0)	4.42E-11	9.33E-08
REC-XHE-FO-GAGRV	2	3.00E-01	(8.0)	2.25E-08 (25.0)	1.79E-10	7.97E-08
HPI-CKV-FT-CV410	1	1.00E-04	(47.5)	1.76E-08 (26.5)	4.92E-10	7.05E-08
HPI-CKV-FT-CV25	1	1.00E-04	(47.5)	1.76E-08 (26.5)	4.92E-10	7.05E-08
RWT-TNK-LF-RWST	1	2.70E-06	(55.0)	1.08E-08 (28.0)	1.23E-10	3.98E-08
SIS-ACT-FA-SISB	1	1.60E-03	(37.5)	1.02E-08 (29.5)	5.74E-11	1.06E-07
SIS-ACT-FA-SISA	1	1.60E-03	(37.5)	1.02E-08 (29.5)	5.74E-11	1.06E-07
MSS-XHE-FO-ISDHR	1	1.40E-02	(25.5)	8.12E-09 (31.5)	1.24E-10	3.09E-08
MSS-CKV-FT-SGDHR	1	2.00E-03	(36.0)	8.12E-09 (31.5)	1.24E-10	3.09E-08
HPI-XVM-PG-XV24	1	4.00E-05	(52.0)	7.04E-09 (33.0)	1.70E-10	2.77E-08
PPS-MOV-FC-OPER	4	2.70E-03	(35.0)	6.52E-09 (34.0)	1.33E-11	2.76E-08
AFW-MDP-FS	3	6.30E-03	(30.0)	6.48E-09 (35.5)	8.09E-11	2.37E-08
BETA-AFW	3	5.60E-02	(16.0)	6.48E-09 (35.5)	8.09E-11	2.37E-08
AFW-TDP-FS-FW2	2	1.10E-02	(27.0)	5.36E-09 (37.0)	4.32E-11	2.05E-08
AFW-CKV-OO-CV142	1	1.00E-03	(40.5)	3.96E-09 (38.0)	3.02E-11	1.54E-08
AFW-TDP-FR-2P6HR	1	3.00E-02	(22.0)	3.81E-09 (39.0)	1.87E-11	1.30E-08
HPI-XHE-FO-ALTIN	1	5.70E-03	(32.0)	2.28E-09 (40.5)	1.94E-11	8.89E-09
HPI-CKV-FT-CV225	1	1.00E-04	(47.5)	2.28E-09 (40.5)	1.94E-11	8.89E-09
AFW-CKV-OO-CV172	1	1.00E-03	(40.5)	2.27E-09 (43.5)	7.15E-11	8.22E-09
AFW-CKV-OO-CV157	1	1.00E-03	(40.5)	2.27E-09 (43.5)	7.15E-11	8.22E-09
AFW-MDP-FS-FW3B	1	6.30E-03	(30.0)	2.27E-09 (43.5)	7.15E-11	8.22E-09
AFW-MDP-FS-FW3A	1	6.30E-03	(30.0)	2.27E-09 (43.5)	7.15E-11	8.22E-09
HPI-MOV-FT-1867D	2	3.00E-03	(33.5)	2.16E-09 (46.0)	9.64E-12	7.91E-09
MSS-XHE-FO-ISAFW	1	6.80E-06	(54.0)	1.97E-09 (47.0)	4.39E-11	7.32E-09

HPI-MDP-FR-1A6HR	1	4.00E-04	(43.0)	1.60E-09	(48.5)	5.94E-11	5.71E-09
HPI-CKV-OO-CV258	1	1.00E-03	(40.5)	1.60E-09	(48.5)	5.94E-11	5.71E-09
AFW-TDP-MA-FW2	1	1.00E-02	(28.0)	1.27E-09	(50.0)	5.11E-12	4.90E-09
ACP-BAC-ST-4KV1H	1	9.00E-05	(50.5)	1.08E-09	(51.5)	4.82E-12	3.96E-09
ACP-BAC-ST-1H1	1	9.00E-05	(50.5)	1.08E-09	(51.5)	4.82E-12	3.96E-09
CPC-XHE-FO-REALN	1	7.00E-02	(14.0)	5.83E-10	(54.0)	6.47E-12	2.27E-09
CPC-STR-PG-6HR	1	1.80E-04	(44.0)	5.83E-10	(54.0)		
BETA-STR	1	2.63E-01	(9.0)	5.83E-10	(54.0)	6.47E-12	2.27E-09

RISK REDUCTION BY INITIATING EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

INIT EVENT	OCCUR	FREQ (RANK)	RISK REDUCTION (RANK)	LOWER 5%	UPPER 5%
IE-T7	38	1.00E-02 (1.0)	1.82E-06 (1.0)	1.23E-07	5.95E-06

SURRY PLANT DAMAGE STATE PDS7
RISK INCREASE BY BASE EVENT (WITH ASSOCIATED UNCERTAINTY INTERVALS)

BASE EVENT	OCCUR	PROB	(RANK)	RISK INCREASE	(RANK)	LOWER 5%	UPPER 5%
RWT-TNK-LF-RWST	1	2.70E-06	(55.0)	4.00E-03	(1.0)	3.87E-04	1.20E-02
IAS-CCF-LF-INAIR	3	2.70E-05	(53.0)	1.38E-03	(2.0)	1.59E-04	4.35E-03
AFW-CCF-LK-STMBD	1	1.00E-04	(47.5)	3.60E-04	(3.0)	2.98E-05	1.16E-03
AFW-PSF-FC-XCONN	1	1.50E-04	(45.0)	3.60E-04	(4.0)	2.98E-05	1.16E-03
MSS-XHE-FO-ISAFF	1	6.80E-06	(54.0)	2.90E-04	(5.0)	7.74E-05	6.97E-04
HPI-XVM-PG-XV24	1	4.00E-05	(52.0)	1.76E-04	(6.0)	7.23E-06	6.23E-04
HPI-CKV-FT-CV410	1	1.00E-04	(47.5)	1.76E-04	(7.5)	7.23E-06	6.23E-04
HPI-CKV-FT-CV25	1	1.00E-04	(47.5)	1.76E-04	(7.5)	7.23E-06	6.23E-04
REC-XHE-FO-DPRES	3	1.40E-02	(25.5)	9.49E-05	(9.0)	1.53E-05	2.62E-04
RCS-XHE-FO-DPRT7	15	2.90E-02	(24.0)	4.95E-05	(10.0)		
HPI-MOV-FT	2	3.00E-03	(33.5)	4.14E-05	(11.0)	1.28E-06	1.62E-04
HPI-CKV-FT-CV225	1	1.00E-04	(47.5)	2.28E-05	(12.0)	3.25E-07	9.25E-05
ACP-BAC-ST-4KV1H	1	9.00E-05	(50.5)	1.20E-05	(13.5)	1.38E-07	4.21E-05
ACP-BAC-ST-1H1	1	9.00E-05	(50.5)	1.20E-05	(13.5)	1.38E-07	4.21E-05
SIS-ACT-FA-SISA	1	1.60E-03	(37.5)	6.39E-06	(15.5)	2.14E-07	2.60E-05
SIS-ACT-FA-SISB	1	1.60E-03	(37.5)	6.39E-06	(15.5)	2.14E-07	2.60E-05
MSS-CKV-FT-SGDHR	1	2.00E-03	(36.0)	4.05E-06	(17.0)	1.00E-07	1.67E-05
HPI-MDP-FR-1A6HR	1	4.00E-04	(43.0)	4.00E-06	(18.0)	2.30E-07	1.29E-05
AFW-CKV-OO-CV142	1	1.00E-03	(40.5)	3.96E-06	(19.0)	4.48E-08	1.58E-05
PORV-BLK	6	1.50E-01	(10.5)	3.84E-06	(20.0)	1.41E-07	1.25E-05
MSS-XHE-FO-BLOCK	4	6.40E-02	(15.0)	3.72E-06	(21.0)	1.52E-07	1.18E-05
SGTR-SGSRV-ODMD2	6	1.50E-01	(10.5)	3.26E-06	(22.0)	1.18E-07	1.01E-05
CPC-STR-PG-6HR	1	1.80E-04	(44.0)	3.24E-06	(23.0)		
AFW-XHE-FO-UNIT2	8	3.60E-02	(20.0)	2.81E-06	(24.0)	3.32E-07	7.86E-06
PPS-MOV-FC-OPER	4	2.70E-03	(35.0)	2.41E-06	(25.0)	2.51E-08	1.03E-05
AFW-CKV-OO-CV172	1	1.00E-03	(40.5)	2.27E-06	(26.5)	1.13E-07	7.66E-06
AFW-CKV-OO-CV157	1	1.00E-03	(40.5)	2.27E-06	(26.5)	1.13E-07	7.66E-06
PPS-SOV-OO-1456	5	3.00E-02	(22.0)	1.97E-06	(28.5)	8.85E-08	7.16E-06
PPS-SOV-OO-1455C	5	3.00E-02	(22.0)	1.97E-06	(28.5)	8.85E-08	7.16E-06
HPI-XHE-FO-UN2S3	5	4.40E-02	(17.0)	1.94E-06	(30.0)	1.05E-07	6.54E-06
HPI-CKV-OO-CV258	1	1.00E-03	(40.5)	1.60E-06	(31.0)	9.92E-08	5.32E-06
PPS-MOV-OO-1536	3	4.00E-02	(18.5)	1.39E-06	(32.5)	1.51E-08	5.96E-06
PPS-MOV-OO-1535	3	4.00E-02	(18.5)	1.39E-06	(32.5)	1.51E-08	5.96E-06
BETA-2MOV	2	8.80E-02	(12.0)	1.29E-06	(34.0)	1.12E-08	4.95E-06
AFW-MDP-FS	3	6.30E-03	(30.0)	1.02E-06	(35.0)	1.70E-08	3.80E-06
HPI-XHE-FO-ALTS3	1	7.40E-02	(13.0)	9.78E-07	(36.0)	8.92E-09	3.75E-06
HPI-MOV-FT-1867D	2	3.00E-03	(33.5)	7.18E-07	(37.0)	2.51E-08	2.63E-06
MSS-XHE-FO-1SDHR	1	1.40E-02	(25.5)	5.72E-07	(38.0)	7.83E-08	1.62E-06
AFW-TDP-FS-FW2	2	1.10E-02	(27.0)	4.82E-07	(39.0)	2.68E-08	1.61E-06
HPI-XHE-FO-ALTIN	1	5.70E-03	(32.0)	3.98E-07	(40.0)	2.31E-08	1.41E-06
AFW-MDP-FS-FW3B	1	6.30E-03	(30.0)	3.58E-07	(41.5)	1.71E-08	1.34E-06
AFW-MDP-FS-FW3A	1	6.30E-03	(30.0)	3.58E-07	(41.5)	1.71E-08	1.34E-06
RCS-XHE-FO-DPT7D	12	4.00E-01	(7.0)	2.92E-07	(43.0)	1.07E-08	1.08E-06
PORV-NOT-BLK	10	8.50E-01	(5.0)	1.46E-07	(44.0)	8.89E-10	5.93E-07
AFW-TDP-MA-FW2	1	1.00E-02	(28.0)	1.26E-07	(45.0)	3.94E-09	4.85E-07
AFW-TDP-FR-2P6HR	1	3.00E-02	(22.0)	1.23E-07	(46.0)	3.91E-09	4.71E-07
RCS-PORV-ODMD	10	5.00E-01	(6.0)	1.22E-07	(47.0)	7.02E-10	4.79E-07

E-303

SURRY PLANT DAMAGE STATE PDS7
 UNCERTAINTY IMPORTANCE BY BASE EVENT

BASE EVENT	OCCUR	PROB (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y .05/TE .05*	Y .95/TE .95*
REC-XHE-FO-DPRES	3	1.40E-02 (25.5)	46.2 (1.0)	2.59	0.88
PORV-BLK	6	1.50E-01 (10.5)	4.0 (2.0)	1.05	1.02
SGTR-SGSRV-ODMD2	6	1.50E-01 (10.5)	3.8 (3.0)	1.03	0.95
HPI-MOV-FT	2	3.00E-03 (33.5)	2.2 (4.5)	1.11	0.98
HPI-MOV-FT-1867D	2	3.00E-03 (33.5)	2.2 (4.5)	1.11	0.98
PPS-SOV-OO-1456	5	3.00E-02 (22.0)	2.1 (6.5)	1.15	1.02
PPS-SOV-OO-1455C	5	3.00E-02 (22.0)	2.1 (6.5)	1.15	1.02
RCS-XHE-FO-DPT7D	12	4.00E-01 (7.0)	1.3 (8.0)	1.07	1.02
AFW-XHE-FO-UNIT2	8	3.60E-02 (20.0)	1.3 (9.0)	1.02	0.98
MSS-XHE-FO-BLOCK	4	6.40E-02 (15.0)	1.0 (10.0)	1.03	1.02
HPI-XHE-FO-UN2S3	5	4.40E-02 (17.0)	0.9 (11.0)	1.00	1.00
MSS-XHE-FO-ISAFF	1	6.80E-06 (54.0)	0.8 (12.0)	1.01	1.00
BETA-STR	1	2.63E-01 (9.0)	0.8 (13.0)	1.00	1.00
IAS-CCF-LF-1NAIR	3	2.70E-05 (53.0)	0.8 (14.0)	1.04	0.99
HPI-XHE-FO-ALTIM	1	5.70E-03 (32.0)	0.8 (15.0)	1.00	1.00
HPI-XHE-FO-ALTS3	1	7.40E-02 (13.0)	0.7 (16.0)	1.01	1.06
AFW-TDP-FS-FW2	2	1.10E-02 (27.0)	0.7 (17.0)	1.01	1.00
BETA-2MOV	2	8.80E-02 (12.0)	0.7 (18.0)	1.06	1.00
RWT-TNK-LF-RWST	1	2.70E-06 (55.0)	0.7 (19.0)	1.00	1.00
PORV-NOT-BLK	10	8.50E-01 (5.0)	0.6 (20.0)	1.03	0.99
PPS-MOV-OO-1536	3	4.00E-02 (18.5)	0.6 (21.5)	1.02	1.05
PPS-MOV-OO-1535	3	4.00E-02 (18.5)	0.6 (21.5)	1.02	1.05
RCS-PORV-ODMD	10	5.00E-01 (6.0)	0.5 (23.0)	1.02	1.03
MSS-XHE-FO-ISDHR	1	1.40E-02 (25.5)	0.5 (24.0)		
AFW-CCF-LK-STMBD	1	1.00E-04 (47.5)	0.5 (25.0)		
HPI-XVM-PG-XV24	1	4.00E-05 (52.0)	0.4 (26.0)		
AFW-TDP-MA-FW2	1	1.00E-02 (28.0)	0.4 (27.0)		
SIS-ACT-FA-SISB	1	1.60E-03 (37.5)	0.3 (28.5)		
SIS-ACT-FA-SISA	1	1.60E-03 (37.5)	0.3 (28.5)		
CPC-XHE-FO-REALN	1	7.00E-02 (14.0)	0.3 (30.0)		
HPI-CKV-FT-CV410	1	1.00E-04 (47.5)	0.2 (32.0)		
HPI-CKV-FT-CV25	1	1.00E-04 (47.5)	0.2 (32.0)		
HPI-CKV-FT-CV225	1	1.00E-04 (47.5)	0.2 (32.0)		
AFW-MDP-FS	3	6.30E-03 (30.0)	0.1 (35.0)		
AFW-MDP-FS-FW3B	1	6.30E-03 (30.0)	0.1 (35.0)		
AFW-MDP-FS-FW3A	1	6.30E-03 (30.0)	0.1 (35.0)		
REC-XHE-FO-GAGRV	2	3.00E-01 (8.0)	0.0 (43.0)		
HPI-MDP-FR-1A6HR	1	4.00E-04 (43.0)	0.0 (43.0)		
AFW-CKV-OO-CV172	1	1.00E-03 (40.5)	0.0 (43.0)		
AFW-TDP-FR-2P6HR	1	3.00E-02 (22.0)	0.0 (43.0)		
AFW-CKV-OO-CV157	1	1.00E-03 (40.5)	0.0 (43.0)		
PPS-MOV-FC-OPER	4	2.70E-03 (35.0)	0.0 (43.0)		
AFW-PSF-FC-XCONN	1	1.50E-04 (45.0)	0.0 (43.0)		
ACP-BAC-ST-1H1	1	9.00E-05 (50.5)	0.0 (43.0)		
HPI-CKV-OO-CV258	1	1.00E-03 (40.5)	0.0 (43.0)		
AFW-CKV-OO-CV142	1	1.00E-03 (40.5)	0.0 (43.0)		
BETA-AFW	3	5.60E-02 (16.0)	0.0 (43.0)		

MSS-CKV-FT-SGDHR	1	2.00E-03	(36.0)	0.0	(43.0)
ACP-BAC-ST-4KV1H	1	9.00E-05	(50.5)	0.0	(43.0)
SGTR-SGSRV-ODMD1	6	1.00E+00	(2.5)		
SGTR-SGADV-ODMD	4	1.00E+00	(2.5)		
RCS-XHE-FO-DPRT7	15	2.90E-02	(24.0)		
CPC-STR-PG-6HR	1	1.80E-04	(44.0)		
MSS-SRV-OO-ODSRV	12	1.00E+00	(2.5)		
MSS-SOV-OO-ODADV	4	1.00E+00	(2.5)		

UNCERTAINTY IMPORTANCE BY INITIATING EVENT

INIT EVENT	OCCUR	FREQ (RANK)	% REDUCTION IN THE UNCERTAINTY OF LOG RISK (RANK)	Y.05/TE.05*	Y.95/TE.95*
IE-T7	38	1.00E-02 (1.0)	31.7 (1.0)	1.77	0.95

* Y.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS HELD CONSTANT AT ITS MEAN VALUE
 TE.xx IS THE .xx QUANTILE OF THE TOP EVENT FREQUENCY WHEN THE EVENT IS NOT HELD CONSTANT

SURRY PLANT DAMAGE STATE PDS7

CUT SET NUMBERS, CUT SET ORDERS, CUT SET FREQUENCIES,
 CUMULATIVE NORMALIZED CUT SET FREQUENCIES AND CUT SETS
 FOR TOP EVENT PDS7 WITH TOP EVENT FREQUENCY 1.82E-06

(THE FIRST COLUMN OF NUMBERS IS THE LINE NUMBERS FOR THE FILE TEMACSETS.DNF)

2	1	6	6.09E-07	0.33530	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	RCS-XHE-FO-DPRT7	*
3					REC-XHE-FO-DPRES	*	SGTR-SGSRV-ODMD1	+				
4	2	6	5.18E-07	0.62031	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	RCS-XHE-FO-DPRT7	*
5					REC-XHE-FO-DPRES	*	SGTR-SGSRV-ODMD2	+				
6	3	7	2.21E-07	0.74191	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
7					RCS-XHE-FO-DPRT7	*	REC-XHE-FO-DPRES	*	SGTR-SGADV-ODMD	+		
8	9	5	7.81E-08	0.78493	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-ALTS3	*	IE-T7	*
9					RCS-XHE-FO-DPT7D	+						
10	21	3	5.40E-08	0.81467	AFW-PSF-FC-XCONN	*	AFW-XHE-FO-UNIT2	*	IE-T7	+		
11	10	5	4.65E-08	0.84025	BETA-2MOV	*	HPI-MOV-FT	*	HPI-XHE-FO-UN2S3	*	IE-T7	*
12					RCS-XHE-FO-DPT7D	+						
13	22	3	3.60E-08	0.86007	AFW-CCF-LK-STMBD	*	AFW-XHE-FO-UNIT2	*	IE-T7	+		
14	29	8	2.61E-08	0.87444	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-OO-1535	*
15					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
16	30	8	2.61E-08	0.88881	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-OO-1536	*
17					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
18	31	8	2.22E-08	0.90102	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-OO-1535	*
19					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
20	32	8	2.22E-08	0.91324	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-OO-1536	*
21					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
22	12	4	1.76E-08	0.92293	HPI-CKV-FT-CV25	*	HPI-XHE-FO-UN2S3	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
23	11	4	1.76E-08	0.93262	HPI-CKV-FT-CV410	*	HPI-XHE-FO-UN2S3	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
24	7	6	1.47E-08	0.94071	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*
25					PORV-NOT-BLK	*	SGTR-SGADV-ODMD	+				
26	4	6	1.22E-08	0.94739	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*
27					REC-XHE-FO-GAGRV	*	SGTR-SGSRV-ODMD1	+				
28	13	3	1.08E-08	0.95334	IE-T7	*	RCS-XHE-FO-DPT7D	*	RWT-TNK-LF-RWST	+		
29	5	6	1.03E-08	0.95903	IAS-CCF-LF-INAIR	*	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*
30					REC-XHE-FO-GAGRV	*	SGTR-SGSRV-ODMD2	+				
31	14	4	1.02E-08	0.96466	IE-T7	*	RCS-XHE-FO-DPT7D	*	SIS-ACT-FA-SISA	*	SIS-ACT-FA-SISB	+
32	34	9	9.47E-09	0.96988	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
33					PPS-MOV-OO-1536	*	PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*
34					SGTR-SGADV-ODMD	+						
35	33	9	9.47E-09	0.97509	IE-T7	*	MSS-SOV-OO-ODADV	*	MSS-XHE-FO-BLOCK	*	PORV-NOT-BLK	*
36					PPS-MOV-OO-1535	*	PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*
37					SGTR-SGADV-ODMD	+						
38	6	4	8.12E-09	0.97956	IE-T7	*	MSS-CKV-FT-SGDHR	*	MSS-XHE-FO-ISDHR	*	RCS-XHE-FO-DPRT7	+
39	15	4	7.04E-09	0.98343	HPI-XHE-FO-UN2S3	*	HPI-XVM-PG-XV24	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
40	23	4	3.96E-09	0.98561	AFW-CKV-OO-CV142	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	IE-T7	+
41	24	5	3.81E-09	0.98771	AFW-MDP-FS	*	AFW-TDP-FR-2P6HR	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
42					IE-T7	+						
43	16	4	2.28E-09	0.98897	HPI-CKV-FT-CV225	*	HPI-XHE-FO-ALTIN	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
44	26	4	2.27E-09	0.99022	AFW-CKV-OO-CV157	*	AFW-MDP-FS-FW3A	*	AFW-XHE-FO-UNIT2	*	IE-T7	+
45	25	4	2.27E-09	0.99147	AFW-CKV-OO-CV172	*	AFW-MDP-FS-FW3B	*	AFW-XHE-FO-UNIT2	*	IE-T7	+
46	8	3	1.97E-09	0.99255	IE-T7	*	MSS-XHE-FO-1SAFW	*	RCS-XHE-FO-DPRT7	+		

47	36	8	1.76E-09	0.99352	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-FC-OPER	*
48					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
49	35	8	1.76E-09	0.99449	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-BLK	*	PPS-MOV-FC-OPER	*
50					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD1	+
51	17	4	1.60E-09	0.99537	HPI-CKV-OO-CV258	*	HPI-MDP-FR-1A6HR	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
52	38	8	1.50E-09	0.99620	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-FC-OPER	*
53					PPS-SOV-OO-1455C	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
54	37	8	1.50E-09	0.99702	IE-T7	*	MSS-SRV-OO-ODSRV	*	PORV-NOT-BLK	*	PPS-MOV-FC-OPER	*
55					PPS-SOV-OO-1456	*	RCS-PORV-ODMD	*	RCS-XHE-FO-DPRT7	*	SGTR-SGSRV-ODMD2	+
56	27	5	1.40E-09	0.99779	AFW-MDP-FS	*	AFW-TDP-FS-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
57					IE-T7	+						
58	28	5	1.27E-09	0.99849	AFW-MDP-FS	*	AFW-TDP-MA-FW2	*	AFW-XHE-FO-UNIT2	*	BETA-AFW	*
59					IE-T7	+						
60	19	4	1.08E-09	0.99908	ACP-BAC-ST-4KV1H	*	HPI-MOV-FT-1867D	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
61	18	4	1.08E-09	0.99968	ACP-BAC-ST-1H1	*	HPI-MOV-FT-1867D	*	IE-T7	*	RCS-XHE-FO-DPT7D	+
62	20	6	5.83E-10	1.00000	BETA-STR	*	CPC-STR-PG-6HR	*	CPC-XHE-FO-REALN	*	HPI-XHE-FO-UN2S3	*
63					IE-T7	*	RCS-XHE-FO-DPT7D	*				

DISTRIBUTION:

Frank Abbey
U. K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
ENGLAND

Kiyoharu Abe
Department of Reactor Safety
Research
Nuclear Safety Research Center
ToKai Research Establishment
JAERI
Tokai-mura, Naga-gun
Ibaraki-ken,
JAPAN

Ulvi Adalioglu
Nuclear Engineering Division
Cekmece Nuclear Research and
Training Centre
P.K.1, Havaalani
Istanbul
TURKEY

Bharat Agrawal
USNRC-RES/AEB
MS: NL/N-344

Kiyoto Aizawa
Safety Research Group
Reactor Research and Development
Project
PNC
9-13m 1-Chome Akasaka
Minatu-Ku
Tokyo
JAPAN

Oguz Akalin
Ontario Hydro
700 University Avenue
Toronto, Ontario
CANADA M5G 1X6

David Aldrich
Science Applications International
Corporation
1710 Goodridge Drive
McLean, VA 22102

Agustin Alonso
University Politecnica De Madrid
J Gutierrez Abascal, 2
28006 Madrid
SPAIN

Christopher Amos
Science Applications International
Corporation
2109 Air Park Road SE
Albuquerque, NM 87106

Richard C. Anoba
Project Engr., Corp. Nuclear Safety
Carolina Power and Light Co.
P. O. Box 1551
Raleigh, NC 27602

George Apostolakis
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024

James W. Ashkar
Boston Edison Company
800 Boylston Street
Boston, MA 02199

Donald H. Ashton
Bechtel Power Corporation
15740 Shady Grove Road
Gaithersburg, MD 20877

J. de Assuncao
Cabinete de Proteccao e Seguranca
Nuclear
Secretario de Estado de Energia
Ministerio da Industria
av. da Republica, 45-6°
1000 Lisbon
PORTUGAL

Mark Averett
Florida Power Corporation
P.O. Box 14042
St. Petersburg, FL 33733

Raymond O. Bagley
Northeast Utilities
P.O. Box 270
Hartford, CT 06141-0270

Juan Bagues
Consejo de Seguridad Nucleare
Sarangela de la Cruz 3
28020 Madrid
SPAIN

George F. Bailey
Washington Public Power Supply
System
P. O. Box 968
Richland, WA 99352

H. Bairiot
Belgonucleaire S A
Rue de Champ de Mars 25
B-1050 Brussels
BELGIUM

Louis Baker
Reactor Analysis and Safety
Division
Building 207
Argonne National Laboratory
9700 South Cass Avenue
Argonne, IL 60439

H-P. Balfanz
TUV-Norddeutschland
Grosse Bahnstrasse 31,
2000 Hamburg 54
FEDERAL REPUBLIC OF GERMANY

Patrick Baranowsky
USNRC-NRR/OEAB
MS: 11E-22

H. Bargmann
Dept. de Mecanique
Inst. de Machines Hydrauliques
et de Mecaniques des Fluides
Ecole Polytechnique de Lausanne
CH-1003 Lausanne
M.E. (ECUBLENS)
CH. 1015 Lausanne
SWITZERLAND

Robert A. Bari
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Richard Barrett
USNRC-NRR/PRAB
MS: 10A-2

Kenneth S. Baskin
S. California Edison Company
P.O. Box 800
Rosemead, CA 91770

J. Basselier
Belgonucleaire S A
Rue du Champ de Mars 25, B-1050
Brussels
BELGIUM

Werner Bastl
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Anton Bayer
BGA/ISH/ZDB
Postfach 1108
D-8042 Neuherberg
FEDERAL REPUBLIC OF GERMANY

Ronald Bayer
Virginia Electric Power Co.
P. O. Box 26666
Richmond, VA 23261

Eric S. Beckjord
Director
USNRC-RES
MS: NL/S-007

Bruce B. Beckley
Public Service Company
P.O. Box 330
Manchester, NH 03105

William Beckner
USNRC-RES/SAIB
MS: NL/S-324

Robert M. Bernero
Director
USNRC-NMSS
MS: 6A-4

Ronald Berryman [2]
Virginia Electric Power Co.
P. O. Box 26666
Richmond, VA 23261

Robert C. Bertucio
NUS Corporation
1301 S. Central Ave, Suite 202
Kent, WA 98032

John H. Bickel
EG&G Idaho
P.O. Box 1625
Idaho Falls, ID 83415

Peter Bieniarz
Risk Management Association
2309 Dietz Farm Road, NW
Albuquerque, NM 87107

Adolf Birkhofer
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

James Blackburn
Illinois Dept. of Nuclear Safety
1035 Outer Park Drive
Springfield, IL 62704

Dennis C. Bley
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

Roger M. Blond
Science Applications Int. Corp.
20030 Century Blvd., Suite 201
Germantown, MD 20874

Simon Board
Central Electricity Generating
Board
Technology and Planning Research
Division
Berkeley Nuclear Laboratory
Berkeley Gloucestershire, GL139PB
UNITED KINGDOM

Mario V. Bonace
Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06101

Gary J. Boyd
Safety and Reliability Optimization
Services
9724 Kingston Pike, Suite 102
Knoxville, TN 37922

Robert J. Breen
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Charles Brinkman
Combustion Engineering
7910 Woodmont Avenue
Bethesda, MD 20814

K. J. Brinkmann
Netherlands Energy Res. Fdtn.
P.O. Box 1
1755ZG Petten NH
NETHERLANDS

Allan R. Brown
Manager, Nuclear Systems and
Safety Department
Ontario Hydro
700 University Ave.
Toronto, Ontario M5G1X6
CANADA

Robert G. Brown
TENERA L.P.
1340 Saratoga-Sunnyvale Rd.
Suite 206
San Jose, CA 95129

Sharon Brown
EI Services
1851 So. Central Place, Suite 201
Kent, WA 98031

Ben Buchbinder
NASA, Code QS
600 Maryland Ave. SW
Washington, DC 20546

R. H. Buchholz
Nutech
6835 Via Del Oro
San Jose, CA 95119

Robert J. Budnitz
Future Resources Associates
734 Alameda
Berkeley, CA 94707

Gary R. Burdick
USNRC-RES/DSR
MS: NL/S-007

Arthur J. Buslik
USNRC-RES/PRAB
MS: NL/S-372

M. Bustraan
Netherlands Energy Res. Fdtn.
P.O. Box 1
1755ZG Petten NH
NETHERLANDS

Nigel E. Buttery
Central Electricity Generating
Board
Booths Hall
Chelford Road, Knutsford
Cheshire, WA168QG
UNITED KINGDOM

Jose I. Calvo Molins
Probabilistic Safety Analysis
Group
Consejo de Seguridad Nuclear
Sor Angela de la Cruz 3, Pl. 6
28020 Madrid
SPAIN

J. F. Campbell
Nuclear Installations Inspectorate
St. Peters House
Balliol Road, Bootle
Merseyside, L20 3LZ
UNITED KINGDOM

Kenneth S. Canady
Duke Power Company
422 S. Church Street
Charlotte, NC 28217

Lennart Carlsson
IAEA A-1400
Wagramerstrasse 5
P.O. Box 100
Vienna, 22
AUSTRIA

Annick Garnino
Electricite de France
32 Rue de Monceau 8EME
Paris, F5008
FRANCE

G. Caropreso
Dept. for Envir. Protect. & Hlth.
ENEA Cre Casaccia
Via Anguillarese, 301
00100 Roma
ITALY

James C. Carter, III
TENERA L.P.
Advantage Place
308 North Peters Road
Suite 280
Knoxville, TN 37922

Eric Cazzoli
Brookhaven National Laboratory
Building 130
Upton, NY 11973

John G. Cesare
SERI
Director Nuclear Licensing
5360 I-55 North
Jackson, MS 39211

S. Chakraborty
Radiation Protection Section
Div. De La Securite Des Inst. Nuc.
5303 Wurenlingen
SWITZERLAND

Sen-I Chang
Institute of Nuclear Energy
Research
P.O. Box 3
Lungtan, 325
TAIWAN

J. R. Chapman
Yankee Atomic Electric Company
1671 Worcester Road
Framingham, MA 01701

Robert F. Christie
Tennessee Valley Authority
400 W. Summit Hill Avenue, W10D190
Knoxville, TN 37902

T. Cianciolo
BWR Assistant Director
ENEA DISP TX612167 ENEUR
Rome
ITALY

Thomas Cochran
Natural Resources Defense Council
1350 New York Ave. NW, Suite 300
Washington, D.C. 20005

Frank Coffman
USNRC-RES/HFB
MS: NL/N-316

Larry Conradi
NUS Corporation
16835 W. Bernardo Drive
Suite 202
San Diego, CA 92127

Peter Cooper
U.K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
UNITED KINGDOM

C. Allin Cornell
110 Coquito Way
Portola Valley, CA 94025

Michael Corradini
University of Wisconsin
1500 Johnson Drive
Madison, WI 53706

E. R. Corran
Nuclear Technology Division
ANSTO Research Establishment
Lucas Heights Research Laboratories
Private Mail Bag 7
Menai, NSW 2234
AUSTRALIA

James Costello
USNRC-RES/SSEB
MS: NL/S-217A

George R. Crane
1570 E. Hobble Creek Dr.
Springville, UT 84663

Mat Crawford
SERI
5360 I-55 North
Jackson, MS 39211

Michael C. Cullingford
Nuclear Safety Division
IAEA
Wagramerstrasse, 5
P.O. Box 100
A-1400 Vienna
AUSTRIA

Garth Cummings
Lawrence Livermore Laboratory
L-91, Box 808
Livermore, CA 94526

Mark A. Cunningham
USNRC-RES/PRAB
MS: NL/S-372

James J. Curry
7135 Salem Park Circle
Mechanicsburg, PA 17055

Peter Cybulskis
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Peter R. Davis
PRD Consulting
1935 Sabin Drive
Idaho Falls, ID 83401

Jose E. DeCarlos
Consejo de Seguridad Nuclear
Sor Angela de la Cruz 3, Pl. 8
28016 Madrid
SPAIN

M. Marc Decreton
Department Technologie
CEN/SCK
Boeretang 200
B-2400 Mol
BELGIUM

Richard S. Denning
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Vernon Denny
Science Applications Int. Corp.
5150 El Camino Real, Suite 3
Los Altos, CA 94303

J. Devooget
Faculte des Sciences Appliques
Universite Libre de Bruxelles
av. Franklin Roosevelt
B-1050 Bruxelles
BELGIUM

R. A. Diederich
Supervising Engineer
Environmental Branch
Philadelphia Electric Co.
2301 Market St.
Philadelphia, PA 19101

Raymond DiSalvo
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Mary T. Drouin
Science Applications International
Corporation
2109 Air Park Road S.E.
Albuquerque, NM 87106

Andrzej Drozd
Stone and Webster
Engineering Corp.
243 Summer Street
Boston, MA 02107

N. W. Edwards
NUTECH
145 Martinville Lane
San Jose, CA 95119

Ward Edwards
Social Sciences Research Institute
University of Southern California
Los Angeles, CA 90089-1111

Joachim Ehrhardt
Kernforschungszentrum Karlsruhe/INR
Postfach 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

Adel A. El-Bassioni
USNRC-NRR/PRAB
MS: 10A-2

J. Mark Elliott
International Energy Associates,
Ltd., Suite 600
600 New Hampshire Ave., NW
Washington, DC 20037

Farouk Eltawila
USNRC-RES/AEB
MS: NL/N-344

Mike Epstein
Fauske and Associates
P. O. Box 1625
16W070 West 83rd Street
Burr Ridge, IL 60521

Malcolm L. Ernst
USNRC-RGN II

F. R. Farmer
The Long Wood, Lyons Lane
Appleton, Warrington
WA4 5ND
UNITED KINGDOM

P. Fehrenback
Atomic Energy of Canada, Ltd.
Chalk River Nuclear Laboratories
Chalk River Ontario, KOJ1P0
CANADA

P. Ficara
ENEA Cre Casaccia
Department for Thermal Reactors
Via Anguillarese, 301
00100 ROMA
ITALY

A. Fiege
Kernforschungszentrum
Postfach 3640
D-7500 Karlsruhe
FEDERAL REPUBLIC OF GERMANY

John Flack
USNRC-RES/SAIB
MS: NLS-324

George F. Flanagan
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

Karl N. Fleming
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

Terry Foppe
Rocky Flats Plant
P. O. Box 464, Building T886A
Golden, CO 80402-0464

Joseph R. Fragola
Science Applications International
Corporation
274 Madison Avenue
New York, NY 10016

Wiktor Frid
Swedish Nuclear Power Inspectorate
Division of Reactor Technology
P. O. Box 27106
S-102 52 Stockholm
SWEDEN

James Fulford
NUS Corporation
910 Clopper Road
Gaithersburg, MD 20878

Urho Fulkkinen
Technical Research Centre of
Finland
Electrical Engineering Laboratory
Otakaari 7 B
SF-02150 Espoo 15
FINLAND

J. B. Fussell
JBF Associates, Inc.
1630 Downtown West Boulevard
Knoxville, TN 37919

John Garrick
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

John Gaunt
British Embassy
3100 Massachusetts Avenue, NW
Washington, DC 20008

Jim Gieseke
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

Frank P. Gillespie
USNRC-NRR/PMAS
MS: 12G-18

Ted Ginsburg
Department of Nuclear Energy
Building 820
Brookhaven National Laboratory
Upton, NY 11973

James C. Glynn
USNRC-RES/PRAB
MS: NL/S-372

P. Govaerts
Departement de la Surete Nucleaire
Association Vincotte
avenue du Roi 157
B-1060 Bruxelles
BELGIUM

George Greene
Building 820M
Brookhaven National Laboratory
Upton, NY 11973

Carrie Grimshaw
Brookhaven National Laboratory
Building 130
Upton, NY 11973

H. J. Van Grol
Energy Technology Division
Energieonderzoek Centrum Nederland
Westerduinweg 3
Postbus 1
NL-1755 Petten ZG
NETHERLANDS

Sergio Guarro
Lawrence Livermore Laboratories
P. O. Box 808
Livermore, CA 94550

Sigfried Hagen
Kernforschungszentrum Karlsruhe
P. O. Box 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

L. Hammar
Statens Karnkraftinspektion
P.O. Box 27106
S-10252 Stockholm
SWEDEN

Stephen Hanauer
Technical Analysis Corp.
6723 Whittier Avenue
Suite 202
McLean, VA 22101

Brad Hardin
USNRC-RES/TRAB
MS: NL/S-169

R. J. Hardwich, Jr.
Virginia Electric Power Co.
P.O. Box 26666
Richmond, Va 23261

Michael R. Haynes
UKAEA Harwell Laboratory
Oxfordshire
Didcot, Oxon., OX11 0RA
ENGLAND

Michael J. Hazzan
Stone & Webster
3 Executive Campus
Cherry Hill, NJ 08034

A. Hedgran
Royal Institute of Technology
Nuclear Safety Department
Bunellvagen 60
10044 Stockholm
SWEDEN

Sharif Heger
UNM Chemical and Nuclear
Engineering Department
Farris Engineering
Room 209
Albuquerque, NM 87131

Jon C. Helton
Dept. of Mathematics
Arizona State University
Tempe, AZ 85287

Robert E. Henry
Fauske and Associates, Inc.
16W070 West 83rd Street
Burr Ridge, IL 60521

P. M. Herttrich
Federal Ministry for the
Environment, Preservation of
Nature and Reactor Safety
Husarenstrasse 30
Postfach 120629
D-5300 Bonn 1
FEDERAL REPUBLIC OF GERMANY

F. Heuser
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

E. F. Hicken
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

D. J. Higson
Radiological Support Group
Nuclear Safety Bureau
Australian Nuclear Science and
Technology Organisation
P.O. Box 153
Rosebery, NSW 2018
AUSTRALIA

Daniel Hirsch
University of California
A. Stevenson Program on
Nuclear Policy
Santa Cruz, CA 95064

H. Hirschmann
Hauptabteilung Sicherheit und
Umwelt
Swiss Federal Institute for
Reactor Research (EIR)
CH-5303 Wurenlingen
SWITZERLAND

Mike Hitchler
Westinghouse Electric Corp.
Savanna River Site
Aiken, SC 29808

Richard Hobbins
EG&G Idaho
P. O. Box 1625
Idaho Falls, ID 83415

Steven Hodge
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

Lars Hoegberg
Office of Regulation and Research
Swedish Nuclear Power Inspectorate
P. O. Box 27106
S-102 52 Stockholm
SWEDEN

Lars Hoeghort
IAEA A-1400
Wagrannerstraase 5
P.O. Box 100
Vienna, 22
AUSTRIA

Edward Hofer
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Peter Hoffmann
Kernforschungszentrum Karlsruhe
Institute for Material
Und Festkorperforschung I
Postfach 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

N. J. Holloway
UKAEA Safety and Reliability
Directorate
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA34NE
UNITED KINGDOM

Stephen C. Hora
University of Hawaii at Hilo
Division of Business Administration
and Economics
College of Arts and Sciences
Hilo, HI 96720-4091

J. Peter Hoseman
Swiss Federal Institute for
Reactor Research
CH-5303, Wurenlingen
SWITZERLAND

Thomas C. Houghton
KMC, Inc.
1747 Pennsylvania Avenue, NW
Washington, DC 20006

Dean Houston
USNRC-ACRS
MS: P-315

Der Yu Hsia
Taiwan Atomic Energy Council
67, Lane 144, Keelung Rd.
Sec. 4
Taipei
TAIWAN

Alejandro Huerta-Bahena
National Commission on Nuclear
Safety and Safeguards (CNSNS)
Insurgentes Sur N. 1776
Col. Florida
C. P. 04230 Mexico, D.F.
MEXICO

Kenneth Hughey [2]
SERI
5360 I-55 North
Jackson, MS 39211

Won-Guk Hwang
Kzunghee University
Yongin-Kun
Kyunggi-Do 170-23
KOREA

Michio Ichikawa
Japan Atomic Energy Research Inst.
Dept. of Fuel Safety Research
Tokai-Mura, Naka-Gun
Ibaraki-Ken, 319-1
JAPAN

Sanford Israel
USNRC-AEOD/ROAB
MS: MNBB-9715

Krishna R. Iyengar
Louisiana Power and Light
200 A Huey P. Long Avenue
Gretna, LA 70053

Jerry E. Jackson
USNRC-RES
MS: NL/S-302

R. E. Jaquith
Combustion Engineering, Inc.
1000 Prospect Hill Road
M/C 9490-2405
Windsor, CT 06095

S. E. Jensen
Exxon Nuclear Company
2101 Horn Rapids Road
Richland, WA 99352

Kjell Johannson
Studsvik Energiteknik AB
S-611 82, Nykoping
SWEDEN

Richard John
SSM, Room 102
927 W. 35th Place
USC, University Park
Los Angeles, CA 90089-0021

D. H. Johnson
Pickard, Lowe & Garrick, Inc.
2260 University Drive
Newport Beach, CA 92660

W. Reed Johnson
Department of Nuclear Engineering
University of Virginia
Reactor Facility
Charlottesville, VA 22901

Jeffery Julius
NUS Corporation
1301 S. Central Ave, Suite 202
Kent, WA 98032

H. R. Jun
Korea Adv. Energy Research Inst.
P.O. Box 7, Daeduk Danju
Chungnam 300-31
KOREA

Peter Kafka
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Geoffrey D. Kaiser
Science Application Int. Corp.
1710 Goodridge Drive
McLean, VA 22102

William Kastenbergl
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024

Walter Kato
Brookhaven National Laboratory
Associated Universities, Inc.
Upton, NY 11973

M. S. Kazimi
MIT, 24-219
Cambridge, MA 02139

Ralph L. Keeney
101 Lombard Street
Suite 704W
San Francisco, CA 94111

Henry Kendall
Executive Director
Union of Concerned Scientists
Cambridge, MA

Frank King
Ontario Hydro
700 University Avenue
Bldg. H11 G5
Toronto
CANADA M5G1X6

Oliver D. Kingsley, Jr.
Tennessee Valley Authority
1101 Market Street
GN-38A Lookout Place
Chattanooga, TN 37402

Stephen R. Kinnersly
Winfrith Atomic Energy
Establishment
Reactor Systems Analysis Division
Winfrith, Dorchester
Dorset DT2 8DH
ENGLAND

Ryohel Kiyose
University of Tokyo
Dept. of Nuclear Engineering
7-3-1 Hongo Bunkyo
Tokyo 113
JAPAN

George Klopp
Commonwealth Edison Company
P.O. Box 767, Room 35W
Chicago, IL 60690

Klaus Koberlein
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

E. Kohn
Atomic Energy Canada Ltd.
Candu Operations
Mississauga
Ontario, L5K 1B2
CANADA

Alan M. Kolaczowski
Science Applications International
Corporation
2109 Air Park Road, S.E.
Albuquerque, NM 87106

S. Kondo
Department of Nuclear Engineering
Faculty of Engineering
University of Tokyo
3-1, Hongo 7, Bunkyo-ku
Tokyo
JAPAN

Herbert J. C. Kouts
Brookhaven National Laboratory
Building 179C
Upton, NY 11973

Thomas Kress
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

W. Kroger
Institut fur Nukleare
Sicherheitsforschung
Kernforschungsanlage Julich GmbH
Postfach 1913
D-5170 Julich 1
FEDERAL REPUBLIC OF GERMANY

Greg Krueger [3]
Philadelphia Electric Co.
2301 Market St.
Philadelphia, PA 19101

Bernhard Kuczera
Kernforschungszentrum Karlsruhe
LWR Safety Project Group (PRS)
P. O. Box 3640
D-7500 Karlsruhe 1
FEDERAL REPUBLIC OF GERMANY

Jeffrey L. LaChance
Science Applications International
Corporation
2109 Air Park Road S.E.
Albuquerque, NM 87106

H. Larsen
Riso National Laboratory
Postbox 49
DK-4000 Roskilde
DENMARK

Wang L. Lau
Tennessee Valley Authority
400 West Summit Hill Avenue
Knoxville, TN 37902

Timothy J. Leahy
EI Services
1851 South Central Place, Suite 201
Kent, WA 98031

John C. Lee
Univ of Michigan, North Campus
Dept. of Nuclear Engineering
Ann Arbor, MI 48109

Tim Lee
USNRC-RES/RPSB
MS: NL/N-353

Mark T. Leonard
Science Applications Int. Corp.
2109 Air Park Road, SE
Albuquerque, NM 87106

Leo LeSage
Director, Applied Physics Div.
Argonne National Laboratory
Building 208, 9700 South Cass Ave.
Argonne, IL 60439

Milton Levenson
Bechtel Western Power Company
50 Beale St.
San Francisco, CA 94119

Librarian
NUMARC/USCEA
1776 I Street NW, Suite 400
Washington, DC 80006

Eng Lin
Taiwan Power Company
242, Roosevelt Rd., Sec. 3
Taipei
TAIWAN

N. J. Liparulo
Westinghouse Electric Corp.
P. O. Box 355
Pittsburgh, PA 15230

Y. H. (Ben) Liu
Dept. of Mechanical Engineering
University of Minnesota
Minneapolis, MN 55455

Bo Liwnang
IAEA A-1400
Swedish Nuclear Power Inspectorate
P.O. Box 27106
S-102 52 Stockholm
SWEDEN

J. P. Longworth
Central Electric Generating Board
Berkeley Gloucester
GL13 9PB
UNITED KINGDOM

Walter Lowenstein
Electric Power Research Institute
3412 Hillview Avenue
P. O. Box 10412
Palo Alto, CA 94303

William J. Luckas
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Hans Ludewig
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Robert J. Lutz, Jr.
Westinghouse Electric Corporation
Monroeville Energy Center
EC-E-371, P. O. Box 355
Pittsburgh, PA 15230-0355

Phillip E. MacDonald
EG&G Idaho, Inc.
P.O. Box 1625
Idaho Falls, ID 83415

Jim Mackenzie
World Resources Institute
1735 New York Ave. NW
Washington, DC 20006

David P. Mackowiak
Idaho Nat. Engineering Laboratory
P.O. Box 1625
Idaho Falls, ID 83415

A. P. Malinauskas
Oak Ridge National Laboratory
P.O. Box Y
Oak Ridge, TN 37831

Giuseppe Mancini
Commission European Comm.
CEC-JRC Eraton
Ispra Varese
ITALY

Lasse Mattila
Technical Research Centre of
Finland
Lonnrotinkatu 37, P. O. Box 169
SF-00181 Helsinki 18
FINLAND

Roger J. Mattson
SCIENTECH Inc.
11821 Parklawn Dr.
Rockville, MD 20852

Donald McPherson
USNRC-NRR/DONRR
MS: 12G-18

Jim Metcalf
Stone and Webster Engineering
Corporation
245 Summer St.
Boston, MA 02107

Mary Meyer
A-1, MS F600
Los Alamos National Laboratory
Los Alamos, NM 87545

Ralph Meyer
USNRC-RES/AEB
MS: NL/N-344

Charles Miller
8 Hastings Rd.
Momsey, NY 10952

Joseph Miller
Gulf States Utilities
P. O. Box 220
St. Francisville, LA 70775

William Mims
Tennessee Valley Authority
400 West Summit Hill Drive.
W10D199C-K
Knoxville, TN 37902

Jocelyn Mitchell
USNRC-RES/SAIB
MS: NL/S-324

Kam Mohktarian
CBI Na-Con Inc.
800 Jorie Blvd.
Oak Brook, IL 60521

James Moody
P.O. Box 641
Rye, NH 03870

S. Mori
Nuclear Safety Division
OECD Nuclear Energy Agency
38 Blvd. Suchet
75016 Paris
FRANCE

Walter B. Murfin
P.O. Box 550
Mesquite, NM 88048

Joseph A. Murphy
USNRC-RES/DSR
MS: NL/S-007

V. I. Nath
Safety Branch
Safety Engineering Group
Sheridan Park Research Community
Mississauga, Ontario L5K 1B2
CANADA

Susan J. Niemczyk
1545 18th St. NW, #112
Washington, DC 20036

Pradyot K. Niyogi
USDOE-Office of Nuclear Safety
Washington, DC 20545

Paul North
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, ID 83415

Edward P. O'Donnell
Ebasco Services, Inc.
2 World Trade Center, 89th Floor
New York, NY 10048

David Okrent
UCLA
Boelter Hall, Room 5532
Los Angeles, CA 90024

Robert L. Olson
Tennessee Valley Authority
400 West Summit Hill Rd.
Knoxville, TN 37902

Simon Ostrach
Case Western Reserve University
418 Glenman Bldg.
Cleveland, OH 44106

D. Paddleford
Westinghouse Electric Corporation
Savanna River Site
Aiken, SC 29808

Robert L. Palla, Jr.
USNRC-NRR/PRAB
MS: 10A-2

Chang K. Park
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Michael C. Parker
Illinois Department of Nuclear
Safety
1035 Outer Park Dr.
Springfield, IL 62704

Gareth Parry
NUS Corporation
910 Clopper Road
Gaithersburg, MD 20878

J. Pelce
Departement de Surete Nucleaire
IPSN
Centre d'Estudes Nucleaires du CEA
B.P. no. 6, Cedex
F-92260 Fontenay-aux-Roses
FRANCE

G. Petrangeli
ENEA Nuclear Energy ALT Disp
Via V. Brancati, 48
00144 Rome
ITALY

Marty Plys
Fauske and Associates
16W070 West 83rd St.
Burr Ridge, IL 60521

Mike Podowski
Department of Nuclear Engineering
and Engineering Physics
RPI
Troy, NY 12180-3590

Robert D. Pollard
Union of Concerned Scientists
1616 P Street, NW, Suite 310
Washington, DC 20036

R. Potter
UK Atomic Energy Authority
Winfrith, Dorchester
Dorset, DT2 8DH
UNITED KINGDOM

William T. Pratt
Brookhaven National Laboratory
Building 130
Upton, NY 11973

M. Preat
Chef du Service Surete Nucleaire et
Assurance Qualite
TRACTEBEL
Bd. du Regent 8
B-100 Bruxells
BELGIUM

David Pyatt
USDOE
MS: EH-332
Washington, DC 20545

William Raisin
NUMAEC
1726 M St. NW
Suite 904
Washington, DC 20036

Joe Rashid
ANATECH Research Corp.
3344 N. Torrey Pines Ct.
Suite 1320
La Jolla, CA 90237

Dale M. Rasmuson
USNRC-RES/PRAB
MS: NL/S-372

Ingvard Rasmussen
Riso National Laboratory
Postbox 49
DK-4000, Roskilde
DENMARK

Norman C. Rasmussen
Massachusetts Institute of
Technology
77 Massachusetts Avenue
Cambridge, MA 02139

John W. Reed
Jack R. Benjamin & Associates, Inc.
444 Castro St., Suite 501
Mountain View, CA 94041

David B. Rhodes
Atomic Energy of Canada, Ltd.
Chalk River Nuclear Laboratories
Chalk River, Ontario KOJ1P0
CANADA

Dennis Richardon
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, PA 15230

Doug Richeard
Virginia Electric Power Co.
P.O.Box 26666
Richmond, VA 23261

Robert Ritzman
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94304

Richard Robinson
USNRC-RES/PRAB
MS: NL/S-372

Jack E. Rosenthal
USNRC-AEOD/ROAB
MS: MNBB-9715

Denwood F. Ross
USNRC-RES
MS: NL/S-007

Frank Rowsome
9532 Fern Hollow Way
Gaithersburg, MD 20879

Wayne Russell
SERI
5360 I-55 North
Jackson, MS 39211

Jorma V. Sandberg
Finnish Ctr. Rad. Nucl. and Safety
Department of Nuclear Safety
P.O. Box 268
SF-00101 Helsinki
FINLAND

G. Saponaro
ENEA Nuclear Engineering Alt.
Zia V Brancati 4B
00144 ROME
ITALY

M. Sarran
United Engineers
P. O. Box 8223
30 S 17th Street
Philadelphia, PA 19101

Marty Sattison
EG&G Idaho
P. O. Box 1625
Idaho Falls, ID 83415

George D. Sauter
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Jorge Schulz
Bechtel Western Power Corporation
50 Beale Street
San Francisco, CA 94119

B. R. Sehgal
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Subir Sen
Bechtel Power Corp.
15740 Shady Grove Road
Location 1A-7
Gaithersburg, MD 20877

S. Serra
Ente Nazionale per l'Energia
Eletttrica (ENEL)
via G. B. Martini 3
Rome
ITALY

Bonnie J. Shapiro
Science Applications International
Corporation
360 Bay Street
Suite 200
Augusta, GA 30901

H. Shapiro
Licensing and Risk Branch
Atomic Energy of Canada Ltd.
Sheridan Park Research Community
Mississauga, Ontario L5K 1B2
CANADA

Dave Sharp
Westinghouse Savannah River Co.
Building 773-41A, P. O. Box 616
Aiken, SC 29802

John Sherman
Tennessee Environmental Council
1719 West End Avenue, Suite 227
Nashville, TN 37203

Brian Sheron
USNRC-RES/DSR
MS: NL/N-007

Rick Sherry
JAYCOR
P. O. Box 85154
San Diego, CA 92138

Steven C. Sholly
MHB Technical Associates
1723 Hamilton Avenue, Suite K
San Jose, CA 95125

Louis M. Shotkin
USNRC-RES/RPSB
MS: NL/N-353

M. Siebertz
Chef de la Section Surete' des
Reacteurs
CEN/SCK
Boeretang, 200
B-2400 Mol
BELGIUM

Melvin Silberberg
USNRC-RES/DE/WNB
MS: NL/S-260

Gary Smith
SERI
5360 I-55 North
Jackson, MS 39211

Gary L. Smith
Westinghouse Electric Corporation
Hanford Site
Box 1970
Richland, WA 99352

Lanny N. Smith
Science Applications International
Corporation
2109 Air Park Road SE
Albuquerque, NM 87106

K. Soda
Japan Atomic Energy Res. Inst.
Tokai-Mura Naka-Gun
Ibaraki-Ken 319-11
JAPAN

Leonard Soffer
USNRC-RES/SAIB
MS: NL/S-324

David Sommers
Virginia Electric Power Company
P. O. Box 26666
Richmond, VA 23261

Herschel Spector
New York Power Authority
123 Main Street
White Plains, NY 10601

Themis P. Speis
USNRC-RES
MS: NL/S-007

Klaus B. Stadie
OECD-NEA, 38 Bld. Suchet
75016 Paris
FRANCE

John Stetkar
Pickard, Lowe & Garrick, Inc.
2216 University Drive
Newport Beach, CA 92660

Wayne L. Stiede
Commonwealth Edison Company
P.O. Box 767
Chicago, IL 60690

William Stratton
Stratton & Associates
2 Acoma Lane
Los Alamos, NM 87544

Soo-Pong Suk
Korea Advanced Energy Research
Institute
P. O. Box 7
Daeduk Danji, Chungnam 300-31
KOREA

W. P. Sullivan
GE Nuclear Energy
175 Curtner Ave., M/C 789
San Jose, CA 95125

Tony Taig
U.K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
UNITED KINGDOM

John Taylor
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Harry Teague
U.K. Atomic Energy Authority
Wigshaw Lane, Culcheth
Warrington, Cheshire, WA3 4NE
UNITED KINGDOM

Technical Library
Electric Power Research Institute
P.O. Box 10412
Palo Alto, CA 94304

Mark I. Temme
General Electric, Inc.
P.O. Box 3508
Sunnyvale, CA 94088

T. G. Theofanous
University of California, S.B.
Department of Chemical and Nuclear
Engineering
Santa Barbara, CA 93106

David Teolis
Westinghouse-Bettis Atomic Power
Laboratory
P. O. Box 79, ZAP 34N
West Mifflin, PA 15122-0079

Ashok C. Thadani
USNRC-NRR/SAD
MS: 7E-4

Garry Thomas
L-499 (Bldg. 490)
Lawrence Livermore National
Laboratory
7000 East Ave.
P.O. Box 808
Livermore, CA 94550

Gordon Thompson
Institute for Research and
Security Studies
27 Ellworth Avenue
Cambridge, MA 02139

Grant Thompson
League of Women Voters
1730 M. Street, NW
Washington, DC 20036

Arthur Tingle
Brookhaven National Laboratory
Building 130
Upton, NY 11973

Rich Toland
United Engineers and Construction
30 S. 17th St., MS 4V7
Philadelphia, PA 19101

Brian J. R. Tolley
DG/XII/D/1
Commission of the European
Communities
Rue de la Loi, 200
B-1049 Brussels
BELGIUM

David R. Torgerson
Atomic Energy of Canada Ltd.
Whiteshell Nuclear
Research Establishment
Pinawa, Manitoba, ROE 1L0
CANADA

Alfred F. Torri
Pickard, Lowe & Garrick, Inc.
191 Calle Magdalena, Suite 290
Encinitas, CA 92024

Klau Trambauer
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FERERAL REPUBLIC OF GERMANY

Nicholas Tsoulfanidis
Nuclear Engineering Dept.
University of Missouri-Rolla
Rolla, MO 65401-0249

Chao-Chin Tung
c/o H.B. Bengelsdorf
ERC Environmental Services Co.
P. O. Box 10130
Fairfax, VA 22030

Brian D. Turland
UKAEA Culham Laboratory
Abingdon, Oxon OX14 3DB
ENGLAND

Takeo Uga
Japan Institute of Nuclear Safety
Nuclear Power Engineering Test
Center
3-6-2, Toranomon
Minato-ku, Tokyo 108
JAPAN

Stephen D. Unwin
Battelle Columbus Division
505 King Avenue
Columbus, OH 43201

A. Valeri
DISP
ENEA
Via Vitaliano Brancati, 48
I-00144 Rome
ITALY

Harold VanderMolen
USNRC-RES/PRAB
MS: NL/S-372

G. Bruce Varnado
ERC International
1717 Louisiana Blvd. NE, Suite 202
Albuquerque, NM 87110

Jussi K. Vaurio
Imatran Voima Oy
Loviisa NPS
SF-07900 Loviisa
FINLAND

William E. Vesely
Science Applications International
Corporation
2929 Kenny Road, Suite 245
Columbus, OH 43221

J. I. Villadoniga Tallon
Div. of Analysis and Assessment
Consejo de Seguridad Nuclear
c/ Sor Angela de la Cruz, 3
28020 Madrid
SPAIN

Willem F. Vinck
Kappellestraat 25
1980
Tervuren
BELGIUM

R. Virolainen
Office of Systems Integration
Finnish Centre for Radiation and
Nuclear Safety
Department of Nuclear Safety
P.O. Box 268
Kumpulantie 7
SF-00520 Helsinki
FINLAND

Raymond Viskanta
School of Mechanical Engineering
Purdue University
West Lafayette, IN 47907

S. Visweswaran
General Electric Company
175 Curtner Avenue
San Jose, CA 95125

Truong Vo
Pacific Northwest Laboratory
Battelle Blvd.
Richland, WA 99352

Richard Vogel
Electric Power Research Institute
P. O. Box 10412
Palo Alto, CA 94303

G. Volta
Engineering Division
CEC Joint Research Centre
CP No. 1
I-21020 Ispra (Varese)
ITALY

Ian B. Wall
Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, CA 94303

Adolf Walser
Sargent and Lundy Engineers
55 E. Monroe Street
Chicago, IL 60603

Edward Warman
Stone & Webster Engineering Corp.
P.O. Box 2325
Boston, MA 02107

Norman Weber
Sargent & Lundy Co.
55 E. Monroe Street
Chicago, IL 60603

Lois Webster
American Nuclear Society
555 N. Kensington Avenue
La Grange Park, IL 60525

Wolfgang Werner
Gesellschaft Fur Reaktorsicherheit
Forschungsgelände
D-8046 Garching
FEDERAL REPUBLIC OF GERMANY

Don Wesley
IMPELL
1651 East 4th Street
Suite 210
Santa Ana, CA 92701

Detlof von Winterfeldt
Institute of Safety and Systems
Management
University of Southern California
Los Angeles, CA 90089-0021

Pat Worthington
USNRC-RES/AEB
MS: NL/N-344

John Wreathall
Science Applications International
Corporation
2929 Kenny Road, Suite 245
Columbus, OH 43221

D. J. Wren
Atomic Energy of Canada Ltd.
Whiteshell Nuclear Research
Establishment
Pinawa, Manitoba, ROE 1L0
CANADA

Roger Wyrick
Inst. for Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, GA 30339

Kun-Joong Yoo
Korea Advanced Energy Research
Institute
P. O. Box 7
Daeduk Danji, Chungnam 300-31
KOREA

Faith Young
Energy People, Inc.
Dixou Springs, TN 37057

Jonathan Young
R. Lynette and Associates
15042 Northeast 40th St.
Suite 206
Redmond, WA 98052

C. Zaffiro
Division of Safety Studies
Directorate for Nuclear Safety and
Health Protection
Ente Nazionale Energie Alternative
Via Vitaliano Brancati, 48
I-00144 Rome
ITALY

Mike Zentner
Westinghouse Hanford Co.
P. O. Box 1970
Richland, WA 99352

X. Zikidis
Greek Atomic Energy Commission
Agia Paraskevi, Attiki
Athens
GREECE

Bernhard Zuczera
Kernforschungszentrum
Postfach 3640
D-7500 Karlsruhe
FEDERAL REPUBLIC OF GERMANY

6500 A. W. Snyder
6510 J. V. Walker
6517 M. Berman
6517 M. P. Sherman
6521 L. D. Bustard
6523 W. A. von Rieseemann
8524 J. A. Wackerly

1521 J. R. Weatherby
3141 S. A. Landenberger [5]
3151 W. I. Klein
5214 D. B. Clauss
6344 E. D. Gorham
6001 D. D. Carlson
6001 R. J. Breeding
6001 D. M. Kunsman
6400 D. J. McCloskey
6410 D. A. Dahlgren
6412 A. L. Camp
6412 S. L. Daniel
6412 T. M. Hake
6412 L. A. Miller
6412 D. B. Mitchell
6412 A. C. Payne, Jr.
6412 T. T. Sype
6412 T. A. Wheeler
6412 D. W. Whitehead
6413 T. D. Brown
6413 F. T. Harper [2]
6415 R. M. Cranwell
6415 W. R. Cramond [3]
6415 R. L. Iman
6418 J. E. Kelly
6418 K. J. Maloney
6419 M. P. Bohn
6419 J. A. Lambright
6422 D. A. Powers
6424 K. D. Bergeron
6424 J. J. Gregory
6424 D. R. Bradley
6424 D. C. Williams
6425 S. S. Dosanjh
6453 J. S. Philbin

BIBLIOGRAPHIC DATA SHEET

(See instructions on the reverse)

1. REPORT NUMBER
(Assigned by NRC, Add Vol., Supp., Rev.,
and Addendum Numbers, if any.)

NUREG/CR-4550
SAND86-2084
Vol. 3, Rev. 1, Part 2

2. TITLE AND SUBTITLE

Analysis of Core Damage Frequency: Surry, Unit 1, Internal
Events Appendices

3. DATE REPORT PUBLISHED

MONTH YEAR
April 1990

4. FIN OR GRANT NUMBER

A1228

5. AUTHOR(S)

R. C. Bertucio,* J. A. Julius*

6. TYPE OF REPORT

Technical

7. PERIOD COVERED (Inclusive Dates)

8. PERFORMING ORGANIZATION - NAME AND ADDRESS (If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)

Sandia National Laboratories
Albuquerque, NM 87185
*EI Services
Kent, WA 98031

9. SPONSORING ORGANIZATION - NAME AND ADDRESS (If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)

Division of Systems Research
Office of Nuclear Regulatory Research
US Nuclear Regulatory Commission
Washington, DC 20555

10. SUPPLEMENTARY NOTES

11. ABSTRACT (200 words or less)

This document contains the accident sequence analyses of internally initiated events for the Surry Nuclear Station, Unit 1. This is one of the five plant analyses conducted as part of the NUREG-1150 effort by the Nuclear Regulatory Commission. NUREG-1150 documents the risk of a selected group of nuclear power plants. The work performed and described here is an extensive reanalysis of that published in November 1986 as NUREG/CR-4550, Volume 3. It addresses comments from numerous reviewers and significant changes to the plant systems and procedures made since the first report. The uncertainty analysis and presentation of results are also much improved. The context and detail of this report are directed toward PRA practitioners who need to know how the work was performed and the details for use in further studies. The mean core damage frequency at Surry was calculated to be 4.0E-5 per year, with a 95% upper bound of 1.3E-4 and 5% lower bound of 6.8E-6 per year. Station blackout type accidents (loss of all AC power) were the largest contributors to the core damage frequency, accounting for approximately 68% of the total. The next type of dominant contributors were Loss of Coolant Accidents (LOCAs). These sequences account for 15% of core damage frequency. No other type of sequence accounts for more than 10% of core damage frequency.

12. KEY WORDS/DESCRIPTORS (List words or phrases that will assist researchers in locating the report.)

Probabilistic Risk Assessment (PRA)
safety analysis
uncertainty analysis
accident sequence analysis

13. AVAILABILITY STATEMENT

unlimited

14. SECURITY CLASSIFICATION

(This Page)

unclassified

(This Report)

unclassified

15. NUMBER OF PAGES

16. PRICE

**UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555**

**OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300**

SPECIAL FOURTH-CLASS RATE
POSTAGE & FEES PAID
USNRC
PERMIT No. G-67