

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

June 10, 1988

D. S. CRUDEN  
VICE PRESIDENT-NUCLEAR

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No. 88-212  
NO/RPC:vlh R3  
Docket Nos. 50-280  
50-281  
License Nos. DPR-32  
DPR-37

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY POWER STATION UNITS 1 AND 2  
PROPOSED TECHNICAL SPECIFICATION CHANGE  
MAIN CONTROL ROOM CHLORINE DETECTION SYSTEM

Pursuant to 10 CFR 50.90, Virginia Electric and Power Company requests an amendment in the form of changes to the Technical Specifications of Operating Licenses DPR-32 and DPR-37 for Surry Power Station Units 1 and 2.

The proposed Technical Specification changes will delete requirements for and references to the Control Room Chlorine Monitoring System. Chlorine gas storage bottles at the sewage treatment plant are scheduled to be permanently removed from the site by June 30, 1988. Since these bottles were the only regulatory significant source of chlorine, the need for the chlorine detection system will be eliminated with this removal. The proposed revision would permit the removal of the associated equipment.

The proposed changes have been reviewed and approved by the Station Nuclear Safety and Operating Committee and by the Safety Evaluation and Control Staff. It has been determined that these changes do not involve either an unreviewed safety question as defined in 10 CFR 50.59 or a significant hazards consideration as defined in 10 CFR 50.92.

This request has been evaluated in accordance with the criteria in 10 CFR 170.12. A voucher check in the amount of \$150.00 is enclosed as an application fee.

Very truly yours,

  
D. S. Cruden

Attachments

1. Proposed Technical Specification Changes
2. Safety Evaluation
3. Voucher Check

8806170022 880610  
PDR ADOCK 05000280  
P DCD

A001  
w/check \$150  
#009176

cc: U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W.  
Suite 2900  
Atlanta, Georgia 30323

Mr. W. E. Holland  
NRC Senior Resident Inspector  
Surry Power Station

Commissioner  
Department of Health  
Room 400  
109 Governor Street  
Richmond, Virginia 23219

Mr. Chandu P. Patel  
NRC Surry Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II



**ATTACHMENT 1**

Proposed Technical Specification Changes